


Native Village of Eyak Wind Energy Feasibility Study

Prepared by Heath Kocan & Casey Pape


Presented by Casey Pape Alternative Energy Coordinator

Native Village of Eyak

- Federally Recognized Tribe in Cordova, AK
- Governed by a fivemember tribal council
- Provides health and social services, economic development, job training and environmental and resource management
- 525 Tribal members



Location of Project






18th Annual Sobriety Celebration & Memorial Potlatch November 11-13 2011 Cordova, Alaska



Why Wind Power?

Reduces petroleum use

- Reduces carbon footprint
- Cost can be competitive with
- diesel generator production
- •When used with storage medium it can greatly reduce diesel generator use and improve grid reliability



C-JAHAROOG 4, 1




$P = \frac{1}{2} C_p A_s \rho \mathbf{v}^3$

C_p = Coefficient of Performance

A_s = The swept area of wind turbine blades

NorthWind 100/21 Wind Turbine Power Curve Standard Density



Wind Speed at Hub Height (m/s)

So Which is Better

A location where the wind blows only
 50% of the time at 10m/s but is calm the rest of the time
 A location where the wind blows all of the time at 5m/s

Both have exactly the same annual mean wind speed

$$P = \frac{1}{2} C_p A_s \rho \mathbf{v}^3$$


Make The Calculation

AEP = Expected PowerxAvailabilityxTime

Case 1: 10m/s 50% of the time $AEP = 60kW \times (8760 \times 0.5)$ = 262,800 kWh/year Case 2: 5m/s all of the time $AEP = 10 \times (8760 \times 1)$ = 87,600 kWh/year



Wind Shear



The type of surface (grass, trees) Slope of surface (flat, hilltop)

Current Energy Generation





Hydro Electric Power


- 2 run of river facilities (5 turbines)
- ~7.5 MW of capacity

Diesel Generator

- 4 diesel generator units
- 7.1 MW of capacity



Current Energy Use



Peak Load

• 7500 kW

Average Load

- 3500 kW (summer)
- 2000 kW (Oct-Apr)

Minimum Load

• 1400 kW


Diesel Use: ~900,000 gallons/yr





NREL Study





- DOE Tribal loan program
- 30m tower erected at Point Whitshed
- Data collected for 18 months
- Reviewed by NREL analyst
- Class 4 wind resource













Pt Whitshed Statistics

- Average wind speed at 29m: 13.1mph (5.9m/s)
- Average power density at 29m: 346W/m²
- Estimated resource at 50m: 14mph, 410W/m²
- Mean turbulence intensity: 0.18
- Capacity factor: 24%, 42% in winter
- Levelized cost of energy: ~\$0.25/kWh



Site Analysis

- MET Towers Installation
- Data Analysis
- Avian Studies
- Environmental Assessment

MET Towers


- 1 30 meter towers, 18 months of continuous data collection (returned to NREL 2010)
- 2 10 meter towers, placed on location at 4 month intervals (NVE owned)
- 1 60 meter tower, on loan from NREL to be installed on Copper River delta





Site Selection

- Soil analysis
- Transmission line access
- Road access: Crane, Turbine blades, tower sections
- Turbine model and quantity
- GIS Multi-Criteria Analysis





Avian Studies

- Spring 2011 migration studies of Point Whitshed and Reservoir were conducted from April 14 to May 24, 2011
- 781observations were tallied during 42 3-hour surveys
 a total of 17,767 individuals
- Of those 781 observations:

203 (26%) – waterfowl


20 (3%) - cranes

94 (12%) - raptors

464 (59%) – various species, primarily gulls (95%)




Soil Analysis







Soil Analysis





Transmission Access



Current best site - No Transmission (submerged cable)

Mile 14 : 1-2 miles needed



Road Access

- Weight Limits (80 ton crane for larger turbines)
- Current best site has no road
- Temporary road at Point Whitshed










- Understand your current energy profile and how wind can play a supporting role
- Conduct regular meetings and obtain community input often
- Use grant money efficiently in the short-term in order to have retain long-term usefulness
- Be realistic with your site selection
- Diversify specialty knowledge and training (factor in personnel turn around)

Thank You


Casey Pape casey@eyak-nsn.gov

907.424.7738



Actual Wind Speed and Forecasted Wind Speed





- Power System
 Modeling
- Grid Connected
 System
- Community Power
 - Financial Modeling

Grid Connected

- Penetration levels: Lo/Med/Hi
- Controls issues
 Wind/Diesel/Hydro
- Controls system has not been implemented on larger systems
- Energy Storage: Batteries, EV's, Flywheels, Compressed Gas, NH₄
- Smart Grid applications







Grid Connected

Flow Battery

NaS battery





IIII File View Inputs Outputs Window Help	
D 🛎 🖬 🗟 🖩 🐯 😭 🏌	
Equipment to consider Add/Remove	Calculate Simulations: 0 of 2304 Progress: Sensitivities: 0 of 30 Status:
GE 1.5sl	
GE 1.5sl	Sensitivity Results Optimization Results Sensitivity variables
₩ → ₽ Hydro Primary Load 1	Wind Speed (m/s) 5.97 Diesel Price (\$/L) 0.8 OR Wind (%) 50
71 MWh/d	Double click on a system below for simulation results.
Cat1 5.5 MW peak	Image: Application of the second s
	▲ 行 合 一 図 1 6316 1090 1090 2403 2500 1500 30000 2000 \$ 20,277,332 2,409,256 \$ 51,075,708 0.154 0.81 2,526,687 1,095
Cat2	▲ 変 ゆ ゆ 御 図 1 6316 1090 2403 2500 1500 30000 2000 \$ 20,277,332 2,412,810 \$ 51,121,144 0.154 0.81 2,526,687 1,095 ▲ 御 図 1 6316 1090 2403 2500 1500 30000 2000 \$ 20,277,332 2,412,810 \$ 51,121,144 0.154 0.81 2,526,687
	本
	🗼 🎘 🛅 🖾 🗂 🗇 🗐 🔟 1 6316 1090 2500 1500 50000 2000 \$ 20,432,888 2,417,526 \$ 51,336,984 0.155 0.81 2,523,196
	森 森 (1) (1,55 (1,
EMD	🗼 🎘 选 🍈 🗇 🖉 2 6316 1090 2403 1500 50000 2000 \$24,776,888 2,082,561 \$51,399,004 0.155 0.85 2,109,378 1,445
AC DC	🗼 🄁 🛅 🗹 2 6316 2403 5000 50000 2000 \$25,243,556 2,046,649 \$51,406,600 0.155 0.85 2,081,710
Resources Other Other	承存 造画図 2 6316 2500 5000 2000 \$25,010,222 2,081,298 \$51,616,200 0.156 0.85 2,123,306 存在 造 画図 6316 1090 1090 2403 2500 1500 9000 2000 \$15,770,000 2,873,240 \$52,499,656 0.158 0.76 3,082,638 643
Hydro resource Q System control	7 7 🖧 📩 🗂 🖾 📾 🔟 6316 1090 2403 2500 1500 9000 2000 \$ 15,770,000 2,876,795 \$ 52,545,092 0.158 0.76 3,082,638 643
Diesel	〒 〒 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
Constraints	▲変色を含し、1 6316 1090 1090 2403 2500 Wind Turbine Inputs
Document	Q2 (2) (2) (2) (316 2403 2500 1500 3 File Edit Help TX 法 問 図 6316 1090 2500 1500 3 File Edit Help
Author Notes	GE 1.5st search space may be insufficient. Choose a wind turbine type and enter at least one quantity and capital cost value in the Costs table. Include the cost of the tower, controller, wiring, installation, and labor. As it searches for the optimal system, HOMER considers each quantity in the Sizes to Consider
661	VRB-ESS Flow Battery power search space may be insufficient. VRB-ESS Flow Battery power search space may be insufficient. Table.
	VRB-ESS Flow Battery storage search space may be insufficient. Hold the pointer over an element or click Help for more information.
×	Completed in 10:19.
	Turbine type GE 1.5sl ■ Details New Delete
	Turbine properties
	Rated power: 1,500 kW AC Manufacturer:
	Website: www.gepower.com
Optim	ization Model
FINDS	the least cost
	Costs Sizes to consider Cost Curve
combinati	On of components Quantity Capital (\$) Replacement (\$) 0&M (\$/yr) Quantity 14,000 12,000 0
combination of components ^{Quantity} Capital (\$) Replacement (\$) 0&M (\$/yr) ¹ 4344000 10000 8500 0 1 4344000 100000 8500 0 1 00000 8500 0 1 00000 0 1 0 0 1 00000 0 1 00000 0 1 0 0	
i inat me	

Lifetime (yrs)

Hub height (m)

Other

25 {..}

25 {..}

2,000

0.0

0.5

Help

1.0 1.5 2.0 2.5 3.0


ΟK

Quantity

Cancel

🗕 Capital 🛛 🗕 Replacement

that meet electrical and thermal loads



GE 1.5 MW Turbine



- Determining community load
- Possible dump loads:
 District heating, battery storage



Project Funding

- Site specific: Eyak corp, City land, USFS
- Tax incentives: CEC, NVE and City are ineligible for most incentives
- Clean Renewable Energy Bonds for Cooperatives
- Possible DOE funding



Project Status

- Site assessments complete, ready for MET tower installation
- Avian studies ready for next years migrations
- Educational outreach
- Working with High School science club on wind study

To Be Completed

- Once funds are available order MET tower components and erect
- Avian studies completed Spring and Fall of 2011 (migratory times)
- System modeling (HOMER, Matlab,Hybrid2)



Go No Go

- More data may be needed based on turbine selection (Taller MET tower data needed at site)
- Is it financially viable?
- Current Outlook: Battery storage needed first due to non-dispatchable power of wind and to allow for higher penetration levels (decreasing diesel consumption)

Project Participants

- Cordova Electric Cooperative
- Eyak Corporation
- Cordova School District
- Alaska Energy Authority











Small Wind

Small Wind Power 300 W to 10 kW Units

- Installed at individual homes, businesses, schools, etc.
- On the "demand" side of the meter, or off the grid entirely
- High reliability, low maintenance
- 9 mph (4m/s) average wind speed



Small Wind

Generator: direct-drive, permanent magnet alternator (no brushes), variable-speed operation

Controller: electronic device that delivers -DC power for charging batteries -AC power for utility interconnection

Result: Simple, rugged design Only 2–4 moving parts Little regular maintenance required





Small Wind Incentives



Rebate grant programs:
 USDA

- Net metering
- Reasonable interconnection
- requirements
- State/City zoning ordinance
- US Treasury tax credit: 30% of project cost (2016)