



# **Evaluation of the Kauai Island Utility Co- operative System for Energy Storage Potential**


**ESS Program Review  
Washington, DC  
November 2, 2006**

## **Principal Investigators**

**Mike Yamane  
Kauai Island Utility Co-op  
Lihue, HI**

**Abbas Akhil & Aaron Murray  
Sandia National Laboratories  
Albuquerque, NM**

# Kauai Island Electric Grid



**KAUAI ISLAND UTILITY  
COOPERATIVE  
ELECTRIC POWER SYSTEM  
ISLAND OF KAUAI**

filename : kau\_int-0503.dwg date: 4/2/96

# KIUC Port Allen Power Plant

*Port Allen Power Plant*



Capacity	Name	Type	Brand	Year in service	Efficiency	#	Individual Capacities
4.0	D1/2	diesel	EMD	1964	34%	2	2.0
10.0	S1	steam turbine	GE	1968	22%	1	10.0
8.2	D3/4/5	diesel	EMD	1968	34%	3	2.7
19.2	GT1	combustion turbine	Hitachi/GE	1973	29%	1	19.2
23.7	GT2	combustion turbine	John Brown/GE	1977	32%	1	23.7
15.7	D6/7	diesel	Wartsila	1989	37%	2	7.9
15.7	D8/9	diesel	Wartsila	1991	37%	2	7.9

Port Allen currently has 12 generating machines capable of producing 96,500 kW's, plus a heat recovery steam generator.



# Study Objectives

- ***Primary Objective:***  
**Identify the generation-side benefits of energy storage and define a storage system that best meets KIUC needs**  
**Reduce diesel fuel consumption**
  
- ***Secondary Objective:***  
**Develop a stability model of the KIUC system based on PSCAD**  
**Improve system stability with energy storage**



# Study Dates

- **Sandia Energy Storage study commenced September 2005**
- **Analysis completed June 2006**
  - Draft report completed
- **Stability study commenced May 2006**
  - Performed by Electric Power Systems Consulting Engineers (EPS)



# Assumptions for Storage Analysis

- ***Storage system size: 4 MW / 16 MWh***
  - *Match nameplate ratings of EMD's at Port Allen*
- **Simplifying assumption for initial analysis**
  - Storage system is completely charged/discharged daily
  - Charged ~ 0200 – 0600 hrs; discharged ~ 1700 – 2100 hrs
- **Three roundtrip efficiencies considered:**
  - 85%, 80% and 70%

# Peak Shaving Analysis

## KIUC system data used:

- 2006 hourly load forecast
- KIUC Commodities run for 2006
- monthly and annual summary

Data Range	
From:	1/1/06
To:	12/31/06

### Commodities Summary 2006

Unit	Mwh	Mbtu	Mbtu/Mwh	\$Total	\$ Maint	\$/Mwh	\$ Fuel	Fuel Usage
AGC_SUB_K_COFFEE	23,740	23,639	1.00	\$3,857,785	\$0	\$162.50	\$3,857,785	23,639 MBTU_P_KCOFF
Total P_KCOF	23,740	23,639	1.00	\$3,857,785	\$0	\$162.50	\$3,857,785	23,639 MBTU_P_KCOF

### January, 2006 Commodities Summary

Unit	Mwh	Mbtu	Mbtu/Mwh	\$Total	\$ Maint	\$/Mwh	\$ Fuel	Fuel Usage
AGC_SUB_KEKAHA	1,272	1,707	1.34	\$68,160	\$0	\$77.18	\$68,160	1,707 MBTU_P_KEKA

### February, 2006 Commodities Summary

Unit	Mwh	Mbtu	Mbtu/Mwh	\$Total	\$ Maint	\$/Mwh	\$ Fuel	Fuel Usage
AGC_SUB_K_COFFEE	2,048	0	0.00	\$322,589	\$0	\$162.37	\$322,589	0 MBTU_P_KCOFF

### March, 2006 Commodities Summary

Unit	Mwh	Mbtu	Mbtu/Mwh	\$Total	\$ Maint	\$/Mwh	\$ Fuel	Fuel Usage
AGC_SUB_K_COFFEE	1,963	0	0.00	\$318,960	\$0	\$162.51	\$318,960	0 MBTU_P_KCOFF

### April, 2006 Commodities Summary

Unit	Mwh	Mbtu	Mbtu/Mwh	\$Total	\$ Maint	\$/Mwh	\$ Fuel	Fuel Usage
AGC_SUB_K_COFFEE	1,000	0	0.00	\$162,104	\$0	\$162.10	\$162,104	0 MBTU_P_KCOFF

### May, 2006 Commodities Summary

Unit	Mwh	Mbtu	Mbtu/Mwh	\$Total	\$ Maint	\$/Mwh	\$ Fuel	Fuel Usage
AGC_SUB_K_COFFEE	1,984	0	0.00	\$322,152	\$0	\$162.36	\$322,152	0 MBTU_P_KCOFF

### June, 2006 Commodities Summary

Unit	Mwh	Mbtu	Mbtu/Mwh	\$Total	\$ Maint	\$/Mwh	\$ Fuel	Fuel Usage
AGC_SUB_K_COFFEE	1,984	0	0.00	\$322,152	\$0	\$162.36	\$322,152	0 MBTU_P_KCOFF

### July, 2006 Commodities Summary

Unit	Mwh	Mbtu	Mbtu/Mwh	\$Total	\$ Maint	\$/Mwh	\$ Fuel	Fuel Usage
AGC_SUB_K_COFFEE	1,984	0	0.00	\$322,152	\$0	\$162.36	\$322,152	0 MBTU_P_KCOFF

### August, 2006 Commodities Summary

Unit	Mwh	Mbtu	Mbtu/Mwh	\$Total	\$ Maint	\$/Mwh	\$ Fuel	Fuel Usage
AGC_SUB_K_COFFEE	1,984	0	0.00	\$322,152	\$0	\$162.36	\$322,152	0 MBTU_P_KCOFF

### September, 2006 Commodities Summary

Unit	Mwh	Mbtu	Mbtu/Mwh	\$Total	\$ Maint	\$/Mwh	\$ Fuel	Fuel Usage
AGC_SUB_K_COFFEE	1,984	0	0.00	\$322,152	\$0	\$162.36	\$322,152	0 MBTU_P_KCOFF

### October, 2006 Commodities Summary

Unit	Mwh	Mbtu	Mbtu/Mwh	\$Total	\$ Maint	\$/Mwh	\$ Fuel	Fuel Usage
AGC_SUB_K_COFFEE	1,984	0	0.00	\$322,152	\$0	\$162.36	\$322,152	0 MBTU_P_KCOFF

### November, 2006 Commodities Summary

Unit	Mwh	Mbtu	Mbtu/Mwh	\$Total	\$ Maint	\$/Mwh	\$ Fuel	Fuel Usage
AGC_SUB_K_COFFEE	1,984	0	0.00	\$322,152	\$0	\$162.36	\$322,152	0 MBTU_P_KCOFF

### December, 2006 Commodities Summary

Unit	Mwh	Mbtu	Mbtu/Mwh	\$Total	\$ Maint	\$/Mwh	\$ Fuel	Fuel Usage
AGC_SUB_K_COFFEE	2,243	0	0.00	\$364,560	\$0	\$162.52	\$364,560	0 MBTU_P_KCOFF
Total P_KCOF	2,243	0	0.00	\$364,560	\$0	\$162.52	\$364,560	0 MBTU_P_KCOFF

Unit	Mwh	Mbtu	Mbtu/Mwh	\$Total	\$ Maint	\$/Mwh	\$ Fuel	Fuel Usage
AGC_SUB_KEKAHA	138	0	0.00	\$10,416	\$0	\$75.27	\$10,416	0 MBTU_P_KEKA
Total P_KEKA	138	0	0.00	\$10,416	\$0	\$75.27	\$10,416	0 MBTU_P_KEKA

Unit	Mwh	Mbtu	Mbtu/Mwh	\$Total	\$ Maint	\$/Mwh	\$ Fuel	Fuel Usage
AGC_SUB_OLOKELE	270	0	0.00	\$26,040	\$0	\$96.42	\$26,040	0 MBTU_P_OLOK
Total P_OLOK	270	0	0.00	\$26,040	\$0	\$96.42	\$26,040	0 MBTU_P_OLOK

Unit	Mwh	Mbtu	Mbtu/Mwh	\$Total	\$ Maint	\$/Mwh	\$ Fuel	Fuel Usage
Total Purchase Power	2,652	0	0.00	\$401,616	\$0	\$151.23	\$401,616	

Unit	Mwh	Mbtu	Mbtu/Mwh	\$Total	\$ Maint	\$/Mwh	\$ Fuel	Fuel Usage
LESC_WAIAHIYD	558	0	0.00	\$20,088	\$20,088	\$36.00	\$0	0 GAL DIESEL
PT_ALLEN_D1_S201	42	487	11.60	\$8,036	\$824	\$191.33	\$7,112	3,558 GAL DIESEL
PT_ALLEN_D2_S202	14	157	11.90	\$2,583	\$297	\$191.33	\$2,286	1,144 GAL DIESEL
PT_ALLEN_D3_S203	188	2,270	11.49	\$35,706	\$2,607	\$190.80	\$33,099	15,569 GAL DIESEL
PT_ALLEN_D4_S204	282	2,944	11.28	\$47,291	\$4,263	\$167.68	\$42,998	21,466 GAL DIESEL
PT_ALLEN_D5_S205	95	1,092	11.49	\$17,176	\$1,254	\$180.80	\$15,922	7,870 GAL DIESEL
PT_ALLEN_G12_CC	646	7,209	11.17	\$106,822	\$1,686	\$165.47	\$105,236	\$2,619 GAL DIESEL


Unit	Mwh	Mbtu	Mbtu/Mwh	\$Total	\$ Maint	\$/Mwh	\$ Fuel	Fuel Usage
Total KF Units	41,862	389,587	9.31	\$5,742,829	\$426,356	\$137.19	\$5,316,473	

2006


# Typical Daily Load Profiles - 2006

**System Peak = 79.58 MW (December)**  
**System Min = 30.46 MW (March)**  
**Annual Generation = 481,000 MWh**  
**Average Daily Generation = 1,321 MWh**

**15 March 2006 (Wednesday)**



**30 December 2006 (Saturday)**






## Peak Shaving Analysis – Cont'd

**16 Mwh of energy storage levels daily KIUC system peak - shown on following plots for both a 85% and 70% roundtrip efficiency storage system**


# Daily Load Profiles for January 2006

## 16 MWh Energy Storage – 85% Efficiency Storage



# Daily Load Profiles for January 2006

## 16 MWh Energy Storage – 70% Efficiency Storage



# Peak Shaving Analysis – Cont'd

Result shows a net *reduction* in fuel usage and maintenance costs for KIUC system


- Kapaia fuel (naptha) usage increases with corresponding increase in maintenance costs
- EMD fuel (diesel) usage and maintenance costs are reduced
- Aggregate annual savings are tabulated below:

	Diesel Maintenance Cost	Diesel Fuel Cost	KPA Maintenance Cost	KPA Fuel Cost	Net Savings
85% Storage Efficiency	\$2,882,283	\$32,202,627	\$1,912,872	\$24,006,818	\$61,004,600
Without Storage	\$2,942,087	\$32,456,405	\$1,901,483	\$23,838,446	\$61,138,421
	<b>-\$59,804</b>	<b>-\$253,778</b>	<b>11,389</b>	<b>168,372</b>	<b>-\$133,821</b>




## D1 With and Without Storage

<b>W/O Storage</b>	<b>503 MWh</b>
<b>W/ Storage</b>	<b>300 MWh</b>
<b>Net Decrease</b>	<b>203 MWh</b>
<b>% Decrease</b>	<b>40 %</b>



# D2 Generation - 2006


<b>W/O Storage</b>	<b>289 MWh</b>
<b>W/ Storage</b>	<b>185 MWh</b>
<b>Net Decrease</b>	<b>104 MWh</b>
<b>% Decrease</b>	<b>36 %</b>





## D5 With and Without Storage

<b>W/O Storage</b>	<b>1,853 MWh</b>
<b>W/ Storage</b>	<b>1,094 MWh</b>
<b>Net Decrease</b>	<b>759 MWh</b>
<b>% Decrease</b>	<b>41 %</b>



# Storage Benefit for Peak Shaving

**Generation from D1, D2 and D5 is significantly reduced**

- D1 reduced by 40%**
- D2 reduced by 36%**
- D5 reduced by 41%**

**(Shown by results of Commodities run)**



# Storage Benefit for Stability

- **KIUC contracted EPS to conduct a stability study using PSSE software**
- **Study commenced in May 2006**
  - **Final report recommends energy storage as an option to address stability issue**
  - **Sandia Labs assisting EPS in storage requirements definition**