

# A Regional Assessment of Energy Storage Systems for the Northwest Power Pool

## Collaboration with the Bonneville Power Administration

Michael Kintner-Meyer, Ph.D.  
Program Review  
Energy Storage Systems Program (ESS)

Washington, DC  
November 2, 2010

Funded by the Energy Storage Systems Program of the U.S. Department Of  
Energy through Pacific Northwest National Laboratories

Contact: email: [Michael.Kintner-Meyer@pnl.gov](mailto:Michael.Kintner-Meyer@pnl.gov)  
phone: 509.375.4306



# Goal and Motivation to Collaborate with BPA

- ▶ Goal: Explore the following questions
  - Explore how much energy storage does the nation need?
  - What kind of storage?
  - Where to place it?
- ▶ Motivation for collaboration with BPA
  - BPA initiated analysis toward storage strategy
  - PNNL needed detailed data
- ▶ What questions do we address?
  - What are the likely balancing requirements for the NWPP in a 14.4 GW wind scenario for 2020 (35% wind capacity compared to total installed, about 12% based on generation)
  - Relative cost competitiveness of different energy storage compared with DR and GT
  - Optimal batteries sizes (right-sizing) and hybridizing
  - What are the energy arbitrage opportunities?
  - How much does location of storage matter?
- ▶ What questions did we NOT address
  - How much of the anticipated balancing requirements can be handled by existing capacity?

# Scenario Definition:

## ► Balancing Services:


- Scope: NWPP, 2019
  - Assume 14.4 GW of total installed capacity of wind.
    - ◆ Existing wind capacity 3.8 GW
    - ◆ Added capacity 10.7 GW
- Technology choices
  - Combustion turbine
  - NAS batteries
  - Li-Ion batteries
  - Demand response
  - Pumped hydro

## ► Arbitrage:

- Scope: NWPP, 2019, WECC's TEPPC\* case
  - Assume 12 GW of total installed capacity of wind.
    - ◆ Existing wind capacity 3.8 GW
    - ◆ Added capacity 8.2 GW



Gas turbine



AEP's NaS



AES's Altair  
Nanotechnologies




DR




Pumped Hydro

# Location of exiting and future wind plants




# Approach for determining balancing requirements




# Resulting Total Balancing Signal

One Month





One Day




# Determining Balancing Requirements

## ➤ Spectral Analysis of the projected imbalance





Imbalances superimposed with scheduled generation



Isolate imbalance




No.	Period	$f_l$ (Hz)	$f_u$ (Hz)	Period of $f_l$	Period of $f_u$
1	Intra-week	0	1.15E-05	Inf.	24 hours
2	Intra-day	1.15E-05	1.36E-04	24 hours	2 hours
3	Intra-hour	1.36E-04	0.0073	2 hours	2 minutes
4	Real-time	0.0073	0.2	2 minutes	5 seconds



# Total requirements for meeting 2019 balancing requirements in NWPP


Total Balancing requirement of NWPP with 14.4 GW wind, selected day



Filtering out INTRA-Hour component



Intra-hour balancing requirements







# Total requirements for meeting 2019 balancing requirements in NWPP

Scenario	Technology
S1	NaS
S2	Li-ion
S3	NaS
	DR
S4	Li-ion
	DR
S5	Pumped Hydro
	NaS
S6	Pumped Hydro
	DR
	NaS
S7	CT
S8	DR
S9-a	Pumped Hydro, Changeover delay = 0
S9-c	Pumped Hydro, Changeover delay = 4 min
	NaS

## Power capacity of all technologies to meet balancing requirement (**GW**)



## Energy storage sizes to meet balancing requirement (**GWh**)



# Cost Performance Characteristics

Parameter	NaS battery	Li-ion battery	Pumped hydro	Combustion turbine	Combined cycle	Demand response
Battery Capital cost \$/kWh	415(230)	1000 (510)				
System Capital cost \$/kW			1750 (1890)	695 (723)	Not used	489
PCS (\$/kW)	200 (150)	200 (150)				
BOP (\$/kW)	100	100				
O&M fixed \$/kW-year	0.46	0.46	4.6	12.75	13.79	
O&M fixed \$/kW-year (PCS)	2	2				
O&M variable cents/kWh	0.7	0.7	0.4	0.376	0.217	
Round trip efficiency	0.78	0.80	0.81	0.315		

# Results of LCC Analysis

- ▶ NaS: \$415/kWh  
\$3,000/kW
- ▶ Li-Ion: \$1000/kWh  
\$2,350/kW
- ▶ Pumped H: \$1,750/kW
- ▶ DR: \$489/kW
- ▶ CT: \$695/kW

C1: Combustion Turbine  
C2: NaS  
C3: Li-ion  
C4: PH multiple mode change  
C5: PH2 mode change  
C6: DR  
C7: NaS+DR  
C8: Li-ion+DR  
C9: PH multiple MC+NaS  
C10: PH2MC+NaS  
C11: PH multiple MC+NaS+DR

# Preliminary Conclusions

- ▶ For a 14+ GW Wind scenario in the NWPP will increase the balancing requirements. Estimated size:
  - Around 2 **GW** power output
  - Above 1 **GWh** energy requirements (if energy storage is used)
- ▶ Life-cycle cost results have large capital component
- ▶ Overall competitiveness depends on price assumptions trading off: learning curves versus material cost projections
- ▶ Na-S is competitive
- ▶ DR can reduce size of Pumped Storage
- ▶ Arbitrage
  - Location of storage does matter. Distributed placement of storage appeared to have higher system benefits

# Future Work

## Programmatic and Policy Questions To Address:

1. What regional differences are important to capture / reflect in storage decisions? =>National assessment of market size for energy storage
2. How much do consolidations of Balancing Authorities influence need for energy storage?
3. How much do load and wind forecasting improvements influence the need for energy storage?
4. What regulatory innovations (market, reliability standards etc.) will be needed to incent industry and consumers to embrace grid transformation and fully capture the benefits of energy storage and smart grid concepts?