

Notrees Energy Storage Project

Jeff Gates

Duke Energy

jeff.gates@duke-energy.com



Project Objectives

- Use energy storage to increase the value and practical application of wind generation
- Integrate storage with intermittent renewable energy production
- Improve use of power-producing assets by storing energy during non-peak generation periods
- Demonstrate benefits of using fast response energy storage to provide ancillary services for grid management
- Verify that energy storage solutions can operate within the ERCOT market protocols
- Demonstrate ramp control and related operational benefits
- Prove storage is commercially viable at utility scale



Project site



- Notrees wind farm, owned and operated by Duke Energy Renewables
- Located in west Texas – Ector and Winkler Counties
- 152.6MW total wind generation capacity
- Energy Storage System (ESS) will be located at the substation and tied on the distribution side

Energy Storage System

- Technology: Advanced lead-acid battery
- OEM Partner – Xtreme Power (XP)
- 36 MW / 24 MWh output
- Modules housed in ~ 6,000 sq. ft. building



- Twenty-four (24) Dynamic Power Modules (DPM™), each rated 1.5 MVA continuous
- Twelve (12) DPM™ cooling pump skids
- Twenty-four (24) DPM™ air/water heat exchangers
- Twenty-four (24) PowerCell™ storage systems including 1.0 MWh storage, racks, and buses
- Two (2) spare PowerCell™ charging and storage systems, etc.

Project Activities to Date

- Site construction began December 2011
- XP DPM™ modules being manufactured and installed
- Metrics & Benefits Plan developed



Upcoming Activities

- Acceptance testing of XP DPR modules ongoing
- Completion of site construction by November 2012
- Commercial operation by December 2012
- First year “Technology Performance Report” by Dec 2012
- System performance testing & analysis, 2013-14

Battery Acceptance Test Plan

- Real power (kW) from the DPR
- Reactive power (kVar) from the DPR
- Apparent power (KVA) from the DPR
- Power factor
- Total dc voltage – Between storage PowerCells and electronics
- PowerCell column pack dc voltage – Between storage PowerCells and electronics
- Max PowerCell column pack dc voltage – Between storage PowerCells and electronics

Acknowledgment: “This material is based upon work supported by the Department of Energy under Award Number(s) DE-OE000195.”

Disclaimer: “This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.”

