

Protocol for Measuring and Expressing Performance for Energy Storage Systems

D. Conover, V. Viswanathan, K. Bray and M. Kintner-Meyer
(Pacific Northwest National Laboratory)

D. Schoenwald, D. Rose, and S. Ferreira
(Sandia National Laboratory)

September 28, 2012

USDOE-OE ESS Peer Review Washington, DC

**Dr. Imre Gyuk - Energy Storage Program Manager,
Office of Electricity Delivery and Energy Reliability**



Sandia
National
Laboratories





Pacific Northwest
NATIONAL LABORATORY

Problem Statement

- ▶ The energy storage market is expanding, with a variety of storage technologies available
- ▶ The lack of a uniform way to evaluate energy storage system (ESS) performance is causing confusion in the market
- ▶ Without an accepted basis for comparing ESS performance, the application and use of storage technology will be hampered

Accomplishments

- ▶ Engaged over 60 entities/organizations in a collaborative way to develop a protocol to measure and express energy storage system performance
- ▶ Completed a protocol to address peak shaving and frequency regulation applications that can be used by industry and as a basis for a consensus standard
- ▶ Established a firm collaborative foundation upon which to foster use of and future enhancement to the protocol to cover additional applications and performance metrics



Participants (Working Group and *Sub-Groups*)

- ✓ **A123 Systems**
- ✓ **AEP**
- ✓ AES Energy Storage
- ✓ ALABC
- ✓ Altairnano
- ✓ Axion Power
- ✓ **BPA**
- ✓ **Clarkson University**
- ✓ CEC
- ✓ CESA
- ✓ Coda Energy
- ✓ Con Ed
- ✓ **Deka Batteries**
- ✓ Dresser-Rand
- ✓ Duke Energy
- ✓ Eaton Yale
- ✓ Emerson
- ✓ **EnerVault**
- ✓ **EOS Energy Storage**
- ✓ EPRI
- ✓ ERCOT
- ✓ **ESA**
- ✓ First Energy Tech
- ✓ GE Energy Storage
- ✓ **HDR/DTA**
- ✓ ICE Energy
- ✓ Ioxus
- ✓ Intertek
- ✓ ISO-NE
- ✓ **K2 Energy Solutions**
- ✓ **KEMA**
- ✓ LADWP
- ✓ Lux Research
- ✓ **Maxwell Technologies**
- ✓ **MISO Energy**
- ✓ **Mustang Prairie, LLC**
- ✓ **NEMA**
- ✓ NGK
- ✓ NRDC
- ✓ NRECA
- ✓ **NEC Labs America**
- ✓ Nichicon America
- ✓ **Nemtzw and Associates**
- ✓ NYSERDA
- ✓ **NY BEST**
- ✓ PacifiCorp
- ✓ PG&E
- ✓ PJM
- ✓ **PNM Resources**
- ✓ **Powin Energy**
- ✓ Premium Power
- ✓ Primus Power
- ✓ **Prudent Energy**
- ✓ SAFT
- ✓ SAIC
- ✓ S&C Electric
- ✓ **SEEO**
- ✓ **Solar Grid Storage**
- ✓ Solon
- ✓ So Cal Edison
- ✓ Southern Company
- ✓ **Steffes Corp**
- ✓ SUNY
- ✓ Velkess
- ✓ Xtreme Power


Section 1.0 - Purpose

- A set of “best practices” for characterizing energy storage systems and measuring and reporting on their performance
- A basis for assessing how individual energy storage systems will perform with respect to key performance attributes relevant to different applications
- Intended to provide a valid and accurate basis for the comparison of different energy storage systems
- Enable more informed decision-making in the selection of energy storage systems for various stationary applications

Section 2.0 - Scope

- Defines test and measurement criteria with which to express and report performance
- Energy storage systems are used for energy intensive stationary applications (peak shaving) and/or power intensive stationary applications (frequency regulation)
- Includes the storage device, any power conversion systems installed with the storage device and may also include any battery management systems
- Agnostic with respect to the storage technology and the size and rating of the energy storage system
- Does not apply to single use storage devices and storage devices that are not coupled with power conversion systems
- Does not address safety, security or operations and maintenance of energy storage systems
- Does not provide pass/fail criteria

Protocol Overview



- Measurement Procedure**
- What to measure
 - How to measure it
 - Temperature
 - Pressure
 - Current
 - Voltage

- Determination of relevant metrics**
- How to calculate from measurements
 - When to measure it
 - Peak power
 - Capacity
 - Ramp rate
 - Response time
 - Available energy at various power

Figure 4-1 Protocol Overview

Summary of Technical Criteria

➤ Applications

- Frequency regulation
- Peak shaving

➤ Duty cycle established

➤ Metrics

- Round trip efficiency at rated power
- Round trip efficiency using duty cycle for fixed duration
- Response time
 - Time to respond after signal receipt
 - Ramp rate

➤ Reference Performance

- Measure energy capacity before and after subjecting to fixed duration duty cycle

➤ Definitions


- Energy storage system
- Rated power
- Energy capacity
- Response time
- Ramp rate
- Round trip efficiency

Frequency Regulation

- Area regulation used by BA to meet NERC BA Performance Control Standards
- ESS subjected to PJM duty cycle
- Round trip efficiency @ rated power = disch energy/charge energy
- Round trip efficiency during duty cycle measured by subjecting ESS to duty cycle from desired initial SOC and bringing ESS back to initial SOC after duty cycle
 - Round trip efficiency = total discharge energy/total charge energy
- Response time measured at extreme SOC – time from no load to full discharge rated power, no load to full charge rated power
- Response time includes time to respond to signal + time to ramp to desired power
- Ability of ESS to track signal $\Sigma(P_{\text{signal}} - P_{\text{ess}})^2$, $\Sigma|P_{\text{signal}} - P_{\text{ess}}|$, $\Sigma|E_{\text{signal}} - E_{\text{ess}}|$ - % total tracking also reported

Frequency regulation duty cycle

- Duty cycle determined from PJM balancing signal for year 2011
- Standard deviation over a 24-hour period used as metric for signal aggressiveness
- Signals grouped into low, average and high standard deviations
- Representative 2-hour intervals with average standard deviation and 1-hour intervals with high standard deviation chosen
 - each being energy neutral
- Duty cycle consisted of three 2-hour average standard deviation (SD) signals followed by two 1-hour high SD signals, three 2-hour average standard deviation (SD) signals followed by two 1-hour high SD signals and four 2-hour average SD signals



Pacific Northwest
NATIONAL LABORATORY

Proudly Operated by Battelle Since 1965


Peak Shaving

Peak Shaving Applications defined in Protocol

Application	Expected Range of Required Discharge Duration	Projected Power Range of Installations
Energy Time Shift (Arbitrage)	3-7 hours	1-500MW
Supply Capacity	4-6 hours	1-500MW
Load Following	2-4 hours	1-500MW
Transmission Congestion Relief	3-5 hours	1-100MW
Distribution Upgrade Deferral	3-6 hours	0.2-20MW
Transmission Upgrade Deferral	3-6 hours	1-100MW
Retail Demand Charge Management	4-6 hours	0.05-10MW
Wind Energy Time Shift (Arbitrage)	3-6 hours	0.2-500MW
Solar Energy Time Shift (Arbitrage)	3-5 hours	0.2-50MW
Renewable Capacity Firming	2-3 hours	0.1-500MW
Baseload generation time shift*	4-6 hours	10MW-500MW

Peak Shaving Duty Cycles

Peak Shaving Duty Cycles as Defined in the Protocol



**Discharge duration is primary differentiator
between peak shaving applications**

Next Steps

- Application of the initial protocol by the industry and use of results by storage technology customers
- Further refinement based on its application and use
- Use as a basis for consensus standards by US and/or international standards developing organizations (SDOs)
- Development of new provisions to address additional applications and performance metrics
- Application and use of new provisions, further refinement and transition through the protocol to US and/or international SDOs
- Continue to strengthen and broaden our unique public-private collaborative process

Acknowledgement

We gratefully acknowledge support from the U. S. Department of Energy, Office of Electricity Delivery and Energy Reliability (Dr. Imre Gyuk, DOE-OE Energy Storage Program)



Pacific Northwest
NATIONAL LABORATORY

Proudly Operated by Battelle Since 1965