

**U.S. Department of Energy
Naval Reactors Representative's Office
Kesselring Site**

National Environmental Policy Act (NEPA) Categorical Exclusion (CX)
Determination Summary Form

KESSELRING SITE S8G-P STRUCTURAL STEEL REFURBISHMENT PROJECT

REFERENCE

10 CFR Part 1021, Department of Energy National Environmental Policy Act Implementing Procedures, Subpart D, Typical Classes of Actions, Appendix B.

PROJECT SCOPE DISCUSSION

S8G prototype has been in service for over 30 years, its structural steel support systems require refurbishment and replacement. Structural steel encompasses pipe supports and support structures on and around S8G prototype which support its operation. The purpose is to remove existing corrosion, install a new long lasting protective coating system, and replace any significantly degraded hardware or items which show material loss. Paint sampling has shown that locations contain lead and asbestos. Structural steel refurbishment and replacement on and around the S8G prototype is a reoccurring project.

The project does not violate applicable regulatory requirements, require construction or major expansion of waste handling facilities, result in unpermitted releases of hazardous substances, or adversely affect environmentally sensitive resources, including wetlands. The project does not involve genetically engineered organisms or species. There are no extraordinary circumstances related to the proposed action. The project has not been segmented to meet the definition of a categorical exclusion and is not connected to other actions with potentially significant and/or cumulative impacts.

CONCLUSION

The Kesselring S8G-P Structural Steel Refurbishment Project is categorically excluded from additional NEPA documentation under 10 CFR 1021 Subpart D, Appendix B, B1.3, B1.16, and B1.34. Specifically, the categorical exclusions that apply are:

B1.3 Routine maintenance

Routine maintenance activities and custodial services for buildings, structures, rights-of-way, infrastructures (including, but not limited to, pathways, roads, and railroads), vehicles and equipment, and localized vegetation and pest control, during which operations may be suspended and resumed, provided that the activities would be conducted in a manner in accordance with applicable requirements. Custodial services are activities to preserve facility appearance, working conditions, and sanitation (such as cleaning, window washing, lawn mowing, trash collection, painting, and snow removal). Routine maintenance activities, corrective (that is, repair), preventive, and predictive, are required to maintain and preserve buildings, structures, infrastructures, and equipment in a condition suitable for a facility to be used for its designated purpose. Such maintenance may occur as a result of severe weather (such as hurricanes, floods, and tornados), wildfires, and other such events. Routine maintenance may result in replacement to the extent that replacement is in-kind and is not a substantial upgrade or improvement. In-kind replacement includes installation of

new components to replace outmoded components, provided that the replacement does not result in a significant change in the expected useful life, design capacity, or function of the facility. Routine maintenance does not include replacement of a major component that significantly extends the originally intended useful life of a facility (for example, it does not include the replacement of a reactor vessel near the end of its useful life). Routine maintenance activities include, but are not limited to:

- (a) Repair or replacement of facility equipment, such as lathes, mills, pumps, and presses;
- (b) Door and window repair or replacement;
- (c) Wall, ceiling, or floor repair or replacement;
- (d) Reroofing;
- (e) Plumbing, electrical utility, lighting, and telephone service repair or replacement;
- (f) Routine replacement of high-efficiency particulate air filters;
- (g) Inspection and/or treatment of currently installed utility poles;
- (h) Repair of road embankments;
- (i) Repair or replacement of fire protection sprinkler systems;
- (j) Road and parking area resurfacing, including construction of temporary access to facilitate resurfacing, and scraping and grading of unpaved surfaces;
- (k) Erosion control and soil stabilization measures (such as reseeded, gabions, grading, and revegetation);
- (l) Surveillance and maintenance of surplus facilities in accordance with DOE Order 435.1, "Radioactive Waste Management," or its successor;
- (m) Repair and maintenance of transmission facilities, such as replacement of conductors of the same nominal voltage, poles, circuit breakers, transformers, capacitors, cross arms, insulators, and downed power lines, in accordance, where appropriate, with 40 CFR part 761 (Polychlorinated Biphenyls Manufacturing, Processing, Distribution in Commerce, and Use Prohibitions) or its successor;
- (n) Routine testing and calibration of facility components, subsystems, or portable equipment (such as control valves, in-core monitoring devices, transformers, capacitors, monitoring wells, lysimeters, weather stations, and flumes);
- (o) Routine decontamination of the surfaces of equipment, rooms, hot cells, or other interior surfaces of buildings (by such activities as wiping with rags, using strippable latex, and minor vacuuming), and removal of contaminated intact equipment and other material (not including spent nuclear fuel or special nuclear material in nuclear reactors); and
- (p) Removal of debris.

B1.16 Asbestos Removal

Removal of asbestos-containing materials from buildings in accordance with applicable requirements (such as 40 CFR part 61, "National Emission Standards for Hazardous Air Pollutants"; 40 CFR part 763, "Asbestos"; 29 CFR part 1910, subpart I, "Personal Protective Equipment"; and 29 CFR part 1926, "Safety and Health Regulations for Construction"; and appropriate state and local requirements, including certification of removal contractors and technicians).

B1.34 Lead-based paint containment, removal, and disposal

Containment, removal, and disposal of lead-based paint in accordance with applicable requirements (such as provisions relating to the certification of removal contractors and technicians at 40 CFR part 745, "Lead-Based Paint Poisoning Prevention In Certain Residential Structures").

NRRO Approval:

HARRY S.
MILLER

Digitally signed by
milleha@nnp.gov
(1000000472)
Date: 2024.04.22
11:44:11 -04'00'