

***Report on Quarterly Air Monitoring,
Area IV, Eighth Quarter 2020***

***Santa Susana Field Laboratory
Ventura County, California***



July 2020

***Prepared for:
United States
Department of Energy***

***Prepared by:
North Wind Portage, Inc.***

(This page intentionally left blank)

**Report on Quarterly Air Monitoring, Area IV,
Eighth Quarter 2020**

**Santa Susana Field Laboratory
Ventura County, CA**

July 2020

Contract No. DE-EM0000837-DT0007583

Prepared for:

U.S. Department of Energy
4100 Guardian Street, Suite 160
Simi Valley, California 93063

Prepared by:

North Wind Portage, Inc.
1425 Higham Street
Idaho Falls, Idaho 83402

(This page intentionally left blank)

PROFESSIONAL CERTIFICATION

**Report on Quarterly Air Monitoring, Area IV, Eighth Quarter 2020
Santa Susana Field Laboratory
Ventura County, California**

July 2020

This report has been prepared by a team of qualified professionals under the supervision of the senior staff whose signatures appear below.



Prepared by:
Candace Christensen, PMP
Quality Manager



Reviewed by:
Brian Dow, P.G., PMP, QSD
Operations Manager



Approved by:
Brad Frazee
Chief Operating Officer

(This page intentionally left blank)

EXECUTIVE SUMMARY

This report summarizes the United States Department of Energy (DOE) air monitoring activities conducted during the eighth quarter (Q8) of the baseline monitoring period (January 1, 2020, to March 31, 2020) at Area IV within in the Santa Susana Field Laboratory (SSFL), located in Ventura County, California. The area specifically discussed within this report is the DOE portion, Area IV of SSFL, known as the Energy Technology Engineering Center (ETEC). Year one of the Baseline Air Monitoring Program consisted of Quarter 1 through Quarter 4. Year two consisted of Quarter 5 through Quarter 7. The program is continuing for a third year, which will consist of Quarter 8 through Quarter 11.

This quarterly report has been developed by North Wind Portage, Inc., on behalf of DOE in cooperation with The Boeing Company (Boeing) and the National Aeronautics and Space Administration (NASA), as part of a Baseline Air Monitoring Program.

The objective of the Baseline Air Monitoring Program is to evaluate baseline (that is, pre-project) conditions. In accordance with *the Final Baseline Air Monitoring Work Plan, Santa Susana Field Laboratory, Ventura County, California* (NASA 2017), the responsible parties are monitoring for particulate matter between 2.5 and 10 microns in aerodynamic diameter (PM₁₀), volatile organic compounds (VOCs), and radionuclides at air monitoring stations DOE-1, DOE-2, DOE-3, and DOE-4 encompassing the ETEC, Area IV portion of the SSFL. Determining the baseline levels for PM₁₀, VOCs, and radionuclides helps distinguish between levels that naturally occur or were previously present at the ETEC site and if onsite remediation activities produce elevated results. Air monitoring will be continued throughout remediation activities to be able to compare results from onsite remediation activities to baseline data.

The following air monitoring activities conducted during Q8 2020 by DOE within Area IV are summarized in this report:

- Collected meteorological data from one location (DOE-4);
- Collected PM₁₀ data from four locations (DOE-1 through DOE-4);
- Collected air samples from four locations (DOE-1 through DOE-4) for VOC laboratory analysis; and
- Collected radionuclide samples for laboratory analysis from four locations (DOE-1 through DOE-4).

Meteorological data, PM₁₀, VOC, and radionuclide data all met the data completeness goal of 80% for Q8. The baseline air monitoring is to be continued beginning April 1, 2020 with the ninth quarter of year three baseline monitoring. Data collected during remediation activities will be compared to the baseline conditions.

The following site activities were conducted during Q8 by DOE within Area IV:

- Annual groundwater sampling event
- Deactivation of CLIN 8, 9 facilities
- Surveillance and maintenance
- Abatement activities.

Site activities were shut down on March 20, 2020, through the end of Q8, due to COVID-19.

CONTENTS

PROFESSIONAL CERTIFICATION iii

EXECUTIVE SUMMARY v

ACRONYMS AND ABBREVIATIONS viii

1. INTRODUCTION 1-1

 1.1 Regional Climate and Wind Direction 1-2

2. SUMMARY 2-1

3. ANALYTICAL SAMPLING EVENTS..... 3-1

4. DATA..... 4-1

 4.1 Meteorological Data 4-1

 4.2 PM₁₀ Data 4-4

 4.3 Volatile Organic Compound Data 4-5

 4.4 Radionuclide Data 4-5

5. QA/QC ACTIVITIES..... 5-1

 5.1 Field QA/QC 5-1

 5.2 Laboratory QA/QC..... 5-4

 5.3 Audit Results 5-4

6. REFERENCES 6-1

FIGURES

Figure 1 – SSFL Air Monitoring Locations

Figure 2 – DOE Air Monitoring Locations

Figure 3 – DOE Quarterly Wind Rose

TABLES

Table 1. Data screening quality control codes for meteorological data. 4-1

Table 2. Data screening summary for monitored meteorological parameters. 4-3

Table 3. PM₁₀ data completeness for January 1, 2020, to March 31, 2020..... 4-4

Table 4. Top five PM₁₀ 24-hour average concentration days. 4-4

Table 5. Ambient air VOC data completeness.....4-5

Table 6. Gross alpha and beta-gamma average results for Q8.....4-6

Table 7. Meteorological sensor recommended maintenance frequency (Met One).....5-4

Table 8. PM₁₀ audit completeness.....5-5

APPENDICES

Appendix A – PM₁₀ Daily Averages and Monthly Statistics

Appendix B – Analytical Results for Ambient Air VOCs

Appendix C – Radionuclide Results

Appendix D – PM₁₀ Monthly Audit Reports and Flow Verification Results

ACRONYMS AND ABBREVIATIONS

| | |
|-------------------|--|
| °C | degrees Celsius |
| °F | degrees Fahrenheit |
| μCi | microcurie(s) |
| μg/m ³ | microgram(s) per cubic meter |
| Boeing | The Boeing Company |
| CAAQS | California Ambient Air Quality Standard |
| CFR | Code of Federal Regulations |
| DASC | Data Assessment Statistical Calculator |
| DOE | U.S. Department of Energy |
| DTSC | State of California Department of Toxic Substances Control |
| EPA | U.S. Environmental Protection Agency |
| ETEC | Energy Technology Engineering Center |
| GC | gas chromatography |
| Hg | mercury |
| HHRA | Human Health Risk Assessment |
| mph | miles per hour |
| MS | mass spectrometry |
| m | meter(s) |
| m/sec | meter(s) per second |
| mb | millibar(s) |
| mL | milliliter(s) |
| MDC | minimum detectable concentration |
| NASA | National Aeronautics and Space Administration |
| NIST | National Institute of Standards and Technology |
| pCi | picocurie(s) |
| PM _{2.5} | particulate matter less than 2.5 microns in aerodynamic diameter |
| PM ₁₀ | particulate matter less than 10 microns in aerodynamic diameter |
| Q1 | first quarter |
| Q2 | second quarter |
| Q3 | third quarter |
| Q4 | fourth quarter |
| Q5 | fifth quarter |
| Q6 | sixth quarter |
| Q7 | seventh quarter |
| Q8 | eighth quarter |
| QA | quality assurance |
| QC | quality control |
| RAWS | Remote Automatic Weather Stations |
| RPD | relative percent difference |
| RSL | regional screening level |
| SDG | sample delivery group |
| SSFL | Santa Susana Field Laboratory |
| VOC | volatile organic compound |

1. INTRODUCTION

National Aeronautics and Space Administration (NASA), The Boeing Company (Boeing), and the U.S. Department of Energy (DOE), also known as the responsible parties, are performing baseline air monitoring at the Santa Susana Field Laboratory (SSFL) site located in Ventura County, California. The SSFL is a business segment of Boeing. SSFL operates the 2,849-acre site located atop a range of hills between the Simi and San Fernando valleys, north of Los Angeles. The westernmost 290 acres of the SSFL, known as Area IV, contains both DOE and Boeing facilities. The DOE portion is mainly contained within the 90 acres known as the Energy Technology Engineering Center (ETEC).

When opened in the late 1950s, ETEC was ideally remote from population centers to enable development of security-sensitive projects. These projects supported research for DOE and its predecessor agencies for nuclear research and energy development. Area IV includes buildings that house test apparatus for large-scale heat transfer and fluid mechanics experiments, mechanical and chemical test facilities, office buildings, and auxiliary facilities.

Baseline air monitoring is being conducted in accordance with the *Final Baseline Air Monitoring Work Plan, Santa Susana Field Laboratory, Ventura County, California* (NASA 2017), which was submitted to the State of California Department of Toxic Substances Control (DTSC) on September 21, 2017. DTSC approved the Work Plan. Final locations of the air monitoring locations were approved by DTSC on January 30, 2018 (DTSC 2018).

The objective of the Baseline Air Monitoring Program is to evaluate baseline (that is, pre-project) conditions and provide a basis for determining the magnitude of deviation from those baseline conditions that may result from onsite remediation activities (project) at SSFL. Responsible parties are monitoring for particulate matter between 2.5 and 10 microns in aerodynamic diameter (PM₁₀), and volatile organic compounds (VOCs), at 14 locations at SSFL. Data were collected for four perimeter samplers (DOE-1 through DOE-4) and analyzed for gross alpha and gross beta. Individual radionuclide concentrations were determined by analysis at an offsite laboratory for these same four locations. Meteorological data are also collected as a part of the Baseline Air Monitoring Program.

Figure 1 shows the air monitoring locations for the Baseline Air Monitoring Program. These locations were selected based on the areas to be remediated, with consideration of winds in the area, topographic features, and accessibility. The air monitoring sites were also selected based on guidance obtained from the U.S. Environmental Protection Agency's (EPA's) *Quality Assurance Handbook for Air Pollution Measurement Systems*, Volume II, Ambient Air Monitoring Program (EPA 2017) and *Meteorological Monitoring Guidance for Regulatory Modeling Applications* (EPA 2000). Sites were evaluated per 40 Code of Federal Regulations (CFR) 58, Appendix C – Ambient Air Quality Monitoring Methodology. DOE is responsible for DOE-1, DOE-2, DOE-3, and DOE-4 of the 14 monitoring locations, represented in Figure 1. VOCs, PM₁₀, and radionuclides are monitored at the four DOE monitoring locations, and meteorological conditions are monitored at the DOE-4 location. The DOE monitoring locations DOE-1 through DOE-4 are shown in Figure 2.

This report summarizes the Q8 quarterly results and quality assurance (QA) activities performed between January 1, 2020, and March 31, 2020.

1.1 Regional Climate and Wind Direction

The climate in the SSFL area is characterized as “Mediterranean.” The mean temperature during the winter months is approximately 50 degrees Fahrenheit (°F) and the mean temperature in the summer months is approximately 70°F. Based on climate data between 2018 and 2019 from Weather Atlas, average rainfall is on the order of 17.9 inches per year. The majority of the rainfall occurs between December and April.

The average hourly wind speed in Simi Valley varies significantly by season. The more turbulent part of the year lasts for 6 months, from November to April, with average western wind speeds of more than 7 miles per hour (mph). The calmer time of year lasts for 6 months, with northerly winds from May to October.

During the fall, winter, and spring, Santa Ana winds can blow from the north or northeast in excess of 35 mph.

2. SUMMARY

This report summarizes the air monitoring data collected during the Q8 reporting period (January 1, 2020, to March 31, 2020).

Quality objectives and data completeness of 80% were met for all meteorological, PM₁₀, VOC, and radionuclide data for Q8 of the Baseline Air Monitoring Program.

Urban background data compared with baseline monitoring data indicate that the PM₁₀ concentrations measured at stations DOE-1, DOE-2, DOE-3, and DOE-4 during Q8 are comparable to the PM₁₀ concentrations measured at stations characterizing urban background. During Q8, none of the five average daily concentrations exceeded the CAAQS of 50 µg/m³ or the National Ambient Air Quality Standard of 150 µg/m³.

During Q8 there were four VOC analytes detected above the EPA Residential Air RSL or the DTSC HHRA. Three analytes were detected during the March 6, 2020, sampling event and one from the March 20, 2020, sampling event. DOE-1 and DOE-3 each had one detection above the screening level and DOE-4 had two analytes detected above the screening level.

Of the 26 radiological sampling events at DOE-1, DOE-2, and DOE-4 and 27 events at DOE-3 in Q8, detections for gross alpha and gross beta that exceeded the MDC are all naturally occurring radionuclides. Detections are expected because the results are calculated at a 95% confidence level. No man-made radionuclides that are contaminants of concern at ETEC were detected.

Data collected during the Q8 reporting period agree with data collected, analyzed, and reported by the State of California Department of Toxic Substances Control, Los Angeles County Emergency Response Organization, the DOE Emergency Response organization, or other Multi-Agency Task Forces. Air monitoring at Area IV of the SSFL is to be continued starting April 1, 2020, for the ninth quarter of the Baseline Air Monitoring Program.

(This page intentionally left blank)

3. ANALYTICAL SAMPLING EVENTS

VOCs are collected according to the EPA Toxic Compendium Method TO-15, *Determination of Volatile Organic Compounds (VOCs) Air Collected in Specially-Prepared Canisters and Analyzed by Gas Chromatography/Mass Spectrometry (GC/MS)* (EPA 1999). Twenty-four-hour time-integrated samples are collected into Summa canisters via a flow controller and sent to an offsite laboratory for analysis. VOCs are collected every other week. There were six VOC sampling events in this reporting period with one field duplicate sample collected during each sampling event.

During Q8, radionuclide samples were collected at four perimeter sampler locations, DOE-1 through DOE-4. These samples were collected on glass fiber (Type A/E) filters that are changed twice a week. After a minimum 120-hour holding time to allow the decay of short-lived radon and thoron daughter products, the samples are simultaneously counted for gross alpha and beta activity with a low-background, thin-window, gas-flow proportional-counting system continually purged with P-10 argon/methane counting gas over a preset time interval. There were 26 sampling events for air samplers DOE-1, -2, and -4 and 27 sampling events for DOE-3 during this reporting period. Following analysis for gross alpha and gross beta radiation, sample filters were combined to form one composite sample representative of each location. The four composite samples were then analyzed for individual radionuclides at an offsite laboratory.

(This page intentionally left blank)

4. DATA

Sections 4.1 through 4.4 discuss Q8 air monitoring data.

4.1 Meteorological Data

General Summary

Meteorological data, also called weather data, is being collected as part of the ETEC cleanup and restoration effort. This information, particularly the wind direction and wind speed, can be used to help understand how dust and other air pollutants from the site are carried by the wind and possibly affect nearby public and residential areas. This is especially important when the E-BAM particulate monitors at the site detect higher than normal amounts of dust in the air. Scientific computer models can be used with this weather data in association with the particulate monitoring data to describe the air quality for the communities near the ETC site. However, before the weather data can be used with the computer models it must first be tested for completeness and accuracy. A detailed description of the weather data collection and quality testing is provided in the following paragraphs.

Monitored meteorology parameters at the DOE-4 station included wind speed, wind direction, air temperature at 2 meters (m) and 10 m, relative humidity, precipitation, barometric pressure, and solar radiation. In addition, statistical parameters provided by the data logger included delta temperature (i.e., defined as the 10-m temperature minus the 2-m temperature), maximum wind speed (i.e., wind gust), and standard deviation of wind direction. Observations were recorded at 15-minute intervals for :00, :15, :30; and :45 minutes each hour. There were 91 days in this reporting period, which covers January 1, 2020, to March 31, 2020, with a total of 8,736 possible 15-minute observations. Note that Q8 represents the start of the Year 3 baseline monitoring period. Year 2 had been abbreviated to include only three quarters: Quarter 5 (Q5) through Quarter 7 (Q7) in order to synchronize baseline monitoring years with the calendar years.

Data Validation and Statistics

Data validation screening was performed on the recorded meteorological observations pursuant to EPA's *Meteorological Monitoring Guidance for Regulatory Modeling Applications* (EPA 2000), Table 8-4 (Suggested Data Screening Criteria) and Table 8-3 (Suggested Quality Control Codes). Validation screening provided the basis for evaluating data completeness and for determining sensor performance and/or maintenance status. Validation was performed following each weekly data download. Data validation quality control codes applied to the meteorological observations are defined in Table 1.

Table 1. Data screening quality control codes for meteorological data.

| Code | Meaning | Description (as used for ETEC meteorological data validation) |
|------|-------------------------|--|
| 0 | Valid | PASS – Observation is accurate within the performance limits of the instrument (i.e., value passes all data validation screening criteria) |
| 3 | Acceptable | PASS – Observation originally failed initial quality control (QC) check (see Code 6), but additional review using other independent data and meteorological judgment support final validity. |
| 6 | Failed initial QC check | FAIL – Observation did not pass data validation screening criteria. |
| 7 | Suspect | FAIL – Observation failed initial data validation QC check (see Code 6) and could not be verified through additional review using other independent data. |
| 8 | Invalid | FAIL – Observation judged to be inaccurate or in error, and the cause is known. |
| 9 | Missing | FAIL – Observation was not collected. |

The validation screening involved comparing, on an individual parameter basis, the recorded values (i.e., observations) against the EPA screening criteria shown in Table 2. The data validation procedure involved an initial automated review to apply a first level QC Code of 0 (valid), 6 (failed), or 9 (missing) as defined in Table 1. Observations initially flagged with a QC Code = 6 were then manually (i.e., second-level) reviewed by a project meteorologist. The procedure is outlined below:

- Values meeting all screening criteria for the respective meteorological parameter were automatically considered “valid” (QC Code = 0).
- Values not meeting a screening criterion were automatically flagged as “failed initial QC” (QC Code = 6). These values were subjected to second-level manual meteorological review using other available observations (e.g., 2-m vs. 10-m temperature at DOE-4 or from nearby Remote Automatic Weather Stations [RAWS] meteorological station CEEC1 in the Cheeseboro Canyon, California, area located 2.6 miles south of the DOE-4 site), and meteorological judgment:
 - Values confirmed by second-level review were deemed “acceptable” (final QC Code = 3).
 - Otherwise, the values were deemed “suspect” (final QC Code = 7).
- Observations known to be inaccurate (QC Code = 8).
- Missing observations were automatically flagged as “missing” (QC Code = 9).

Values that pass validation with a final QC Code of 0 or 3 are included in the data completeness statistics and the final validated meteorological data set. Values with a final QC Code of 7, 8, or 9 are excluded from the final dataset and counted against the data completeness percentage. Quarterly data statistics for the meteorological parameters are listed in Table 2 along with year-to-date and project-to date results. Year-to-date and Project-to-date percentages are calculated as total valid observations through the completed quarters for the year divided by the total possible observations through this same period.

The meteorological data completeness goal is 80% on an annual basis. Data completeness statistics for all completed reporting quarters in Year 3 of the baseline monitoring are presented in Table 2. In summary, the data completeness goal was achieved for all meteorological parameters in Q8.

Wind Rose

The final validated 15-minute meteorological dataset was used to develop the wind rose for Q8 as presented in Figure 3. A wind rose is a graphical representation of wind speed and direction distribution (or climatology) for the period of interest. The frequency of winds blowing from a particular direction is shown as petals on the wind rose, with the frequency of wind speeds depicted by color bands. Calm winds are identified as being less than 0.5 meters per second (m/sec).

During Q8, data capture for wind speed and direction at DOE-4 was 100%. The average and maximum wind speeds were 4.5 m/sec and 20.2 m/s, respectively. The maximum recorded wind gust was 29.2 m/sec. The primary predominant wind direction was from the north and north-northeast with a secondary peak from the east-southeast.

Table 2. Data screening summary for monitored meteorological parameters.

| Meteorological Parameter | Screening Criteria ⁽¹⁾ (for valid sensor responses) | Data Completeness Percent (%) ⁽²⁾ | | |
|--|--|--|----------------|-----------------|
| | | Q8 | Year 3 to Date | Project to Date |
| Wind Speed | between 0 and 25 m/sec (meters/second) | 100 | 100 | 89.02 |
| | > 0.1 m/sec variation over 3 hours | | | |
| | > 0.5 m/sec variation over 12 hours | | | |
| Wind Direction | between 0 and 360 degrees | 100 | 100 | 89.02 |
| | > 1 degree variation over 3 hours | | | |
| | > 10 degree variation over 12 hours | | | |
| Standard Deviation of Wind Direction | Inherits the completeness stats of Wind Direction | 100 | 100 | 89.02 |
| Temperature @ 2 m | ≤ local record high (monthly basis) | 100 | 100 | 89.01 |
| | ≥ local record low (monthly basis) | | | |
| | > 0.5 Celsius (°C) variation over 12 hours | | | |
| Temperature @ 10 m | ≤ local record high (monthly basis) | 100 | 100 | 89.02 |
| | ≥ local record low (monthly basis) | | | |
| | > 0.5°C variation over 12 hours | | | |
| Delta Temperature | ≤ 0.1°C during daytime | 100 | 100 | 89.01 |
| | ≥ -0.1°C during nighttime | | | |
| | between -3.0 and 5.0°C | | | |
| Relative Humidity (and Dewpoint Temperature) | relative humidity between 0-100% | 100 | 100 | 76.48 |
| | dew point T ≤ ambient T | | | |
| | dew point T ≤ 5.0°C variation over 1 hour | | | |
| | dew point T > 0.5°C variation over 12 hours | | | |
| Precipitation | ≤ 1 inch in 1 hour | 99.84 | 99.84 | 88.99 |
| | ≤ 4 inches in 24 hours | | | |
| | ≥ 2 inches in 3 months | | | |
| Barometric Pressure | between 871 and 982 millibar (mb) (local) (i.e., between 940 and 1060 mb sea level) | 100 | 100 | 89.02 |
| | ≤ 6 mb variation over 3 hours | | | |
| Solar Radiation | > 0 at night | 99.74 | 99.74 | 88.96 |
| | ≤ maximum possible for date and latitude | | | |

(1) Screening criteria from EPA Meteorological Monitoring Guidance (EPA 2000), Table 8-4.

(2) Data Completeness % = [Observations Passing] / [Possible Observations].
Missing or suspect observations count against data completeness statistics.
Year Two is an abbreviated data collection year spanning the period Apr 15–Dec 31, 2019 (i.e., Quarters 5, 6, and 7). This was done to synchronize future data collection years with calendar years.
The number of possible 15-minute observations in the completed reporting periods:
 • Q1 = 8,736 • Q2 = 8,832 • Q3 = 8,832 • Q4 = 8,640 • Year One = 35,040
 • Q5 = 8,736 • Q6 = 8,832 • Q7 = 7,488 • Year Two = 25,056 (only 3 quarters)
 • Q8 = 8,736 • Year Three = (in progress)

4.2 PM₁₀ Data

PM₁₀ data, defined as coarse particles between 2.5 and 10 micrometers in diameter, are measured at the ETEC site. Sources of particulate matter can be naturally occurring or caused by human activity. The air monitoring conducted at ETEC is used to determine if any suspended particles are from activities conducted onsite or if they are consistent with surrounding air quality data. Some of the naturally occurring particles can originate from high winds, forest or grass fires, burning of fossil fuels in vehicles, or stirred-up road dust.

PM₁₀ data are collected with Met One E-BAM monitors at four monitoring locations. The Met One E-BAM uses the principle of beta attenuation to provide a determination of mass concentration. Twenty-four-hour concentrations are calculated from the hourly concentrations. There were 91 days in this reporting period.

- DOE-1 had 55 valid reading days (of 91), with the shortfall due to an O-ring failure on February 16, 2020, with no replacements available onsite. There is no available data from February 17, 2020, through March 24, 2020.
- DOE-2 had valid readings all 91 days.
- DOE-3 had 86 valid reading days (of 91), with the shortfall due to the following reasons. The air pump failed during Q7 and there were no replacements available onsite. DOE-3 was not repaired and returned to service until January 6, 2020. There is no available data from January 1, 2020, until January 6, 2020.
- DOE-4 had valid readings all 91 days.

Although some station units needed repair during Q8, data completeness for PM₁₀ exceeded the project goal of 80% completeness for total samples collected (see Table 3). The complete table of daily averages is presented in Appendix A.

Table 3. PM₁₀ data completeness for January 1, 2020, to March 31, 2020.

| Location | Valid Readings (Days) | Possible Readings (Days) | Data Completeness (Percent) |
|---------------------------------|-----------------------|--------------------------|-----------------------------|
| DOE-1 | 55 | 91 | 65 |
| DOE-2 | 91 | 91 | 100 |
| DOE-3 | 86 | 91 | 95 |
| DOE-4 | 91 | 91 | 100 |
| Average Total Data Completeness | | | 88.74 |

The five highest PM₁₀ results identified for the reporting period are listed in Table 4 along with the California Ambient Air Quality Standard (CAAQS) for PM₁₀. PM₁₀ concentrations were consistent with levels typically found in urban air. Of these top five results, two were recorded at DOE-1 and DOE-4 and one at DOE-2. All of the top five values were below the CAAQS and the National Ambient Air Quality Standard of 150 micrograms per cubic meter (µg/m³). Two of the top five values were recorded on the same day, January 16, 2020, when winds exceeded 6 m/sec compared to the usual 0.5 to 1.5 m/sec. High winds are known to increase air particulates.

Table 4. Top five PM₁₀ 24-hour average concentration days.

| Date | Location | PM ₁₀ Value (µg/m ³) | CAAQS (µg/m ³) |
|-----------|----------|---|----------------------------|
| 2/3/2020 | DOE-4 | 39.75000 | 50 |
| 1/16/2020 | DOE-4 | 27.62500 | 50 |
| 2/9/2020 | DOE-1 | 27.50000 | 50 |
| 1/26/2020 | DOE-1 | 24.62500 | 50 |
| 1/16/2020 | DOE-2 | 24.41600 | 50 |

4.3 Volatile Organic Compound Data

Volatile organic compounds (VOCs) are organic chemicals that have a high vapor pressure, which causes them to evaporate quickly and enter the surrounding air. VOCs can be both naturally occurring or man-made. The VOC data collected can help distinguish between man-made detections from onsite activities or naturally existing organic chemicals. The VOC data collected are compared against screening levels. These screening levels are risk-based concentrations derived from standardized equations combining exposure information with toxicity data.

Each of the four DOE locations was sampled during the six VOC sampling events this period. Data completeness goals for VOCs exceeded the project goal of 85% (see Table 5).

Table 5. Ambient air VOC data completeness.

| Location | Valid Readings (Days) | Possible Readings (Days) | Data Completeness (Percent) |
|---------------------------------|-----------------------|--------------------------|-----------------------------|
| DOE-1 | 6 | 6 | 100 |
| DOE-2 | 6 | 6 | 100 |
| DOE-3 | 6 | 6 | 100 |
| DOE-4 | 6 | 6 | 100 |
| Average Total Data Completeness | | | 100 |

VOC detection results are presented in Table B-1 (Appendix B), including comparison to the April 2019 DTSC Human Health Risk Assessment (HHRA) Note 3 Screening Levels (DTSC 2019) or the May 2018 EPA Residential Air Regional Screening Levels (RSLs) (EPA 2018). There were four analytes detected above the screening levels. Three analytes were detected during the March 6, 2020, sampling event and one from the March 20, 2020, sampling event. Two of the four detections were above the EPA RSL. Ethyl acetate was detected at 170 $\mu\text{g}/\text{m}^3$ at DOE-1 and 260 $\mu\text{g}/\text{m}^3$ at DOE-4. The remaining two analytes were detected above DTSC RSL. Benzene was detected at 0.96 $\mu\text{g}/\text{m}^3$ at DOE-4 and methylene chloride was detected at 1.2 $\mu\text{g}/\text{m}^3$ at DOE-3.

Two man-made VOC analytes, dichlorodifluoromethane (Freon-12) and ethyl acetate, have been detected routinely at all four monitoring stations, during all quarterly sampling events, and in duplicate samples. Ethyl acetate had two separate recordings that exceeded the screening limits. Both of these were detected on March 6, 2020 — one recording at DOE-1 and the other at DOE-4. Based on laboratory QC data (method blanks, clean canister certifications), the sampling process and laboratory process are not the sources of the two analytes. The onsite source of the analytes is currently unknown.

4.4 Radionuclide Data

ETEC continuously monitors air at multiple locations for radioactive particles. This is performed for two reasons: (1) to determine the background airborne radioactivity concentration so that any possible releases from work activities can be detected, and (2) to detect any possible release from existing activities. As shown on the trend graphs, the background airborne radioactive contamination continued at low and stable concentrations, and there was no detected release of material.

There were 105 airborne radioactivity filter samples collected in Q8 — 26 each with DOE-1, DOE-2, and DOE-4, and 27 with DOE-3. Each sample was collected on a glass-fiber filter (as discussed in Section 3) and was analyzed using a “low background” Protean radiation counter system onsite. These samples included background radioactive materials and the potential of Area IV–specific radioactive materials.

The alpha and beta data are presented in Table C-1 (Appendix C). The onsite analysis determined only “alpha” or “beta/gamma” and did not analyze for specific isotopes. Isotopic analysis was performed later by an offsite laboratory. Each sample produced a gross alpha and beta-gamma count. The analysis compared these values with the background radiation count rates, and using the volume of air collected determined the net counts and the minimum detectable concentration (MDC) for each sampling event. Some results in Table C-1 (Appendix C) that are less than the MDC are shown as negative values (because detector background is subtracted from the result).

All alpha samples were below the MDC, and each MDC was below the airborne effluent limits specified in California regulations. There was no possibility of significant Area IV alpha radioactive material on these filters.

Although 57% of the beta samples were below MDC, the gross (background radioactive material included) samples exceeded the MDC in 43% of samples, indicating the presence of airborne radioactive material (including background materials). Similarly, 82% of the gross alpha samples were below the MDC.

Following collection and onsite analysis, the air filters were composited and analyzed for specific radionuclides by an offsite laboratory. This data is shown in Table C-2 (Appendix C). This laboratory data determined that most radioactive material present was natural in origin, consisting of beryllium-7, polonium-210, potassium-40, combined radium-226 and radium-228, thorium-228, thorium-230, thorium-232, uranium-233/234, uranium-235/236, and uranium-238.

While artificial radionuclides (e.g., Cs-137, Sr-90, Pu-239) were present in very small amounts, none of the results were above the MDC in Q8. The presence of these radionuclides is considered a part of the normal variation of global fallout and resuspension activities.

A summary of the gross air sampling data is shown below (Table 6).

Table 6. Gross alpha and beta-gamma average results for Q8.

| Location | Average alpha Result (μCi/mL) | Average alpha MDC (μCi/mL) | Average beta Result (μCi/mL) | Average beta MDC (μCi/mL) |
|----------|-------------------------------|----------------------------|------------------------------|---------------------------|
| DOE 1 | 3.22E-15 | 5.93E-15 | 1.86E-14 | 2.59E-14 |
| DOE 2 | 3.83E-15 | 6.00E-15 | 3.19E-14 | 2.63E-14 |
| DOE 3 | 3.40E-15 | 7.76E-15 | 6.74E-15 | 3.42E-14 |
| DOE 4 | 3.48E-15 | 5.84E-15 | 2.10E-14 | 2.55E-14 |

5. QA/QC ACTIVITIES

The following QA/QC activities were conducted for the PM₁₀, VOC, radionuclide, and meteorological data collection and analysis.

5.1 Field QA/QC

5.1.1 PM₁₀

The 24-hour daily averages for Q8 are presented in Appendix A along with the monthly minimum, maximum, and 95th percentile for each station location.

Flow Verifications

Functionality of the Met One E-BAM units is verified and recorded monthly during instrument audits; however, the instruments are also checked several times a week for operability. During the monthly audits, the Met One E-BAM temperature, pressure, and flow rate are verified against a National Institute of Standards and Technology (NIST) traceable flowmeter. E-BAM units are occasionally swapped out for maintenance, and preliminary audits of the new units are performed. None of the results exceeded the flow rate measurement quality objective of +/- 4%.

Complete audit reports and flow verification results for Q8 are presented in Appendix D of this document. The flow rate verifications were based on 40 CFR 58, Appendix A, 3.3.1 and 4.2.2 through 4.2.3, along with the *Guideline on the Meaning and the Use of Precision and Bias Data Required by 40 CFR Part 58 Appendix A* (EPA 2007). The *Data Assessment Statistical Calculator* (DASC) tool, which is an EPA Excel-based software application, was used to perform the necessary statistical calculations based on input audit data. Sections 2 and 2.5 of this EPA guidance document (EPA 2007) provide additional information and instruction for using the DASC tool.

5.1.2 VOCs

A minimum of 20% of the VOC results are undergoing third-party data validation. During this quarter, one of the six sample delivery groups (SDGs), SDG P2000961, underwent data validation. The data validation ensures that the required analytical measurement quality objectives are met to ensure the data are of sufficient quality for their intended purpose.

Each location had valid readings six of the six sample days for a sample completeness of 100%. Data completeness goals for VOCs exceeded the project goal of 85%.

5.1.3 Field Duplicates

Six field duplicates were collected during this reporting period, one per sampling event. Ethyl acetate (in SDGs P2000072, P2000340, P2000652, and P2000961) was detected in five field duplicate pairs, exceeding the quality objective of +/- 15% relative percent difference (RPD). For SDG P2000961 analytes MEK, THF, and toluene. For SDG P2000652 the analyte toluene was detected at levels higher than the RL in either the sample or duplicate, and in comparison, were reported as a non-detect in the associated sample or duplicate and exceeded the quality objective of +/- 15% RPD. For SDG P20001318, the analyte toluene was detected at a level less than 2 × IDL and the absolute difference between the two results was less than 2 × RDL and exceeded the quality objective of +/- 15% RPD. Fifteen sample and duplicate analyte detections were within the quality objective of +/- 15% RPD. There were no other detections associated with the samples and associated duplicates collected during this reporting period.

5.1.4 Canister Pressure

Vacuum in the canisters is measured before and after sampling with an analog pressure gauge to ensure proper function. Final canister vacuums ranged from -5 inches mercury (Hg) to -1 inches Hg during this reporting period.

5.1.5 Radiological

The detector for onsite gross alpha and beta sample analysis is calibrated annually by a third-party vendor using sources traceable to the NIST. The detector is checked in by counting alpha- and beta-emitting sources at the site when received from the vendor following calibration. This establishes an acceptable performance range for daily source checks. On each day the detector is used, performance is determined with the site source. The detector may be used if the daily check is within the acceptable performance range.

Samples analyzed at the offsite laboratory are QC-checked at the laboratory. These QC checks include blanks, laboratory replicates, matrix spikes, and matrix spike duplicates. Barium, which behaves chemically similar to radium, is used as a carrier to determine the yield of the chemical extraction.

Because the QC test associated with the laboratory radium evaluation was higher than expected, it is possible that the radium values are underreported. However, since the results were less than 0.1% of the airborne release limit, and also within typical values, there is no reason to believe that there was an airborne release approaching the limits.

A minimum of 20% of the annual radiological analytical results are undergoing third-party data validation. The SDG from this quarter underwent the annual data validation for Year 3, exceeding the minimum of 20%.

5.1.6 Meteorological

During the reporting period, a weekly data validation screening and review was performed on the monitored meteorological parameters based on the EPA guidance document *Meteorological Monitoring Guidance for Regulatory Modeling Applications* (EPA 2000), Table 8-4 – Suggested Data Screening Criteria, as outlined in Section 4.1. The data validation procedure provided the basis for evaluating data completeness and for determining sensor performance and/or maintenance status.

5.1.7 Maintenance

General maintenance was performed on the meteorological station February 25, 2020. This included inspection of the meteorological tower sensors, E-BAM monitoring unit wind sensors, and solar-powered batteries to ensure proper functioning.

5.1.8 Corrective Action

Issues and corrective actions regarding the PM₁₀ monitors and the meteorological station are noted in Sections 5.1.8.1 and 5.1.8.2, respectively. No issues or corrective actions were noted regarding the remaining monitoring equipment or sampling events during this reporting period.

5.1.8.1 PM₁₀ Monitors

Refer to Section 4.2 for a detailed description of PM₁₀ air monitoring equipment issues.

5.1.8.2 Meteorological Station

Although there were no unresolved data quality issues impacting the data completion goal during Q8, the solar radiometer occasionally has readings that exceed the daily screening criteria and an improperly programmed data logger has continued to affect the calculation of delta temperature (i.e., temperature difference between 2 m and 10 m).

Delta Temperature Calculation – As stated in the corrective actions section of the Q3 air monitoring report (North Wind, Inc. 2019), the new data logger installed in December 2018 (due to Woolsey Fire wildfire damage on November 8, 2018) was programmed to calculate delta temperature inversely to how it had been calculated in the original data logger. Consequently, the delta temperature observations are now being calculated with an opposite sign compared to the values from the original data logger.

The equations below represent the before and after delta temperature calculations:

- Prior to November 7, 2018:

$$\text{Delta Temperature} = [\text{Temperature @ 10 m}] \text{ minus } [\text{Temperature @ 2 m}] \quad (\text{Eq. 4-1})$$

- November 7 to December 18, 2018:

Station DOE-4 inoperable due to wildfire damage

- After December 18, 2018:

$$\text{Delta Temperature} = [\text{Temperature @ 2 m}] \text{ minus } [\text{Temperature @ 10 m}] \quad (\text{Eq. 4-2})$$

For consistency with the initial data collection quarters, the delta temperature calculations from the new data logger continue to be adjusted through postprocessing to conform with Equation 4-1. The adjustment is simply a multiplication factor of “-1” applied to the delta temperature values from the new data logger prior to performing the data validation.

Meteorological Data Sensor Maintenance – Although not a corrective action, the manufacturer’s recommended maintenance frequency for meteorological sensors is presented below. Proper and timely maintenance of the meteorological sensors is critical for ensuring that the data are not only valid (based on screening criteria) but also accurate. Schedules for maintenance and calibration are listed in the sensor user manuals and are based on the service time of the sensor. Table 7 lists the maintenance schedules for the Met One sensors installed at the DOE-4 meteorological station.

Table 7. Meteorological sensor recommended maintenance frequency (Met One).

| Sensor | Frequency | Maintenance |
|------------|-------------|---|
| WS | 6–12 Month | Inspect for proper operation (manual check of pulses per revolution, bearing condition, anemometer cup condition, and bearing replacement if warranted) |
| | 12–24 Month | Return to Met One for complete overhaul |
| WD | 6–12 Month | Inspect for proper operation (manual check of sensor readings through 360°) |
| | 6–12 Month | Field calibration |
| | 12–24 month | Replace bearings & potentiometer |
| T | 6–12 Month | Inspect sensor for proper operation (field comparison sensor reading against a precision mercury thermometer) |
| RH | 6–12 Month | Inspect sensor for proper operation (compare sensor reading against local weather service or field psychrometer) |
| | 12 Month | Return sensor to Met One for calibration and replacement of O-rings and filter membrane |
| Rain Gauge | 6 Month | Clean sensor and bucket and field verify proper operation |
| Pressure | 12 Month | Return sensor to Met One for calibration and replacement of O-rings and filter membrane |
| Radiometer | Monthly | Clean sensor glass dome with clean rag/tissue |

Note: Maintenance schedules as specified in the respective Met One sensor user manuals.

5.2 Laboratory QA/QC

This report covers 30 air monitoring samples for VOCs collected and analyzed according to the EPA Toxic Compendium Method TO-15, *Determination of Volatile Organic Compounds (VOCs) in Air Collected in Specially-Prepared Canisters and Analyzed by Gas Chromatography/Mass Spectrometry (GC/MS)* (EPA 1999). These samples were reported under six SDGs by the laboratory. All six SDG analyses were performed by ALS in Simi Valley, CA. For each SDG, the laboratory ran continuing calibration verification, a method blank, and laboratory control samples, and verified surrogate recoveries for each sample.

The laboratory provided certified clean canisters for the sampling events. The certification of the canister batch is considered the equipment blank for each sampling event. The ALS case narrative discusses the cleaning of the canisters.

5.3 Audit Results

The PM₁₀ instruments were calibrated at the manufacturer and were functioning properly upon installation. The PM₁₀ instruments were audited monthly with a secondary NIST traceable flow meter. Although audits occur only monthly, the instruments were checked several times a week to ensure that they were functioning. Table 8 lists the dates for audits conducted in January through March. No flow rate comparisons exceeded the project’s acceptance criterion of +/- 4. Complete audit reports are presented in Appendix D.

Table 8. PM₁₀ audit completeness.

| Location | Met One E-BAM Serial Number | Parameter | Date |
|----------|--------------------------------|------------------|-----------|
| DOE-1 | X16067 | PM ₁₀ | 1/07/2020 |
| DOE-2 | Y12096 | PM ₁₀ | 1/07/2020 |
| DOE-3 | W23313 | PM ₁₀ | 1/07/2020 |
| DOE-4 | W23310 | PM ₁₀ | 1/07/2020 |
| DOE-1 | X16067 | PM ₁₀ | 2/11/2020 |
| DOE-2 | Y12096 | PM ₁₀ | 2/11/2020 |
| DOE-3 | W23313 | PM ₁₀ | 2/11/2020 |
| DOE-4 | W23310 | PM ₁₀ | 2/11/2020 |
| *DOE-4 | W23314 | PM ₁₀ | 2/12/2020 |
| DOE-1 | W23310 | PM ₁₀ | 3/25/2020 |
| DOE-2 | Y12096 | PM ₁₀ | 3/18/2020 |
| DOE-3 | W23313 | PM ₁₀ | 3/18/2020 |
| DOE-4 | W23314 | PM ₁₀ | 3/18/2020 |

*Audit conducted after E-BAM replaced.

(This page intentionally left blank)

6. REFERENCES

- 10 Code of Federal Regulations (CFR) 20, Appendix B, “Annual Limits on Intake (ALIs) and Derived Air Concentrations (DACs) of Radionuclides for Occupational Exposure; Effluent Concentrations; Concentrations for Release to Sewerage,” Table 2.
- 40 CFR 58, Appendix C –Ambient Air Quality Monitoring Methodology.
- California Environmental Protection Agency, Department of Toxic Substances Control (DTSC). 2018. *Approval of the Final Air Monitoring Station Locations for the Santa Susana Field Laboratory, Ventura County, California*. January.
- California Environmental Protection Agency, DTSC. 2019. Human and Ecological Risk Office Human Health Risk Assessment Note Number 3, DTSC-modified Screening Levels. April. <https://www.dtsc.ca.gov/AssessingRisk/upload/HHRA-Note-3-April-2019.pdf>.
- National Aeronautics and Space Administration (NASA). 2017. *Santa Susana Field Laboratory Baseline Air Monitoring Report Work Plan Report*. Prepared for California Department of Toxic Substances Control. Prepared on behalf of National Aeronautics and Space Administration, George C. Marshall Space Flight Center, The Boeing Company, and Department of Energy, Energy Technology and Engineering Center. September. Available online at: https://www.dtsc-ssfl.com/files/lib_air_monitor/work_plan/67496_SSFL_AirMonitoringWorkPlan_Final.pdf
- North Wind, Inc. 2019. *Report on Quarterly Air Monitoring , Area IV, Third Quarter 2018–2019, Santa Susana Field Laboratory, Ventura County, California*. Prepared for United States Department of Energy. May.
- U.S. Environmental Protection Agency (EPA). 1999. *Air Method, Toxic Organics-15 (TO-15), Determination of Volatile Organic Compounds (VOCs) in Air Collected in Specially-Prepared Canisters and Analyzed by Gas Chromatography/Mass Spectrometry (GC/MS)*. EPA 625/R-96/010b. January. Available online at: <https://www.epa.gov/homeland-security-research/epa-air-method-toxic-organics-15-15-determination-volatile-organic>
- U.S. Environmental Protection Agency (EPA). 2000. *Meteorological Monitoring Guidance for Regulatory Modeling Applications, United State Environmental Protection Agency, Office of Air Quality Planning and Standards*. EPA-454/R-99-005. February.
- U.S. Environmental Protection Agency (EPA). 2004. *The Particle Pollution Report, Current Understanding of Air Quality and Emissions through 2003, United States Environmental Protection Agency, Office of Air Quality Planning and Standards*. EPA-454-R-04-002. December.
- U.S. Environmental Protection Agency (EPA). 2007. *Guideline on the Meaning and the Use of Precision and Bias Data Required by 40 CFR Part 58 Appendix A, Version .1.1*. EPA-454/B-07-001. October 2007.
- U.S. Environmental Protection Agency (EPA). 2017. *Quality Assurance Handbook for Air Pollution Measurement Systems, Volume II, Ambient Air Monitoring Program*. EPA-454/B-17-001. January.
- U.S. Environmental Protection Agency (EPA). 2018. Regional Screening Levels – Generic Tables. <https://www.epa.gov/risk/regional-screening-levels-rsls-generic-tables>. May.
- Solar Energy Research Institute (SERI). 1981. *A Simplified Clear Sky Model for Direct and Diffuse Insolation on Horizontal Surfaces*. SERI/TR-642-761, February 1981.

(This page intentionally left blank)

Figure 1 – SSFL Air Monitoring Locations




Figure 2 – DOE Air Monitoring Locations





Figure 3 – DOE Quarterly Wind Rose



(This page intentionally left blank)

APPENDIX A

PM₁₀ Daily Averages and Monthly Statistics

(This page intentionally left blank)

PM₁₀ Daily Averages

| Site ID | DOE-1 | DOE-2 | DOE-3 | DOE-4 |
|-------------|---|---|---|---|
| Sample Date | PM ₁₀ (µg/m ³) (CAAQS 50 µg/m ³) | PM ₁₀ (µg/m ³) (CAAQS 50 µg/m ³) | PM ₁₀ (µg/m ³) (CAAQS 50 µg/m ³) | PM ₁₀ (µg/m ³) (CAAQS 50 µg/m ³) |
| 01/01/20 | 9.00000 | 5.62500 | | 12.37500 |
| 01/02/20 | 1.45800 | 3.12500 | | 1.91600 |
| 01/03/20 | 5.79100 | 4.16600 | | 3.79100 |
| 01/04/20 | 8.50000 | 5.25000 | | 5.37500 |
| 01/05/20 | 2.79100 | 4.66600 | | 3.54100 |
| 01/06/20 | 1.33300 | 3.12500 | | 2.83300 |
| 01/07/20 | 0.70800 | 2.45800 | 0.38400 | 1.08300 |
| 01/08/20 | 20.16600 | 10.04100 | 10.50000 | 19.25000 |
| 01/09/20 | 5.29100 | 2.54100 | 2.37500 | 4.41600 |
| 01/10/20 | 3.16600 | 4.37500 | 3.95800 | 4.00000 |
| 01/11/20 | 10.66600 | 7.00000 | 6.83300 | 9.91600 |
| 01/12/20 | 7.12500 | 6.45800 | 6.75000 | 7.29100 |
| 01/13/20 | 10.70800 | 11.41600 | 11.87500 | 13.25000 |
| 01/14/20 | 17.45800 | 15.79100 | 16.00000 | 18.04100 |
| 01/15/20 | 19.62500 | 20.87500 | 18.45800 | 24.16600 |
| 01/16/20 | 21.66600 | 24.41600 | 22.20800 | 27.62500 |
| 01/17/20 | 1.70800 | 2.20800 | 1.20800 | 3.25000 |
| 01/18/20 | 0.58300 | 1.41600 | 1.12500 | 0.87500 |
| 01/19/20 | 1.20800 | 2.70800 | 1.29100 | 1.25000 |
| 01/20/20 | 13.33300 | 8.75000 | 8.54100 | 15.04100 |
| 01/21/20 | 16.75000 | 4.70800 | 3.54100 | 10.20800 |
| 01/22/20 | 5.75000 | 5.58300 | 3.83300 | 5.33300 |
| 01/23/20 | 2.04100 | 4.70800 | 2.41600 | 2.83300 |
| 01/24/20 | 2.91600 | 4.37500 | 2.87500 | 3.95800 |
| 01/25/20 | 7.75000 | 7.62500 | 7.50000 | 8.70800 |
| 01/26/20 | 24.62500 | 14.041 | 12.04100 | 19.54100 |
| 01/27/20 | 5.58300 | 4.333 | 3.91600 | 4.70800 |
| 01/28/20 | 1.87500 | 4.958 | 2.25000 | 3.79100 |
| 01/29/20 | 9.08300 | 10.208 | 9.16600 | 10.75000 |
| 01/30/20 | 4.08300 | 7.583 | 4.45800 | 4.25000 |
| 01/31/20 | 0.62500 | 2.66600 | 1.16600 | 1.20800 |
| 02/01/20 | 1.45800 | 3.83300 | 1.33300 | 1.04100 |
| 02/02/20 | 13.16600 | 8.29100 | 7.58300 | 10.45800 |
| 02/03/20 | 13.00000 | 22.20800 | 13.37500 | 39.75000 |
| 02/04/20 | 6.91600 | 7.50000 | 6.41600 | 7.58300 |
| 02/05/20 | 5.66600 | 5.66600 | 3.79100 | 5.95800 |

| Site ID | DOE-1 | DOE-2 | DOE-3 | DOE-4 |
|-------------|---|---|---|---|
| Sample Date | PM ₁₀ (µg/m ³) (CAAQS 50 µg/m ³) | PM ₁₀ (µg/m ³) (CAAQS 50 µg/m ³) | PM ₁₀ (µg/m ³) (CAAQS 50 µg/m ³) | PM ₁₀ (µg/m ³) (CAAQS 50 µg/m ³) |
| 02/06/20 | 10.50000 | 8.50000 | 7.45800 | 10.20800 |
| 02/07/20 | 15.45800 | 16.29100 | 16.54100 | 14.29100 |
| 02/08/20 | 16.95800 | 19.66600 | 20.75000 | 23.58300 |
| 02/09/20 | 27.50000 | 13.66600 | 14.58300 | 21.79100 |
| 02/10/20 | 12.58300 | 15.41600 | 12.58300 | 16.66600 |
| 02/11/20 | 5.08300 | 5.66600 | 5.75000 | 4.75000 |
| 02/12/20 | 10.12500 | 12.37500 | 12.41600 | 11.42100 |
| 02/13/20 | 15.37500 | 18.66600 | 17.62500 | 16.54100 |
| 02/14/20 | 21.54100 | 16.83300 | 16.79100 | 15.20800 |
| 02/15/20 | 15.50000 | 15.50000 | 15.62500 | 12.91600 |
| 02/16/20 | 18.29100 | 14.91600 | 14.70800 | 13.33300 |
| 02/17/20 | | 10.95800 | 9.25000 | 7.66600 |
| 02/18/20 | | 15.91600 | 14.54100 | 13.16600 |
| 02/19/20 | | 22.04100 | 21.50000 | 16.00000 |
| 02/20/20 | | 14.25000 | 16.00000 | 12.62500 |
| 02/21/20 | | 12.83300 | 13.29100 | 11.41600 |
| 02/22/20 | | 8.95800 | 8.16600 | 7.12500 |
| 02/23/20 | | 12.25000 | 9.54100 | 9.08300 |
| 02/24/20 | | 13.41600 | 11.45800 | 10.70800 |
| 02/25/20 | | 6.70800 | 4.45800 | 5.79100 |
| 02/26/20 | | 6.54100 | 5.00000 | 5.37500 |
| 02/27/20 | | 5.79100 | 4.58300 | 4.33300 |
| 02/28/20 | | 4.70800 | 4.50000 | 3.50000 |
| 02/29/20 | | 11.16600 | 12.79100 | 8.91600 |
| 03/01/20 | | 14.75000 | 10.79100 | 8.33300 |
| 03/02/20 | | 8.33300 | 8.87500 | 6.45800 |
| 03/03/20 | | 6.37500 | 4.54100 | 24.25000 |
| 03/04/20 | | 18.66600 | 21.87500 | 20.00000 |
| 03/05/20 | | 18.58300 | 17.12500 | 18.29100 |
| 03/06/20 | | 13.83300 | 15.41600 | 13.08300 |
| 03/07/20 | | 4.33300 | 5.75000 | 2.83300 |
| 03/08/20 | | 2.75000 | 1.16600 | 0.91600 |
| 03/09/20 | | 6.25000 | 4.87500 | 2.45800 |
| 03/10/20 | | 4.75000 | 2.50000 | 0.25000 |
| 03/11/20 | | 6.04100 | 3.45800 | 2.37500 |
| 03/12/20 | | 5.87500 | 3.41600 | 3.79100 |
| 03/13/20 | | 0.75000 | 0.75000 | 0.83300 |

| Site ID | DOE-1 | DOE-2 | DOE-3 | DOE-4 |
|-------------|---|---|---|---|
| Sample Date | PM ₁₀ (µg/m ³) (CAAQS 50 µg/m ³) | PM ₁₀ (µg/m ³) (CAAQS 50 µg/m ³) | PM ₁₀ (µg/m ³) (CAAQS 50 µg/m ³) | PM ₁₀ (µg/m ³) (CAAQS 50 µg/m ³) |
| 03/14/20 | | 0.45800 | 3.25000 | 0.37500 |
| 03/15/20 | | 4.04100 | 4.25000 | 3.54100 |
| 03/16/20 | | 4.33300 | 3.29100 | 2.16600 |
| 03/17/20 | | 2.33300 | 1.75000 | 1.25000 |
| 03/18/20 | | 9.45800 | 7.08300 | 4.12500 |
| 03/19/20 | | 6.04100 | 3.08300 | 3.70800 |
| 03/20/20 | | 3.08300 | 3.91600 | 2.45800 |
| 03/21/20 | | 7.33300 | 3.41600 | 4.33300 |
| 03/22/20 | | 2.95800 | 2.75000 | 2.29100 |
| 03/23/20 | | 2.29100 | 2.45800 | 1.12500 |
| 03/24/20 | | 4.70800 | 3.08300 | 2.08300 |
| 03/25/20 | 7.07100 | 3.62500 | 2.95800 | 3.04100 |
| 03/26/20 | 4.50000 | 4.75000 | 3.45800 | 3.79100 |
| 03/27/20 | 5.91600 | 5.79100 | 5.66600 | 5.50000 |
| 03/28/20 | 13.87500 | 11.12500 | 11.91600 | 9.58300 |
| 03/29/20 | 13.37500 | 12.33300 | 9.50000 | 8.25000 |
| 03/30/20 | 5.08300 | 7.83300 | 5.83300 | 3.83300 |
| 03/31/20 | 5.50000 | 11.00000 | 7.37500 | 5.187 |

Note: Gray-shaded boxes indicate Instrument not working. Please see section 4.2

PM₁₀ Monthly Statistics

| Location ID | January 2020 | | | February 2020 | | | March 2020 | | |
|-------------|------------------|---------|-----------|------------------|---------|-----------|------------------|---------|-----------|
| | PM ₁₀ | | | PM ₁₀ | | | PM ₁₀ | | |
| | High | Low | 95th PCTL | High | Low | 95th PCTL | High | Low | 95th PCTL |
| DOE-1 | 24.6250 | 0.58300 | 20.91600 | 27.50000 | 0.00000 | 22.73280 | 13.87500 | 4.50000 | 13.72500 |
| DOE-2 | 24.4160 | 1.41600 | 18.33300 | 22.20800 | 3.83300 | 21.09100 | 18.66600 | 0.45800 | 16.66650 |
| DOE-3 | 22.2080 | 0.00000 | 17.84350 | 21.50000 | 1.33300 | 19.50000 | 21.87500 | 0.75000 | 16.27050 |
| DOE-4 | 27.6250 | 0.87500 | 21.85350 | 39.75000 | 1.04100 | 22.86620 | 24.25000 | 0.25000 | 19.14550 |

PCTL = percentile

APPENDIX B

Analytical Results for Ambient Air VOCs

(This page intentionally left blank)

Table B-1. Ambient air VOC detection results compared to RSLs.

| Location ID | Sample Date | Analyte | Result (µg/m ³) | Screening Level Value (µg/m ³) | SL Source |
|-------------|-------------|-------------------------|-----------------------------|--|------------------|
| DOE-1 | 01/07/2020 | Dichlorodifluoromethane | 2.4 | 100 | US EPA RSL |
| DOE-1 | 01/07/2020 | Ethyl acetate | 43 | 73 | US EPA RSL |
| DOE-1 | 01/07/2020 | Trichlorofluoromethane | 1.3 | 1300 | DTSC HHRA NOTE 3 |
| DOE-2 | 01/07/2020 | Dichlorodifluoromethane | 2.5 | 100 | US EPA RSL |
| DOE-2 | 01/07/2020 | Ethyl acetate | 37 | 73 | US EPA RSL |
| DOE-2 | 01/07/2020 | Trichlorofluoromethane | 1.3 | 1300 | DTSC HHRA NOTE 3 |
| DOE-3 | 01/07/2020 | Dichlorodifluoromethane | 2.5 | 100 | US EPA RSL |
| DOE-3 | 01/07/2020 | Ethyl acetate | 25 | 73 | US EPA RSL |
| DOE-3 | 01/07/2020 | Trichlorofluoromethane | 1.3 | 1300 | DTSC HHRA NOTE 3 |
| DOE-4 | 01/07/2020 | Dichlorodifluoromethane | 2.5 | 100 | US EPA RSL |
| DOE-4 | 01/07/2020 | Ethyl acetate | 27 | 73 | US EPA RSL |
| DOE-4 | 01/07/2020 | Trichlorofluoromethane | 1.3 | 1300 | DTSC HHRA NOTE 3 |
| DOE-1 | 01/21/2020 | Dichlorodifluoromethane | 2.1 | 100 | US EPA RSL |
| DOE-1 | 01/21/2020 | Ethyl acetate | 3.6 | 73 | US EPA RSL |
| DOE-1 | 01/21/2020 | Trichlorofluoromethane | 1.1 | 1300 | DTSC HHRA NOTE 3 |
| DOE-2 | 01/21/2020 | Dichlorodifluoromethane | 2.2 | 100 | US EPA RSL |
| DOE-2 | 01/21/2020 | Ethyl acetate | 5.7 | 73 | US EPA RSL |
| DOE-2 | 01/21/2020 | Trichlorofluoromethane | 1.1 | 1300 | DTSC HHRA NOTE 3 |
| DOE-3 | 01/21/2020 | Dichlorodifluoromethane | 2.2 | 100 | US EPA RSL |
| DOE-3 | 01/21/2020 | Ethyl acetate | 19 | 73 | US EPA RSL |
| DOE-3 | 01/21/2020 | Tetrahydrofuran | 0.98 | 2100 | US EPA RSL |
| DOE-3 | 01/21/2020 | Toluene | 0.83 | 310 | DTSC HHRA NOTE 3 |
| DOE-3 | 01/21/2020 | Trichlorofluoromethane | 1.1 | 1300 | DTSC HHRA NOTE 3 |
| DOE-4 | 01/21/2020 | Dichlorodifluoromethane | 2.2 | 100 | US EPA RSL |
| DOE-4 | 01/21/2020 | Ethyl acetate | 3.3 | 73 | US EPA RSL |
| DOE-4 | 01/21/2020 | Toluene | 0.75 | 310 | DTSC HHRA NOTE 3 |
| DOE-4 | 01/21/2020 | Trichlorofluoromethane | 1.1 | 1300 | DTSC HHRA NOTE 3 |
| DOE-1 | 02/05/2020 | Dichlorodifluoromethane | 3.0 | 100 | US EPA RSL |
| DOE-1 | 02/05/2020 | Ethyl acetate | 8.3 | 73 | US EPA RSL |
| DOE-1 | 02/05/2020 | Hexane, n- | 2.7 | 730 | US EPA RSL |
| DOE-1 | 02/05/2020 | Trichlorofluoromethane | 1.3 | 1300 | DTSC HHRA NOTE 3 |

| Location ID | Sample Date | Analyte | Result (µg/m ³) | Screening Level Value (µg/m ³) | SL Source |
|-------------|-------------|-------------------------|-----------------------------|--|------------------|
| DOE-2 | 02/05/2020 | Dichlorodifluoromethane | 2.5 | 100 | US EPA RSL |
| DOE-2 | 02/05/2020 | Ethyl acetate | 7.2 | 73 | US EPA RSL |
| DOE-2 | 02/05/2020 | Hexane, n- | 2.1 | 730 | US EPA RSL |
| DOE-2 | 02/05/2020 | Trichlorofluoromethane | 1.3 | 1300 | DTSC HHRA NOTE 3 |
| DOE-3 | 02/05/2020 | Dichlorodifluoromethane | 2.5 | 100 | US EPA RSL |
| DOE-3 | 02/05/2020 | Ethyl acetate | 8.6 | 73 | US EPA RSL |
| DOE-3 | 02/05/2020 | Hexane, n- | 1.8 | 730 | US EPA RSL |
| DOE-3 | 02/05/2020 | Trichlorofluoromethane | 1.3 | 1300 | DTSC HHRA NOTE 3 |
| DOE-4 | 02/05/2020 | Dichlorodifluoromethane | 2.5 | 100 | US EPA RSL |
| DOE-4 | 02/05/2020 | Ethyl acetate | 8.5 | 73 | US EPA RSL |
| DOE-4 | 02/05/2020 | Hexane, n- | 1.7 | 730 | US EPA RSL |
| DOE-4 | 02/05/2020 | Trichlorofluoromethane | 1.3 | 1300 | DTSC HHRA NOTE 3 |
| DOE-1 | 02/20/2020 | Dichlorodifluoromethane | 2.1 | 100 | US EPA RSL |
| DOE-1 | 02/20/2020 | Ethyl acetate | 43 | 73 | US EPA RSL |
| DOE-1 | 02/20/2020 | Toluene | 0.98 | 310 | DTSC HHRA NOTE 3 |
| DOE-1 | 02/20/2020 | Trichlorofluoromethane | 1.1 | 1300 | DTSC HHRA NOTE 3 |
| DOE-2 | 02/20/2020 | Benzene | 0.78 | 0.097 | DTSC HHRA NOTE 3 |
| DOE-2 | 02/20/2020 | Dichlorodifluoromethane | 2.2 | 100 | US EPA RSL |
| DOE-2 | 02/20/2020 | Ethyl acetate | 29 | 73 | US EPA RSL |
| DOE-2 | 02/20/2020 | Toluene | 0.99 | 310 | DTSC HHRA NOTE 3 |
| DOE-2 | 02/20/2020 | Trichlorofluoromethane | 1.1 | 1300 | DTSC HHRA NOTE 3 |
| DOE-3 | 02/20/2020 | Dichlorodifluoromethane | 2.1 | 100 | US EPA RSL |
| DOE-3 | 02/20/2020 | Ethyl acetate | 19 | 73 | US EPA RSL |
| DOE-3 | 02/20/2020 | Trichlorofluoromethane | 1.1 | 1300 | DTSC HHRA NOTE 3 |
| DOE-4 | 02/20/2020 | Dichlorodifluoromethane | 2.1 | 100 | US EPA RSL |
| DOE-4 | 02/20/2020 | Ethyl acetate | 29 ;J | 73 | US EPA RSL |
| DOE-4 | 02/20/2020 | Trichlorofluoromethane | 1.1 | 1300 | DTSC HHRA NOTE 3 |
| DOE-1 | 03/06/2020 | Dichlorodifluoromethane | 2.2 | 100 | US EPA RSL |
| DOE-1 | 03/06/2020 | Ethyl acetate | 170 | 73 | US EPA RSL |
| DOE-1 | 03/06/2020 | Toluene | 2.5 | 310 | DTSC HHRA NOTE 3 |
| DOE-1 | 03/06/2020 | Trichlorofluoromethane | 1.3 | 1300 | DTSC HHRA NOTE 3 |
| DOE-2 | 03/06/2020 | 2-butanone | 1.9 | 5200 | US EPA RSL |
| DOE-2 | 03/06/2020 | Dichlorodifluoromethane | 2.3 | 100 | US EPA RSL |

| Location ID | Sample Date | Analyte | Result ($\mu\text{g}/\text{m}^3$) | Screening Level Value ($\mu\text{g}/\text{m}^3$) | SL Source |
|-------------|-------------|-------------------------|--|---|------------------|
| DOE-2 | 03/06/2020 | Ethyl acetate | 15 | 73 | US EPA RSL |
| DOE-2 | 03/06/2020 | Trichlorofluoromethane | 1.3 | 1300 | DTSC HHRA NOTE 3 |
| DOE-3 | 03/06/2020 | Dichlorodifluoromethane | 2.3 | 100 | US EPA RSL |
| DOE-3 | 03/06/2020 | Ethyl acetate | 39 | 73 | US EPA RSL |
| DOE-3 | 03/06/2020 | Toluene | 1.0 | 310 | DTSC HHRA NOTE 3 |
| DOE-3 | 03/06/2020 | Trichlorofluoromethane | 1.3 | 1300 | DTSC HHRA NOTE 3 |
| DOE-4 | 03/06/2020 | Benzene | 0.96 | 0.097 | DTSC HHRA NOTE 3 |
| DOE-4 | 03/06/2020 | Dichlorodifluoromethane | 2.3 | 100 | US EPA RSL |
| DOE-4 | 03/06/2020 | Ethyl acetate | 260 | 73 | US EPA RSL |
| DOE-4 | 03/06/2020 | Toluene | 3.7 | 310 | DTSC HHRA NOTE 3 |
| DOE-4 | 03/06/2020 | Trichlorofluoromethane | 1.3 | 1300 | DTSC HHRA NOTE 3 |
| DOE-1 | 03/20/2020 | Dichlorodifluoromethane | 2.5 | 100 | US EPA RSL |
| DOE-1 | 03/20/2020 | Trichlorofluoromethane | 1.4 | 1300 | DTSC HHRA NOTE 3 |
| DOE-2 | 03/20/2020 | Dichlorodifluoromethane | 2.6 | 100 | US EPA RSL |
| DOE-2 | 03/20/2020 | Trichlorofluoromethane | 1.4 | 1300 | DTSC HHRA NOTE 3 |
| DOE-3 | 03/20/2020 | Dichlorodifluoromethane | 2.4 | 100 | US EPA RSL |
| DOE-3 | 03/20/2020 | Ethyl acetate | 8.2 | 73 | US EPA RSL |
| DOE-3 | 03/20/2020 | Isopropanol | 7.8 | 210 | US EPA RSL |
| DOE-3 | 03/20/2020 | Methylene chloride | 1.2 | 1 | DTSC HHRA NOTE 3 |
| DOE-3 | 03/20/2020 | Tetrahydrofuran | 1.6 | 2100 | US EPA RSL |
| DOE-3 | 03/20/2020 | Toluene | 0.86 | 310 | DTSC HHRA NOTE 3 |
| DOE-3 | 03/20/2020 | Trichlorofluoromethane | 1.3 | 1300 | DTSC HHRA NOTE 3 |
| DOE-4 | 03/20/2020 | Dichlorodifluoromethane | 2.6 | 100 | US EPA RSL |
| DOE-4 | 03/20/2020 | Trichlorofluoromethane | 1.4 | 1300 | DTSC HHRA NOTE 3 |

Note: The bold numbers are above the screening levels.

(This page intentionally left blank)

APPENDIX C
Radionuclide Results

(This page intentionally left blank)

Table C-1. Gross alpha and gross beta air sample results for air samplers.

| Air Station ID | Sample Collection Date | Gross Alpha ($\mu\text{Ci/mL}$) | Gross Alpha MDC ($\mu\text{Ci/mL}$) | Gross Beta ($\mu\text{Ci/mL}$) | Gross Beta MDC ($\mu\text{Ci/mL}$) |
|--------------------------------|------------------------|-----------------------------------|---------------------------------------|----------------------------------|--------------------------------------|
| Sample Location – DOE-1 | | | | | |
| DOE-1 | 1/3/2020 | 4.09E-15 | 5.10E-15 | 5.31E-14 | 2.09E-14 |
| DOE-1 | 1/7/2020 | -3.64E-15 | 5.11E-15 | 4.16E-14 | 2.10E-14 |
| DOE-1 | 1/10/2020 | 3.06E-15 | 6.82E-15 | 1.61E-14 | 2.80E-14 |
| DOE-1 | 1/13/2020 | 6.39E-16 | 6.73E-15 | 2.88E-14 | 2.76E-14 |
| DOE-1 | 1/16/2020 | 7.28E-15 | 6.90E-15 | 4.14E-14 | 2.83E-14 |
| DOE-1 | 1/20/2020 | -1.04E-15 | 4.99E-15 | 1.58E-14 | 2.05E-14 |
| DOE-1 | 1/23/2020 | -2.79E-15 | 6.81E-15 | 3.46E-14 | 2.80E-14 |
| DOE-1 | 1/27/2020 | 2.28E-16 | 5.12E-15 | 7.22E-15 | 2.10E-14 |
| DOE-1 | 1/30/2020 | -2.47E-15 | 6.86E-15 | -3.80E-15 | 2.82E-14 |
| DOE-1 | 2/3/2020 | 6.91E-15 | 4.95E-15 | 9.91E-15 | 2.23E-14 |
| DOE-1 | 2/6/2020 | 3.63E-15 | 6.59E-15 | -1.96E-14 | 2.98E-14 |
| DOE-1 | 2/10/2020 | 6.87E-15 | 4.91E-15 | 5.80E-14 | 2.22E-14 |
| DOE-1 | 2/13/2020 | 4.63E-15 | 6.53E-15 | 3.87E-14 | 2.95E-14 |
| DOE-1 | 2/17/2020 | 1.20E-14 | 4.88E-15 | 6.56E-14 | 2.20E-14 |
| DOE-1 | 2/20/2020 | 1.40E-14 | 6.56E-15 | 6.77E-14 | 2.96E-14 |
| DOE-1 | 2/24/2020 | 7.98E-15 | 4.96E-15 | 6.06E-14 | 2.24E-14 |
| DOE-1 | 2/27/2020 | 4.38E-15 | 6.67E-15 | 1.20E-14 | 3.02E-14 |
| DOE-1 | 3/2/2020 | 4.04E-15 | 4.66E-15 | 3.50E-14 | 2.10E-14 |
| DOE-1 | 3/5/2020 | 7.98E-15 | 7.04E-15 | -1.05E-14 | 3.18E-14 |
| DOE-1 | 3/9/2020 | 1.42E-15 | 4.98E-15 | -3.17E-16 | 2.25E-14 |
| DOE-1 | 3/12/2020 | 1.53E-15 | 6.58E-15 | -2.03E-14 | 2.97E-14 |
| DOE-1 | 3/16/2020 | 1.15E-15 | 4.94E-15 | -8.95E-15 | 2.23E-14 |
| DOE-1 | 3/19/2020 | 1.77E-16 | 8.34E-15 | -2.48E-14 | 3.77E-14 |
| DOE-1 | 3/23/2020 | 1.31E-15 | 5.64E-15 | -1.95E-14 | 2.55E-14 |
| DOE-1 | 3/26/2020 | -8.98E-16 | 6.53E-15 | -8.02E-15 | 2.95E-14 |
| DOE-1 | 3/30/2020 | 1.15E-15 | 4.93E-15 | 1.22E-14 | 2.23E-14 |
| Sample Location – DOE-2 | | | | | |
| DOE-2 | 1/3/2020 | 4.09E-15 | 5.10E-15 | 4.87E-14 | 2.09E-14 |
| DOE-2 | 1/7/2020 | 3.06E-15 | 5.10E-15 | 6.27E-14 | 2.10E-14 |
| DOE-2 | 1/10/2020 | -2.45E-15 | 6.81E-15 | 6.07E-14 | 2.80E-14 |
| DOE-2 | 1/13/2020 | -3.09E-15 | 6.72E-15 | 5.65E-14 | 2.76E-14 |
| DOE-2 | 1/16/2020 | 2.05E-15 | 6.91E-15 | 6.33E-14 | 2.84E-14 |
| DOE-2 | 1/20/2020 | 2.74E-15 | 4.99E-15 | 3.34E-14 | 2.05E-14 |
| DOE-2 | 1/23/2020 | -3.84E-16 | 6.80E-15 | 6.67E-14 | 2.79E-14 |
| DOE-2 | 1/27/2020 | 1.52E-15 | 5.13E-15 | -3.36E-15 | 2.11E-14 |
| DOE-2 | 1/30/2020 | -3.85E-15 | 6.86E-15 | 1.42E-14 | 2.82E-14 |
| DOE-2 | 2/3/2020 | 5.87E-15 | 4.95E-15 | 6.50E-15 | 2.24E-14 |

| Air Station ID | Sample Collection Date | Gross Alpha (μCi/mL) | Gross Alpha MDC (μCi/mL) | Gross Beta (μCi/mL) | Gross Beta MDC (μCi/mL) |
|-------------------------|------------------------|----------------------|--------------------------|---------------------|-------------------------|
| DOE-2 | 2/6/2020 | 4.67E-15 | 6.58E-15 | -1.12E-15 | 2.97E-14 |
| DOE-2 | 2/10/2020 | 1.10E-14 | 4.92E-15 | 3.43E-14 | 2.22E-14 |
| DOE-2 | 2/13/2020 | 8.08E-15 | 6.52E-15 | 1.51E-14 | 2.95E-14 |
| DOE-2 | 2/17/2020 | 1.25E-14 | 4.88E-15 | 6.58E-14 | 2.20E-14 |
| DOE-2 | 2/20/2020 | 1.33E-14 | 6.56E-15 | 5.84E-14 | 2.97E-14 |
| DOE-2 | 2/24/2020 | 9.82E-15 | 4.96E-15 | 8.53E-14 | 2.24E-14 |
| DOE-2 | 2/27/2020 | 5.79E-15 | 6.67E-15 | 5.93E-14 | 3.01E-14 |
| DOE-2 | 3/2/2020 | 6.27E-15 | 4.66E-15 | 3.43E-14 | 2.11E-14 |
| DOE-2 | 3/5/2020 | 6.11E-15 | 7.03E-15 | 4.09E-14 | 3.18E-14 |
| DOE-2 | 3/9/2020 | 5.90E-15 | 4.98E-15 | 2.63E-14 | 2.25E-14 |
| DOE-2 | 3/12/2020 | 2.87E-15 | 7.34E-15 | 1.09E-15 | 3.32E-14 |
| DOE-2 | 3/16/2020 | -1.30E-15 | 6.83E-15 | 8.25E-15 | 3.09E-14 |
| DOE-2 | 3/19/2020 | 1.94E-15 | 8.34E-15 | 1.45E-14 | 3.77E-14 |
| DOE-2 | 3/23/2020 | 1.93E-15 | 4.92E-15 | 4.38E-15 | 2.22E-14 |
| DOE-2 | 3/26/2020 | 4.84E-16 | 6.53E-15 | -2.57E-14 | 2.95E-14 |
| DOE-2 | 3/30/2020 | 6.27E-16 | 4.93E-15 | -5.23E-17 | 2.23E-14 |
| Sample Location – DOE-3 | | | | | |
| DOE-3 | 1/3/2020 | 2.54E-15 | 5.09E-15 | 2.08E-14 | 2.09E-14 |
| DOE-3 | 1/7/2020 | -2.09E-15 | 5.11E-15 | 2.62E-14 | 2.10E-14 |
| DOE-3 | 1/10/2020 | 3.40E-15 | 6.81E-15 | 3.60E-14 | 2.80E-14 |
| DOE-3 | 1/13/2020 | 3.01E-15 | 6.71E-15 | 2.30E-14 | 2.76E-14 |
| DOE-3 | 1/16/2020 | 6.57E-16 | 6.92E-15 | 3.14E-14 | 2.84E-14 |
| DOE-3 | 1/20/2020 | 4.72E-16 | 4.98E-15 | 5.01E-15 | 2.04E-14 |
| DOE-3 | 1/23/2020 | -4.11E-17 | 6.79E-15 | 3.35E-14 | 2.79E-14 |
| DOE-3 | 1/27/2020 | 4.87E-16 | 5.13E-15 | 4.57E-14 | 2.11E-14 |
| DOE-3 | 1/30/2020 | 1.69E-15 | 6.87E-15 | -6.91E-15 | 2.82E-14 |
| DOE-3 | 2/3/2020 | -9.44E-16 | 4.96E-15 | 9.66E-15 | 2.24E-14 |
| DOE-3 | 2/6/2020 | 2.93E-15 | 6.58E-15 | -2.51E-15 | 2.97E-14 |
| DOE-3 | 2/10/2020 | 8.95E-15 | 4.92E-15 | 3.20E-14 | 2.22E-14 |
| DOE-3 | 2/13/2020 | 5.67E-15 | 6.53E-15 | 2.14E-14 | 2.95E-14 |
| DOE-3 | 2/17/2020 | 7.07E-15 | 4.87E-15 | 5.37E-14 | 2.20E-14 |
| DOE-3 | 2/20/2020 | 1.16E-14 | 6.57E-15 | 6.15E-14 | 2.97E-14 |
| DOE-3 | 2/24/2020 | 9.56E-15 | 4.96E-15 | 5.38E-14 | 2.24E-14 |
| DOE-3 | 2/27/2020 | 4.03E-15 | 6.67E-15 | -5.37E-15 | 3.01E-14 |
| DOE-3 | 3/2/2020 | 3.80E-15 | 4.66E-15 | 2.17E-14 | 2.11E-14 |
| DOE-3 | 3/5/2020 | -5.95E-16 | 7.03E-15 | -7.52E-15 | 3.17E-14 |
| DOE-3 | 3/9/2020 | 1.42E-15 | 4.98E-15 | 8.13E-15 | 2.25E-14 |
| DOE-3 | 3/12/2020 | 3.27E-15 | 6.58E-15 | -1.12E-14 | 2.97E-14 |
| DOE-3 | 3/16/2020 | 6.28E-16 | 4.94E-15 | -1.13E-14 | 2.23E-14 |

| Air Station ID | Sample Collection Date | Gross Alpha ($\mu\text{Ci/mL}$) | Gross Alpha MDC ($\mu\text{Ci/mL}$) | Gross Beta ($\mu\text{Ci/mL}$) | Gross Beta MDC ($\mu\text{Ci/mL}$) |
|-------------------------|------------------------|-----------------------------------|---------------------------------------|----------------------------------|--------------------------------------|
| DOE-3 | 3/17/2020 | 1.55E-14 | 5.43E-14 | -2.40E-13 | 2.45E-13 |
| DOE-3 | 3/19/2020 | 5.07E-15 | 1.02E-14 | 6.91E-15 | 4.60E-14 |
| DOE-3 | 3/23/2020 | 3.67E-16 | 4.95E-15 | -1.66E-14 | 2.24E-14 |
| DOE-3 | 3/26/2020 | 1.87E-15 | 6.55E-15 | -1.95E-14 | 2.96E-14 |
| DOE-3 | 3/30/2020 | 1.41E-15 | 4.94E-15 | 1.22E-14 | 2.23E-14 |
| Sample Location – DOE-4 | | | | | |
| DOE-4 | 1/3/2020 | 3.83E-15 | 5.10E-15 | 2.80E-14 | 2.09E-14 |
| DOE-4 | 1/7/2020 | -2.89E-16 | 5.11E-15 | 1.21E-14 | 2.10E-14 |
| DOE-4 | 1/10/2020 | -7.29E-16 | 6.81E-15 | 8.22E-15 | 2.80E-14 |
| DOE-4 | 1/13/2020 | 2.67E-15 | 6.71E-15 | 2.87E-14 | 2.76E-14 |
| DOE-4 | 1/16/2020 | 3.80E-15 | 6.93E-15 | 3.77E-14 | 2.84E-14 |
| DOE-4 | 1/20/2020 | -1.03E-15 | 4.97E-15 | 1.63E-14 | 2.04E-14 |
| DOE-4 | 1/23/2020 | 1.33E-15 | 6.80E-15 | 3.25E-14 | 2.79E-14 |
| DOE-4 | 1/27/2020 | 2.04E-15 | 5.13E-15 | 2.01E-14 | 2.11E-14 |
| DOE-4 | 1/30/2020 | 1.69E-15 | 6.87E-15 | 9.69E-15 | 2.82E-14 |
| DOE-4 | 2/3/2020 | 4.83E-15 | 4.96E-15 | -2.42E-15 | 2.24E-14 |
| DOE-4 | 2/6/2020 | 2.58E-15 | 6.58E-15 | 5.86E-15 | 2.97E-14 |
| DOE-4 | 2/10/2020 | 1.92E-15 | 4.91E-15 | 5.67E-14 | 2.22E-14 |
| DOE-4 | 2/13/2020 | 1.22E-14 | 6.52E-15 | 4.11E-14 | 2.95E-14 |
| DOE-4 | 2/17/2020 | 2.43E-15 | 4.88E-15 | 6.15E-15 | 2.20E-14 |
| DOE-4 | 2/20/2020 | 1.09E-14 | 6.57E-15 | 8.80E-14 | 2.97E-14 |
| DOE-4 | 2/24/2020 | 6.66E-15 | 4.96E-15 | 4.67E-14 | 2.24E-14 |
| DOE-4 | 2/27/2020 | 1.25E-14 | 6.67E-15 | 1.06E-13 | 3.02E-14 |
| DOE-4 | 3/2/2020 | 2.07E-15 | 4.67E-15 | 1.33E-14 | 2.11E-14 |
| DOE-4 | 3/5/2020 | 6.47E-15 | 7.02E-15 | 2.45E-14 | 3.17E-14 |
| DOE-4 | 3/9/2020 | 8.97E-16 | 4.98E-15 | -1.56E-14 | 2.25E-14 |
| DOE-4 | 3/12/2020 | 3.37E-15 | 6.78E-15 | -1.77E-14 | 3.06E-14 |
| DOE-4 | 3/16/2020 | 3.24E-15 | 4.94E-15 | 1.07E-14 | 2.23E-14 |
| DOE-4 | 3/19/2020 | 4.24E-15 | 6.45E-15 | -1.72E-14 | 2.92E-14 |
| DOE-4 | 3/23/2020 | -1.57E-16 | 4.95E-15 | 3.35E-15 | 2.23E-14 |
| DOE-4 | 3/26/2020 | 1.18E-15 | 6.56E-15 | -1.82E-14 | 2.96E-14 |
| DOE-4 | 3/30/2020 | 1.67E-15 | 4.94E-15 | 2.12E-14 | 2.23E-14 |

Note: Some values are negative after background subtraction

Table C-2. Individual radionuclide analysis for the composite filter samples.

| Radionuclide | Result (pCi/sample) | MDC (pCi/sample) | Data Qualifier | Airborne Concentration (μ Ci/mL) |
|---|------------------------|---------------------|-------------------|---|
| Location DOE-1 – Air volume/sample = 9.71E8 mL | | | | |
| Cesium-137 | 0.163 | 6.47 | U U | 1.005E-12 |
| Strontium-90 | -1.07 | 2.92 | U U | -6.596E-12 |
| Cobalt-60 | -0.514 | 6.78 | U U | -3.169E-12 |
| Potassium-40 | 112 | 59.2 | | 6.905E-10 |
| Beryllium-7 | 0 | 107 | UI U | 0.000E+0 |
| Plutonium-238 | -0.0361 | 0.306 | U U | -2.225E-13 |
| Polonium-210 | 9.95 | 0.922 | | 6.134E-11 |
| Plutonium-241 | 3.77 | 15.5 | U U | 2.324E-11 |
| Thorium-230 | 2.26 | 0.972 | UJ | 1.393E-11 |
| Thorium-228 | 0.186 | 1.82 | U U | 1.147E-12 |
| Actinium-228 | -17.6 | 32.9 | U U | -1.085E-10 |
| Americium-241 | 0.0927 | 0.587 | U UJ | 5.715E-13 |
| Plutonium-239 | -0.144 | 0.462 | U UJ | -8.877E-13 |
| Ra-228 – total | -0.177 | 4.23 | U U | -1.091E-12 |
| Radium-226, -228 combined | 0.896 | 4.17 | U U | 5.524E-12 |
| Thorium-232 | -0.0754 | 1.28 | U U | -4.648E-13 |
| Uranium-238 | 0.937 | 0.153 | UJ | 5.776E-12 |
| Uranium-233/234 | 0.763 | 0.186 | UJ | 4.704E-12 |
| Uranium-235/236 | 0.117 | 0.149 | U U | 7.213E-13 |
| Location DOE-2 – Air volume/sample = 9.62E8 mL | | | | |
| Cesium-137 | 2.17 | 7.57 | U U | 1.338E-11 |
| Strontium-90 | 0.19 | 2.04 | U U | 1.171E-12 |
| Cobalt-60 | 2.74 | 10.1 | U U | 1.689E-11 |
| Potassium-40 | 0 | 58.2 | UI U | 0.000E+0 |
| Beryllium-7 | 129 | 89.8 | | 7.953E-10 |
| Plutonium-238 | 0.00706 | 0.154 | U U | 4.352E-14 |
| Polonium-210 | 11.2 | 0.541 | | 6.905E-11 |
| Plutonium-241 | 6.09 | 11.4 | U U | 3.754E-11 |
| Thorium-230 | 0.978 | 0.459 | UJ | 6.029E-12 |
| Thorium-228 | 0.772 | 0.3 | | 4.759E-12 |
| Actinium-228 | 9.28 | 37.8 | U U | 5.721E-11 |
| Americium-241 | 0.00291 | 0.224 | U U | 1.794E-14 |
| Plutonium-239 | -0.0111 | 0.186 | U UJ | -6.843E-14 |
| Ra-228 – total | 2.13 | 2.08 | | 1.313E-11 |
| Radium-226, -228 combined | 3.32 | 5.31 | U U | 2.047E-11 |
| Thorium-232 | 0.443 | 0.396 | UJ | 2.731E-12 |
| Uranium-238 | 0.64 | 0.148 | UJ | 3.945E-12 |

| Radionuclide | Result (pCi/sample) | MDC (pCi/sample) | Data Qualifier | Airborne Concentration (μ Ci/mL) |
|---|------------------------|---------------------|-------------------|---|
| Uranium-233/234 | 0.781 | 0.271 | UJ | 4.815E-12 |
| Uranium-235/236 | 0.096 | 0.211 | U U | 5.918E-13 |
| Location DOE-3 – Air volume/sample = 9.76E8 mL | | | | |
| Cesium-137 | 1.25 | 6.65 | U U | 7.706E-12 |
| Strontium-90 | -0.132 | 1.64 | U U | -8.137E-13 |
| Cobalt-60 | 0.0117 | 6.53 | U U | 7.213E-14 |
| Potassium-40 | 77.2 | 87.6 | U U | 4.759E-10 |
| Beryllium-7 | 140 | 75.7 | | 8.631E-10 |
| Plutonium-238 | 0.0702 | 0.227 | U U | 4.328E-13 |
| Polonium-210 | 11.8 | 0.589 | | 7.274E-11 |
| Plutonium-241 | 2.07 | 13.1 | U U | 1.276E-11 |
| Thorium-230 | 0.66 | 0.552 | UJ | 4.069E-12 |
| Thorium-228 | 0.261 | 0.503 | U U | 1.609E-12 |
| Actinium-228 | 6.58 | 30.1 | U U | 4.056E-11 |
| Americium-241 | 0.0563 | 0.151 | U U | 3.471E-13 |
| Plutonium-239 | -0.0825 | 0.298 | U UJ | -5.086E-13 |
| Ra-228 – total | 0.79 | 3.24 | U U | 4.870E-12 |
| Radium-226, -228 combined | 3.48 | 2.02 | UJ | 2.145E-11 |
| Thorium-232 | 0.631 | 0.383 | UJ | 3.890E-12 |
| Uranium-238 | 0.591 | 0.291 | UJ | 3.643E-12 |
| Uranium-233/234 | 0.408 | 0.442 | U U | 2.515E-12 |
| Uranium-235/236 | -0.0083 | 0.291 | U U | -5.117E-14 |
| Location DOE-4 – Air volume/sample = 9.83E8 mL | | | | |
| Cesium-137 | 3.21 | 5.63 | U U | 1.979E-11 |
| Strontium-90 | -0.194 | 1.41 | U U | -1.196E-12 |
| Cobalt-60 | -1.84 | 7.42 | U U | -1.134E-11 |
| Potassium-40 | 0 | 61.5 | UI U | 0.000E+0 |
| Beryllium-7 | 0 | 81.9 | UI U | 0.000E+0 |
| Plutonium-238 | 0.00915 | 0.228 | U U | 5.641E-14 |
| Polonium-210 | 10.4 | 0.655 | | 6.411E-11 |
| Plutonium-241 | 3.52 | 10.6 | U U | 2.170E-11 |
| Thorium-230 | 0.713 | 0.391 | UJ | 4.395E-12 |
| Thorium-228 | 0.221 | 0.659 | U U | 1.362E-12 |
| Actinium-228 | -17.9 | 24.9 | U U | -1.103E-10 |
| Americium-241 | 0.0291 | 0.218 | U U | 1.794E-13 |
| Plutonium-239 | 0.0518 | 0.167 | U UJ | 3.193E-13 |
| Ra-228 – total | 1.76 | 2.03 | U U | 1.085E-11 |
| Radium-226, -228 combined | 2.67 | 3.84 | U U | 1.646E-11 |
| Thorium-232 | 0.659 | 0.25 | UJ | 4.063E-12 |

| Radionuclide | Result (pCi/sample) | MDC (pCi/sample) | Data Qualifier | Airborne Concentration (μCi/mL) |
|---------------------|--------------------------------|-----------------------------|---------------------------|---|
| Uranium-238 | 0.747 | 0.11 | UJ | 4.605E-12 |
| Uranium-233/234 | 0.517 | 0.158 | J | 3.187E-12 |
| Uranium-235/236 | 0.0492 | 0.0738 | U U | 3.033E-13 |

APPENDIX D

PM₁₀ Monthly Audit Reports and Flow Verification Results

(This page intentionally left blank)



One-Point Flow Rate Bias Estimate

| | | | |
|-----------------------|--|-----------------------------|-----------------|
| Site ID: DOE-1 | E-BAM Serial #: X16067 / W23310 | Pollutant type: PM10 | Bias (%) |
|-----------------------|--|-----------------------------|-----------------|

| Quarter | Date | Meas Val (Y) | Audit Val (X) | d (Eqn. 1) | Percentile | d ² | d | d ² |
|---------|-----------------------|--------------|---------------|------------|------------|----------------|-------|-----------------|
| 8 | 1/7/2020 (X16067) | 14.00 | 14.12 | -0.850 | 25th | 0.722 | 0.850 | 0.722 |
| | | 16.70 | 16.80 | -0.595 | | 0.354 | 0.595 | 0.354 |
| | | 17.50 | 17.50 | 0.000 | | -0.595 | 0.000 | 0.000 |
| 8 | 2/11/2020 (X16067) | 14.00 | 14.00 | 0.000 | 75th | 0.000 | 0.000 | 0.000 |
| | | 16.70 | 16.78 | -0.477 | | 0.227 | 0.477 | 0.227 |
| | | 17.50 | 17.65 | -0.850 | | 0.000 | 0.722 | 0.850 |
| 8 | 3/25/2020 (W23310) | 14.00 | 14.06 | -0.427 | 0.000 | 0.182 | 0.427 | 0.182 |
| | | 16.70 | 16.65 | 0.300 | | 0.090 | 0.300 | 0.090 |
| | | 17.50 | 17.40 | 0.575 | | 0.330 | 0.575 | 0.330 |


| | | |
|-----|-------------------|--------------|
| n | Σ d | "AB" (Eqn 4) |
| 9 | 4.073 | 0.453 |
| n-1 | Σ d ² | "AS" (Eqn 5) |
| 8 | 2.629 | 0.313 |

| | |
|-------------------------|---------------------|
| Bias (%) (Eqn 3) | Both Signs Positive |
| 0.65 | FALSE |
| Signed Bias (%) | Both Signs Negative |
| -0.65 | TRUE |

Note: Unit W23310 replaced Unit X16067 which was taken out of service for maintenance on 3/25/2020.

Return to Main Menu

Print Worksheet



Reference: U.S. EPA, Ambient Monitoring Technology Information Center (AMTIC) Quality Indicator Assessment Reports
 Data Assessment Statistical Calculator - Software to calculate precision and bias statistics (MS Excel) - 11/3/2017 (dasc_11_3_17.xls)
<https://www3.epa.gov/ttn/amtic/gareport.html>



One-Point Flow Rate Bias Estimate

| | | | |
|-----------------------|-------------------------------|-----------------------------|-----------------|
| Site ID: DOE-2 | E-BAM Serial #: Y12096 | Pollutant type: PM10 | Bias (%) |
|-----------------------|-------------------------------|-----------------------------|-----------------|


| Quarter | Date | Meas Val (Y) | Audit Val (X) | d (Eqn. 1) | Percentile | d ² | d | d ² |
|---------|-----------|--------------|---------------|------------|-------------|----------------|-------|-----------------|
| 8 | 1/7/2020 | 14.00 | 14.08 | -0.568 | 25th | 0.323 | 0.568 | 0.323 |
| | | 16.70 | 16.88 | -1.066 | | 1.137 | 1.066 | 1.137 |
| | | 17.50 | 17.65 | -0.850 | | -0.568 | 0.722 | 0.850 |
| 8 | 2/11/2020 | 14.00 | 14.06 | -0.427 | 75th | 0.182 | 0.427 | 0.182 |
| | | 16.70 | 16.71 | -0.060 | | 0.004 | 0.060 | 0.004 |
| | | 17.50 | 17.59 | -0.512 | | -0.285 | 0.262 | 0.512 |
| 8 | 3/18/2020 | 14.00 | 14.04 | -0.285 | | 0.081 | 0.285 | 0.081 |
| | | 16.70 | 16.74 | -0.239 | | 0.057 | 0.239 | 0.057 |
| | | 17.50 | 17.57 | -0.398 | | 0.159 | 0.398 | 0.159 |

| | | |
|------------|-------------------------|---------------------|
| n | Σ d | "AB" (Eqn 4) |
| 9 | 4.405 | 0.489 |
| n-1 | Σ d ² | "AS" (Eqn 5) |
| 8 | 2.927 | 0.310 |

| | |
|-------------------------|---------------------|
| Bias (%) (Eqn 3) | Both Signs Positive |
| 0.68 | FALSE |
| Signed Bias (%) | Both Signs Negative |
| -0.68 | TRUE |

Return to Main Menu

Print Worksheet



Reference: U.S. EPA, Ambient Monitoring Technology Information Center (AMTIC) Quality Indicator Assessment Reports
 Data Assessment Statistical Calculator - Software to calculate precision and bias statistics (MS Excel) - 11/3/2017 (dasc_11_3_17.xls)
<https://www3.epa.gov/ttn/amtic/qareport.html>



One-Point Flow Rate Bias Estimate

| | | | |
|-----------------------|-------------------------------|-----------------------------|-----------------|
| Site ID: DOE-3 | E-BAM Serial #: W23313 | Pollutant type: PM10 | Bias (%) |
|-----------------------|-------------------------------|-----------------------------|-----------------|


| Quarter | Date | Meas Val (Y) | Audit Val (X) | d (Eqn. 1) | Percentile | d ² | d | d ² |
|---------|-----------|--------------|---------------|------------|------------|----------------|-------|-----------------|
| 8 | 1/7/2020 | 14.00 | 14.01 | -0.071 | 25th | 0.005 | 0.071 | 0.005 |
| | | 16.70 | 16.68 | 0.120 | | 0.014 | 0.120 | 0.014 |
| | | 17.50 | 17.49 | 0.057 | | -0.179 | 0.003 | 0.057 |
| 8 | 2/11/2020 | 14.00 | 14.03 | -0.214 | 75th | 0.046 | 0.214 | 0.046 |
| | | 16.70 | 16.71 | -0.060 | | 0.004 | 0.060 | 0.004 |
| | | 17.50 | 17.47 | 0.172 | | 0.114 | 0.029 | 0.172 |
| 8 | 3/18/2020 | 14.00 | 14.03 | -0.214 | 0.114 | 0.046 | 0.214 | 0.046 |
| | | 16.70 | 16.73 | -0.179 | | 0.032 | 0.179 | 0.032 |
| | | 17.50 | 17.48 | 0.114 | | 0.013 | 0.114 | 0.013 |

| | | |
|-----|-------------------|--------------|
| n | Σ d | "AB" (Eqn 4) |
| 9 | 1.201 | 0.133 |
| n-1 | Σ d ² | "AS" (Eqn 5) |
| 8 | 0.193 | 0.063 |

| | |
|-------------------------|---------------------|
| Bias (%) (Eqn 3) | Both Signs Positive |
| 0.17 | FALSE |
| Signed Bias (%) | Both Signs Negative |
| +/-0.17 | FALSE |

Return to Main Menu

Print Worksheet



Reference: U.S. EPA, Ambient Monitoring Technology Information Center (AMTIC) Quality Indicator Assessment Reports
 Data Assessment Statistical Calculator - Software to calculate precision and bias statistics (MS Excel) - 11/3/2017 (dasc_11_3_17.xls)
<https://www3.epa.gov/ttn/amtic/qareport.html>



One-Point Flow Rate Bias Estimate

| | | | |
|-----------------------|--|-----------------------------|-----------------|
| Site ID: DOE-4 | E-BAM Serial #: W23310 / W23314 | Pollutant type: PM10 | Bias (%) |
|-----------------------|--|-----------------------------|-----------------|

| Quarter | Date | Meas Val (Y) | Audit Val (X) | d (Eqn. 1) | Percentile | d ² | d | d ² | |
|---------|-----------------------|--------------|---------------|------------|-------------|----------------|-------|-----------------|-------|
| 8 | 1/7/2020 (W23310) | 14.00 | 14.02 | -0.143 | 25th | 0.020 | 0.143 | 0.020 | |
| | | 16.70 | 16.70 | 0.000 | | 0.000 | 0.000 | 0.000 | |
| | | 17.50 | 17.48 | 0.114 | | -0.342 | 0.013 | 0.114 | 0.013 |
| 8 | 2/12/2020 (W23314) | 14.00 | 14.03 | -0.214 | 75th | 0.046 | 0.214 | 0.046 | |
| | | 16.70 | 16.72 | -0.120 | | -0.120 | 0.014 | 0.120 | 0.014 |
| | | 17.50 | 17.56 | -0.342 | | -0.120 | 0.117 | 0.342 | 0.117 |
| 8 | 3/18/2020 (W23314) | 14.00 | 14.03 | -0.214 | | 0.046 | 0.214 | 0.046 | |
| | | 16.70 | 16.79 | -0.536 | | 0.287 | 0.536 | 0.287 | |
| | | 17.50 | 17.58 | -0.455 | | 0.207 | 0.455 | 0.207 | |


| | | |
|------------|-------------------------|---------------------|
| n | Σ d | "AB" (Eqn 4) |
| 9 | 2.137 | 0.237 |
| n-1 | Σ d ² | "AS" (Eqn 5) |
| 8 | 0.750 | 0.174 |

| | |
|-------------------------|---------------------|
| Bias (%) (Eqn 3) | Both Signs Positive |
| 0.35 | FALSE |
| Signed Bias (%) | Both Signs Negative |
| -0.35 | TRUE |

Note: Unit W23310 sent to Met-One for repair on 2/12/2020.

Return to Main Menu

Print Worksheet



Reference: U.S. EPA, Ambient Monitoring Technology Information Center (AMTIC) Quality Indicator Assessment Reports
 Data Assessment Statistical Calculator - Software to calculate precision and bias statistics (MS Excel) - 11/3/2017 (dasc_11_3_17.xls)
<https://www3.epa.gov/ttn/amtic/gareport.html>

NORTHWIND INC.

Baseline Air Monitoring Program - DOE

E-BAM Monthly Audit and Maintenance

Station # DOE-1

Serial # X16067

Audit Date: 1/7/2020

Audited By: T.S.W. Wilford

Flow Audit

Flow Audit Device Model: BGI Delta Cal DC-1A Serial No: 158047 Calibration Date: 1/21/2019
 Leak Check Value: as found: 0.5 as left: 0.5

| | E-BAM | Ref. Std. | | E-BAM | Ref. Std. |
|----------------------|-----------------------------|-------------------|----------|-------------------|-------------------|
| Ambient Temperature: | as found: <u>17.6</u> °C | <u>17.3</u> °C | as left: | <u>17.6</u> °C | <u>17.3</u> °C |
| Barometric Pressure: | as found: <u>718.3</u> mmHg | <u>715.5</u> mmHg | as left: | <u>718.3</u> mmHg | <u>715.5</u> mmHg |
| 16.7 lpm Flow Rate | as found: <u>16.7</u> lpm | <u>16.8</u> lpm | as left: | <u>16.7</u> lpm | <u>16.8</u> lpm |
| 14.0 lpm Flow Rate | as found: <u>14.0</u> lpm | <u>14.12</u> lpm | as left: | <u>14.0</u> lpm | <u>14.12</u> lpm |
| 17.5 lpm Flow Rate | as found: <u>17.5</u> lpm | <u>17.5</u> lpm | as left: | <u>17.5</u> lpm | <u>17.5</u> lpm |

Mechanical Audits (Y = Yes N = No)

| | | | | |
|---------------------------|----------|----------|---------|----------|
| Sample nozzle clean: | as found | <u>Y</u> | as left | <u>Y</u> |
| Tape support vane clean: | as found | <u>Y</u> | as left | <u>Y</u> |
| Tape spool covers tight: | as found | <u>Y</u> | as left | <u>Y</u> |
| PM10 particle trap clean: | as found | <u>Y</u> | as left | <u>Y</u> |
| PM10 drip jar empty: | as found | <u>Y</u> | as left | <u>Y</u> |
| PM10 bug screen clear: | as found | <u>Y</u> | as left | <u>Y</u> |

Manual Span Membrane Test

Expected Span Mass (mg/cm2): 0.906
 Measured Span Mass (mg/cm2): 0.900
 Difference (mg/cm2): 0.006

Pump Test

| Flow Rate (lpm) | Vacuum Value (Hg) | Quality Category (Good / Marginal / Poor) |
|-----------------|-------------------|---|
| <u>14.3</u> | <u>402.5</u> | <u>Good to Marginal</u> |

Setup and Calibration Values

| Parameter | Expected | Found | Parameter | Expected | Found | Parameter | Expected | Found |
|--------------|-------------|---------------|------------------|----------|---------------|-----------------|----------|--------------|
| Clock | <u>1005</u> | <u>1005</u> | Analog Mode | Hourly | <u>hourly</u> | Flow Type | Actual | <u>Act</u> |
| Location | <u>1</u> | <u>1</u> | Baud Rate | 9600 | <u>9600</u> | Restart Voltage | 12.5 v | <u>12.5v</u> |
| Tape Advance | 24 hrs | <u>24 hr</u> | RH Setpoint | 45% | <u>45%</u> | Std Cond Temp | 25 C | <u>25C</u> |
| Realtime Avg | 60 mins | <u>60 min</u> | Delta T Setpoint | 15 C | <u>15 C</u> | DAC | 8.0 v | <u>8.0v</u> |
| Machine Type | PM-10 | <u>PM-10</u> | RH Control | On | <u>on</u> | RH Connect | No | <u>NO</u> |
| Analog FS | 1.0 v | <u>1.0v</u> | Flow Setpoint | 16.7 | <u>16.7</u> | Pump Protect | Off | <u>off</u> |

Last 6 Errors in E-BAM Error Log

| Error | Date | Time | Error | Date | Time |
|--------------------------|---------------|-------------|-------|------|------|
| <u>1 No New Messages</u> | <u>1/7/20</u> | <u>1010</u> | | | |
| <u>2</u> | | | | | |
| <u>3</u> | | | | | |

Audit Notes:

NORTHWIND

Baseline Air Monitoring Program - DOE

E-BAM Monthly Audit and Maintenance

Station # DOE-2

Serial #

Y12096

Audit Date: 1/7/2020

Audited By:

TJW

Flow Audit

Flow Audit Device Model: BGI Delta Cal DC-1A Serial No: 158047 Calibration Date: 1/21/2019
 Leak Check Value: as found: 0.5 as left: 0.5

| | E-BAM | Ref. Std. | | E-BAM | Ref. Std. |
|----------------------|-----------------------------|-------------------|----------|-------------------|-------------------|
| Ambient Temperature: | as found: <u>18.8</u> °C | <u>18.8</u> °C | as left: | <u>18.8</u> °C | <u>18.8</u> °C |
| Barometric Pressure: | as found: <u>712.5</u> mmHg | <u>712.5</u> mmHg | as left: | <u>712.5</u> mmHg | <u>712.5</u> mmHg |
| 16.7 lpm Flow Rate | as found: <u>14.7</u> lpm | <u>16.88</u> lpm | as left: | <u>16.7</u> lpm | <u>16.88</u> lpm |
| 14.0 lpm Flow Rate | as found: <u>14.0</u> lpm | <u>14.08</u> lpm | as left: | <u>14.0</u> lpm | <u>14.08</u> lpm |
| 17.5 lpm Flow Rate | as found: <u>17.5</u> lpm | <u>17.65</u> lpm | as left: | <u>17.5</u> lpm | <u>17.65</u> lpm |

Mechanical Audits (Y = Yes N = No)

| | | | | |
|---------------------------|----------|----------|---------|----------|
| Sample nozzle clean: | as found | <u>Y</u> | as left | <u>Y</u> |
| Tape support vane clean: | as found | <u>Y</u> | as left | <u>Y</u> |
| Tape spool covers tight: | as found | <u>Y</u> | as left | <u>Y</u> |
| PM10 particle trap clean: | as found | <u>Y</u> | as left | <u>Y</u> |
| PM10 drip jar empty: | as found | <u>Y</u> | as left | <u>Y</u> |
| PM10 bug screen clear: | as found | <u>Y</u> | as left | <u>Y</u> |

Manual Span Membrane Test

Expected Span Mass (mg/cm²): 0.848
 Measured Span Mass (mg/cm²): 0.881
 Difference (mg/cm²): 0.033

% Difference 3.8% Pass 14.2

Pump Test

| Flow Rate | Vacuum Value | Quality Category |
|-------------------|--------------|------------------------|
| 14.0 - 15.0 (lpm) | (Hg) | Good / Marginal / Poor |
| <u>14.2</u> | <u>403.0</u> | <u>Marginal</u> |

Setup and Calibration Values

| Parameter | Expected | Found | Parameter | Expected | Found | Parameter | Expected | Found |
|--------------|-------------|--------------|------------------|----------|---------------|-----------------|----------|--------------|
| Clock | <u>1128</u> | <u>1128</u> | Analog Mode | Hourly | <u>Hourly</u> | Flow Type | Actual | <u>Act</u> |
| Location | <u>2</u> | <u>2</u> | Baud Rate | 9600 | <u>9600</u> | Restart Voltage | 12.5 v | <u>12.5v</u> |
| Tape Advance | 24 hrs | <u>24</u> | RH Setpoint | 45% | <u>45%</u> | Std Cond Temp | 25 C | <u>25.0</u> |
| Realtime Avg | 60 mins | <u>60min</u> | Delta T Setpoint | 15 C | <u>15°C</u> | DAC | 8.0 v | <u>8.0v</u> |
| Machine Type | PM-10 | <u>PM-10</u> | RH Control | On | <u>On</u> | RH Connect | No | <u>NO</u> |
| Analog FS | 1.0 v | <u>1.0v</u> | Flow Setpoint | 16.7 | <u>16.7</u> | Pump Protect | Off | <u>OFF</u> |

Last 6 Errors in E-BAM Error Log

| Error | Date | Time | Error | Date | Time |
|--------------------------|---------------|-------------|-------|------|------|
| <u>1 No New Messages</u> | <u>1/7/20</u> | <u>1131</u> | | | |
| <u>2</u> | | | | | |
| <u>3</u> | | | | | |

Audit Notes:

NORTHWIND

Baseline Air Monitoring Program - DOE

E-BAM Monthly Audit and Maintenance

Station # DOE-3

Serial # W23313

Audit Date: 1/7/2020

Audited By: TS W. Illiford

Flow Audit

Flow Audit Device Model: BGI Delta Cal DC-1A Serial No: 158047 Calibration Date: 1/21/2019
 Leak Check Value: as found: 0.7 as left: 0.7

| | E-BAM | Ref. Std. | | E-BAM | Ref. Std. |
|----------------------|-----------------------------|-------------------|----------|-------------------|-------------------|
| Ambient Temperature: | as found: <u>20.0</u> °C | <u>19.4</u> °C | as left: | <u>20.0</u> °C | <u>19.4</u> °C |
| Barometric Pressure: | as found: <u>713.2</u> mmHg | <u>712.5</u> mmHg | as left: | <u>713.2</u> mmHg | <u>712.5</u> mmHg |
| 16.7 lpm Flow Rate | as found: <u>16.7</u> lpm | <u>16.68</u> lpm | as left: | <u>16.7</u> lpm | <u>16.68</u> lpm |
| 14.0 lpm Flow Rate | as found: <u>14.0</u> lpm | <u>14.01</u> lpm | as left: | <u>14.0</u> lpm | <u>14.01</u> lpm |
| 17.5 lpm Flow Rate | as found: <u>17.5</u> lpm | <u>17.49</u> lpm | as left: | <u>17.5</u> lpm | <u>17.49</u> lpm |

Mechanical Audits (Y = Yes N = No)

| | | | | |
|---------------------------|----------|----------|---------|----------|
| Sample nozzle clean: | as found | <u>Y</u> | as left | <u>Y</u> |
| Tape support vane clean: | as found | <u>Y</u> | as left | <u>Y</u> |
| Tape spool covers tight: | as found | <u>Y</u> | as left | <u>Y</u> |
| PM10 particle trap clean: | as found | <u>Y</u> | as left | <u>Y</u> |
| PM10 drip jar empty: | as found | <u>Y</u> | as left | <u>Y</u> |
| PM10 bug screen clear: | as found | <u>Y</u> | as left | <u>Y</u> |

Manual Span Membrane Test

Expected Span Mass (mg/cm2): 0.885
 Measured Span Mass (mg/cm2): 0.883
 Difference (mg/cm2): 0.002
 % Difference / Pass or Fail: 0.22%

Pump Test

| Flow Rate | Vacuum Value | Quality Category |
|-------------------|--------------|------------------------|
| 14.0 - 15.0 (lpm) | (Hg) | Good / Marginal / Poor |
| <u>14.7</u> | <u>424.0</u> | <u>Marginal</u> |

Setup and Calibration Values

| Parameter | Expected | Found | Parameter | Expected | Found | Parameter | Expected | Found |
|--------------|-------------|--------------|------------------|----------|---------------|-----------------|----------|--------------|
| Clock | <u>1325</u> | <u>1325</u> | Analog Mode | Hourly | <u>hourly</u> | Flow Type | Actual | <u>Act</u> |
| Location | <u>3</u> | <u>3</u> | Baud Rate | 9600 | <u>9600</u> | Restart Voltage | 12.5 v | <u>12.5V</u> |
| Tape Advance | 24 hrs | <u>24hr</u> | RH Setpoint | 45% | <u>45%</u> | Std Cond Temp | 25 C | <u>25C</u> |
| Realtime Avg | 60 mins | <u>60min</u> | Delta T Setpoint | 15 C | <u>15C</u> | DAC | 8.0 v | <u>8.0V</u> |
| Machine Type | PM-10 | <u>PM-10</u> | RH Control | On | <u>ON</u> | RH Connect | No | <u>NO</u> |
| Analog FS | 1.0 v | <u>1.0V</u> | Flow Setpoint | 16.7 | <u>16.7</u> | Pump Protect | Off | <u>off</u> |

Last 6 Errors in E-BAM Error Log

| Error | Date | Time | Error | Date | Time |
|--------------------------|---------------|-------------|-------|------|------|
| <u>1 No New Messages</u> | <u>1/7/20</u> | <u>1336</u> | | | |
| <u>2</u> | | | | | |
| <u>3</u> | | | | | |

Audit Notes:

* Initial Audit for W23313 after repairs and before put back into service

NORTHWIND

Baseline Air Monitoring Program - DOE

E-BAM Monthly Audit and Maintenance

Station # DOE-4

Serial # W23310

Audit Date: 1/7/2020

Audited By: T Swillford

Flow Audit

Flow Audit Device Model: BGI Delta Cal DC-1A Serial No: 158047 Calibration Date: 1/21/2019
 Leak Check Value: as found: 0.7 as left: 0.7

| | E-BAM | Ref. Std. | | E-BAM | Ref. Std. |
|----------------------|-----------------------------|-------------------|----------|-------------------|-------------------|
| Ambient Temperature: | as found: <u>18.6</u> °C | <u>18.7</u> °C | as left: | <u>18.6</u> °C | <u>18.7</u> °C |
| Barometric Pressure: | as found: <u>705.0</u> mmHg | <u>704.5</u> mmHg | as left: | <u>705.0</u> mmHg | <u>704.5</u> mmHg |
| 16.7 lpm Flow Rate | as found: <u>16.7</u> lpm | <u>16.7</u> lpm | as left: | <u>16.7</u> lpm | <u>16.7</u> lpm |
| 14.0 lpm Flow Rate | as found: <u>14.0</u> lpm | <u>14.02</u> lpm | as left: | <u>14.0</u> lpm | <u>14.0</u> lpm |
| 17.5 lpm Flow Rate | as found: <u>17.5</u> lpm | <u>17.48</u> lpm | as left: | <u>17.5</u> lpm | <u>17.48</u> lpm |

Mechanical Audits (Y = Yes N = No)

| | | | | |
|---------------------------|----------|----------|---------|----------|
| Sample nozzle clean: | as found | <u>Y</u> | as left | <u>Y</u> |
| Tape support vane clean: | as found | <u>Y</u> | as left | <u>Y</u> |
| Tape spool covers tight: | as found | <u>Y</u> | as left | <u>Y</u> |
| PM10 particle trap clean: | as found | <u>Y</u> | as left | <u>Y</u> |
| PM10 drip jar empty: | as found | <u>Y</u> | as left | <u>Y</u> |
| PM10 bug screen clear: | as found | <u>Y</u> | as left | <u>Y</u> |

Manual Span Membrane Test

Pump Test

| | | | | |
|---|--------------|-----------------------------------|-------------------------|--|
| Expected Span Mass (mg/cm ²): | <u>0.915</u> | Flow Rate 14.0 - 15.0 (lpm) | Vacuum Value (Hg) | Quality Category Good / Marginal / Poor |
| Measured Span Mass (mg/cm ²): | <u>0.914</u> | | | |
| Difference (mg/cm ²): | <u>0.001</u> | | | |
| % Difference / Pass or Fail: | <u>0.12%</u> | <u>14.7</u> | <u>421.1</u> | <u>Marginal</u> |

Setup and Calibration Values

| Parameter | Expected | Found | Parameter | Expected | Found | Parameter | Expected | Found |
|--------------|-------------|---------------|------------------|----------|---------------|-----------------|----------|--------------|
| Clock | <u>1415</u> | <u>1415</u> | Analog Mode | Hourly | <u>hourly</u> | Flow Type | Actual | <u>Act</u> |
| Location | <u>4</u> | <u>4</u> | Baud Rate | 9600 | <u>9600</u> | Restart Voltage | 12.5 v | <u>12.5</u> |
| Tape Advance | 24 hrs | <u>24 hr</u> | RH Setpoint | 45% | <u>45%</u> | Std Cond Temp | 25 C | <u>25.0</u> |
| Realtime Avg | 60 mins | <u>60 min</u> | Delta T Setpoint | 15 C | <u>15 C</u> | DAC | 8.0 v | <u>8.0 v</u> |
| Machine Type | PM-10 | <u>PM-10</u> | RH Control | On | <u>on</u> | RH Connect | No | <u>No</u> |
| Analog FS | 1.0 v | <u>1.0 v</u> | Flow Setpoint | 16.7 | <u>16.7</u> | Pump Protect | Off | <u>off</u> |

Last 6 Errors in E-BAM Error Log

| Error | Date | Time | Error | Date | Time |
|--------------------------|---------------|-------------|-------|------|------|
| <u>1 No New Messages</u> | <u>1/7/20</u> | <u>1420</u> | | | |
| <u>2</u> | | <u>5</u> | | | |
| <u>3</u> | | <u>6</u> | | | |

Audit Notes:

NORTHWIND INC.

Baseline Air Monitoring Program - DOE E-BAM Monthly Audit and Maintenance

Station # DOE-1 Serial # X16067
 Audit Date: 2/11/2020 Audited By: TRW

Flow Audit

Flow Audit Device Model: BGI Delta Cal DC-1A Serial No: 158047 Calibration Date: ~~1/21/2019 TRW~~
 Leak Check Value: as found: 0.5 as left: 0.5 2/6/2020

| | E-BAM | Ref. Std. | | E-BAM | Ref. Std. |
|----------------------|-----------------------------|-------------------|----------|-------------------|-------------------|
| Ambient Temperature: | as found: <u>18.1</u> °C | <u>17.90</u> °C | as left: | <u>18.1</u> °C | <u>17.90</u> °C |
| Barometric Pressure: | as found: <u>715.6</u> mmHg | <u>714.0</u> mmHg | as left: | <u>715.6</u> mmHg | <u>714.0</u> mmHg |
| 16.7 lpm Flow Rate | as found: <u>16.7</u> lpm | <u>16.78</u> lpm | as left: | <u>16.7</u> lpm | <u>16.78</u> lpm |
| 14.0 lpm Flow Rate | as found: <u>14.0</u> lpm | <u>14.0</u> lpm | as left: | <u>14.0</u> lpm | <u>14.0</u> lpm |
| 17.5 lpm Flow Rate | as found: <u>17.5</u> lpm | <u>17.65</u> lpm | as left: | <u>17.5</u> lpm | <u>17.65</u> lpm |

Mechanical Audits (Y = Yes N = No)

| | | | | |
|---------------------------|----------|----------|---------|----------|
| Sample nozzle clean: | as found | <u>Y</u> | as left | <u>Y</u> |
| Tape support vane clean: | as found | <u>Y</u> | as left | <u>Y</u> |
| Tape spool covers tight: | as found | <u>Y</u> | as left | <u>Y</u> |
| PM10 particle trap clean: | as found | <u>Y</u> | as left | <u>Y</u> |
| PM10 drip jar empty: | as found | <u>Y</u> | as left | <u>Y</u> |
| PM10 bug screen clear: | as found | <u>Y</u> | as left | <u>Y</u> |

| Manual Span Membrane Test | | Pump Test | |
|---|-------------------------------|-------------|--------------|
| Expected Span Mass (mg/cm ²): | <u>0.906</u> | Flow Rate | Vacuum |
| Measured Span Mass (mg/cm ²): | <u>0.917</u> ^{TRW} | 14.0 - 15.0 | Value |
| Difference (mg/cm ²): | <u>0.906 0.011</u> | (lpm) | (Hg) |
| % Difference / <u>Pass</u> or Fail: | <u>1.2%</u> | <u>14.7</u> | <u>411.1</u> |
| | | | <u>Good</u> |

Setup and Calibration Values

| Parameter | Expected | Found | Parameter | Expected | Found | Parameter | Expected | Found |
|--------------|-------------|----------------|------------------|----------|---------------|-----------------|----------|--------------|
| Clock | <u>1226</u> | <u>1226</u> | Analog Mode | Hourly | <u>Hourly</u> | Flow Type | Actual | <u>Act</u> |
| Location | <u>1</u> | <u>1</u> | Baud Rate | 9600 | <u>9600</u> | Restart Voltage | 12.5 v | <u>12.5V</u> |
| Tape Advance | 24 hrs | <u>24 hrs</u> | RH Setpoint | 45% | <u>45%</u> | Std Cond Temp | 25 C | <u>25C</u> |
| Realtime Avg | 60 mins | <u>60 mins</u> | Delta T Setpoint | 15 C | <u>15C</u> | DAC | 8.0 v | <u>8.0V</u> |
| Machine Type | PM-10 | <u>PM-10</u> | RH Control | On | <u>on</u> | RH Connect | No | <u>No</u> |
| Analog FS | 1.0 v | <u>1.0 v</u> | Flow Setpoint | 16.7 | <u>16.7</u> | Pump Protect | Off | <u>off</u> |

Last 6 Errors in E-BAM Error Log

| Error | Date | Time | Error | Date | Time |
|--------------------------|----------------|-------------|-------|------|------|
| <u>1 No New Messages</u> | <u>2/11/20</u> | <u>1235</u> | | | |
| <u>2</u> | | | | | |
| <u>3</u> | | | | | |

Audit Notes:
* Cleaned Nozzle and Sampling Vane.

NORTHWIND

Baseline Air Monitoring Program - DOE E-BAM Monthly Audit and Maintenance

Station # DOE-2 Serial # Y12096
 Audit Date: 2/11/2020 Audited By: TBW

| Flow Audit | | | | | | |
|--------------------------|-----------------------------|------------|---------------------|----------------------------|------------|-------------------|
| Flow Audit Device Model: | BGI Delta Cal DC-1A | Serial No: | 158047 | Calibration Date: | 1/21/2019 | |
| Leak Check Value: | as found: <u>0.4</u> | | as left: <u>0.4</u> | | | |
| Ambient Temperature: | as found: <u>17.6</u> °C | Ref. Std.: | <u>17.1</u> °C | as left: <u>17.6</u> °C | Ref. Std.: | <u>17.1</u> °C |
| Barometric Pressure: | as found: <u>710.2</u> mmHg | Ref. Std.: | <u>710.5</u> mmHg | as left: <u>710.2</u> mmHg | Ref. Std.: | <u>710.5</u> mmHg |
| 16.7 lpm Flow Rate | as found: <u>16.7</u> lpm | Ref. Std.: | <u>16.71</u> lpm | as left: <u>16.7</u> lpm | Ref. Std.: | <u>16.71</u> lpm |
| 14.0 lpm Flow Rate | as found: <u>14.0</u> lpm | Ref. Std.: | <u>14.06</u> lpm | as left: <u>14.0</u> lpm | Ref. Std.: | <u>14.06</u> lpm |
| 17.5 lpm Flow Rate | as found: <u>17.5</u> lpm | Ref. Std.: | <u>17.59</u> lpm | as left: <u>17.5</u> lpm | Ref. Std.: | <u>17.59</u> lpm |

| Mechanical Audits (Y = Yes N = No) | | | |
|--------------------------------------|----------|-------|---------------|
| Sample nozzle clean: | as found | _____ | as left _____ |
| Tape support vane clean: | as found | _____ | as left _____ |
| Tape spool covers tight: | as found | _____ | as left _____ |
| PM10 particle trap clean: | as found | _____ | as left _____ |
| PM10 drip jar empty: | as found | _____ | as left _____ |
| PM10 bug screen clear: | as found | _____ | as left _____ |

| Manual Span Membrane Test | Pump Test | | |
|---|-----------------------------------|-------------------------|--|
| Expected Span Mass (mg/cm2): <u>0.848</u> | Flow Rate 14.0 - 15.0 (lpm) | Vacuum Value (Hg) | Quality Category Good / Marginal / Poor |
| Measured Span Mass (mg/cm2): <u>0.870</u> | | | |
| Difference (mg/cm2): <u>0.022</u> | | | |
| % Difference <u>Pass</u> or Fail: <u>2.5%</u> | <u>14.4</u> | <u>406.6</u> | <u>Good</u> |

| Setup and Calibration Values | | | | | | | | |
|------------------------------|----------|--------|------------------|----------|--------|-----------------|----------|-------|
| Parameter | Expected | Found | Parameter | Expected | Found | Parameter | Expected | Found |
| Clock | 1331 | 1331 | Analog Mode | Hourly | Hourly | Flow Type | Actual | Act |
| Location | 2 | 2 | Baud Rate | 9600 | 9600 | Restart Voltage | 12.5 v | 12.5v |
| Tape Advance | 24 hrs | 24hr | RH Setpoint | 45% | 45% | Std Cond Temp | 25 C | 25°C |
| Realtime Avg | 60 mins | 60 min | Delta T Setpoint | 15 C | 15°C | DAC | 8.0 v | 8.0v |
| Machine Type | PM-10 | PM-10 | RH Control | On | On | RH Connect | No | NO |
| Analog FS | 1.0 v | 1.0v | Flow Setpoint | 16.7 | 16.7 | Pump Protect | Off | Off |

| Last 6 Errors in E-BAM Error Log | | | | | | |
|----------------------------------|---------|------|---|-------|------|------|
| Error | Date | Time | | Error | Date | Time |
| 1 No New Messages | 2/11/20 | 1337 | 4 | | | |
| 2 | | | 5 | | | |
| 3 | | | 6 | | | |

Audit Notes:

NORTHWIND INC

Baseline Air Monitoring Program - DOE E-BAM Monthly Audit and Maintenance

Station # DOE-3

Serial # W23313

Audit Date: 2/11/2020

Audited By: TBW

Flow Audit

Flow Audit Device Model: BGI Delta Cal DC-1A Serial No: 158047 Calibration Date: 1/21/2019
 Leak Check Value: as found: 0.6 as left: 0.6

| | E-BAM | Ref. Std. | | E-BAM | Ref. Std. |
|----------------------|-----------------------------|-------------------|----------|-------------------|-------------------|
| Ambient Temperature: | as found: <u>19.0</u> °C | <u>18.6</u> °C | as left: | <u>19.0</u> °C | <u>18.6</u> °C |
| Barometric Pressure: | as found: <u>711.6</u> mmHg | <u>712.0</u> mmHg | as left: | <u>711.6</u> mmHg | <u>712.0</u> mmHg |
| 16.7 lpm Flow Rate | as found: <u>16.7</u> lpm | <u>16.71</u> lpm | as left: | <u>16.7</u> lpm | <u>16.71</u> lpm |
| 14.0 lpm Flow Rate | as found: <u>14.0</u> lpm | <u>14.03</u> lpm | as left: | <u>14.0</u> lpm | <u>14.03</u> lpm |
| 17.5 lpm Flow Rate | as found: <u>17.5</u> lpm | <u>17.47</u> lpm | as left: | <u>17.5</u> lpm | <u>17.47</u> lpm |

Mechanical Audits (Y = Yes N = No)

| | | | | |
|---------------------------|----------|----------|---------|----------|
| Sample nozzle clean: | as found | <u>Y</u> | as left | <u>Y</u> |
| Tape support vane clean: | as found | <u>Y</u> | as left | <u>Y</u> |
| Tape spool covers tight: | as found | <u>Y</u> | as left | <u>Y</u> |
| PM10 particle trap clean: | as found | <u>Y</u> | as left | <u>Y</u> |
| PM10 drip jar empty: | as found | <u>Y</u> | as left | <u>Y</u> |
| PM10 bug screen clear: | as found | <u>Y</u> | as left | <u>Y</u> |

Manual Span Membrane Test

Expected Span Mass (mg/cm2): 0.885
 Measured Span Mass (mg/cm2): 0.869
 Difference (mg/cm2): 0.016
 % Difference Pass or Fail: 1.8 %

Pump Test

| Flow Rate | Vacuum Value | Quality Category |
|-------------------|--------------|------------------------|
| 14.0 - 15.0 (lpm) | (Hg) | Good / Marginal / Poor |
| <u>14.5</u> | <u>409.5</u> | <u>Good</u> |

Setup and Calibration Values

| Parameter | Expected | Found | Parameter | Expected | Found | Parameter | Expected | Found |
|--------------|-------------|--------------|------------------|----------|---------------|-----------------|----------|--------------|
| Clock | <u>1428</u> | <u>1428</u> | Analog Mode | Hourly | <u>Hourly</u> | Flow Type | Actual | <u>Act</u> |
| Location | <u>3</u> | <u>3</u> | Baud Rate | 9600 | <u>9600</u> | Restart Voltage | 12.5 v | <u>12.5V</u> |
| Tape Advance | 24 hrs | <u>24hr</u> | RH Setpoint | 45% | <u>45%</u> | Std Cond Temp | 25 C | <u>25°C</u> |
| Realtime Avg | 60 mins | <u>60min</u> | Delta T Setpoint | 15 C | <u>15°C</u> | DAC | 8.0 v | <u>8.0V</u> |
| Machine Type | PM-10 | <u>PM-10</u> | RH Control | On | <u>on</u> | RH Connect | No | <u>NO</u> |
| Analog FS | 1.0 v | <u>1.0V</u> | Flow Setpoint | 16.7 | <u>16.7</u> | Pump Protect | Off | <u>OFF</u> |

Last 6 Errors in E-BAM Error Log

| Error | Date | Time | Error | Date | Time |
|--------------------------|------------------|-------------|-------|------|------|
| <u>1 No New Messages</u> | <u>2/11/2020</u> | <u>1435</u> | | | |
| <u>2</u> | | | | | |
| <u>3</u> | | | | | |

Audit Notes:



**Baseline Air Monitoring Program - DOE
E-BAM Monthly Audit and Maintenance**

Station # DOE-4

Serial # W23310

Audit Date: 2/11/2020

Audited By: T. Stewart Williford

Flow Audit

Flow Audit Device Model: BGI Delta Cal DC-1A Serial No: 158047 Calibration Date: 1/21/2019
Leak Check Value: as found: _____ as left: _____

| | as found: | E-BAM | Ref. Std. | as left: | E-BAM | Ref. Std. |
|----------------------|------------|------------|------------|------------|------------|------------|
| Ambient Temperature: | _____ °C | _____ °C | _____ °C | _____ °C | _____ °C | _____ °C |
| Barometric Pressure: | _____ mmHg | _____ mmHg | _____ mmHg | _____ mmHg | _____ mmHg | _____ mmHg |
| 16.7 lpm Flow Rate | _____ lpm | _____ lpm | _____ lpm | _____ lpm | _____ lpm | _____ lpm |
| 14.0 lpm Flow Rate | _____ lpm | _____ lpm | _____ lpm | _____ lpm | _____ lpm | _____ lpm |
| 17.5 lpm Flow Rate | _____ lpm | _____ lpm | _____ lpm | _____ lpm | _____ lpm | _____ lpm |

Mechanical Audits (Y = Yes N = No)

Sample nozzle clean: as found _____ as left _____
Tape support vane clean: as found _____ as left _____
Tape spool covers tight: as found _____ as left _____
PM10 particle trap clean: as found _____ as left _____
PM10 drip jar empty: as found _____ as left _____
PM10 bug screen clear: as found _____ as left _____

Manual Span Membrane Test

Pump Test

| | | | |
|-------------------------------|-----------------------------------|-------------------------|--|
| Expected Span Mass (mg/cm2) : | Flow Rate 14.0 - 15.0 (lpm) | Vacuum Value (Hg) | Quality Category Good / Marginal / Poor |
| Measured Span Mass (mg/cm2) : | | | |
| Difference (mg/cm2) : | | | |
| % Difference / Pass or Fail: | | | |

Setup and Calibration Values

| Parameter | Expected | Found | Parameter | Expected | Found | Parameter | Expected | Found |
|--------------|----------|-------|------------------|----------|-------|-----------------|----------|-------|
| Clock | | | Analog Mode | Hourly | | Flow Type | Actual | |
| Location | | | Baud Rate | 9600 | | Restart Voltage | 12.5 v | |
| Tape Advance | 24 hrs | | RH Setpoint | 45% | | Std Cond Temp | 25 C | |
| Realtime Avg | 60 mins | | Delta T Setpoint | 15 C | | DAC | 8.0 v | |
| Machine Type | PM-10 | | RH Control | On | | RH Connect | No | |
| Analog FS | 1.0 v | | Flow Setpoint | 16.7 | | Pump Protect | Off | |

Last 6 Errors in E-BAM Error Log

| Error | Date | Time | Error | Date | Time |
|-------|------|------|-------|------|------|
| 1 | | | 4 | | |
| 2 | | | 5 | | |
| 3 | | | 6 | | |

Audit Notes:

** When I tried to Audit the Flow rate the unit kept turning off. when I turned the unit back on it would return back to the original Start up menu ~~at 12:30~~ and the same ~~to~~ When I would try to start up the unit again it would turn off again. Took unit down and will send into met One.

NORTHWIND

Baseline Air Monitoring Program - DOE E-BAM Monthly Audit and Maintenance

Station # DOE-4

Serial # W23314

Audit Date: 2/12/2020

Audited By: TSW

Flow Audit

Flow Audit Device Model: BGI Delta Cal DC-1A Serial No: 158047 Calibration Date: 1/21/2019
 Leak Check Value: as found: 0.4 as left: 0.4

| | E-BAM | Ref. Std. | | E-BAM | Ref. Std. |
|----------------------|-----------------------------|-------------------|----------|-------------------|-------------------|
| Ambient Temperature: | as found: <u>11.3</u> °C | <u>10.9</u> °C | as left: | <u>11.3</u> °C | <u>10.9</u> °C |
| Barometric Pressure: | as found: <u>707.3</u> mmHg | <u>705.0</u> mmHg | as left: | <u>707.3</u> mmHg | <u>705.0</u> mmHg |
| 16.7 lpm Flow Rate | as found: <u>16.7</u> lpm | <u>16.72</u> lpm | as left: | <u>16.7</u> lpm | <u>16.72</u> lpm |
| 14.0 lpm Flow Rate | as found: <u>14.0</u> lpm | <u>14.03</u> lpm | as left: | <u>14.0</u> lpm | <u>14.03</u> lpm |
| 17.5 lpm Flow Rate | as found: <u>17.5</u> lpm | <u>17.56</u> lpm | as left: | <u>17.5</u> lpm | <u>17.56</u> lpm |

Mechanical Audits (Y = Yes N = No)

| | | | | |
|---------------------------|----------|----------|---------|----------|
| Sample nozzle clean: | as found | <u>Y</u> | as left | <u>Y</u> |
| Tape support vane clean: | as found | <u>Y</u> | as left | <u>Y</u> |
| Tape spool covers tight: | as found | <u>Y</u> | as left | <u>Y</u> |
| PM10 particle trap clean: | as found | <u>Y</u> | as left | <u>Y</u> |
| PM10 drip jar empty: | as found | <u>Y</u> | as left | <u>Y</u> |
| PM10 bug screen clear: | as found | <u>Y</u> | as left | <u>Y</u> |

Manual Span Membrane Test

Expected Span Mass (mg/cm2): 0.919
 Measured Span Mass (mg/cm2): 0.927
 Difference (mg/cm2): 0.008
 % Difference / Pass or Fail: TSW 0.87%

Pump Test

| Flow Rate | Vacuum Value | Quality Category |
|-------------------|--------------|------------------------|
| 14.0 - 15.0 (lpm) | (Hg) | Good / Marginal / Poor |
| <u>14.1</u> | <u>420.3</u> | <u>Marginal</u> |

Setup and Calibration Values

| Parameter | Expected | Found | Parameter | Expected | Found | Parameter | Expected | Found |
|--------------|-------------|---------------|------------------|----------|---------------|-----------------|----------|--------------|
| Clock | <u>0903</u> | <u>0903</u> | Analog Mode | Hourly | <u>Hourly</u> | Flow Type | Actual | <u>Act</u> |
| Location | <u>4</u> | <u>4</u> | Baud Rate | 9600 | <u>9600</u> | Restart Voltage | 12.5 v | <u>12.5v</u> |
| Tape Advance | 24 hrs | <u>24 hrs</u> | RH Setpoint | 45% | <u>45%</u> | Std Cond Temp | 25 C | <u>25°C</u> |
| Realtime Avg | 60 mins | <u>60mins</u> | Delta T Setpoint | 15 C | <u>15°C</u> | DAC | 8.0 v | <u>8.0v</u> |
| Machine Type | PM-10 | <u>PM-10</u> | RH Control | On | <u>On</u> | RH Connect | No | <u>NO</u> |
| Analog FS | 1.0 v | <u>1.0v</u> | Flow Setpoint | 16.7 | <u>16.7</u> | Pump Protect | Off | <u>off</u> |

Last 6 Errors in E-BAM Error Log

| Error | Date | Time | Error | Date | Time |
|--------------------------|----------------|-------------|-------|------|------|
| <u>1 No New Messages</u> | <u>2/12/20</u> | <u>0945</u> | | | |
| <u>2</u> | | | | | |
| <u>3</u> | | | | | |

Audit Notes:

Initial Audit for W23314 Replaced W23310



**Baseline Air Monitoring Program - DOE
E-BAM Monthly Audit and Maintenance**

Station # DOE-1 Serial # W23310
 Audit Date: 3/25/2020 Audited By: TS Williford

| Flow Audit | | | | | |
|--------------------------|----------------------------|-------------------|--------------------------|-------------------|-----------------|
| Flow Audit Device Model: | <u>BGI Delta Cal DC-1A</u> | Serial No: | <u>158047</u> | Calibration Date: | <u>2/5/2020</u> |
| Leak Check Value: | as found: _____ | | as left: _____ | | |
| | E-BAM | Ref. Std. | | E-BAM | Ref. Std. |
| Ambient Temperature: | as found: <u>11.5</u> °C | <u>12.0</u> °C | as left: <u>11.5</u> °C | <u>12.0</u> °C | |
| Barometric Pressure: | as found: <u>714</u> mmHg | <u>713.6</u> mmHg | as left: <u>714</u> mmHg | <u>713.6</u> mmHg | |
| 16.7 lpm Flow Rate | as found: <u>16.7</u> lpm | <u>16.65</u> lpm | as left: <u>16.7</u> lpm | <u>16.65</u> lpm | |
| 14.0 lpm Flow Rate | as found: <u>14.0</u> lpm | <u>14.06</u> lpm | as left: <u>14.0</u> lpm | <u>14.06</u> lpm | |
| 17.5 lpm Flow Rate | as found: <u>17.5</u> lpm | <u>17.40</u> lpm | as left: <u>17.5</u> lpm | <u>17.40</u> lpm | |

| Mechanical Audits (Y = Yes N = No) | | | | | |
|--------------------------------------|----------|----------|---------|----------|--|
| Sample nozzle clean: | as found | <u>Y</u> | as left | <u>Y</u> | |
| Tape support vane clean: | as found | <u>Y</u> | as left | <u>Y</u> | |
| Tape spool covers tight: | as found | <u>Y</u> | as left | <u>Y</u> | |
| PM10 particle trap clean: | as found | <u>Y</u> | as left | <u>Y</u> | |
| PM10 drip jar empty: | as found | <u>Y</u> | as left | <u>Y</u> | |
| PM10 bug screen clear: | as found | <u>Y</u> | as left | <u>Y</u> | |

| Manual Span Membrane Test | Pump Test | | |
|--|-------------|--------------|------------------------|
| Expected Span Mass (mg/cm2) : <u>0.915</u> | Flow Rate | Vacuum | Quality Category |
| Measured Span Mass (mg/cm2) : <u>0.921</u> | 14.0 - 15.0 | Value | Good / Marginal / Poor |
| Difference (mg/cm2) : <u>0.006</u> | (lpm) | (Hg) | |
| % Difference / <u>Pass</u> or Fail: <u>0.65%</u> | <u>14.0</u> | <u>406.8</u> | <u>Marginal</u> |

| Setup and Calibration Values | | | | | | | | |
|------------------------------|-------------|--------------|------------------|----------|---------------|-----------------|----------|--------------|
| Parameter | Expected | Found | Parameter | Expected | Found | Parameter | Expected | Found |
| Clock | <u>1015</u> | <u>1115</u> | Analog Mode | Hourly | <u>Hourly</u> | Flow Type | Actual | <u>Act</u> |
| Location | <u>1</u> | <u>1</u> | Baud Rate | 9600 | <u>9600</u> | Restart Voltage | 12.5 v | <u>12.5v</u> |
| Tape Advance | 24 hrs | <u>24</u> | RH Setpoint | 45% | <u>45%</u> | Std Cond Temp | 25 C | <u>25C</u> |
| Realtime Avg | 60 mins | <u>60</u> | Delta T Setpoint | 15 C | <u>15C</u> | DAC | 8.0 v | <u>8.0v</u> |
| Machine Type | PM-10 | <u>PM-10</u> | RH Control | On | <u>on</u> | RH Connect | No | <u>No</u> |
| Analog FS | 1.0 v | <u>1.0v</u> | Flow Setpoint | 16.7 | <u>16.7</u> | Pump Protect | Off | <u>off</u> |

| Last 6 Errors in E-BAM Error Log | | | | | | |
|----------------------------------|----------------|--------------|-------|------|------|--|
| Error | Date | Time | Error | Date | Time | |
| 1 <u>No New Messages</u> | <u>3/25/20</u> | <u>12:10</u> | 4 | | | |
| 2 | | | 5 | | | |
| 3 | | | 6 | | | |

Audit Notes:
 * Initial Audit for W23310 after receiving from met one.



Baseline Air Monitoring Program - DOE

E-BAM Monthly Audit and Maintenance

Station # DOE-2
 Audit Date: 3/18/2020

Serial # Y12096
 Audited By: T.S. Williford

| Flow Audit | | | | | |
|--------------------------|----------------------------|-------------------|---------------------|-------------------|-----------------|
| Flow Audit Device Model: | <u>BGI Delta Cal DC-1A</u> | Serial No: | <u>158047</u> | Calibration Date: | <u>2/5/2020</u> |
| Leak Check Value: | as found: <u>0.5</u> | | as left: <u>0.5</u> | | |
| Ambient Temperature: | as found: | <u>11.4</u> °C | Ref. Std.: | <u>11.1</u> °C | as left: |
| Barometric Pressure: | as found: | <u>704.5</u> mmHg | Ref. Std.: | <u>704.5</u> mmHg | as left: |
| 16.7 lpm Flow Rate | as found: | <u>16.7</u> lpm | Ref. Std.: | <u>16.74</u> lpm | as left: |
| 14.0 lpm Flow Rate | as found: | <u>14.0</u> lpm | Ref. Std.: | <u>14.04</u> lpm | as left: |
| 17.5 lpm Flow Rate | as found: | <u>17.5</u> lpm | Ref. Std.: | <u>17.57</u> lpm | as left: |

| Mechanical Audits (Y = Yes N = No) | | | | | |
|--------------------------------------|----------|----------|---------|----------|--|
| Sample nozzle clean: | as found | <u>Y</u> | as left | <u>Y</u> | |
| Tape support vane clean: | as found | <u>Y</u> | as left | <u>Y</u> | |
| Tape spool covers tight: | as found | <u>Y</u> | as left | <u>Y</u> | |
| PM10 particle trap clean: | as found | <u>Y</u> | as left | <u>Y</u> | |
| PM10 drip jar empty: | as found | <u>Y</u> | as left | <u>Y</u> | |
| PM10 bug screen clear: | as found | <u>Y</u> | as left | <u>Y</u> | |

| Manual Span Membrane Test | | Pump Test | | |
|-------------------------------------|--------------|-------------|--------------|------------------------|
| Expected Span Mass (mg/cm2): | <u>0.848</u> | Flow Rate | Vacuum | Quality Category |
| Measured Span Mass (mg/cm2): | <u>0.877</u> | 14.0 - 15.0 | Value | Good / Marginal / Poor |
| Difference (mg/cm2): | <u>0.029</u> | (lpm) | (Hg) | |
| % Difference / <u>Pass</u> or Fail: | <u>3.4%</u> | <u>14.3</u> | <u>406.9</u> | <u>Good / Marginal</u> |

| Setup and Calibration Values | | | | | | | | |
|------------------------------|-------------|---------------|------------------|----------|---------------|-----------------|----------|---------------|
| Parameter | Expected | Found | Parameter | Expected | Found | Parameter | Expected | Found |
| Clock | <u>1040</u> | <u>1040</u> | Analog Mode | Hourly | <u>Hourly</u> | Flow Type | Actual | <u>Act</u> |
| Location | <u>2</u> | <u>2</u> | Baud Rate | 9600 | <u>9600</u> | Restart Voltage | 12.5 v | <u>12.5 v</u> |
| Tape Advance | 24 hrs | <u>24 hrs</u> | RH Setpoint | 45% | <u>45%</u> | Std Cond Temp | 25 C | <u>25 C</u> |
| Realtime Avg | 60 mins | <u>60</u> | Delta T Setpoint | 15 C | <u>15 C</u> | DAC | 8.0 v | <u>8.0 v</u> |
| Machine Type | PM-10 | <u>PM-10</u> | RH Control | On | <u>On</u> | RH Connect | No | <u>NO</u> |
| Analog FS | 1.0 v | <u>1.0 v</u> | Flow Setpoint | 16.7 | <u>16.7</u> | Pump Protect | Off | <u>off</u> |

| Last 6 Errors in E-BAM Error Log | | | | | |
|----------------------------------|----------------|-------------|-------|------|------|
| Error | Date | Time | Error | Date | Time |
| <u>1 No New Message</u> | <u>3/18/20</u> | <u>1143</u> | 4 | | |
| 2 | | | 5 | | |
| 3 | | | 6 | | |

Audit Notes:



**Baseline Air Monitoring Program - DOE
E-BAM Monthly Audit and Maintenance**

Station # DOE-3 Serial # 423313
 Audit Date: 3/18/2020 Audited By: T.S. Williford

| Flow Audit | | | | | |
|--------------------------|-----------------------------|-----------------------------|----------------------------|-----------------------------|----------|
| Flow Audit Device Model: | BGI Delta Cal DC-1A | Serial No: | 158047 | Calibration Date: | 2/5/2020 |
| Leak Check Value: | as found: <u>0.6</u> | | as left: <u>0.6</u> | | |
| Ambient Temperature: | as found: <u>13.3</u> °C | Ref. Std. <u>12.7</u> °C | as left: <u>13.3</u> °C | Ref. Std. <u>12.7</u> °C | |
| Barometric Pressure: | as found: <u>706.0</u> mmHg | Ref. Std. <u>706.0</u> mmHg | as left: <u>706.0</u> mmHg | Ref. Std. <u>706.0</u> mmHg | |
| 16.7 lpm Flow Rate | as found: <u>16.7</u> lpm | Ref. Std. <u>16.73</u> lpm | as left: <u>16.7</u> lpm | Ref. Std. <u>16.73</u> lpm | |
| 14.0 lpm Flow Rate | as found: <u>14.0</u> lpm | Ref. Std. <u>14.03</u> lpm | as left: <u>14.0</u> lpm | Ref. Std. <u>14.03</u> lpm | |
| 17.5 lpm Flow Rate | as found: <u>17.5</u> lpm | Ref. Std. <u>17.48</u> lpm | as left: <u>17.5</u> lpm | Ref. Std. <u>17.48</u> lpm | |

| Mechanical Audits (Y = Yes N = No) | | | | | |
|--------------------------------------|----------|----------|---------|----------|--|
| Sample nozzle clean: | as found | <u>Y</u> | as left | <u>Y</u> | |
| Tape support vane clean: | as found | <u>Y</u> | as left | <u>Y</u> | |
| Tape spool covers tight: | as found | <u>Y</u> | as left | <u>Y</u> | |
| PM10 particle trap clean: | as found | <u>Y</u> | as left | <u>Y</u> | |
| PM10 drip jar empty: | as found | <u>Y</u> | as left | <u>Y</u> | |
| PM10 bug screen clear: | as found | <u>Y</u> | as left | <u>Y</u> | |

| Manual Span Membrane Test | Pump Test | | |
|--|-----------------------------------|-------------------------|--|
| Expected Span Mass (mg/cm2) : <u>0.885</u> | Flow Rate 14.0 - 15.0 (lpm) | Vacuum Value (Hg) | Quality Category Good / Marginal / Poor |
| Measured Span Mass (mg/cm2) : <u>0.883</u> | | | |
| Difference (mg/cm2) : <u>0.002</u> | | | |
| % Difference / Pass or Fail: <u>0.23%</u> | <u>14.4</u> | <u>415.7</u> | <u>Marginal</u> |

| Setup and Calibration Values | | | | | | | | |
|------------------------------|-------------|---------------|------------------|----------|---------------|-----------------|----------|--------------|
| Parameter | Expected | Found | Parameter | Expected | Found | Parameter | Expected | Found |
| Clock | <u>1131</u> | <u>1131</u> | Analog Mode | Hourly | <u>Hourly</u> | Flow Type | Actual | <u>Act</u> |
| Location | <u>3</u> | <u>3</u> | Baud Rate | 9600 | <u>9600</u> | Restart Voltage | 12.5 v | <u>12.5v</u> |
| Tape Advance | 24 hrs | <u>24 hr</u> | RH Setpoint | 45% | <u>45%</u> | Std Cond Temp | 25 C | <u>25C</u> |
| Realtime Avg | 60 mins | <u>60 min</u> | Delta T Setpoint | 15 C | <u>15 C</u> | DAC | 8.0 v | <u>8.0v</u> |
| Machine Type | PM-10 | <u>PM-10</u> | RH Control | On | <u>On</u> | RH Connect | No | <u>NO</u> |
| Analog FS | 1.0 v | <u>1.0 v</u> | Flow Setpoint | 16.7 | <u>16.7</u> | Pump Protect | Off | <u>off</u> |

| Last 6 Errors in E-BAM Error Log | | | | | | |
|----------------------------------|----------------|-------------|-------|------|------|--|
| Error | Date | Time | Error | Date | Time | |
| <u>1 No New Messages</u> | <u>3/18/20</u> | <u>1241</u> | 4 | | | |
| <u>2</u> | | | 5 | | | |
| <u>3</u> | | | 6 | | | |

Audit Notes:



Baseline Air Monitoring Program - DOE
E-BAM Monthly Audit and Maintenance

Station # DOE-4 Serial # W23314
 Audit Date: 3/18/2020 Audited By: T.S. Williford

| Flow Audit | | | | | |
|--------------------------|-----------------------------|------------|-------------------|-------------------|-------------------|
| Flow Audit Device Model: | <u>BGI Delta Cal DC-1A</u> | Serial No: | <u>158047</u> | Calibration Date: | <u>2/5/2020</u> |
| Leak Check Value: | as found: <u>0.4</u> | as left: | <u>0.4</u> | | |
| Ambient Temperature: | as found: <u>13.7</u> °C | Ref. Std.: | <u>12.5</u> °C | as left: | <u>13.7</u> °C |
| Barometric Pressure: | as found: <u>699.0</u> mmHg | Ref. Std.: | <u>698.0</u> mmHg | as left: | <u>699.0</u> mmHg |
| 16.7 lpm Flow Rate | as found: <u>16.7</u> lpm | Ref. Std.: | <u>16.79</u> lpm | as left: | <u>16.7</u> lpm |
| 14.0 lpm Flow Rate | as found: <u>14.0</u> lpm | Ref. Std.: | <u>14.03</u> lpm | as left: | <u>14.0</u> lpm |
| 17.5 lpm Flow Rate | as found: <u>17.5</u> lpm | Ref. Std.: | <u>17.58</u> lpm | as left: | <u>17.5</u> lpm |

| Mechanical Audits (Y = Yes N = No) | | | | | |
|--------------------------------------|----------|----------|---------|----------|--|
| Sample nozzle clean: | as found | <u>Y</u> | as left | <u>Y</u> | |
| Tape support vane clean: | as found | <u>Y</u> | as left | <u>Y</u> | |
| Tape spool covers tight: | as found | <u>Y</u> | as left | <u>Y</u> | |
| PM10 particle trap clean: | as found | <u>Y</u> | as left | <u>Y</u> | |
| PM10 drip jar empty: | as found | <u>Y</u> | as left | <u>Y</u> | |
| PM10 bug screen clear: | as found | <u>Y</u> | as left | <u>Y</u> | |

| Manual Span Membrane Test | | Pump Test | | |
|---|--------------|-------------|--------------|------------------------|
| Expected Span Mass (mg/cm ²): | <u>0.919</u> | Flow Rate | Vacuum | Quality Category |
| Measured Span Mass (mg/cm ²): | <u>0.926</u> | 14.0 - 15.0 | Value | Good / Marginal / Poor |
| Difference (mg/cm ²): | <u>0.007</u> | (lpm) | (Hg) | |
| % Difference <u>Pass</u> or Fail: | <u>0.75%</u> | <u>14.8</u> | <u>419.1</u> | <u>Marginal</u> |

| Setup and Calibration Values | | | | | | | | |
|------------------------------|-------------|----------------|------------------|----------|---------------|-----------------|----------|--------------|
| Parameter | Expected | Found | Parameter | Expected | Found | Parameter | Expected | Found |
| Clock | <u>1229</u> | <u>1229</u> | Analog Mode | Hourly | <u>Hourly</u> | Flow Type | Actual | <u>Act</u> |
| Location | <u>4</u> | <u>4</u> | Baud Rate | 9600 | <u>9600</u> | Restart Voltage | 12.5 v | <u>12.5v</u> |
| Tape Advance | 24 hrs | <u>24 hrs</u> | RH Setpoint | 45% | <u>45%</u> | Std Cond Temp | 25 C | <u>25C</u> |
| Realtime Avg | 60 mins | <u>60 mins</u> | Delta T Setpoint | 15 C | <u>15C</u> | DAC | 8.0 v | <u>8.0v</u> |
| Machine Type | PM-10 | <u>PM-10</u> | RH Control | On | <u>on</u> | RH Connect | No | <u>NO</u> |
| Analog FS | 1.0 v | <u>1.0 v</u> | Flow Setpoint | 16.7 | <u>16.7</u> | Pump Protect | Off | <u>off</u> |

| Last 6 Errors in E-BAM Error Log | | | | | |
|----------------------------------|-------------|----------------|-------|------|------|
| Error | Date | Time | Error | Date | Time |
| <u>1 No New Messages</u> | <u>1340</u> | <u>3/18/20</u> | 4 | | |
| <u>2</u> | | | 5 | | |
| <u>3</u> | | | 6 | | |

Audit Notes:
