

Attachment G

MPSC Case No, U-21090, Order approving settlement
(June 23, 2022)

STATE OF MICHIGAN
BEFORE THE MICHIGAN PUBLIC SERVICE COMMISSION

* * * * *

In the matter of the application of CONSUMERS	)	
ENERGY COMPANY for approval of its integrated	)	
resource plan pursuant to MCL 460.6t and for other	)	Case No. U-21090
relief.	)	
_____	)	

At the June 23, 2022 meeting of the Michigan Public Service Commission in Lansing,
Michigan.

PRESENT: Hon. Daniel C. Scripps, Chair
Hon. Tremaine L. Phillips, Commissioner

ORDER APPROVING SETTLEMENT AGREEMENT

I. Procedural History

On June 30, 2021, Consumers Energy Company (Consumers) filed an application, together with supporting testimony and exhibits, pursuant to: (1) Section 6t of Public Act 341 of 2016 (Act 341), MCL 460.6t; (2) the November 21, 2017 order in Case No. U-18418, Exhibit A, which approved the Michigan Integrated Resource Planning Parameters; (3) the December 20, 2017 order in Case Nos. U-15896 *et al.*, Exhibit A, which approved the Integrated Resource Plan (IRP) Filing Requirements; and (4) the February 18, 2021 order in Case Nos. U-20633 *et al.*, which adopted additional modeling scenarios to assist in achieving the objectives of Executive Directive 2020-10 (ED 2020-10) and Governor Gretchen Whitmer’s MI (Michigan) Healthy Climate Plan.

On July 22, 2021, a prehearing conference was held before Administrative Law Judge Sally L. Wallace (ALJ). Intervenor status was granted to the Michigan Environmental Council, Natural

Resources Defense Council, Inc., and Sierra Club (collectively, MNS); the Michigan Department of Attorney General (Attorney General); the Great Lakes Renewable Energy Association, Inc. (GLREA); the Environmental Law and Policy Center of the Midwest, Ecology Center, Inc., Union of Concerned Scientists, Inc., and Vote Solar (collectively, the Clean Energy Organizations (CEOs)); Hemlock Semiconductor Operations LLC (HSC); Cadillac Renewable Energy, LLC, Genesee Power Partner Limited Partnership, Decker Energy-Grayling, Inc., Hillman Power Company, L.L.C., Tondu Corporation, Viking Energy of Lincoln, LLC, and Viking Energy of McBain, LLC, (collectively, the Biomass Merchant Plants (BMPs)); the Association of Businesses Advocating Tariff Equity (ABATE); Energy Michigan; Michigan Energy Innovation Business Council, Institute for Energy Innovation, and Clean Grid Alliance (jointly, EIBC/IEI/CGA); Midland Cogeneration Venture Limited Partnership (MCV); Michigan Electric Transmission Company, LLC (METC); Wolverine Power Supply Cooperative, Inc. (WPSC); Michigan Public Power Agency (MPPA); Residential Customer Group (RCG); Citizens Utility Board of Michigan (CUB); and Urban Core Collective (UCC). Permissive intervention was granted to the Mackinac Center for Public Policy (Mackinac). Consumers and the Commission Staff (Staff) also participated in the proceeding.

The ALJ issued a Proposal for Decision (PFD) on March 7, 2022. On or before March 21, 2022, exceptions were filed by Consumers, HSC, the Attorney General, the Staff, MNS, the CEOs, GLREA, Mackinac, ABATE, the BMPs, UCC, EIBC/IEI/CGA, and WPSC. On March 28, 2022, replies to exceptions were filed by Consumers, Energy Michigan, HSC, the Attorney General, the Staff, MNS, the CEOs, GLREA, ABATE, the BMPs, UCC, EIBC/IEI/CGA, and WPSC.

On April 20, 2022, Consumers entered into a settlement agreement with the following parties: the Staff, MNS, the Attorney General, the CEOs, UCC, CUB, HSC, EIBC/IEI/CGA, METC, and

GLREA. The settlement agreement recommends approval of Consumers' proposed course of action (PCA) with changes and covers issues such as: the acquisition of new resources; investments in demand response (DR), conservation voltage reduction (CVR), and energy waste reduction (EWR); deployment of energy storage; retirement of certain coal-fired generation units and associated decommissioning costs; a financial compensation mechanism (FCM); avoided cost methodology under the Public Utility Regulatory Policies Act of 1978 (PURPA); and implementation of competitive bidding. MPPA, MCV, RCG, and ABATE did not join the settlement, but offered statements of non-objection.

On April 20, 2022, Consumers and the Staff jointly filed a motion to extend the statutory deadline found in Section 6t(7) of Act 341, MCL 460.6t(7). In its April 25, 2022 order in the present case (April 25 order), the Commission granted the joint motion and extended the deadlines for the Commission's 300-day and 360-day orders. In addition, the Commission set a tentative schedule for the remainder of this proceeding. *See*, April 25 order, p. 5.

On May 4, 2022, Energy Michigan, Mackinac, WPSC, and the BMPs filed responses objecting to the settlement agreement. MNS, the CEOs, Energy Michigan, the Staff, the BMPs, and WPSC filed direct testimony in the contested settlement phase of this proceeding on May 9, 2022. MNS, the Staff, EIBC/IEI/CGA, WPSC, the BMPs, Consumers, and the CEOs filed rebuttal testimony on May 13, 2022. Initial briefs on the contested settlement were filed by MNS, Mackinac, EIBC/IEI/CGA, the Attorney General, the CEOs, HSC, the Staff, Consumers, CUB, the BMPs, and WPSC on May 25, 2022, and reply briefs were filed by MNS, the Staff, the CEOs, Consumers, WPSC, and the BMPs on May 27, 2022. UCC filed a letter in support of the settlement agreement on May 25, 2022. The evidentiary record in this contested settlement proceeding consists of 315 pages of transcript and 22 exhibits, all of which appear in Volume 10

of the transcript. Unless otherwise noted, all citations to briefing in this order refer to the briefing in the contested settlement phase of this case and not the contested IRP phase.

II. Applicable Law

Act 341 requires the Commission to approve an IRP if the proposed IRP “represents the most reasonable and prudent means of meeting the electric utility’s energy and capacity needs” based on whether the proposed plan: (1) appropriately balances a series of statutorily listed factors; (2) uses a workforce comprised of residents of this state to the extent practicable in the completion of construction or investment in new or existing capacity resources; and (3) meets the requirements of subsection 6t(5) of Act 341, which enumerates the information to be included in an IRP. MCL 460.6t(8).

In addition, Rule 431 of the Michigan Administrative Code, Mich Admin Code, R 792.10431, governs proceedings before the Commission where a settlement is filed. Pursuant to Rule 431(5)(a)-(c), the Commission may approve a contested settlement agreement when the Commission determines the following conditions are met: (1) objecting parties have been given a reasonable opportunity to present evidence and arguments in opposition to the settlement agreement, (2) the public interest is adequately represented by the parties who entered into the settlement agreement, and (3) the settlement agreement is in the public interest, represents a fair and reasonable resolution of the proceeding, and is supported by substantial evidence on the record as a whole.

III. Proposed Settlement Agreement

Under the terms of the settlement agreement, the parties to the settlement (settlement parties) agree that Consumers’ PCA, as modified, should be approved by the Commission as the most reasonable and prudent means of meeting the company’s energy and capacity needs for the 5-year,

10-year, and 15-year time horizons as required by Sections 6t(3) and 6t(8)(a) of Act 341, MCL 460.6t. Settlement Agreement, p. 3. The settlement parties agree that Consumers will file its next IRP consistent with the requirements of Section 6t. *Id.* The settlement agreement, attached to this order as Exhibit A, contains the following provisions relevant to the arguments in the contested settlement proceeding:

The settlement agreement provides that Consumers' PCA shall include the proposed purchase of the New Covert Generating Facility (Covert plant) in 2023 but shall not include the ownership of the Dearborn Industrial Generation Plant (DIG), the Livingston Generating Station (Livingston), and the Kalamazoo River Generating Station (Kalamazoo) (collectively, CMS plants). Settlement Agreement, pp. 2-3. The parties agree that the identified capital costs that Consumers will incur for DR, CVR, and the purchase of the Covert plant in the next three years are reasonable and prudent, should be approved for cost recovery purposes, and will be included in Consumers next electric rate case, consistent with Sections (11) and (17) of Act 341, MCL 460.6t(11),(17). *Id.*, p. 4. The parties agree to the projected capacity values provided by the Covert plant, and DR, CVR, and EWR resources in the next three years. *Id.*

The settlement provides for the approval of a battery deployment program as proposed in rebuttal testimony of company witness Blumenstock in the principal case. *Id.*; *see also*, 3 Tr 185, 203-205.

The settlement agreement provides that D.E. Karn (Karn) Units 3 and 4 will be retired on or before May 31, 2031, and J.H. Campbell (Campbell) Units 1, 2, and 3 will be retired on or before May 31, 2025. Settlement Agreement, pp. 4-5.

The settlement agreement provides that Consumers shall issue a one-time competitive solicitation following the approval of the settlement agreement that includes the following parameters:

a. The One-Time Solicitation will seek projects which will provide the Company with capacity credit in the MISO [Midcontinent Independent System Operator, Inc.] Zone 7 starting in the 2025 Planning Year;

b. The One-Time Solicitation will include two all source tranches:

i. The first tranche will seek up to 500 ZRCs [zonal resource credits] of capacity and associated energy and renewable energy credits ("RECs"), if applicable, from PPAs [power purchase agreements] with terms up to 10 years. This tranche will seek dispatchable, nonintermittent generation capable of dispatching up or down in every hour of the year in response to wholesale energy market signals, providing capacity which meets the Local Clearing Requirement of MISO Zone 7; and

ii. The second tranche will seek up to 200 ZRCs of capacity and associated energy and RECs, if applicable, secured from unaffiliated third parties via PPAs or other third-party agreements that do not result in Company ownership with terms up to 25 years, at the discretion of the bidder. This tranche will seek intermittent resources and dispatchable, nonintermittent clean capacity resources (including battery storage resources), providing capacity which meets the Local Clearing Requirement of MISO Zone 7. This tranche will furthermore take into consideration the ability of the offered capacity to meet the Local Clearing Requirement of MISO Zone 7 for the duration of the contract length. Prior to the issuance of the second tranche portion of the OneTime Solicitation, the Company shall hold a stakeholder meeting including parties to this case and energy storage developers to discuss methods to improve RFPs [requests for proposals] and response to solicitations with respect to stand-alone storage projects and hybrid-storage projects.

c. The Company's acquisition of the 700 ZRCs and associated energy and RECs, if applicable, sought in the One-Time Solicitation shall be considered incorporated into the PCA approved in Paragraph 1 of this Settlement Agreement. However, the actual selected bid(s) will be submitted in Case No. U-21090 for Commission approval subsequent to the completion of the OneTime Solicitation;

i. In that approval proceeding, the Commission shall: (i) confirm whether the solicitation process followed by the Company is consistent with the requirements of the Settlement Agreement; (ii) grant approval of the recovery of the costs associated with the selected project(s) pursuant to applicable law or make a preliminary finding that the costs associated 7 with the project(s) that

prevail in the solicitation are reasonable and prudent; and (iii) grant any other approvals or findings necessary as required or provided by applicable law.

d. The One-Time Solicitation will not be used to set the Company's avoided costs rates or capacity needs under PURPA.

Id., pp. 6-7.

The settlement agreement provides for an extension of the annual competitive bidding process used to acquire supply-side resource technologies as approved in the settlement agreement in Case No. U-20165 with modifications. *Id.*, pp. 7-9.

The settlement agreement provides that Consumers “will donate \$5 million in 2022 to a low-income fund that provides bill assistance to Consumers Energy’s electric customers.” *Id.*, p. 11. The settlement agreement also provides that Consumers will donate \$2 million annually to the same fund during the amortization period for the regulatory asset created to recover the unrecovered book balance of Campbell Units 1, 2, and 3. *Id.* These donations will not be recovered in rates. *Id.*, p. 12.

The settlement agreement provides that in future IRPs, Consumers will: “(i) collect the necessary data to compute marginal line losses and report these with average line losses and (ii) include marginal line losses and avoided transmission and distribution costs in its evaluation of all distributed resources, including residential DR potential.” *Id.*

The settlement agreement provides that Consumers will “develop a distributed generation as a resource model approach that considers economic distribution connected solar to be modeled by bundling resources installed at the customer level to compare the total economic costs to the utility of distributed generation as a resource to other selectable supply-side resources” *Id.* The settlement also provides that in its next IRP, Consumers will “consider transmission and how it can facilitate the mitigation of reliability and economic impacts to the electric system.” *Id.*, p. 13.

The settlement agreement provides that Consumers’ next IRP will include further analyses on environmental emissions, health impacts from emissions, and environmental justice. The settlement agreement also provides that Consumers will “take . . . steps to engage and gather input from the public prior to the filing of its next IRP with the Commission” *Id.*, pp. 13-14.

IV. Evidentiary Record

Because the Commission has decided to read the record for purposes of evaluating the settlement agreement, a summary of the evidentiary record related to the settlement agreement follows.¹

A. Direct Testimony

1. Michigan Environmental Council, Natural Resources Defense Council, Inc., Sierra Club, and Citizens Utility Board of Michigan

MNS and CUB presented the direct testimony of Douglas B. Jester. Mr. Jester testifies that the settlement agreement is in the public interest and recommends that the Commission approve the settlement agreement. Mr. Jester opines that “retiring the entire Campbell plant will benefit both customers and the environment and is therefore in the public interest.” 10 Tr 4327.

Mr. Jester notes that no party in this case opposed the retirement of Campbell Units 1 and 2 and adds that the ALJ also recommended approval of these retirements. Mr. Jester posits that “[t]he Campbell plant has a greater carbon impact than any other resource owned by [Consumers], and its retirement is critical to meeting state and federal climate goals, including the Michigan Healthy Climate Plan.” 10 Tr 4327 (footnote omitted). Mr. Jester presents tables compiling Michigan’s greenhouse gas emissions and the associated goals from the MI Healthy Climate Plan to

¹ The Commission notes that, in the original IRP proceeding that resulted in a PFD, the evidentiary record included 4,094 pages of transcript across nine volumes and over 500 exhibits with certain transcript pages and exhibits designated as confidential. PFD, p. 3. The Commission references this evidence throughout this order.

demonstrate that it is “not possible to meet the 2025 goal of the Michigan Healthy Climate Plan without the retirement of the Campbell plant by 2025[.]” adding that, “the Michigan Healthy Climate Plan calls for the retirement of all coal generation by 2030, which would necessarily include the Campbell units.” 10 Tr 4330.

Mr. Jester adds that because the Campbell plant emits other pollutants, such as sulfur dioxide (SO₂), nitrogen oxide (NO_x), and particulate matter (PM_{2.5}), the retirement of the entire Campbell plant is likely to have health benefits beyond those of reducing the company’s carbon output. 10 Tr 4327.

In addition to the environmental and health benefits outlined above, Mr. Jester testifies that “[e]xtensive modeling conducted by Consumers and by MNS in this case demonstrated that retiring Campbell in 2025 is economic for customers.” 10 Tr 4327.

Mr. Jester provides that “paragraph 1 of the [settlement] agreement approves Consumers’ continued ramp-up of solar resources—an initiative first approved as part of Consumers’ 2018 IRP.” 10 Tr 4330. Additionally, Mr. Jester provides that:

In the 2018 case, the Commission approved a plan that included approximately 5 GW [gigawatts] nameplate [capacity] of new solar resources in the 2020s. In this case, Consumers proposed to continue those additions and also procure an additional 2 GW of solar in the 2030s above the levels included in the 2018 IRP. Paragraph 8 of the settlement agreement provides that Consumers will continue to utilize annual competitive solicitations to procure these solar resources.

10 Tr 4330. Mr. Jester posits that the Consumers’ proposed procurement is a reasonable and beneficial settlement term. 10 Tr 4330. Mr. Jester notes that the benefits the Commission recognized in 2018 IRP, such as the environmental benefits of additional renewable energy resources and the use of annual solicitations to promote competitive pricing, will continue with the new settlement agreement. 10 Tr 4331.

With respect to the proposed gas plant acquisitions, Mr. Jester opines that the settlement agreement terms regarding the acquisition of the Covert gas plant are reasonable and prudent. 10 Tr 4331. Mr. Jester provides that these terms include the approval of the acquisition of Covert and the recovery of the associated \$815 million purchase cost. The parties also agreed that Consumers would not obtain the CMS plants from its affiliate, CMS Enterprises Company (CMS Enterprises). 10 Tr 4331.

Mr. Jester notes that no party opposed the acquisition of the Covert plant and the ALJ recommended the Commission approve the acquisition. 10 Tr 4331. Mr. Jester posits that both the Staff and Consumers testified in the primary proceeding that “because Covert is currently in PJM [PJM Interconnection, L.L.C.’s American Electric Power (AEP) Zone], Consumers’ acquisition of Covert will add 1,114 Zonal Resource Credits or ZRCs to MISO Zone 7.” 10 Tr 4331. Mr. Jester adds that the addition of these ZRCs to Zone 7 “will support reliability for Consumers as well as overall resource adequacy for Zone 7.” 10 Tr 4331. Mr. Jester concludes that “[f]or these reasons, acquisition of Covert is both in the public interest from a reliability and resource adequacy standpoint” and is supported by the record in this case. 10 Tr 4331.

Mr. Jester asserts that Consumers’ agreement not to acquire the CMS plants is also in the public interest. Mr. Jester posits that the record demonstrated numerous concerns with acquisition of these plants from CMS Enterprises including, “issues with respect to affiliate transactions” and “the nature of the gas plant RFP solicitation that led to the proposed purchase of these plants” 10 Tr 4331-4332. Finally, Mr. Jester notes that the ALJ and the Staff also recommended the Commission deny the acquisition of the affiliate plants from CMS Enterprises. 10 Tr 4332.

Mr. Jester supports the proposed one-time solicitation of capacity and energy for the 2025 planning year (PY). Mr. Jester outlines the terms of the one-time solicitation as follows:

In paragraph 6 of the settlement [agreement], the parties agree that Consumers will issue a one-time competitive solicitation for PPAs to begin in PY 2025. The solicitation will contain two tranches. The first tranche will seek up to 500 ZRCs of energy and capacity for up to 10 years from dispatchable, non-intermittent generation. The second tranche will seek up to 200 ZRCs of energy and capacity for up to 25 years from clean energy resources (including battery storage).

10 Tr 4333. Mr. Jester posits that “[t]he first tranche will provide energy and capacity of similar characteristics to what Consumers sought via the proposal to acquire the CMS plants[.]” adding that “soliciting 10-year PPAs instead of acquiring affiliate assets planned to remain in rate base until 2040 will reduce risks to customers.” 10 Tr 4333. Mr. Jester also notes that a solicitation for PPAs addresses some of the issues identified with the earlier RFP by parties and the ALJ’s decision, which include that the earlier RFP only sought assets for purchase, and risks related to environmental permitting and fixed operating and maintenance expenses. 10 Tr 4333. Mr. Jester testifies that the second tranche is also in the public interest as it will “provide additional clean energy resources for Consumers’ portfolio” 10 Tr 4334.

Mr. Jester provides that “[p]aragraph 4(i) of the settlement [agreement] provides that Karn units 3-4 will not retire in 2023 but instead will continue operating and retire on or before their previously planned retirement date of May 31, 2031, absent extraordinary circumstances.”

10 Tr 4334. Mr. Jester posits that Karn Units 3 and 4 “provide substantial capacity but operate infrequently.” 10 Tr 4334. Mr. Jester testifies that “[c]ontinuing to operate Karn 3-4 supports Consumers’ attainment of planning reserve margin requirements [PRMR] by maintaining more than 780 ZRCs in the Company’s portfolio.” 10 Tr 4334. Further, Mr. Jester notes that Karn Units 3 and 4 staying online supports resource adequacy in MISO Zone 7 by maintaining these additional ZRCs. Mr. Jester testifies that keeping Karn Units 3 and 4 in operation removes the “unrecovered net book value from the total balance of the regulatory asset that Consumers seeks . . . lowering the costs of the regulatory asset for customers.” 10 Tr 4334-4335.

Mr. Jester supports the regulatory asset provisions of the settlement agreement mentioned above. Mr. Jester provides that “[i]n paragraph 5 of the settlement, the parties agree that after retirement of the Campbell plan in 2025, the return on equity used to calculate the WACC [weighted average cost of capital] for the regulatory asset will be 9.0%.” 10 Tr 4335. Mr. Jester posits that:

Consumers has taken a very firm position that it will not retire Campbell in 2025 without being able to recover a return of and on the unrecovered balance. Therefore, it was necessary for the other parties to agree with a regulatory asset based on WACC for this settlement [agreement] to occur and to facilitate Consumers’ permanent exit from coal generation three years from now.

10 Tr 4335. Mr. Jester notes, however, that “setting the ROE [return on equity] at 9.0% for the calculation of the WACC on the regulatory asset is a significant compromise for Consumers, as that figure is substantially lower than the authorized ROE of 9.9% that the Commission approved in Consumers Energy’s last electric rate case, [Case No.] U-20963.” 10 Tr 4335.

Mr. Jester posits that Consumers’ low-income customer bill assistance donations are a beneficial settlement term. Mr. Jester provides that “Consumers agreed in paragraph 13 of the settlement [agreement] to donate funds to its low-income bill assistance programs.” 10 Tr 4336. Mr. Jester notes that these funds will not be recovered in rates. Specifically, “Consumers will donate \$5 million in 2022 and \$2 million per year for the rest of the term of the regulatory asset for the Campbell plant.” 10 Tr 4336. Mr. Jester asserts that “[t]he need for additional low-income customer bill assistance has been demonstrated both in recent Consumers electric rate cases and in recent Consumers EWR cases, and recognized by the Commission in a variety of orders.” 10 Tr 4336 (footnote omitted).

Mr. Jester provides that “[p]aragraph 9 of the settlement [agreement] requires Consumers to use commercially reasonable efforts to maintain the 50/50 split between owned resources and

PPAs for new solar procurements” that was first approved in the settlement agreement in Case No. U-20165. 10 Tr 4336. Mr. Jester also notes that paragraph 9 “creates an absolute cap of 60% on capacity that Consumers acquires for ownership in any annual solicitation, while setting no cap on the amount of new solar the Company may acquire via PPA” and “maintains the bar on Consumers affiliates participating in the PPA portion of the solicitations.” 10 Tr 4337. Mr. Jester opines that “[t]he Commission found this allocation reasonable and in the public interest” in Consumers last IRP and that “this term maintains the essential components of that agreement.” 10 Tr 4337. Mr. Jester posits that making a commercially reasonable efforts to maintain the 50/50 split “promotes competition among third-party developers which reduces customer costs” and “helps support the solar industry in Michigan.” 10 Tr 4337. Mr. Jester notes that this provision of the settlement agreement is consistent with the ALJ’s recommendations on the issue. 10 Tr 4337.

Mr. Jester testifies that paragraph 10 of the settlement agreement provides for an extension of the FCM approved in Case No. U-21065, Consumers’ 2018 IRP. 10 Tr 4337. Mr. Jester opines that “[a]n FCM is a reasonable incentive for the Commission to authorize” given that “Consumers has substantially changed its business model by agreeing to shift its resource portfolio away from coal generation and toward solar generation, and by agreeing to procure the solar generation via competitive solicitations under which half of that capacity will be in the form of PPAs.”

10 Tr 4338.

Mr. Jester provides that paragraph 16 of the settlement agreement “states that the parties agree in Consumers’ next IRP to consider how transmission investments can improve reliability and access to economic sources of power from areas outside Zone 7.” 10 Tr 4338. Mr. Jester supports the transmission provision as a reasonable and beneficial settlement term and notes that the ALJ’s

decision “found that Consumers’ transmission analysis in this case was deficient and did not meet the terms of the settlement agreement in [Case No.] U-21065.” 10 Tr 4338-4339.

Mr. Jester supports the proposed battery storage investments outlined in the settlement agreement. Mr. Jester provides that the “parties agree to approval of a battery deployment program in paragraph 3 of the settlement agreement” as proposed in the principal rebuttal testimony in this case. 10 Tr 4339. Mr. Jester outlines that “Consumers proposed . . . to advance investment in 75 MW [megawatts] of battery storage resources. The settlement [agreement] reserves approval of the costs of the program to future electric rate cases.” 10 Tr 4339. Mr. Jester posits that Consumers made the battery proposal in response to testimony from the Staff, MNS, and other parties that “called for acceleration of battery storage investments as part of Consumers’ resource portfolio for this IRP.” 10 Tr 4339. Mr. Jester notes that “battery deployment will provide another clean energy resource to bolster Consumers’ maintenance of its PRMR and support resource adequacy in Zone 7.” 10 Tr 4339.

Mr. Jester provides that in paragraph 14 of the settlement agreement, Consumers agrees “to collect further data on marginal line losses and to include marginal line losses and avoided transmission and distribution (T&D) costs in the evaluation of all distributed resources, including residential demand response, for its next IRP.” 10 Tr 4340. Mr. Jester defers to testimony of CUB witness David Gard and MNS witness Chris Neme in explaining “the importance of these issues to the evaluation of EWR potential and DR potential for future IRPs.” 10 Tr 4340.

Mr. Jester notes that paragraphs 17 and 18 of the settlement agreement contain provisions regarding an environmental justice analysis and community outreach for Consumers’ next IRP. Mr. Jester supports these settlement terms and posits that “[t]he environmental justice analysis will provide vital information regarding the people and communities who bear disproportionate

impacts of electric generation activities—information that has been lacking in Michigan IRP cases up until now.” 10 Tr 4341.

Finally, Mr. Jester provides that “[p]aragraph 7 of the settlement agreement requires Consumers to publicly file its community transition plans for the Campbell and Karn sites.” 10 Tr 4341. Mr. Jester defers to testimony of MNS witness Tyler Comings regarding the need for public filing of transition plans. 10 Tr 4341.

Mr. Jester concludes that “[t]he settlement agreement in this case continues and significantly extends the progress of the settlement [agreement] in [Case No.] U-20165.” 10 Tr 4341.

Mr. Jester posits that the settlement agreement is “supported by the great weight of evidence in the record of this case and consistent with many of the findings and recommendations in the PFD.”

10 Tr 4342. Thus, Mr. Jester recommends the Commission approve the proposed settlement agreement.

2. Environmental Law and Policy Center of the Midwest, Ecology Center, Inc., Union of Concerned Scientists, Inc., and Vote Solar

The CEOs presented the direct testimony of James Gignac, Senior Midwest Energy Analyst employed by the Union of Concerned Scientists. Mr. Gignac posits that the proposed settlement supports the public interest. Mr. Gignac posits that the settlement agreement “supports the public interest in three main ways: (1) it aligns with important climate action goals intended to protect Michiganders; (2) it improves economic and public health outcomes; and (3) it includes beneficial modeling and community engagement commitments for the Company’s next IRP.” 10 Tr 4375.

Mr. Gignac avers that “Consumers approach of retiring all its coal-fired power plants by 2025 aligns with Governor Whitmer’s MI Healthy Climate Plan’s goal to phase out Michigan’s remaining coal plants by 2030” and “the Company’s plans to add 8,000 megawatts of solar by

2040 is an important step toward the MI Healthy Climate Plan’s target for renewable energy to be providing 60 percent of Michigan’s electricity generation by 2030.” 10 Tr 4375.

Mr. Gignac posits that “the proposed settlement [agreement] helps reduce financial and public health costs related to Consumers’ resource plan” because “the Company has agreed to a lower rate of return for its retiring coal plants and will commit tens of millions of dollars of shareholder funds to support bill assistance for lower-income customers.” 10 Tr 4376. Mr. Gignac opines that expert testimony in this case “demonstrated the benefits of earlier coal plant retirements in the form of avoided negative health outcomes.” 10 Tr 4376.

Finally, Mr. Gignac argues that commitments made by Consumers for its future IRPs “will ensure that additional information and perspectives are available to inform both the Company’s assessment of its future resource options as well as Commission and stakeholder review of its proposals.” 10 Tr 4376-4377. Mr. Gignac includes the agreement to model distributed generation as a resource, to conduct public health and environmental justice analyses, and to expand opportunities and forums for community input among the beneficial modeling and community engagement commitments made by Consumers. 10 Tr 4376-4377.

For the reasons outlined above, Mr. Gignac concludes that the Commission should approve the settlement agreement as it “represents a reasonable resolution of the issues” 10 Tr 4377.

3. Energy Michigan

Energy Michigan presented the direct testimony of Alexander J. Zakem. Mr. Zakem testifies that in the contested settlement agreement, Consumers fails to address the impacts the PCA will have on resource adequacy and the competitive market. Mr. Zakem explains that the settlement agreement does not require that the 500 ZRC capacity need that Consumers is seeking to fill through the one-time solicitation agreed to under subsection 6.b.i of the settlement agreement “be

additional to what is already being counted toward MISO Zone 7's resource adequacy requirements." 10 Tr 4297. Mr. Zakem opines that because the settlement agreement does not require that the capacity being added by Consumers be additional to that already available in Zone 7, the settlement agreement is subject to concerns about "insufficient resources in the zone for a competitive pricing market." 10 Tr 4298. Mr. Zakem therefore recommends the Commission "examine the [s]ettlement [agreement] carefully and review its effects on resource adequacy and competitive pricing in Zone 7" and if the Commission finds that the settlement agreement "fails to adequately address resource adequacy or anti-competitive concerns, then the Commission should reject the [s]ettlement [agreement]." 10 Tr 4298.

4. The Commission Staff

In the Staff's direct testimony, Paul Proudfoot, the Director of the Energy Resources Division, asserts that Consumers' PCA, as modified by the settlement agreement, meets the statutory requirements of Section 6t(8) of Act 341, MCL 460.6t(8). 10 Tr 4400. For this reason, Mr. Proudfoot recommends the Commission approve the contested settlement agreement in its entirety without recommending changes under Section 6t(7). 10 Tr 4400. Mr. Proudfoot also states that the contested settlement agreement meets the requirements of Rule 431. 10 Tr 4400.

5. Biomass Merchant Plants

The BMPs presented the direct testimony of Richard A. Polich, a Managing Director with GDS Associates, Inc. Mr. Polich testifies that the continued operation of the biomass plants can offset some deficiencies he posits are present in the proposed contested settlement agreement.

Mr. Polich opines that the settlement inconsistently results in Consumers having excess generation capacity in some years and capacity shortages in other years, which he argues is contrary to IRP best practices. Mr. Polich explains:

The settlement [agreement] includes procurement of the Covert Generation Facility (Covert) in 2023 which results in Consumers' having 20.1% excess capacity. It then adds 700 MW (ZRC) of generation resources in 2025 that is procured through a competitive solicitation that is deeply flawed. Although Consumers retires 1,344 MW (ZRC) of generation in 2025, the [s]ettlement [agreement] would result in 16.2% excess generation in 2025 and an average of 18.7% excess generation over the next six years, assuming solar generation continues to be accredited at 50% of real capacity by MISO.

10 Tr 4277. Further, Mr. Polich adds that “[t]he addition of Covert in 2023 means Consumers’ rate payers will be paying 2 years of unnecessary costs for Covert capacity that is unnecessary.”

10 Tr 4277. Mr. Polich likens the biomass plants to solar generation as they are net zero carbon generation and to natural gas plants as they are baseload generation. Mr. Polich concludes that:

If it is reasonable and prudent for Consumers to acquire both fossil and renewable capacity from 2023 through 2030 that results in excess capacity for the period of 2023-2030, the prudent course of action is for Consumers to continue to purchase capacity and energy from the Biomass Plants after the expiration of their current contracts through at least 2035 when Consumers is likely to be capacity deficient.

10 Tr 4278.

Mr. Polich argues that the one-time solicitation outlined in section 6 of the settlement agreement is “deeply flawed.” 10 Tr 4278. Mr. Polich posits that the timing of the competitive solicitation is flawed as “Consumers is proposing to start the procurement process so the capacity of both tranches will provide capacity in 2025.” 10 Tr 4278. Mr. Polich opines that:

The timing of the procurement process will not result in new capacity being added to the Michigan market and will likely favor existing generation facilities such as the Kalamazoo Plant, Livingston Plant and Dearborn Industrial Generation because it will be impossible for new generation to obtain a MISO Interconnection Services Agreement, complete project engineering, obtain financing and construct the plant by 2025.

10 Tr 4279. Mr. Polich concludes that, given the timeline to obtain a MISO interconnection agreement, complete project engineering, and obtain financing, “it is very unlikely that there will be sufficient time to complete a power generation project for operation in 2025.” 10 Tr 4279.

Mr. Polich also argues that “MISO Zone 7 is projected to be short 397.4 MW (ZRC) in 2023.” 10 Tr 4279. Mr. Polich notes that “MISO’s recent [sic] completed 2022/2023 Planning Resource Auction (PRA) resulted in capacity shortages in all northern MISO regions due to planned retirements of fossil generation resources The PRA resulted in capacity costs of \$236.66/MW-day in MISO Zone 7, which is equal to the cost of new entry [CONE] or cost of adding new gas fired generation.” 10 Tr 4279. Mr. Polich posits that this “shows the volatility of the MISO planning process to which Consumers and its customers will be subject.” 10 Tr 4279.

Mr. Polich posits that the one-time solicitation outlined in the settlement agreement “results in a preference for non-intermittent fossil generation . . .” 10 Tr 4280. As outlined in the settlement agreement, the one-time solicitation seeks projects that will provide the company with capacity in MISO Zone 7 starting in the 2025 planning year. The settlement agreement also states that the first tranche will seek “dispatchable, non-intermittent generation capable of dispatching up or down in every hour of the year in response to wholesale energy market signals, providing capacity which meets the Local Clearing Requirement of MISO Zone 7.” Settlement Agreement, p. 6. Mr. Polich argues that these requirements preclude the participation of the BMPs as they will still be under contract in 2025 and can be dispatched on 24 hours-notice, as opposed to hourly. 10 Tr 4280. Mr. Polich further asserts that “only generation resources which are currently operating, not under contract with Consumers, have obtained MISO interconnection approval, and completed primary engineering are likely to be able to bid into the One-Time Solicitation.” 10 Tr 4280.

Mr. Polich takes issue with the language in the settlement agreement describing the second tranche of the one-time solicitation that states, “[t]his tranche will seek intermittent resources and dispatchable, nonintermittent clean capacity resources.” 10 Tr 4280 (quoting Settlement

Agreement, p. 6). Mr. Polich posits that “[t]he term ‘clean capacity resources’ is an undefined term and can mean any generation resource that is cleaner than [sic] Consumers existing generation resources. Thus, natural gas plants could offer proposals into the second tranche because the language is very ambiguous.” 10 Tr 4280.

Mr. Polich opines that “the One-Time Solicitation will likely result in Consumers acquiring [a] substantial amount of natural gas capacity in addition to the Covert capacity.” 10 Tr 4281. Mr. Polich argues that an increase in the average price of natural gas over the last two years “clearly demonstrates the volatility of natural gas pricing and highlights the risk of becoming totally dependent on such a single, volatile fuel source.” 10 Tr 4281.

Mr. Polich also posits that the one-time solicitation in the second tranche of the settlement agreement “will likely result in the acquisition of only intermittent generation because solar generation with battery storage will likely be too expensive to compete with solar generation without battery storage and due to shortages of materials[,]” specifically lithium carbonate. 10 Tr 4281.

Mr. Polich opines that if MISO changes the solar ZRC accreditation from its current 50% accreditation to a 30% accreditation, Consumers will face a capacity shortfall in 2031 due to closing of Karn Units 3 and 4 and the expiration of Consumers contract with Midland Cogeneration Venture. 10 Tr 4282.

Mr. Polich avers that the settlement agreement does not meet the stated goals of paragraph 16 “to be Carbon Neutral by 2040[,]” as the Covert plant and 200 MW of generation from PPAs originating under the one-time solicitation “are fossil fuel generation resources and are not carbon neutral.” 10 Tr 4283.

In conclusion, Mr. Polich requests, on behalf of the BMPs that “the Commission approve the Settlement Agreement only if it is amended to include a provision whereby Consumers Energy continues to purchase capacity and energy from the Biomass Plants” through amended PPAs. 10 Tr 4286.

6. Wolverine Power Supply Cooperative

WPSC presented the direct testimony of Thomas King, Jr. Mr. King argues that “Consumers Energy’s and Michigan’s reliability and resource adequacy situation is no better (and arguably, worse) under the proposed Settlement Agreement than in the originally filed IRP.” 10 Tr 4301. Mr. King posits that “the changes reflected in the proposed Settlement Agreement continue to assume capacity replacements that add no incremental capacity to MISO Zone 7.” 10 Tr 4302. Mr. King provides MISO’s 2022 PRA results as exhibit WPSC-6. Mr. King argues that this exhibit demonstrates why MISO’s North and Central Zones cleared at CONE in 2022. Mr. King quotes MISO as stating “that previous projections of surplus were ‘eroded by an increased load forecast, less capacity entering the auction as result of retirements, and the decreased accredited capacity of new resources.’” 10 Tr 4303 (quoting Exhibit WPSC-6, slide 2)(emphasis omitted). Mr. King posits that “[w]hen load growth is under-forecasted, dispatchable resources are retired too quickly, and intermittent resources are over-accredited, reliability is at risk.” 10 Tr 4303. Mr. King further quotes the MISO 2022 PRA results as stating that “[u]nless more capacity is built that can supply reliable generation, shortfalls such as those highlighted in this year’s auction will continue.” 10 Tr 4303 (quoting Exhibit WPSC-6, slide 9).

Mr. King further avers that under the settlement agreement, Consumers’ plan is “based almost entirely on a 700 MW speculative solicitation of both dispatchable and intermittent resources that

likely cannot be built in time and, therefore, is likely to result in the purchase from the affiliated plants because they will be the only dispatchable resources in Zone 7” 10 Tr 4302-4303.

Finally, Mr. King argues that “when Consumers’ PCA and proposed Settlement Agreement assumptions are updated to reflect more current data from Consumers’ own capacity demonstration filing in Case No. U-21099 and more reasonable assumptions, Consumers will likely be capacity negative in 2025[,]” meaning it will be “unlikely to serve its own load with its own resources in 2025.” 10 Tr 4303-4304. Mr. King posits that the assumptions Consumers used in its capacity demonstration are unreasonable. Specifically, Mr. King states that it is unreasonable for Consumers to assume a declining PRMR in its PCA and capacity demonstration as “it conflicts with MISO’s statements of increasing load forecasts (see Exhibit WPSC-6), Wolverine’s own growth, and publicly disclosed growth in Michigan.” 10 Tr 4305. Similar to the BMPs, Mr. King avers that “MISO is considering changes to solar capacity accreditation to move from a static solar accreditation value to an Effective Load Carrying Capability (ELCC) approach, similar to what is used for wind.” 10 Tr 4306-4307. Mr. King also outlines similar concerns regarding supply chain challenges causing disruptions to solar project developments. Specifically, Mr. King opines that “disruptions in the solar industry due to the United States Department of Commerce [DOC] investigation into Chinese solar tariff avoidance, are likely to result in project development delays.” 10 Tr 4307.

Mr. King concludes that the Commission “should reject this settlement [agreement]” and “adjust the timeline for retirement of Campbell 3 in a way that reasonably ensures replacement is possible—not only for the joint owners of Campbell 3, but for all LSEs [load serving entities] who rely on the grid to ensure their own reliability” 10 Tr 4309.

B. Rebuttal Testimony

1. Michigan Environmental Council, Natural Resources Defense Council, Inc., Sierra Club, and Citizens Utility Board of Michigan

Mr. Jester, on behalf of MNS and CUB, responds to the direct settlement testimony of WPSC, Energy Michigan, and the BMPs. Mr. Jester focused his rebuttal testimony on “the objecting parties’ claims regarding resource adequacy, the procurement of new clean energy resources by 2025, and MISO capacity credit for solar resources.” 10 Tr 4346.

Mr. Jester responds to claims by WPSC and Energy Michigan that the settlement agreement would worsen the resource adequacy measures in Zone 7 by arguing that “[u]nder the settlement, more than 2,000 ZRCs of capacity will be added to Zone 7 over the next several years.”

10 Tr 4349. Mr. Jester posits that “[t]hese resource additions will not only provide replacement capacity for the retiring Campbell coal plant in 2025, they will result in a significant net increase of capacity when compared to the status quo.” 10 Tr 4349. Specifically, Mr. Jester provides that “the settlement [agreement] will add 1,114 ZRCs to MISO Zone 7 through the acquisition of the Covert combined-cycle gas plant in 2023.” 10 Tr 4349 (footnote omitted). Mr. Jester adds that “the settlement [agreement] provides that Consumers will deploy a new, utility-scale battery storage program in the years 2024-27, which will add approximately 71 ZRCs of new capacity.” 10 Tr 4349-4350 (footnote omitted). Mr. Jester posits that “because the settlement agreement preserves the solar ramp-up proposed as part of the original PCA, the settlement [agreement] would add 250 ZRCs of new solar generation by the 2025/2026 planning year, increasing to 852 ZRCs by 2028/2029 with further increases throughout the 2030s.” 10 Tr 4350 (footnote omitted). Finally, Mr. Jester argues that “by preserving the EWR and DR provisions from Consumers’ original PCA, the settlement [agreement] will provide 94 ZRCs of demand-side resources by 2025/26, increasing to 231 ZRCs by 2028/29, with further increases in later years.”

10 Tr 4350 (footnote omitted). Mr. Jester concludes that these resource additions will support resource adequacy by providing replacement capacity for the retiring Campbell Units in May 2025. Specifically, Mr. Jester avers that “[i]n the 2025/2026 planning year . . . the settlement [agreement] will result in a projected net increase of at least 127 ZRCs. By 2028/29, the projected increase will be at least 923 ZRCs.” 10 Tr 4350. Mr. Jester notes that these calculations are conservative as they only account for the first tranche of the one-time solicitation seeking up 500 ZRCs of energy and capacity for up to 10 years from dispatchable generation and do not include the resources from the second tranche seeking up to 200 ZRCs of energy and capacity for up to 25 years from clean capacity resources. Mr. Jester posits that the calculations also assume that all of the dispatchable ZRCs come from existing generation sources. Mr. Jester concludes that “the settlement [agreement] will bolster Zone 7’s resource adequacy” and as such, the Commission should disregard resource adequacy concerns raised by WPSC and Energy Michigan. 10 Tr 4352.

Mr. Jester responds to claims by WPSC and posits that “the settlement agreement will improve Consumers’ capacity position relative to the original IRP.” 10 Tr 4352. Mr. Jester opines that WPSC’s claim that the proposed settlement agreement continues to assume capacity replacements that add no incremental capacity to Zone 7 is “plainly incorrect” as “the settlement provides for more than 2,000 ZRCs of new Zone 7 capacity over the next six years, including the addition of the Covert plant (1,114 ZRC) in 2023. 10 Tr 4353. Mr. Jester posits that, as explained above, the one-time solicitation will result in a net increase of ZRCs in both the 2025/26 and 2028/29 planning years. 10 Tr 4353.

Mr. Jester responds to WPSC’s arguments that solicited resources cannot be built in time to provide energy and capacity in the 2025/26 planning year. Mr. Jester posits that “no party has claimed that the dispatchable generation tranche will be supplied with new resources” and thus,

“the evidence does not support Mr. King’s speculative claims about the difficulty of developing new clean energy resources by 2025/26.” 10 Tr 4353. Further, Mr. Jester avers that “Consumers would have enough capacity resources to meet customer needs in 2025/26 even if the one-time solicitation failed entirely.” 10 Tr 4353.

Finally, regarding Consumers’ capacity position, Mr. Jester rebuts WPSC’s claim that Consumers will be capacity negative in 2025. Mr. Jester posits that the testimony provided by Mr. King “does not explain some of the assumptions reflected in [Exhibit WPSC-7]” and “does not present independent sources to support his claims about increased load and the PRMR margin.” 10 Tr 4355 (footnote omitted). Mr. Jester also avers that Mr. King’s projected capacity position assumes that Karn Units 3 and 4 were operating in planning year 2025/2026 when Consumers capacity demonstration filing assumed Karn Units 3 and 4 would have retired in 2023, and the CMS plants would be acquired in 2025, in line with the implementation of the original PCA. Mr. Jester notes that in Case No. U-21099, the Staff concluded that “all Michigan LSEs have satisfied the capacity demonstration requirements and have procured appropriate levels of resources for planning year 2025/26.” 10 Tr 4356 (quoting Case No. U-21099, filing #U-21099-0060, p. iii).

Mr. Jester addresses the arguments of the BMPs and WPSC about recent PRA results. As Mr. Jester summarizes, “Mr. Polich asserts that MISO Zone 7 is projected to be short in 2023, and Mr. King cites the PRA results in warning more broadly about reliability risks.” 10 Tr 4358 (footnote omitted). Mr. Jester opines that “[a]lthough . . . MISO should carefully scrutinize the PRA results and pursue solutions to improve resource adequacy for MISO North/Central, the auction results do not undercut the settlement agreement in this case.” 10 Tr 4358. Mr. Jester reiterates that “the settlement agreement will *improve* Zone 7’s resource adequacy.” 10 Tr 4358-

4359 (emphasis in original). Further, Mr. Jester posits that “[b]ecause the settlement improves the capacity position of MISO Zone 7, it therefore also improves the capacity position of MISO’s North/Central region.” 10 Tr 4360.

Mr. Jester responds to the BMPs’ and WPSC’s concerns that there is not enough time to develop new resources capable of bidding into the one-time solicitation for clean energy resources and the possible decline of the ELCC of solar. Mr. Jester posits that concerns about developing clean energy resources by the 2025/2026 planning year are based on the assumption that the development process would not start until 2023. 10 Tr 4361. Mr. Jester first reiterates his position that “no one has suggested that the dispatchable generation tranche (500 ZRCs) of the one-time solicitation will be filled with new resources. . . .” 10 Tr 4362. Mr. Jester then opines that while the witnesses for the BMPs and WPSC assume that projects will not begin development until 2023, “[i]n reality, there are numerous clean energy projects already in the MISO generator interconnection queue. Because these projects are already in development, many of them will likely be capable of bidding into the solicitations for planning year 2025/26.” 10 Tr 4362-4363. Mr. Jester posits that there are currently “more than 13,011 MW of solar, battery, and solar/battery hybrid projects located in the MISO Zone 7 that have an application in-service date by or before June 1, 2025” including “9,842 MW of solar, 1,249 MW of solar/battery hybrid, and 1,920 MW of battery storage.” 10 Tr 4363-4364 (footnotes omitted). Mr. Jester notes that a number of the projects have completed phase 2 or phase 3 of interconnection studies and are therefore highly likely to proceed. 10 Tr 4364. Mr. Jester thus concludes that the concerns raised by the BMPs and WPSC are misplaced.

Regarding the concerns of the BMPs and WPSC about the potential decline of solar ELCC from 50%, Mr. Jester posits that “[a]lthough MISO has had discussions about adjusting solar’s

ELCC as part of its future shift to a seasonal capacity market, no such proposal has been finalized nor submitted for FERC [Federal Energy Regulatory Commission] approval.” 10 Tr 4365.

Mr. Jester notes that a MISO stakeholder process subcommittee has been using modeling assumptions including an “ELCC of 50% through 2026, and with the ELCC linearly declining in subsequent years until it hits 20% in 2041.” 10 Tr 4365-4366 (footnote omitted). In his footnote, Mr. Jester elaborates that “[f]or the previous year’s analysis, the subcommittee modeled a decline to 30%, which may be where Mr. Polich got his figure.” 10 Tr 4366, n. 51. However, Mr. Jester opines that “[t]his modeling document does not undercut the reasonableness of the settlement agreement[,]” providing that “this document is simply describing a modeling analysis; it does not reflect a policy change.” 10 Tr 4366. Mr. Jester also provides that “accreditation for each solar facility begins at 50% until operational records from that facility become available, after which it is based on average production during the hours of 2pm to 5pm ET in the months of June, July, and August.” 10 Tr 4366 (footnote omitted). Mr. Jester argues that this distinction is important as “there is on-the-ground evidence in Michigan that the ELCC for solar facilities may be much higher.” 10 Tr 4367. Specifically, “Consumers currently has three solar facilities whose MISO capacity credit ranges between 56.67% and 67%.” 10 Tr 4367 (footnote omitted). Finally, Mr. Jester notes that “although the ELCC of new solar may decline if solar achieves high levels of penetration in Michigan, that effect can be mitigated, and this dynamic will not affect the capacity provided by solar deployed in the earlier years of Consumers’ resource plan.” 10 Tr 4367.

2. Environmental Law and Policy Center of the Midwest, Ecology Center, Inc., Union of Concerned Scientists, Inc., and Vote Solar

Kevin Lucas, Senior Director of Utility Regulation and Policy at the Solar Energy Industries Association (SEIA), responds to the direct settlement testimony of WPSC on behalf of the CEOs. Mr. Lucas responds to the assertion by WPSC’s witness, Mr. King, that the solar capacity sought

by Consumers “will not be available by 2025 due to the current United States Department of Commerce . . . investigation regarding avoidance of tariffs from Chinese-made solar cells.”

10 Tr 4382. Mr. Lucas provides that “the DOC is investigating whether solar imports from Cambodia, Malaysia, Thailand, and Vietnam are circumventing antidumping and countervailing duties on Chinese-made crystalline silicon cells” and further, “[i]f imposed, tariffs would increase the cost of solar products from these countries 50-250%” 10 Tr 4382. Mr. Lucas avers that “[b]ecause of the uncertainty surrounding pricing of solar panels due to the retroactive nature of potential tariffs, panel shipments to the US have largely frozen since DOC initiated its investigation. This in turn impacts projects that are under construction and planned to come online in the near future as they are unable to secure a supply of solar panels.” 10 Tr 4383. However, Mr. Lucas posits that “SEIA believes the current supply chain issue is largely short-term and that it will be mitigated when a decision is reached and as domestic manufacturing capacity comes online.” 10 Tr 4384. Thus, Mr. Lucas concludes that Mr. King’s arguments are not supported by analysis and “[w]hile there may be some projects in Michigan that experience schedule impacts from the DOC investigation, these impacts are concentrated in the relatively near-term period.” 10 Tr 4384.

3. The Commission Staff

Mr. Proudfoot, on behalf of the Staff, responds to the direct settlement testimony of Energy Michigan and WPSC. Mr. Proudfoot limits his rebuttal testimony to the issues of the resource acquisition methodology of the one-time solicitation, resource adequacy, and the application of the settlement agreement factors outlined in Rule 431(5) parts (b) and (c). Addressing Mr. Zakem’s concerns that the settlement agreement does not require that the 500 ZRCs acquired through the one-time solicitation be additional resources to those present in Zone 7, Mr. Proudfoot posits that

“Mr. Zakem fails to recognize that Subsection 6.b.1. does not require the 500 ZRCs to be pre-existing (already counted towards MISO Zone 7 resource adequacy).” 10 Tr 4404. Mr. Proudfoot notes that under the terms of the settlement agreement, these resources will be competitively bid, thus “respondents to the solicitation could be from some of the projects currently in the MISO Queue (ITC Transmission, Michigan only) that makes up nearly 1,800 MW of projects that are currently in Study Phase 2 or 3.” 10 Tr 4404 (footnote omitted).

Mr. Proudfoot states that, in contrast to the RFP conducted by the company in its IRP filing which was limited to pre-existing gas resources within Zone 7, “the Company is now requesting dispatchable, non-intermittent resources (not specifically gas) with no requirement to be pre-existing.” 10 Tr 4404. Mr. Proudfoot argues that “between existing projects and the intermittent and dispatchable projects in the MISO Queue, there is opportunity to add new capacity within MISO Zone 7.” 10 Tr 4404. Mr. Proudfoot also notes that in the second tranche of the one-time solicitation provided for in subsection 6.b.1.ii of the settlement agreement, “the Company will request 200 ZRCs from unaffiliated third parties via Power Purchase Agreements (PPAs) for intermittent and dispatchable resources.” 10 Tr 4405. Thus, Mr. Proudfoot concludes that “[b]etween the two tranches, the Settlement Agreement provides the opportunity for a wide variety of new resources to bid in and ultimately be built within MISO Zone 7” 10 Tr 4405.

Mr. Proudfoot responds to resource adequacy concerns made by Energy Michigan and WPSC. Mr. Proudfoot asserts that the settlement agreement is “a resource adequacy improvement over the Company’s original PCA.” 10 Tr 4405. Mr. Proudfoot cites the key difference between the resource adequacy of the company’s original PCA and the settlement agreement to be the delayed retirement of Karn Units 3 and 4. Mr. Proudfoot explains that the original PCA called for the retirement of Karn Units 3 and 4 by May 31, 2023, while the settlement agreement delays the

retirement until May 31, 2031. Mr. Proudfoot posits that Consumers “was originally proposing to retire approximately 2800 MW (nameplate) generation from MISO Zone 7” while the settlement agreement “only retires a portion of that amount, approximately 1500 MW” 10 Tr 4405.

Further, Mr. Proudfoot notes that along with the commitment to retire the entire Campbell plant, Consumers “is proposing to add approximately 1176 MW to Zone 7 through the acquisition of the Covert Power Plant.” 10 Tr 4405. Further, Mr. Proudfoot provides that Consumers “continues its solar build out and is expected to add 300 MW of solar resources in 2023, 500 MW of solar resources in 2024, and 500 MW of solar resources in 2025[.]” noting that under the current MISO ELCC construct, “that is approximately 400 ZRC’s [sic] of new resources within MISO Zone 7.” 10 Tr 4406 (footnote omitted). Mr. Proudfoot adds that the one-time solicitation for 700 MW set forth in the settlement agreement is additional to the resources outlined above. 10 Tr 4406.

Mr. Proudfoot concludes that the “Staff does not believe the [settlement agreement] is likely to result in the Company being short on capacity in 2025.” 10 Tr 4406. Mr. Proudfoot opines that the 7.4% reserve margin used by Consumers in its Capacity Demonstration in Case No. U-21099 is reasonable as it “comes directly from the 2022-2023 MISO Loss of Load Expectation (LOLE) Study Report.” 10 Tr 4406 (footnote omitted).

Regarding Rule 431(5)(a), Mr. Proudfoot testifies that all parties have been given an opportunity to present arguments in opposition to the settlement agreement through direct and rebuttal testimony. 10 Tr 4407. In regard to Rule 431(5)(b) and (c), Mr. Proudfoot asserts that the “Staff believes that Consumers has adequately met its requirements under [Public Act] 341 of 2016 . . . and provided a reasonable revised PCA.” 10 Tr 4407. Mr. Proudfoot posits that not only did Consumers and the Staff sign the settlement agreement, but so did other parties who represent residential customers (the Attorney General, CUB, and Urban Core Collective); commercial and

industrial customers (HSC, MCV, and MPPA); businesses in Michigan’s advanced energy sector (EIBC/IEI/CGA); environmental groups (MNS and the CEOs); a transmission company (METC); and third-party developers (GLREA). 10 Tr 4407-4408. Mr. Proudfoot opines that the signatories to the settlement agreement “represent most, if not all, of Michigan’s sectors concerned with the future of energy related issues.” 10 Tr 4408. Mr. Proudfoot concludes that “it is Staff’s opinion that this [settlement agreement] meets the requirements of Rule 431.” 10 Tr 4408.

4. Biomass Merchant Plants

Mr. Polich, on behalf of the BMPs, filed rebuttal testimony to reassert his position that the continued operation of the biomass plants fosters resource adequacy and contributes to Consumers goal of being carbon neutral by 2040. 10 Tr 4289. Mr. Polich takes the position that “it is in the Public Interest for the continued utilization of the Biomass Plants to be incorporated into the [s]ettlement [agreement] by extending their contracts through at least 2035” as it will “help alleviate Consumers’ capacity deficiency that occurs in several years of 2025 through 2038” 10 Tr 4289. Mr. Polich poses that there are “significant risks associated with adding 7,800 MW of solar capacity as proposed[,]” including the magnitude of the capacity; the possible lowering of MISO’s current 50% solar accreditation; and MISO interconnection, development, financing, and construction risks. 10 Tr 4290-4291. Mr. Polich also notes the settlement agreement’s “reliance on natural gas generation as the only form of non-intermittent generation to supplement the renewable generation.” 10 Tr 4291.

Mr. Polich responds to MNS’ position that the settlement agreement improves upon Consumers’ initially filed PCA by eliminating the purchase of certain gas plants from Consumers’ affiliate CMS Enterprises. Mr. Polich asserts that “[s]ince the only bidders in the One-Time Solicitation first tranche will likely be existing generation, the bidders will be the same entities that

bid into Consumers' solicitation that resulted in three CMS plants being successful bidders."

10 Tr 4292. Mr. Polich also responds to Mr. Jester's testimony that the second tranche of the one-time solicitation is beneficial to the public interest. Mr. Polich argues that "the timing of the solicitation and 2025 in-service date will limit bidders to those with MISO interconnection agreements, preliminary engineering, major equipment under contract, and rights to construction sites already procured" adding that "it is highly unlikely any generation project can be constructed by the summer of 2025 in-service date." 10 Tr 4293.

5. Wolverine Power Supply Cooperative

Mr. King, on behalf of WPSC, responds to the direct testimony of MNS and the BMPs. Mr. King focuses his testimony on Mr. Jester's claims regarding "the clear reliability deficiencies resulting from the proposed: (1) one-time solicitation; (2) retirement dates for Campbell Unit 3 and Karn Units 3 and 4; and (3) transmission considerations." 10 Tr 4311. Additionally, Mr. King focuses on Mr. Polich's "statements identifying Zone 7 and Consumers as import dependent." 10 Tr 4311.

Mr. King disagrees with Mr. Jester's position that "the one-time solicitation of 700 ZRCs contemplated in the disputed [settlement] agreement is a reasonable and beneficial settlement [agreement] term sufficient to replace the retirement of Campbell Unit 3." 10 Tr 4311. Mr. King reasserts that "500 of the 700 ZRC[s] are unlikely to result in any new capacity to Zone 7 due to the solicitation requirements being 'dispatchable, non-intermittent generation capable of dispatching up or down in every hour of the year...[in] Zone 7.'" 10 Tr 4312 (quoting Settlement Agreement, p. 6). Mr. King further provides that "only the CMS plants, or a portion thereof, are available today in Zone 7. And nothing new exists in MISO's interconnection queue."

10 Tr 4312. Mr. King posits that, "the second tranche of 200 ZRCs are likely to be procured from

intermittent resources . . . because much like Tranche 1, there are unlikely any nonintermittent resources available today or in the MISO interconnection queue.” 10 Tr 4312. Mr. King asserts that there are reliability implications if the CMS plants are the only resources available to participate in the one-time solicitation. Specifically, “[r]eplacing Campbell Unit 3 with existing Zone 7 capacity produces a net negative capacity position in the Zone.” 10 Tr 4312.

Mr. King opines that by supporting the retirement of Campbell Unit 3, Mr. Jester, “fails to analyze, or even consider, the public health and safety impacts resulting from lower reliability.” 10 Tr 4313.

Mr. King addresses Mr. Jester’s position that delaying the retirement of Karn Units 3 and 4 from 2023 to 2031 is a reasonable and beneficial settlement term. Mr. King argues that “[w]hile the continued operation of existing resources is prudent in order to maintain reliability, extending the retirement date for Karn Units 3 and 4 does not appear to be a reasonable or prudent path as the units are, [sic] less reliable and provide insufficient additional capacity.” 10 Tr 4314.

Specifically, Mr. King provides that the settlement agreement proposes to extend the operation Karn Units 3 and 4 which have an installed capacity of 1,120 MW and accredited capacity of 790 MW (70.5% accredited) while continuing to expedite the retirement of the Campbell Units which have an installed capacity of 1,393 MW and an accredited capacity of 1,346 MW (96.6% accredited). 10 Tr 4314.

Mr. King refutes Mr. Jester’s testimony supporting the settlement terms that require Consumers to consider the reliability and economic value of transmission in its next IRP to access resources outside Zone 7. Mr. King posits that this consideration must happen sooner than Consumers’ next IRP as “Zone 7 is already import reliant in the upcoming 2022/23 Planning Year (and has been for seven of the last nine capacity auctions) to meet its PRMR” 10 Tr 4314.

Mr. King avers that “[w]hen Consumers and Zone 7 are import reliant . . . [i]f one of a few existing ties fails or export capability (elsewhere) is reduced (e.g., retirements or forced outage), proportional load shed is the next step.” 10 Tr 4315.

Finally, Mr. King encourages improving access to external resources. 10 Tr 4315. Mr. King posits that “Michigan should demand greater, more resilient, and more diverse ties to the greater market/grid.” 10 Tr 4315.

6. Michigan Energy Innovation Business Council, Institute for Energy Innovation, and Clean Grid Alliance

EIBC/IEI/CGA presented the rebuttal testimony of Edward Burgess, the Senior Director at Strategen Consulting. Mr. Burgess responds to the direct testimony of Mr. Polich on behalf of the BMPs on “timing delays and other risks associated with solar development[.]” specifically, that the settlement “simply ignores risks associated with intermittent solar generation.”

10 Tr 4388-4389 (footnote omitted). Mr. Burgess opines that the settlement addresses some of these potential risks by turning them into opportunities, such as better utilization of Michigan manufactured components and low-carbon manufacturing. 10 Tr 4389. Mr. Burgess rebuts Mr. Polich’s position that the one-time solicitation outlined in the settlement agreement is flawed. Mr. Burgess posits that Mr. Polich’s assumptions that “the second tranche procurement Settlement Paragraph 6.b.ii ‘will likely result in the acquisition of only intermittent generation because solar generation with battery storage will likely be too expensive to compete with solar generation without battery storage and due to shortages of material’” is an improper reading of the settlement [agreement]. 10 Tr 4389-4390 (quoting 10 Tr 4281) (footnote omitted). Mr. Burgess asserts that “[t]he fact that the ‘duration of the contract length’ will be taken into account for all new supply side resources, including solar and battery storage capacity options, will enable especially battery storage capacity options to be evaluated on par with intermittent resources in terms of the full price

of the contract.” 10 Tr 4390 (quoting Settlement Agreement, p. 6). Further, Mr. Burgess adds that “the fact that the solicitation is tailored towards ZRCs that meet the Local Clearing Requirements of MISO Zone 7 means that it already inherently accounts for any intermittency concerns through the MISO capacity accreditation process.” 10 Tr 4390.

Finally, Mr. Burgess posits that the technology neutral language of the one-time solicitation in section 6.b.ii of the settlement agreement rectifies concerns that Consumers’ initial PCA “did not adequately model nor otherwise address the potential inclusion of battery storage resources.” 10 Tr 4391.

7. Consumers

Consumers presented the rebuttal testimony and exhibits of Richard T. Blumenstock, Thomas P. Clark, and Michael A. Torrey. Each witness’ testimony will be addressed here in turn.

Mr. Blumenstock, Executive Director of Electric Supply at Consumers, focuses his rebuttal testimony on responding to assertions raised by Energy Michigan, WPSC, and the BMPs.

Mr. Blumenstock provides an overview of how the settlement agreement aligns with subsection 6t(8)(a)(i-vii) of Act 341, MCL 460.6t(8)(a)(i-vii), on pages 7-15 of his rebuttal testimony.

Mr. Blumenstock responds to the testimony of Energy Michigan’s witness Zakem by claiming:

Energy Michigan is continuing to rely on its direct testimony as previously submitted in this case before the Settlement Agreement was reached The problem with that approach is that Mr. Zakem’s direct testimony was focused on the Company’s purchase of the Dearborn Industrial Generation (“DIG”), the Kalamazoo River Generating Station (“Kalamazoo”), and the Livingston Generating Station (“Livingston”) plants . . . and the Settlement Agreement no longer provides for the purchase of those plants in the manner initially proposed by the Company. Mr. Zakem has also made no adjustment to his initial position to account for the fact that the Settlement Agreement continues operation of Karn Units 3 and 4 until 2031, as opposed to 2023, as initially proposed by the Company.

10 Tr 4128-4129. Thus, Mr. Blumenstock posits that Mr. Zakem’s assessment “no longer accurately describes the elements of the PCA, as modified by the Settlement Agreement.”

10 Tr 4129. Mr. Blumenstock also claims that Mr. Zakem’s position that the one-time solicitation provided for in the settlement agreement may result in resources that are already being counted toward resource adequacy requirements in MISO Zone 7 is speculative. 10 Tr 4129.

Mr. Blumenstock responds to WPSC’s arguments on purported reliability issues that Mr. King claims are at risk in the settlement agreement. Addressing Mr. King’s argument that Consumers will likely be capacity negative in 2025, Mr. Blumenstock argues that the 28 ZRC capacity shortfall Mr. King calculated is insignificant as “a small magnitude surplus *or* shortfall can shift over a relatively short period of time. This is why the Company implements a strategy of maintaining approximately 200 ZRCs of capacity surplus.” 10 Tr 4131 (emphasis in original). Mr. Blumenstock posits that Mr. King’s capacity position calculation is also flawed as it “relies on the exclusion of capacity acquired through the one-time solicitation . . .” 10 Tr 4131 (emphasis in original). Mr. Blumenstock further provides that Mr. King’s “claim that the Company could be capacity negative in 2025 would assume the Company is wholly unsuccessful in its one-time solicitation—that 0 ZRC of capacity are acquired through a Request for Proposals soliciting up to 700 ZRCs.” 10 Tr 4131. Mr. Blumenstock avers that Mr. King’s testimony fails to explain how the equalization adjustment factor used in his capacity position is calculated or appropriately used. 10 Tr 4133.

Mr. Blumenstock responds to the BMPs’ testimony by Mr. Polich that “the Company did not appropriately consider biomass plants in this IRP” 10 Tr 4135. Mr. Blumenstock opines that “the Company is not under any obligation to enter new PPAs with the BMPs or extend the BMPs’ existing contracts.” 10 Tr 4135. Mr. Blumenstock asserts that “the Company did consider biomass plants in the development of the IRP. The Company considered biomass plants as it began its modeling process, but due to the fact that those resources were not viable options on an

economic or cost basis, biomass plants did not pass the Company's resource screen process.

10 Tr 4136. Mr. Blumenstock notes that "the plants which make up the BMPs are included in the PCA through the end of their current PPA terms." 10 Tr 4136. Mr. Blumenstock opines that "the flaw in the BMPs' position is that the Company did not have adequate information to determine the cost of new PPAs or PPA extensions with the BMPs in the development of this IRP" and "throughout this proceeding, the BMPs have failed to produce any evidence in the record establishing the costs that the BMPs could agree to in new PPAs or PPA extension[s]."

10 Tr 4136.

Mr. Blumenstock addresses Mr. Polich's testimony making recommendations to the proposed settlement agreement, arguing that "Paragraph 22 of the Settlement Agreement provides that if the Commission rejects or modifies the Settlement Agreement or any provision of the Settlement Agreement, the Settlement Agreement shall be deemed to be withdrawn." 10 Tr 4137.

Mr. Blumenstock also asserts that the BMPs' requested modifications to the settlement agreement are "beyond the scope of this contested settlement." 10 Tr 4138.

Mr. Blumenstock responds to Mr. Polich's claims that the settlement agreement will result in Consumers having "excess capacity between 2023 and 2030 and capacity shortages between 2031 and 2038." 10 Tr 4139. Mr. Blumenstock elaborates that "the Purchase Sale Agreement ('PSA') for [the Covert] plant provides for the purchase in 2023" and "Mr. Polich has also not established that the Company has any ability to move the start date of the Covert Plant purchase." 10 Tr 4140. Further, Mr. Blumenstock posits that "even if the Covert Plant does provide surplus energy and capacity for a short period, the Company can monetize the energy and capacity of the Covert Plant by selling it into the MISO markets and using the resulting revenue to lower power supply costs to

the benefit of customers.” 10 Tr 4141. Responding to Mr. Polich’s assertion that the one-time solicitation is not needed until 2030, Mr. Blumenstock opines that:

the one-time solicitation included in the proposed Settlement Agreement also supports the retirement of Campbell Units 1, 2, and 3. It is expected that the 500 ZRCs of dispatchable generation and the 200 ZRCs of intermittent and non-intermittent clean resources will provide sufficiency of supply to support retirement of the Campbell Units. However, until such resources are acquired and operational on behalf of customers, the Settlement Agreement provides for continued operation of Karn Units 3 and 4, which provide low-cost capacity for the benefit of customers. The continued operation of Karn Units 3 and 4 further addresses reliability concerns for customers.

10 Tr 4141. Mr. Blumenstock concludes that “[b]ecause the one-time solicitation will support the retirement of Campbell Units 1, 2, and 3, and the need for continued operations of Karn 3 and 4 can be assessed in the future, the BMPs have not established that the one-time solicitation is unnecessary or to the detriment of customers.” 10 Tr 4141-4142,

Mr. Blumenstock rebuts Mr. Polich’s claim that the settlement agreement will result in a capacity shortfall position in the years 2031 through 2038. Mr. Blumenstock explains that “Mr. Polich suggests that *if* a change to solar accreditation is made at MISO, the PCA would result in capacity shortfalls eight years into the future.” 10 Tr 4142 (emphasis in original).

Mr. Blumenstock posits that “the PCA was developed using current MISO solar capacity accreditation practices.” 10 Tr 4142. Mr. Blumenstock opines that “[w]hile discussions in MISO have raised the possibility of changes to solar capacity accreditation, it would be premature to adopt such changes ahead of MISO itself issuing the rule change.” 10 Tr 4142. Further, Mr. Blumenstock provides that “at the Company’s existing solar facilities, capacity accreditation, based on actual performance, has been as high as 65%” and “[w]hile the possibility of lowering the accreditation is under consideration, actual performance will ultimately dictate the levels of capacity customers receive from these resources.” 10 Tr 4142. Additionally, Mr. Blumenstock

notes that Mr. Polich's projected capacity shortfall is to occur eight years in the future.

Mr. Blumenstock avers that Consumers "will file at least one, if not multiple IRPs between now and that time. If changes to solar accreditation occur at MISO, the Company has ample time to respond and adjust the PCA." 10 Tr 4143-4144.

Mr. Blumenstock responds to Mr. Polich's arguments that the one-time solicitation proposed in the settlement agreement is "deeply flawed." 10 Tr 4144; 10 Tr 4289. In response to Mr. Polich's claims that "the one-time solicitation will favor existing generation facilities[.]" specifically due to "engineering, financing, and construction time limitations, as well as delays in the MISO interconnection process[.]" Mr. Blumenstock "disagrees that this is a flaw in the design of the solicitation." 10 Tr 4144. Mr. Blumenstock posits that "the resources acquired in the one-time solicitation will help replace the capacity and energy lost by Campbell Units 1, 2, and 3 in 2025" and "[f]urthermore, beyond speculating what plants can participate, Mr. Polich fails to establish anything unreasonable about the solicitation." 10 Tr 4144. Mr. Blumenstock avers that the resources sought in the one-time solicitation are consistent with the modeling presented by the company in its principal case.

In response to Mr. Polich's argument that Consumers chose to exclude the BMPs from its IRP, Mr. Blumenstock avers that the settlement provides that the first tranche of the solicitation requires "dispatchable, nonintermittent generation *capable* of dispatching up or down in every hour of the year in response to wholesale energy market signals." 10 Tr 4146 (emphasis in original) (quoting Settlement Agreement, p. 6); *see also*, 10 Tr 4272. Mr. Blumenstock argues that Mr. Polich has asserted throughout these proceedings "that the BMPs' 'generation facilities can provide *around the clock*, renewable, *dispatchable* and reliable power generation.'" 10 Tr 4146 (emphasis in original) (quoting 7 Tr 2684). Mr. Blumenstock concludes that Mr. Polich's testimony with regard

to the fact that the BMPs are dispatchable has been inconsistent. 10 Tr 4146. Additionally, Mr. Blumenstock provides that “certain BMPs are offered into the MISO Day-Ahead Market as units which can dispatch on an hourly basis. Since the MISO Day-Ahead Market clears the day prior to operation, the plants are provided dispatch notice prior to actual operation.” 10 Tr 4147.

Mr. Blumenstock rebuts Mr. Polich’s claim that the term “clean capacity resources,” is not defined in the settlement agreement. Mr. Blumenstock asserts that “[t]he Company’s generation portfolio includes fossil fuel and clean capacity resources such as solar and hydro generation.” 10 Tr 4147. Mr. Blumenstock provides that “[t]he Settlement Agreement specifically provides that ‘[t]his tranche will seek intermittent resources and dispatchable, nonintermittent clean capacity resources *(including battery storage resources)* providing capacity which meets the Local Clearing Requirement of MISO Zone 7.’” 10 Tr 4148 (emphasis in original) (quoting Settlement Agreement, p. 6). Mr. Blumenstock argues that “[s]ince the Settlement Agreement provides ‘battery storage resources’ as an example of the ‘dispatchable, nonintermittent clean capacity resources’ that can participate in the second tranche, the Settlement Agreement is not ‘very ambiguous,’ as Mr. Polich claims.” 10 Tr 4148 (citing 10 Tr 4280).

Mr. Blumenstock addresses Mr. Polich’s arguments that the one-time solicitation “‘will likely result in Consumers acquiring [a] substantial amount of natural gas capacity in addition to the Covert capacity’” and “‘volatility of natural gas pricing.’” 10 Tr 4148 (quoting 10 Tr 4281). Mr. Blumenstock dismisses Mr. Polich’s arguments as speculation and asserts that Consumers witness Brian D. Gallaway addressed gas prices in the initial record of this case and “established that gas price volatility is not expected to continue into the future.” 10 Tr 4148. Further, Mr. Blumenstock asserts that “the Company will have an incredibly diverse resources portfolio that includes: pumped storage and hydro generation, gas generation, wind generation, solar

generation, energy efficiency, DR, and emerging technologies such as grid modernization and battery storage to meet the future demand of its customers.” 10 Tr 4148-4149. Mr. Blumenstock also posits that “[t]he Company maintains PPAs with numerous technology types.” 10 Tr 4149.

Mr. Blumenstock addresses Mr. Polich’s final concern with the one-time solicitation, that the one-time solicitation will result in “‘only intermittent generation because solar generation with battery storage will likely be too expensive to compete with solar generation without battery storage and due to shortages of materials.’” 10 Tr 4149 (quoting 10 Tr 4281). Mr. Blumenstock again dismisses this argument as speculation and opines that “[t]he one-time solicitation is a competitive bidding process which will consider the value of the resources which are bid. If certain resources are ‘too expensive,’ as Mr. Polich claims, that issue will naturally be resolved through the ranking of eligible bids.” 10 Tr 4149.

Addressing Mr. Polich’s testimony that the settlement agreement does not meet the intent of being carbon neutral by 2040 as stated in the settlement agreement, Mr. Blumenstock replies that “[p]aragraph 16 of the Settlement Agreement merely reiterates that the Company’s filed IRP ‘set forth a proposal to be Carbon Neutral by 2040 and retire all coal generation by 2025.’” 10 Tr 4149 (quoting Settlement Agreement, p. 13). However, Mr. Blumenstock posits that “there is nothing in the Settlement Agreement that will necessarily impede the Company’s ability to meet its goal.” 10 Tr 4149. Further, Mr. Blumenstock provides that “the 20-year capacity plan provided by the Company in this IRP assumed cessation of the Covert Plant by May 31, 2040. The final solution in 2040 will vary dependent upon the evolution of cleaner technologies, the possibility of carbon sequestration technologies, and potential for carbon offsets.” 10 Tr 4150.

Turning to Mr. Polich’s assertion that Karn Units 3 and 4 could be designated as a system support resource (SSR) by MISO, Mr. Blumenstock posits that “[a]n SSR designation would not

be due to a capacity or energy shortfall. An SSR designation would result from an electric transmission system deficiency that must be mitigated before Karn Units 3 and 4 could be retired.” 10 Tr 4152. Mr. Blumenstock avers that “Karn Units 3 and 4 will continue to operate to ensure near-term reliability for the benefit of Consumers Energy customers. These units may be operated through May 31, 2031, depending on the Company’s capacity needs and the outcome of the Company’s resource procurement efforts.” 10 Tr 4152. Mr. Blumenstock also provides that the cost burden associated with designating Karn Units 3 and 4 as SSR units would shift to the entirety of Zone 7 and would thus not pose an increased risk to customers. 10 Tr 4152.

Mr. Blumenstock concludes that Energy Michigan, WPSC, and the BMPs have not established any basis for the Commission to reject the settlement agreement. 10 Tr 4154.

In his rebuttal testimony, Mr. Clark responds to claims raised by Energy Michigan, WPSC, and the BMPs. Specifically, Mr. Clark focuses his rebuttal testimony on: (1) reliability concerns raised by these witnesses in connection with Consumers’ retirement of Campbell Unit 3; (2) the potential volatility of MISO’s capacity planning process and its impact on the company’s customers; (3) claims that the settlement agreement fails to address the forthcoming MISO seasonal capacity construct; (4) claims that the settlement agreement will impact reliability for residents in the lower peninsula and result in a capacity shortfall between 2031 and 2038; and (5) claims regarding competitive pricing in Michigan resulting from the settlement agreement. 10 Tr 4223.

Mr. Clark responds to Mr. King’s positions on behalf of WPSC with regard to the company’s projected solar capacity additions and their accreditations. Mr. Clark posits that the company is confident that its solar capacity expansion will be successful despite issues with supply chain and local zoning and “to the extent that the Company experiences minor delays beyond the 2025-2026

planning year, it continues to have sufficient capacity to reliably serve its load as a result of the continuing operation of Karn Units 3 and 4 and the one-time solicitation proposed in the Settlement Agreement.” 10 Tr 4227. With respect to a potential reduction in solar capacity accreditation, Mr. Clark opines that “the current ELCC is 50% of a solar generator’s installed capacity, and there is no certainty of timeline for a reduction from the current MISO practice.” 10 Tr 4227.

Mr. Clark rebuts Mr. King’s testimony “that a continued reduction to the Company’s PRMR is not reasonable,” stating that “[w]hile the Company’s forecasted load may be increasing, the Company’s internal waste reduction and demand response programs are also increasing, thereby offsetting a large portion of the growth.” 10 Tr 4227. Mr. Clark adds that “the planning reserve margin (‘PRM’) provided by MISO is decreasing, thereby allowing the Company’s PRMR to decrease rather than increase.” 10 Tr 4227-4228 (footnote omitted). Mr. Clark provides that “[t]he Company’s most recent capacity demonstration filing reflects that the PRM provided by MISO dropped from 8.70% for planning year 2022-2023 to 7.40% for planning year 2025-2026.” 10 Tr 4228 (footnote omitted). Mr. Clark notes that “[t]he Planning Year 2022-2023 Loss of Load Expectation Study Report indicates that the 2025-2026 planning year PRM decreased slightly from the 2022-2023 planning year PRM primarily based upon expected new unit additions.” 10 Tr 4228.

Addressing Mr. King’s argument that Consumers’ IRP is “based almost entirely on a 700 MW speculative solicitation of both dispatchable and intermittent resources[.]” Mr. Clark posits that “the Company has projected sufficient capacity for planning year 2025-2026, even without the additional 700 ZRCs of capacity proposed to be acquired via the solicitation.” 10 Tr 4228 (quoting 10 Tr 4302-4303). Mr. Clark opines that “neither a short delay in the onboarding of this

additional capacity nor a lack of available additional economic capacity would have a material, detrimental impact to the Company's immediate capacity position[,]" which would be reviewed subsequently in later IRP filings. 10 Tr 4229.

Mr. Clark responds to Energy Michigan's testimony from Mr. Zakem that "the Settlement Agreement will impact resource adequacy and the competitive market because the 500 ZRCs of dispatchable capacity that the company is seeking via solicitation will not necessarily be in addition to what is already being counted toward LRZ 7's resource adequacy requirements." 10 Tr 4229. Mr. Clark argues that "Consumers Energy, like all other LSEs, is responsible for ensuring that it has adequate supply to meet its customers' needs." 10 Tr 4229. Mr. Clark posits that "the Company has a requirement to serve its own customers' load while meeting applicable MISO requirements. The Company does not have an obligation to ensure LRZ 7 has adequate capacity for all LSEs to meet their customers' supply needs." 10 Tr 4229.

Addressing Mr. Zakem's concerns that the settlement agreement is anti-competitive, Mr. Clark adds that:

Other LSE's, [sic] like Energy Michigan's AES [alternative electric supplier] members maintain the obligation to serve their own load and to ensure equitable contribution to reliability requirements. Consumers Energy is not responsible to provide a reliability backstop for the benefit of AESs unless the requirement to provide backup capacity is triggered by an AES's failure to meet its own four-year forward capacity obligations as required under Public Act 341 of 2016.

10 Tr 4230. Mr. Clark avers that "[o]ther LSEs have been aware of the Company's PCA since June of 2021[,]" which has provided ample time to secure resources they may need to satisfy their own capacity obligations." 10 Tr 4231. Further, Mr. Clark argues that "the Company has not issued the one-time solicitation yet and therefore, other LSEs continue to have the opportunity and ability to secure resources they may need to satisfy their own capacity obligations prior to the issuance of the one-time solicitation." *Id.* Mr. Clark posits that "[b]ased on Staff's March 25,

2022 Capacity Demonstration Results report² filed in Case No. U-21099, all LSEs met their filing requirement detailing how the necessary capacity resources will be met for the Planning Year 2025-2026 (with one exception).” *Id.* (footnote omitted). Mr. Clark opines that “since all LSEs provided capacity projections through Planning Year 2025-2026, the 500 ZRCs of capacity that the Company will solicit for starting in 2025 should have no impact on an LSE who should have already committed capacity for the Planning Year 2025-2026.” 10 Tr 4231.

Mr. Clark then turns to the assertion of Mr. King on behalf of WPSC and Mr. Zakem on behalf of Energy Michigan on the impact the settlement agreement will have on resource adequacy. Mr. Clark avers that neither party provided specific information showing reliability risks to WPSC or Energy Michigan’s members. 10 Tr 4233.

C. Initial Briefs

1. Energy Michigan

Energy Michigan contends that the Commission is required to determine that an electric utility’s IRP “represents the most reasonable and prudent means of meeting the electric utility’s energy and capacity needs.” Energy Michigan’s initial brief, pp. 1-2 (quoting MCL 460.6t(8)(a)) (emphasis in original). Energy Michigan further posits that Rule 431 requires that for approval of a proposed contested settlement agreement, the Commission must find that “the settlement is in the public interest, represents a fair and reasonable resolution to the proceeding, and, if the settlement is contested, is supported by substantial evidence on the record as a whole.” Energy Michigan’s initial brief, p. 2 (quoting Rule 431(5)(c)). Energy Michigan avers that “[t]he Commission’s administrative rules may not overrule the underlying statute.” Energy Michigan’s

² Consumers testimony references the Capacity Demonstration Results which can be accessed on the Commission’s website at: <https://mi-psc.force.com/sfc/servlet.shepherd/version/download/0688y000002Qy56AAC> (accessed June 6, 2022).

initial brief, p. 2. Energy Michigan argues that “when a statute and an administrative rule conflict, the statute necessarily controls. While administrative agencies have what have been described as ‘quasi-legislative’ powers, such as rulemaking authority, these agencies cannot exercise legislative power by creating law or changing the laws enacted by the Legislature.” *Id.* (quoting *Imagine Entertainment, Inc v Dep’t of Treasury*, 334 Mich App 658, 664; 965 NW2d 720 (2020)). Energy Michigan posits that under this precedent, the Commission must consider whether the IRP appropriately balances the factors enumerated under Section 6t(8)(a) of Act 341, including: (1) resource adequacy and capacity to serve anticipated peak electric load, applicable planning reserve margin, and local clearing requirement; (2) reliability; and (3) competitive pricing. Energy Michigan’s initial brief, pp. 2-3 (citing MCL 460.6t(8)(a)(i)(iii-iv)). Energy Michigan argues that “[b]ecause Consumers’ proposed settlement [agreement] would have a detrimental effect on resource adequacy, reliability and competitive pricing in Michigan, the Commission should reject Consumers’ proposed Settlement Agreement.” Energy Michigan’s initial brief, p. 3.

Energy Michigan asserts that the proposed settlement agreement fails to meet the standards set forth in Section 6t(8) of Act 341 and is not in the public interest. *Id.* Energy Michigan cites to the record to demonstrate that “the Company is proposing to solicit capacity from wholesale generators that may exist in LRZ 7.” *Id.* (quoting 10 Tr 4229). Energy Michigan argues that changing ownership of resources that already exist in Zone 7 to meet Consumers’ capacity needs “has adverse effects on resource adequacy, reliability, and competitive pricing.” Energy Michigan’s initial brief, p. 3. Energy Michigan argues that while Consumers “does not believe that it has any responsibility for the rest of Michigan (*i.e.*, LRZ 7)[,]” the Commission “has a statutory responsibility to consider resource adequacy and reliability under the requirements of Section 6t.” *Id.*, pp. 3, 4.

Energy Michigan opines that if the one-time solicitation proposed in the settlement agreement is necessary, “the acquisition of 500 MW of existing in-zone capacity would not actually contribute to resource adequacy” *Id.*, p. 4. Additionally, Energy Michigan posits that if Consumers does not need the capacity represented by the one-time solicitation, “that solicitation is not the most reasonable and prudent means of meeting the utility’s capacity needs, as it would lead to an oversupply” and thus “has the potential to cause a market power issue.” *Id.*

Finally, Energy Michigan “disputes the characterization of this settlement process as involving all parties or as being open to negotiation on the concerns that Energy Michigan expressed in its testimony and briefs.” *Id.*, p. 5. Energy Michigan claims that it “was never invited to a settlement meeting, and Energy Michigan’s comments on the draft settlement agreement were neither welcomed nor considered, as [it was] explicitly told that no changes to the draft [it was] sent would be considered.” *Id.*

Thus, Energy Michigan requests that the Commission reject the proposed settlement agreement as it would negatively affect resource adequacy, reliability, and competitive pricing in Michigan. *Id.*

2. Michigan Environmental Council, Natural Resources Defense Council, Inc., Sierra Club, and Citizens Utility Board of Michigan

MNS contends that the settlement agreement meets all of the requirements of Rule 431 and should be approved.

MNS asserts that the settlement agreement is in the public interest because it results in the closure of the Campbell plant and Consumers’ exit from coal generation by 2025, and this step is critical to addressing the climate crisis and complying with the MI Healthy Climate Plan as shown in Mr. Jester and Mr. Gignac’s testimony. MNS’ initial brief, p. 4 (citing 10 Tr 4330, 4375).

MNS asserts that the settlement agreement benefits the public health in other ways as well,

through the increase to solar resources, the avoidance of the construction of new gas plants, and the removal of numerous other air pollutants (in addition to carbon dioxide) which contribute to numerous premature deaths each year. MNS' initial brief, p. 5 (citing 7 Tr 2426).

MNS notes that the retirement of the Campbell plant provides cost benefits to ratepayers as well. MNS contends that the undisputed evidence in the case showed that Campbell Units 1 and 2 are uneconomic. With respect to Campbell Unit 3, responding to WPSC's argument that this closure should be delayed, MNS notes that the settlement agreement is not severable, making it impossible for the Commission to simply adjust that timeline but approve the settlement agreement. MNS argues that such a delay would be harmful to ratepayers because the retirement of Campbell in 2025 will save customers more than \$150 million. MNS' initial brief, p. 8 (citing 10 Tr 4327).

MNS asserts that the settlement agreement is also in the public interest and a fair and reasonable resolution of the case because "it formalizes two important components of a cleaner grid: Consumers' solar ramp-up from its previous IRP; and faster deployment of battery storage investments" MNS' initial brief, pp. 8-9. MNS posits that Section 3 of the settlement agreement accelerates the transition to cleaner energy while reserving cost approval for later rate cases. MNS further indicates that the settlement agreement is in the public interest because it provides for stakeholder engagement prior to Consumers' first competitive solicitation for batteries (Section 3) and provides that the second tranche of the one-time ZRC solicitation will include battery storage resources (Section 6.b.ii.). Citing the testimony of Mr. Jester and Mr. Blumenstock, MNS contends that:

Consumers' battery proposal is a fair and reasonable settlement term for three reasons: (1) it will 'bolster Consumers' maintenance of its PRMR'; (2) it will 'support resource adequacy in Zone 7'; and (3) it may 'lead to the development of new battery storage resources within Zone 7.' The addition of battery storage

resources also addresses commodity price risks by providing ‘flexibility to adjust to changes in fuel costs, technology cost, electric demand, or the business environment’ and contributing to the diversification of Consumers’ generation supply. Finally, because Consumers proposed to advance its battery storage investment in response to testimony from Commission Staff, MNS, and other parties, this settlement term reflects the input of parties who represent the public interest.

MNS’ initial brief, p. 10 (quoting 10 Tr 4124, 4339).

MNS posits that the settlement agreement also benefits customers by removing the possibility of the CMS acquisitions which had affiliate transaction issues, significant costs, and significant operational risks. MNS points out that the settlement agreement also benefits ratepayers financially by providing for a 9% ROE to calculate the WACC for the Campbell regulatory asset (Section 5), which is more favorable than the 9.9% ROE approved in Case No. U-20963. MNS notes that Section 13 of the settlement agreement provides for the donations to low-income programs for the remaining term of the Campbell regulatory asset, and further provides that these funds will not be recovered from ratepayers. MNS’ initial brief, pp. 12-15 (quoting 10 Tr 4336). Thus, MNS points out, the settlement agreement facilitates the retirement of aging coal units while providing for lower costs for ratepayers and the funding of low-income bill assistance programs. MNS’ initial brief, p. 15.

MNS argues that the settlement agreement avoids the problematic aspects of Consumers’ original PCA while retaining the benefits, noting that the settlement continues the ramp up of solar PPA procurement, retains the 50/50 ownership-to-PPA ratio, and retains the existing FCM calculation. MNS also points to provisions that benefit the communities that will be affected by the Campbell retirement including community engagement and transition plans (Section 7.b.). *Id.*, pp. 16-19.

Responding to WPSC's arguments, MNS asserts that the settlement agreement will actually help improve resource adequacy. MNS notes that:

the Settlement will add thousands of zonal resource credits (ZRCs) to Zone 7, including:

- 1,114 ZRCs through the acquisition of the Covert combined-cycle gas plant;
- a new battery storage program in the 2024-27, which will add 71 ZRCs of new capacity;
- 250 ZRCs of new solar generation by the 2025/2026 planning year, increasing to 852 ZRCs by 2028/2029, with further increases throughout the 2030s; and
- 94 ZRCs of demand-side resources (EWR and DR) by 2025/26, increasing to 231 ZRCs by 2028/29, with further increases in later years.

MNS' initial brief, p. 20 (citing 10 Tr 4347-4350; Settlement Agreement, paragraphs 1-3; Exhibit A-14, p. 9; and Exhibit MEC-79, p. 1). MNS highlights Mr. Jester's testimony that for the 2025/2026 planning year the settlement agreement will result in an estimated net increase of 127 ZRCs, and for the 2028/2029 planning year a net increase of 923 ZRCs. MNS' initial brief, p. 20 (citing 10 Tr 4349-4350). Added to this is Consumers' obligation to seek PPAs for up to 200 additional ZRCs (Section 6.b.ii.). MNS observes that the Staff agrees that resource adequacy will be strengthened, noting Mr. Proudfoot's testimony that Zone 7 resources will increase, under the terms of the settlement agreement, by approximately 400 ZRCs by 2025. MNS' initial brief, p. 22 (citing 10 Tr 4405-4406). MNS contends that the settlement agreement thereby complies with the statutory requirement that the IRP ensure resource adequacy and capacity. MCL 460.6t(8)(a)(i). MNS also argues that Mr. Jester and Mr. Blumenstock refuted Mr. King's calculations and arguments. MNS' initial brief, p. 23 (citing 10 Tr 4354-4356, 4130-4134).

Finally, MNS points to the diversity of the parties that are signatories to the settlement agreement as evidence that the agreement is in the public interest and argues that, by comparison, the objecting parties' interests are relatively narrow. MNS asserts that Energy Michigan is a trade group with narrow business interests; WPSC is a power supply cooperative with a contractual

interest in opposing the Campbell retirement; the BMPs seek only to extend their PPAs with Consumers; and Mackinac submitted no evidence and evinces only an ideological opposition to closing coal plants. MNS' initial brief, pp. 25-27. MNS argues that the settlement agreement satisfies the Rule 431 criteria and should be approved. *Id.*, pp. 27-28.

3. Mackinac Center for Public Policy

Mackinac argues that the Commission should reject the settlement agreement because it does not represent “the most reasonable and prudent means of meeting the electric utility’s energy and capacity needs” as required in the language of MCL 460.6t(8)(a). Mackinac’s initial brief, p. 3 (quoting MCL 460.6t(8)(a)). Mackinac also contends that the settlement agreement does not meet the requirements of Rule 431(5) because it is not in the public interest and is not supported by substantial evidence on the record. Mackinac’s initial brief, pp. 4-5.

Mackinac asserts that the settlement agreement is not in the public interest because it presents a risk of “systemwide instability and rapid price swings.” *Id.*, p. 5. Mackinac states that this is partially due to the overreliance in the settlement agreement on acquiring additional power from the MISO market. Mackinac quotes from its exceptions to argue that MISO does not have sufficient capacity to serve the relevant demand. Mackinac asserts that the settlement agreement could cause reliability problems in MISO Zone 7 if early plant closures are “allowed to move forward without sufficient replacement capacity.” Mackinac’s initial brief, p. 7 (quoting Mackinac’s exceptions, p. 7). Mackinac “acknowledge[s] that the proposed Settlement Agreement addresses this somewhat by acknowledging that Karn Units 3 and 4 may be required to stay in operation,” but argues that the settlement agreement does not do enough to alleviate the concern about “systemwide instability and rapid price swings.” Mackinac’s initial brief, p. 8. Mackinac

argues that the recent results of the MISO Planning Resource Auction for Zone 7 show the potential for a shortfall.³

Mackinac further states that the settlement agreement fails to consider the recent volatility of natural gas prices. Mackinac argues that natural gas plays a “heavy role” in the settlement and thus natural gas pricing should be central to the Commission’s decision. *Id.*, p. 10. Mackinac again quotes extensively from its exceptions and argues that the settlement agreement fails to address the concerns that were laid out in the exceptions. Mackinac asserts that Henry Hub prices are at “near-historic levels” and that the price of coal compares favorably to natural gas. *Id.*, pp. 14-15. Mackinac asserts that “a reasonable and prudent path would be to rework the Company’s modelling scenarios with more realistic natural gas prices.” *Id.*, p. 15.

Mackinac further expresses concern that:

[p]er the Proposed Settlement Agreement, the Company will spend over \$30 million ratepayer dollars establishing programs specifically designed to limit customer access to electricity services during periods of higher demand (cold or hot weather): \$23,751,000 for demand response programs, and \$9,736,315 for conservation voltage reduction. These expenditures are deemed necessary because the Company is working from its wholly voluntary plan to reach net-zero CO2 emissions by designing a system that will be unable to meet customer demand, especially during periods of extreme weather.

Id., p. 16 (citing Settlement Agreement, p. 4). Mackinac continues, arguing that the settlement agreement fails to address the issues of restricted supply chains and significant price increases for certain minerals such as lithium, cobalt, and nickel. Mackinac posits that Consumers’ planned expansion of the use of batteries will still be insufficient to provide the necessary backup power

³ Mackinac’s initial brief contains numerous links to publicly available documents sourced from governmental entities or the media. None of the referenced documents are part of the record in this case. Mackinac did not present evidence in either the primary phase or the contested settlement phase of the case.

during extended periods of inclement weather, and that, in any case, developing a sufficient level of backup battery power would be prohibitively expensive. Mackinac asserts that the settlement agreement also fails to consider the significant environmental costs associated with Consumers' goal of becoming carbon neutral by 2040, which, Mackinac insists, will add to the growing level of "industry-wide instability, insolvencies, supply chain issues, and stalled development projects in the solar and wind industries." Mackinac's initial brief, p. 19.

Mackinac states that, under Section 5 of the settlement agreement, Consumers will be transferring stranded costs associated with Campbell Units 1, 2, and 3 to ratepayers as well as decommissioning costs (after a reasonableness and prudence review). Mackinac opines that an increasing level of instability is being designed into Consumers' system through the loss of large, dispatchable generation sources which are replaced by what it refers to as "weather-dependent and non-dispatchable renewable sources." *Id.*, pp. 9, 19-20.

Mackinac argues that Consumers' proposed donations to low-income programs are "a band-aid solution to the problems caused by its own decision to impose on ratepayers the cost of its wholly voluntary goal of net-zero emission by 2040 goals, as well as the systemwide costs associated with weather-dependent and variable renewable energy sources." *Id.*, pp. 20-21 (footnote omitted). Mackinac concludes that:

The Company is developing and constructing a system that precludes the use of coal and nuclear and relies solely on wind, solar, storage, and (over the upcoming two decades) slowly decreasing levels of natural gas for actual generation of electricity services for customers. Other programs such as EWR, CVR, and demand response target reduced supply and use by customers of electricity services, not the actual provision of electric service to customers. Mackinac Center objects to these measures.

Id., p. 21.

4. Michigan Energy Innovation Business Council, Institute for Energy Innovation, and Clean Grid Alliance

EIBC/IEI/CGA support the settlement agreement, noting that Rule 431 encourages parties to enter into settlement agreements when possible. EIBC/IEI/CGA contend that the settlement agreement meets all of the criteria for an approvable settlement under Rule 431(5) because the objecting parties were given a reasonable opportunity to present evidence and argument in opposition; the public interest is represented by the parties who entered into the agreement; and the settlement agreement is a fair and reasonable resolution of the proceeding that is supported by substantial evidence on the record. EIBC/IEI/CGA note that discovery continued during the contested settlement phase of the case and cross-examination took place. EIBC/IEI/CGA's initial brief, pp. 5-6. They also note the testimony from the Staff regarding the cross-section of signatories to the agreement, including parties who represent residential customers, commercial and industrial customers, advanced energy sector businesses, environmental groups, a transmission company, and third-party developers. *Id.*, p. 7 (citing 10 Tr 4407-4408). EIBC/IEI/CGA note that, under Section 6.b.ii. of the settlement agreement, Consumers is making a commitment to acquiring new clean energy resources of up to 200 ZRCs through PPAs or other third-party agreements. EIBC/IEI/CGA's initial brief, p. 7.

Responding to the objection that the settlement agreement will result in serious supply chain issues, EIBC/IEI/CGA opine that the settlement agreement turns these risks into opportunities by calling for better utilization of "Michigan manufactured components and low-carbon manufacturing" in the competitive bidding process. EIBC/IEI/CGA's initial brief, p. 8 (quoting Settlement Agreement, p. 9). EIBC/IEI/CGA aver that the concerns about pricing that have been expressed by the objectors are addressed by Consumers' commitment to continue the 50/50 company-ownership to third-party ownership construct that was approved in Case No. U-20165.

EIBC/IEI/CGA's initial brief, pp. 9-10. EIBC/IEI/CGA conclude that the settlement agreement meets the requirements of Rule 431(5) and should be approved. *Id.*, pp. 10-11.

5. Michigan Department of Attorney General

The Attorney General states that her primary concerns with Consumers' IRP are affordability, reliability, and the use of sustainable sources of energy. She contends that the settlement agreement addresses all three of these concerns. The Attorney General notes that the settlement agreement provides for the closure of Consumers' remaining coal plants and argues that this benefits public health and is consistent with Governor Whitmer's MI Healthy Climate Plan. Attorney General's initial brief, p. 8 (citing 10 Tr 4375, 4327-4330, and 4122).

Beginning with affordability, the Attorney General notes that evidence shows that the early retirement of the Campbell plant will save ratepayers \$150 million in avoidable capital expenditures. Attorney General's initial brief, p. 9 (citing 10 Tr 4327). She argues that the settlement agreement also saves money for ratepayers by eliminating Consumers' proposal to acquire the affiliated CMS plants, which avoids the potential \$515 million in immediate costs as well as future retirement costs and the unrecovered book value of Karn Units 3 and 4. Attorney General's initial brief, pp. 9-10 (citing 10 Tr 4334-4335). The Attorney General further notes that, with respect to the regulatory asset, the settlement provides for a WACC of 9.0% rather than the current ROE of 9.9%, also benefiting ratepayers. And finally, the settlement agreement provides for assistance to low-income ratepayers with direct funding of \$5 million this year and another potential \$2 million annually over the next 14 years. Attorney General's initial brief, p. 10.

Addressing reliability, she contends that the settlement agreement provides for adequate existing and new resources to meet capacity needs. Attorney General's initial brief, p. 11 (citing 10 Tr 4330-4335, 4406, 4224-4229, 4139, and 4142-4144). The Attorney General points to the

continued availability of Karn Units 3 and 4, as well as the solicitation for PPAs that will provide up to 700 ZRCs of energy and capacity beginning in 2025. She also cites to the provision that Consumers seeks 2 additional GW of new solar energy and undertake a battery storage program. Attorney General's initial brief, p. 11 (citing 10 Tr 4339). The Attorney General further states that:

the Settlement Agreement requires the Company to conduct certain evaluations and take other actions prior to the next IRP that can lead to benefits for ratepayers including, but not limited to, developing a distributed generation resource model; gathering input from the public before filing its next IRP; gauging interest in combined heat and power resources and model for the next IRP proceeding; providing total emissions for certain pollutants in the next IRP case; presenting PM2.5-related health impacts from power plant emissions in the next IRP case; conducting environmental justice screenings near power plants; and reporting on low-income customers['] participation in energy reduction and load reduction activities and rooftop solar adoption.

Attorney General's initial brief, pp. 11-12 (citing Settlement Agreement, pp. 12-16). The Attorney General urges the Commission to approve the settlement agreement.

6. Environmental Law and Policy Center of the Midwest, Ecology Center, Inc., Union of Concerned Scientists, Inc., and Vote Solar

The CEOs take the position that the contested settlement agreement is in the public interest and supported by record evidence. The CEOs contend that the settlement supports the public interest because: “(1) it aligns with important climate action goals intended to protect Michiganders; (2) it improves economic and public health outcomes; and (3) it includes beneficial modeling and community engagement commitments for the Company's next IRP.” CEOs' initial brief, p. 6 (quoting 10 TR 4375). The CEOs posit that “the Settlement Agreement is consistent with Governor Whitmer's MI Healthy Climate Plan, and is responsive to the urgency of addressing climate change.” *Id.* The CEOs opine that the settlement agreement balances the cost to Consumers associated with retirement of its coal plants with the impacts on low-income

customers. CEOs' initial brief, p. 6 (citing 10 TR 4376). The CEOs state that expert testimony in the record demonstrates avoided negative health outcomes as a benefit of the early coal plant retirements and that significant public health and environmental concerns associated with acquiring the DIG facility are avoided under the settlement agreement. CEOs' initial brief, pp. 6-7. Finally, the CEOs aver that the settlement agreement has important implications for future IRPs including the commitments to model distributed generation as a resource, conduct public health and environmental justice analyses, and provide expanded opportunities for community input and public participation. *Id.*, p. 7 (citing 10 Tr 4376). The CEOs argue the Commission should find the settlement agreement to be in the public interest.

7. Hemlock Semiconductor Operations, LLC

HSC supports the settlement and recommends that the Commission approve it. HSC's initial brief, p. 2. HSC opines that "parties were given a reasonable opportunity to present evidence and arguments in opposition to the record." *Id.*, p. 4. HSC posits that the public interest was adequately represented by parties entering into the settlement agreement as "the signatories to the Settlement Agreement represent a broad cross-section of interests" *Id.*, p. 5. HSC also notes that "the Michigan Court of Appeals has affirmed a Commission determination that the public interest was adequately represented by the Staff when the Staff was a party to a contested settlement agreement." *Id.* (citing *Attorney General v Mich Pub Serv Comm*, 237 Mich App 82, 93094; 602 NW2d 225 (1999) (*Attorney General*)). HSC opines that "all the parties who filed testimony in opposition to the settlement represent competitors of Consumers. In each case, the objecting party is seeking to advance its own particular interest, and not the public interest." HSC's initial brief, p. 6 (footnote omitted). HSC submits that the settlement agreement is a fair and reasonable resolution of the proceeding as "Consumers and others presented testimony and

arguments that the Settlement Agreement reflects significant compromise by all involved” which is “evident when comparing the details of Consumers’ initial PCA with the terms of the proposed Settlement Agreement.” *Id.* Finally, HSC posits that the settlement agreement is supported by 315 pages of transcript and 23 exhibits while the principal record in this case consisted of 4,094 pages of transcript across 9 volumes and over 500 exhibits. *Id.*, p. 7. HSC concludes that the settlement agreement “is supported by substantial evidence on the record and should be approved.” *Id.*

8. The Commission Staff

In response to the concerns raised regarding resource adequacy, the Staff responds “that this settlement agreement appropriately balances the resource adequacy concerns of Zone 7, Consumers’ need to serve the load and demand of its customers, and the benefits of Consumers’ decision to work towards becoming carbon neutral by 2040.” Staff’s initial brief, p. 4 (citing Settlement Agreement, p. 13). The Staff notes that its testimony highlights the addition of the Covert plant and the investments in renewable generation. *Id.* The Staff notes its concerns regarding resource adequacy of Zone 7, but states that:

it also understands that Consumers Energy is not tasked with providing resource adequacy for the entirety of Zone 7 at the sole expense of Consumers’ ratepayers. Staff expects all load serving entities within MISO Zone 7 to contribute the necessary capacity to meet capacity obligations at MISO and through Michigan’s State Reliability Mechanism (MCL 460.6w) and that these load serving entities will make the necessary investments to ensure that all customer needs within the zone are fully planned for. Therefore, Staff recommends that the Commission find that this settlement agreement appropriately balances the reliability needs of Zone 7 and the needs of Consumers’ ratepayers.

Staff’s initial brief, p. 5. The Staff reiterates that while the CMS plants “can bid into one tranche of the solicitation, the CMS [plants] are only able to bid in for the capacity they have available that is not currently contracted for” which “constitutes less than 500 ZRCs in 2025.” *Id.*, p. 6 (citing

Settlement Agreement, pp. 6-7; 3 Tr 138, 366). The Staff also states other resources, such as distributed energy resources, may be available by 2025, and are not currently counted within Zone 7. Further, the Staff reiterates testimony indicating “that the second tranche of the solicitation will likely result in additional new resources.” Staff’s initial brief, p. 6.

In response to the BMPs, the Staff states that, while the biomass plants are reliable resources, the Commission cannot modify the proposed settlement agreement to extend the PPA’s to 2035, because the settlement agreement is not severable, and any modification or rejection of a provision deems the settlement agreement to be withdrawn. Further, the Staff indicates that the biomass plants are able to participate in the one-time solicitation as set forth in the settlement agreement. *See, id.*, p. 7.

9. Consumers Energy Company

Consumers contends that the settlement agreement satisfies the requirements of Rule 431. Consumers’ initial brief, p. 10. Consumers argues that the signatories of the settlement agreement adequately represent the public interest and reiterates testimony from its witness, Mr. Torrey, “on the nature, scope, and diversity of parties’ interests” in this case. *Id.*, p. 11. Consumers also quotes testimony from the Staff’s witness, Mr. Proudfoot, that “the 18 parties that signed ‘represent most, if not all, of Michigan’s sectors concerned with the future of energy related issues,’ thus satisfying the requirement that the parties represent the public interest.” *Id.*, p. 11 (quoting 10 Tr 4408). Consumers posits that Mr. Torrey’s and Mr. Proudfoot’s testimony demonstrates that “the signing parties ‘represent a broad, diverse group of parties advocating for the economic and environmental interests of Consumers Energy’s electric customers and the state of Michigan,’ who are also focused on ensuring the Company’s customers are provided with reliable electricity.” Consumers’ initial brief, p. 11 (quoting 10 Tr 4257).

Consumers contends that “[t]he Commission should consider the four parties that signed statements of non-objection to the Settlement Agreement in reaching a finding that the Settlement Agreement adequately represents the public interest because those parties, having had an opportunity to contest the Settlement Agreement, elected not to do so.” Consumers’ initial brief, p. 12. Similar to HSC, Consumers posits that “[t]he Michigan Court of Appeals has upheld the Commission’s finding that a utility’s and Staff’s involvement in a settlement agreement can be sufficient to ensure that the public interest is adequately represented and also found that that ‘participation of fewer than all interested parties in the negotiation does not mandate a conclusion that the signatories to the settlement did not represent the public interest.’” *Id.* (quoting *Attorney General*, p. 94). Consumers concludes that “[t]he factual circumstances presented in this proceeding meet and exceed the Commission’s requirement for ensuring that the settling parties adequately represent the public interest.” Consumers’ initial brief, p. 12.

Consumers notes that of the four parties opposing the settlement agreement—Energy Michigan, Mackinac, WPSC, and the BMPs—only three filed testimony in the present case. *Id.*, p. 13. Further, Consumers argues that “[u]nlike the broad and diverse group of parties who signed the Settlement Agreement, the three parties who submitted testimony opposing the Settlement Agreement are all business competitors of Consumers Energy.” *Id.* (citing 10 Tr 4262).

Consumers reiterates its testimony that:

Energy Michigan and Wolverine would benefit financially from the opportunity created in this proceeding to procure surplus capacity to meet their own customers’ needs at a lower cost than building their own. The BMPs would also benefit financially if they received contract extensions at the expense of other resources which make up the PCA. That kind of motivation represents the opposite of the public interest.

Consumers’ initial brief, p. 13 (quoting 10 Tr 4263). Consumers concludes that “the broad-based coalition of parties who signed the Settlement Agreement and the parties who signed statements of

non-objection are a far better representation of the public interest in this proceeding than the parties who oppose it.” Consumers’ initial brief, p. 13 (citing 10 Tr 4263).

Consumers argues that the settlement agreement represents a fair and reasonable resolution to the proceedings as it “represents a significant compromise that was negotiated in good faith and proposes to resolve this matter based on the positions of the parties in the record.” Consumers’ initial brief, p. 14. Consumers avers that the settlement agreement meets the requirements for approval set out under Section 6t of Act 341. Specifically, Consumers posits that “all 18 signing parties agree that the PCA, as provided in the Settlement Agreement, represents the most reasonable and prudent plan to meet the Company’s energy and capacity needs over the 5-year, 10-year, and 15-year time horizons” as required by Section 6t(8)(a) of Act 341. *Id.* Consumers reiterates testimony by company witness Blumenstock on the settlement agreement’s compliance with Section 6t(8) of Act 341, including how the settlement agreement: (1) ensures resource adequacy and capacity that is sufficient in quantity to serve anticipated peak electric load plus applicable PRMR and LCR; (2) ensures compliance with applicable state and federal environmental regulations; (3) ensures competitive pricing; (4) ensures reliability; (5) addresses commodity price risk and ensures diversity of generation supply; and (5) proposes reasonable and cost effective levels of peak load reduction (DR, CVR, EWR). *See*, Consumers’ initial brief, pp. 14-19. Consumers cites to testimony by the Staff that the company’s IRP PCA as revised by the settlement agreement meets the requirements of Act 341 as additional support. Consumers’ initial brief, pp. 19-20.

As noted above, Consumers argues that the settlement agreement “was supported in the extensive record created in the proceedings leading up to the filing of the Settlement Agreement, which consisted of over 4,000 pages of testimony and over 500 exhibits” as well as the additional

evidence provided on the contested settlement. *Id.*, p. 20. Consumers notes the position of company witness, Mr. Blumenstock, MNS, and the Staff that the settlement agreement is supported by substantial evidence in the record as a whole. Consumers quotes the Staff's testimony that:

As stated above, the record in this case is substantial. All issues addressed in the [Settlement Agreement] have been addressed in testimony, rebuttal, brief, exceptions, and robust discovery. The [Settlement Agreement] was filed after a full record has been developed in this case. Therefore, based on all of the above, it is Staff's opinion that this [Settlement Agreement] meets the requirements of Rule 431.

Id., p. 21 (quoting 10 Tr 4408). Further, Consumers posits that "certain objecting parties have also attempted to interject issues into this contested settlement proceeding which are not based on the initial record at all." Consumers' initial brief, pp. 21-22. Specifically, Consumers references WPSC's reliance on the company's December 1, 2021 capacity demonstration in Case No. U-21099 and the BMPs' proposal that the settlement agreement be modified to require Consumers to extend their PPAs with the represented plants. *Id.*, p. 22. Consumers concludes that the settlement agreement "is in the public interest, represents a fair and reasonable resolution of the proceedings, and is supported by substantial evidence on the record as a whole" and thus "it should be approved by the Commission in its entirety without and modifications or conditions." *Id.*

Turning to the arguments of the individual objecting parties, Consumers argues that these objections fail to provide grounds to reject or modify the settlement agreement. *Id.*, p. 23. Consumers opines that these "arguments demonstrate a self-interested concern that the Settlement Agreement will challenge their ability to profit off Consumers Energy and its customers and Michigan's hybrid deregulation construct." *Id.* Addressing WPSC's position that the settlement agreement will negatively impact reliability, Consumers avers that the settlement agreement "will

bring at least 2,084 ZRCs into MISO LRZ 7 and retire only approximately 1,400 ZRCs of capacity, with a net addition for LRZ of nearly 700 ZRCs (at least).” *Id.*, p. 24. Consumers posits that “[t]his increase will enable the Company to manage any challenges or delays associated with bringing new resources online, changes in MISO’s planning requirements that may impact the Company’s PRMR, the migration to a seasonal capacity construct, and any degradation that might be applied to solar capacity accreditation.” *Id.* Consumers then addresses claims regarding reliability and resource adequacy of WPSC, Energy Michigan, the BMPs, and Mackinac individually. *See*, Consumers’ initial brief, pp. 24-56. As these positions are thoroughly outlined above, they will not be repeated here.

Consumers concludes that “the intent and focus of the Company’s original PCA were maintained” by the settlement agreement “ensuring the Company’s clean energy transition, as initially set forth in the Company’s 2018 IRP.” Consumers’ initial brief, p. 56. Consumers argues that the PCA, as modified by the settlement agreement will “help lead a faster clean energy transformation by accelerating the Company’s exit from coal-fired generation in 2025 while increasing reliability and providing resource adequacy for customers.” *Id.* The company provides that “the Settlement Agreement will continue the Company’s competitive procurement of clean energy resources by procuring approximately 8,000 MWs of solar resources by 2040 and will also accelerate the deployment of battery storage.” *Id.*, pp. 56-57. Finally, “like the Company’s initially filed plan, the PCA, as modified in the Settlement Agreement, continues to save customers money—providing for customer savings of nearly \$600 million.” *Id.*, p. 57.

Consumers asserts that the settlement agreement “meets the requirements of the Commission’s rule for approving contested settlement agreements, Rule 431, and the requirements for approving an IRP under Section 6t.” *Id.*

10. The Biomass Merchant Plants

The BMPs first summarize the contested settlement agreement before turning to the issue of the scope of the proceeding. The BMPs aver that their position is not beyond the scope of this IRP proceeding as their “objections in this proceeding are that the modified IRP fails specific statutory requirements of MCL 460.6t(8)” and that the “most reasonable and prudent means” under the statute requires the review of alternative plans which is what the BMPs offered in this case. BMPs’ initial brief, p. 6, 8 (emphasis omitted). The BMPs reiterate their objections, which were overruled by the ALJ to the company’s testimony, again claiming they did not have an opportunity to respond. *See, id.*, pp. 9-10.⁴

The BMPs argue that the settlement agreement fails the resource adequacy and reliability requirements under the statute as there is a shortfall in ZRCs. Thus, the BMPs state that the settlement agreement should be modified because “[c]ontinuing to purchase capacity and energy from the BMPs through 2035 would, in fact, correct both that statutory defect and the Company’s strategic goal.” *Id.*, p. 11. The BMPs further argue that the settlement agreement also fails to recognize the likelihood of the reduction of solar accreditation “down as low as 30% in the next

⁴ The Commission notes that the BMPs made several references to appealing evidentiary rulings throughout its initial brief. *See*, BMPs’ initial brief, pp. 9, 10, 36, 42-43. The Commission’s rules set forth the standard for appealing rulings of presiding officers. *See*, Mich Admin Code, R 792.10433 (Rule 433). In part, Rule 433(3) states that “[a]n offer of proof shall be made in connection with an appeal of a ruling excluding evidence” and that “[i]f the ruling excluded written evidence or evidence that refers to documents or records, the offer of proof shall consist of a copy of the evidence, documents, or records.” In addition, Rule 433(4) states that an application for appealing a ruling of a presiding officer “shall be supported by a clear and concise brief, pursuant to the provisions of R 792.10434, stating the basis for the appeal and showing that it complies with the provisions of this rule. The brief shall be supported by specific factual allegations as appropriate.” The Commission finds that the BMPs have not met these minimum standards set forth under Rule 433. Therefore, the Commission denies any appeal of rulings made by the presiding officer in this proceeding as set forth in the BMPs’ initial brief.

several years.” *Id.*, p. 12 (footnote omitted). The BMPs reiterate the testimony to aver that resource adequacy concerns are compounded by issues surrounding solar and battery storage and that the settlement agreement fails to address “the question of what energy is being stored, solar or fossil fuel generated energy. Solar energy can only be stored if that solar production exceeds load. If the load exceeds the solar generation, the energy being stored is from fossil fuel generation.” *Id.*, p. 15.

The BMPs reiterate their concern regarding Consumers’ “use of an incorrect solar capacity factor” which it avers “is 20.6% greater than the average capacity factor of all solar generation facilities currently operating in Consumers’ service territory.” *Id.*, pp. 4, 17. The BMPs state “[i]n contrast to the proposed solar capacity, the generation from the Biomass Plants is well known and MISO is not considering revisions to their ZRC accreditations.” *Id.*, p. 22.

Citing MCL 460.6t(8)(b), ED 2020-10, and the IRP filing requirements, the BMPs argue that “despite the fact that the Biomass Plants are located within Consumers’ service territory,” the settlement agreement disregards “the economic impact of the potential closure of those plants on the communities in which they are located.” BMPs’ initial brief, pp. 22-23. Therefore, the BMPs aver that the settlement agreement violates the statutory mandate because it “chooses to import energy into Michigan from other states” and “supports out-of-state construction and production rather than in-state construction, construction upgrades, construction maintenance and in-states generation.” *Id.*, p. 24.

The BMPs contend that the settlement agreement also does not meet the requirements in MCL 460.6t(8)(a)(v) because it fails to address potential future lack of capacity and that any early retiring plant could be designated as a system support resource (SSR), requiring it to remain in operation and that the “designation costs can run into significant millions of dollars.” BMPs’

initial brief, pp. 25-26. Similarly, under MCL 460.6t(8)(a)(vi), the BMPs aver that the settlement does not “appropriately balance the diversity of generation resources” which “impacts that commodity price risk” under MCL 460.6t(a)(v). BMPs’ initial brief, p. 26. The BMPs reiterate the record testimony to support this contention arguing that “the first tranche of the One Time Solicitation will almost certainly result in Consumers acquiring natural gas capacity” which will likely include the CMS plants, “all of which are natural gas fired generation” and that this “concentrated amount of natural gas fired generation has commodity price risk” *Id.*, pp. 27-28.

The BMPs restate the position that Consumers has inappropriately excluded generation from the biomass plants from the settlement agreement and that the company improperly relied on “the cost of new Biomass construction even though the Biomass Plants are existing construction, not new construction.” *Id.*, p. 30 (emphasis omitted). Reiterating record testimony, the BMPs aver that the settlement agreement violates the “statutory obligation under MCL 460.6t(1)(f)(iii) to include ‘any supply-side and demand-side resources that reasonably could address any need for additional generation capacity’” BMPs’ initial brief, p. 33. The BMPs further claim that the biomass plants are excluded from the one-time solicitation based upon the criteria set forth in the settlement agreement. *See, id.*, pp. 35-38.

The BMPs contend that the settlement agreement violates ED 2020-10 and Michigan’s Healthy Climate Plan. *Id.*, p. 38. In support of this position, the BMPs state:

The Settlement Agreement simply fails to consider the environmental benefits of the Biomass Plants as compared to the non-intermittent fossil fuel generation that will be acquired under the IRP as modified by the Settlement Agreement. It also fails to consider the unequaled ability of the Biomass Plants to help Consumers reach the goals of both Executive Directive 2020-10 and Michigan Healthy Climate Plan. The Biomass Plants’ fuel composition is described in detail in Mr. Polich’s testimony. The Biomass Plants are not only net-zero carbon generation, they have

the further benefit of preventing the release of Methane from decomposing forest wood waste into the atmosphere.

BMPs' initial brief, p. 40 (footnote omitted). The BMPs further argue that the environmental benefits of biomass fueled generation include a much smaller land use than solar and that "[c]ontinuing to purchase 188 MW of energy from the existing Biomass Plants means that between 1,128 to 1,504 acres of land can be left undisturbed by an equivalent amount of solar projects." *Id.*, p. 42.

The BMPs restate that the ALJ erred in numerous evidentiary rulings including sustaining objections and limiting the time for cross-examination. *See, id.*, p. 43. In conclusion, the BMPs "object to the Settlement Agreement as presented and request that it be amended to include a provision pursuant to which Consumers will continue to purchase capacity and energy from the Biomass Plants after the end dates of their current contracts until 2035." *Id.*, p. 44.

11. Citizens Utility Board of Michigan

CUB argues that the settlement agreement improves upon Consumers' original PCA and is in compliance with Rule 431. CUB states that the settlement agreement improves the PCA as it improves the future analyses of marginal line losses and avoided transmission and distribution costs and that:

[w]hile the Settlement Agreement does not require Consumers to reevaluate residential DR potential in this IRP . . . its commitment to collecting and reporting valuable marginal line loss data and including marginal line losses and avoided T&D costs in its evaluation of all distributed resources in future IRPs is a fair and reasonable compromise.

CUB's initial brief, p. 3. CUB also notes that the settlement agreement removes the 20% FIM Consumers was seeking in this proceeding. *Id.*

CUB notes that the parties signing the settlement agreement "represent a broad spectrum of the public interest, including the interests of residential ratepayers, commercial and industrial

ratepayers, businesses, and environmental groups” demonstrating the public interest is adequately represented. *Id.*, p. 4 (citing 10 Tr 4407-4408). CUB reemphasizes its testimony and avers that the substantial record demonstrates that the settlement agreement “and provides a fair and reasonable resolution of their respective concerns in this proceeding.” *Id.*, p. 5. Finally, CUB states that “the objecting parties have been given a reasonable opportunity to present evidence and arguments in opposition” to the contested settlement agreement, therefore satisfying all requirements of Rule 431. CUB’s initial brief, p. 6.

12. Wolverine Power Supply Cooperative

WPSC argues that the settlement agreement fails to meet the requirements of Rule 431. WPSC avers that the settlement agreement is not in the public interest as it will allow the retirement of Campbell 3 in 2025 which “will further stress Michigan’s already-strained grid system” and that this “fails to represent a fair and reasonable resolution to the proceeding.” WPSC’s initial brief, pp. 2-3. Pointing to the record and the PFD, WPSC states that a 2025 retirement of Campbell 3 is not well-supported. WPSC argues that approval of the settlement agreement “requires a set of parallel, perfect, and, therefore, unlikely outcomes” and lists those outcomes as follows:

(1) despite MISO’s projections, Zone 7 realizes sufficient resources to serve Michigan, (2) Consumers realizes declining load growth, despite economic projections and announced load growth; (3) Consumers’ one-time solicitation is fully successful in acquiring 700 incremental Zonal Resource Credits (“ZRC”) that are installed and delivered in less than three years, and (4) Consumers realizes the outcome of its modeling—a complete disconnection from the rest of Michigan’s grid.

Id., p. 3 (footnote omitted).

WPSC states that:

[w]hen reviewing more current data from Consumers’ own capacity demonstration filing in Case No. U-21099, which shows a 271 ZRC deficit in 2022 or 425 ZRC

lower than the PCA even with the same supply mix, . . . unless it acquires a material portion of the solicitation, Consumers will be capacity negative in 2025, even with the Covert purchase and keeping Karn Unit 3 and 4 online through 2030. (Testimony of Thomas King, 10 Tr 4303; Rebuttal Testimony of Thomas King, 10 Tr 4311-4312.)

Id., p. 4 (emphasis in original). WPSC further argues that the settlement agreement's effort of allowing a one-time solicitation of 700 ZRCs to combat reliability concerns from the early retirement "does not ensure Consumers customers are shielded from resource adequacy shortfalls in Zone 7 – the projects must actually be built and the 700 ZRCs of dispatchable and intermittent resources likely cannot be built in time." *Id.*, p. 4. Continuing, WPSC points out that "the proposed solicitation will not create any incremental (i.e., new) Zone 7 capacity" and is merely another path to utilize the CMS plants as originally proposed in the PCA. *Id.* Reiterating its testimony, if Campbell 3 is replaced with existing Zone 7 capacity there will be a net negative capacity position in the zone which, WPSC avers "places Michigan on a path toward load shed (e.g., blackouts) that is likely to harm Michigan residents." *Id.*, p. 6 (citing 10 Tr 4312).

WPSC reiterates its testimony that, despite Consumers' assumption, the market reality is that there is a declining PRMR between 2022 and 2025, and that it "it conflicts with MISO's statements of increasing load forecasts." *Id.*, p. 7 (citing 10 Tr 4305 and Exhibit WPSC-6). WPSC further points to developmental projects which will result in incremental load increases and argues that Consumers' estimates of increases in DR are not supported by any evidence indicating that such is possible. WPSC further states that the company's assurances that there is time to address the shortfall in the future is insufficient and that "it is unreasonable for Consumers to utilize an unsupported, lower reserve margin for the future." *Id.*, p. 8.

WPSC further argues that, while the first 500 ZRCs for the proposed solicitation are likely to come from existing Zone 7 resources, "the second tranche of 200 ZRCs are likely to be procured

from intermittent resources” and that “[t]he record is devoid of evidence regarding where the needed resources would come from.” *Id.*, p. 9 (citing 10 Tr 4312). WPSC states that the denial that the solicitation is speculative “demonstrates a fundamental misunderstanding of the current renewables landscape” and even as “more solar resources are added to the grid, less benefit is realized and the solar capacity accreditation declines to match performance.” *Id.* (citing Exhibit WPSC-8). WPSC reiterates its position that the 500 MW is unreasonable noting that:

[e]ven if the proposed 500 MW of projects were able to procure materials and Consumers is capable of acquiring and utilizing the nearly 3,500 necessary open acres of Michigan land, the projects would also need to achieve the local government approvals, complete MISO’s byzantine generation queue process, and complete transmission improvements necessary to facilitate construction and interconnection—all within the limited time available.

Id., p. 10.

In addition, WPSC avers that the settlement agreement inappropriately requires Consumers to be treated as an island rather than an integrated and interconnected participant in the Michigan electric grid. WPSC argues that “[g]iven the likely capacity shortfall in Zone 7, the [settlement agreement’s] failure to address transmission deficiencies will exacerbate the problems created by hastily retiring generation resources. If one of the few existing ties fail or export capability from other areas is reduced, the only other option will be load shed.” *Id.*, p. 11 (footnote omitted).

WPSC concludes that, under Rule 431, the Commission must deny the settlement agreement as it “is not supported by *any* evidence within the record, and certainly is not supported by *substantial* evidence on the record” but rather that the record demonstrates additional modeling and analysis is needed to support an early retirement of Campbell Unit 3. *Id.*, p. 12 (emphasis in original). WPSC further states that “[r]ushing the retirement of Campbell Unit 3 may allow the Commission to continue forward with its admirable goal of reducing Michigan’s carbon emissions, but it will come at the risk of electric reliability and related health and safety of

Michiganders.” *Id.* WPSC avers that the settlement agreement does not reflect the most reasonable and prudent path and that the Commission should “require Consumers to keep Campbell Unit 3 in operation, at least until Consumers can present hard data that verifies that Campbell Unit 3 can be retired without jeopardizing reliability and, as the PFD notes, Consumers has not modeled or analyzed these issues sufficiently.” *Id.*, p. 13.

13. Urban Core Collective

UCC filed a statement in support of the settlement agreement in lieu of an initial brief to reaffirm its initial support as a signatory to the settlement agreement. *See*, Case No. U-21090, filing #U-21090-0857.

D. Reply Briefs

1. Michigan Environmental Council, Natural Resources Defense Council, Inc., Sierra Club, and Citizens Utility Board of Michigan

In reply to Energy Michigan, MNS argues that Energy Michigan errs in positing that the considerations under MCL 460.6t(8) somehow trump the Rule 431 criteria. MNS’ reply brief, pp. 2-3. MNS notes that the Michigan Administrative Procedures Act (APA) also addresses settlements and provides that contested cases may end in settlement when agreed to by the parties in MCL 24.278(2). *Id.*, p. 3. MNS contends that Rule 431 implements this statutory requirement. While agreeing with Energy Michigan that it is important to harmonize the IRP statute and Rule 431, MNS contends that Energy Michigan’s reading of MCL 460.6t(8) would make applying the requirements of Rule 431 an “empty exercise.” *Id.*, p. 4. MNS further contends that Energy Michigan’s argument conflicts with the Commission’s approval of the contested settlement in Case No. U-20165. *Id.* (citing June 7, 2019 order in Case No. U-20165, p. 76 (June 7 order); *see also*, June 7 order, p. 91).

MNS states that it addressed Energy Michigan’s resource adequacy and pricing arguments in its initial brief, and notes that Energy Michigan was included in all settlement discussions, asserting that Energy Michigan was included in multiple emails regarding the settlement conference which took place in February 2022. MNS’ reply brief, p. 5.

In reply to WPSC, MNS again argues (as it did in its initial brief) that, contrary to WPSC’s assertions, the settlement agreement will actually improve resource adequacy in Zone 7. MNS again points to the 1,114 ZRCs from the Covert gas plant, 71 ZRCs of new battery storage, 250 ZRCs of new solar generation, and 94 ZRCs of new demand side resources, and states that “[e]ven with the retirement of the Campbell coal units, these resource additions will result in an overall net increase in Zone 7 resources.” *Id.*, p. 7 (citing 9 Tr 5-6, 10 Tr 4350, and Settlement Agreement, Sections 1-3); *see also*, 10 Tr 4405-4406. MNS further argues that WPSC’s repeated citations to the PFD for support are inapposite since the PFD evaluated the original PCA, which presented actual resource adequacy concerns. MNS’ reply brief, pp. 8-9.

MNS contends that the Commission should not consider the websites and news stories cited by WPSC regarding the PRMR because they are not part of the record, and, in any case, Mr. Jester, Mr. Proudfoot, and Mr. Clark rebutted these concerns. MNS’ reply brief, p. 10 (quoting 10 Tr 4406-4407) (citing 10 Tr 4358-4359 and 4227-4228). MNS notes that Mr. Proudfoot testified that:

The reserve margin used by the Company in its capacity demonstration for 2025 comes directly from the 2022-2023 MISO Loss of Load Expectation (LOLE) Study Report. It is also worth noting that assuming a constant reserve margin of 8.7% instead of 7.4% would represent about 100 MW of additional obligation to the Company. The differences between Karn Units 3 & 4 and the CMS capacity is still likely enough to cover this difference, even without counting any additional capacity from the one-time solicitation.

MNS' reply brief, p. 10 (quoting 10 Tr 4406-4407). MNS asserts that WPSC's claims about Consumers being capacity negative are simply untrue as shown by the list of ZRCs described above, and states that "Consumers would still have a surplus even if both tranches of the one-time solicitation fail entirely: in that extremely unlikely scenario, Consumers would still have a 514 ZRC surplus in 2025/26." MNS' reply brief, p. 11 (citing 10 Tr 4354). Finally, on this issue, MNS avers that Mr. Jester showed that Mr. King's calculations were incorrect because Mr. King assumed that Karn Units 3 and 4 would be operating in the 2025/2026 planning year. MNS' reply brief, p. 12 (citing 10 Tr 4355). MNS notes that WPSC fails to cite to any record evidence showing that the retirement of Campbell Unit 3 in 2025 is unsupported. MNS' reply brief, p. 12.

In reply to the BMPs, MNS argues that their claims regarding a lower ELCC are exaggerated and inaccurate, and states that the BMPs mischaracterized Mr. Clark's testimony where he indicated that the ELCC "could" drop. MNS' reply brief, p. 15 (citing 5 Tr 1123) (emphasis omitted). Additionally, MNS notes that several witnesses refuted this argument, including Mr. Clark himself when he testified that the ELCC has been stable for six years and no changes are pending. MNS' reply brief, pp. 15-16 (citing 10 Tr 4226-4227, 4236). MNS observes that Mr. Blumenstock testified that even applying the BMPs' 30% ELCC figure, there would be no shortfall for eight years. MNS' reply brief, p. 16 (citing 10 Tr 4142-4143). Additionally, MNS notes, Mr. Jester showed that the BMPs' figure comes from an exploratory modeling exercise. MNS' reply brief, p. 16 (citing 10 Tr 4365-4366).

Finally, MNS objects to the BMPs' appeal of certain evidentiary rulings made by the ALJ, noting that the BMPs fail to cite to any legal authority in support of their appeal. MNS argues that a party may not "simply announce a position on appeal and leave it to the reviewing body to search for authority to support the party's position." MNS' reply brief, p. 18 (citing *Wilson v*

Taylor, 457 Mich 232, 243; 577 NW2d 100 (1998)). MNS contends that the BMPs’ counsel misrepresented how long his cross-examination of Mr. Blumenstock would last, and then offered questions on irrelevant subjects. MNS’ reply brief, p. 18 (citing 10 Tr 4193, 4211). MNS contends that, under MCL 24.280(1)(d), the presiding officer is empowered to regulate the course of the proceedings. MNS avers that the ALJ’s rulings were reasonable and well within her authority and should be affirmed. MNS’ reply brief, pp. 18-19.

In reply to Mackinac, MNS urges the Commission to give no weight to Mackinac’s brief. As an initial matter, MNS alleges that Mackinac did not comply with the requirements of Rule 431(3) when it filed its objection, because it failed to state its objections with particularity or specify how it would be adversely affected by the settlement agreement. Additionally, MNS argues, Mackinac’s initial brief is mostly cut-and-pasted from its exceptions, and the exceptions were focused on the PFD and the original PCA – a different factual scenario. MNS notes that Mackinac’s initial brief is filled with unsupported assertions and relies heavily on news stories and website links that are not part of the record, contrary to the requirements of the APA. MNS’ reply brief, pp. 20-21 (citing MCL 24.276 and 24.285). Moreover, MNS posits, DR and CVR programs are not designed to cut off customers from electricity. MNS describes Mackinac as “ill-informed.” MNS’ reply brief, pp. 21-22.

2. The Commission Staff

In reply, the Staff states that MCL 460.6t(8) provides seven factors for the Commission to balance when determining if the statutory requirements are satisfied. The Staff states that the settlement agreement is a compromise made by parties with a wide variety of interests and is reasonable and prudent. The Staff also contends that “the settlement agreement also balances the

reliability needs of MISO Zone 7 with Consumers’ ability to provide energy and capacity to its customers.” Staff’s reply brief, p. 2 (citing Staff’s initial brief, pp. 3-5).

Regarding resource adequacy concerns, the Staff replies that the PCA, as modified by the settlement agreement, is reasonable and prudent and balances the reliability needs of Zone 7. *See*, Staff’s reply brief, p. 3. Continuing, the Staff avers that “[g]iven the capacity from Karn Units 3 and 4, additional solar resources, and the up to 700 MW one-time solicitation set forth in the settlement agreement, Staff . . . does not believe Consumers is likely to be short on capacity in 2025” and that “this capacity is more than sufficient to make up the capacity assumed for the CMS [plants] contemplated in Consumers’ original IRP and may even be sufficient to meet Consumers’ previous planning reserve margin of 8.7% that [WPSC] referenced in direct testimony.” *Id.*, pp. 3-4 (citing 10 Tr 4306, 4406-4407).

In response to the BMPs’ testimony regarding a deficiency in 2035, the Staff replies:

that the IRP statute requires 5-, 10-, and 15-year projections of the utility’s load obligation and plan, but Commission cost approval for investments or resources used to meet energy and capacity need is only presumed reasonable and prudent for those actions commenced within three years of Commission approval of the IRP. MCL 460.6t(3), (11).

Staff’s reply brief, p. 4. Therefore, the Staff avers that there is a likelihood that changes will occur between the approval of the IRP and the long-term projections as further reinforced by the requirement in MCL 460.6t(20) for regulated utilities make an IRP filing at least every 5 years. *Id.*

Finally, the Staff avers that Mackinac’s “initial brief contains many footnotes citing to material that was not offered into evidence or addressed in testimony” and that Mackinac “did not file testimony in either phase of this proceeding and filed a one-page objection to the settlement agreement.” *Id.*, p. 6. Therefore, the Staff requests that the Commission disregard the portions of

Mackinac's briefing supporting its objections to the settlement agreement not supported on the record.

3. Environmental Law and Policy Center of the Midwest, Ecology Center, Inc., Union of Concerned Scientists, Inc., and Vote Solar

In reply to the BMPs, the CEOs point out that the BMPs' request to modify the settlement agreement is a form of relief that is unavailable because the settlement agreement is not severable, thus modification would result in rejection of the entire agreement. CEOs' reply brief, p. 1, n. 1. The CEOs further aver that the BMPs' contracts should not be extended in any case due to the non-carbon pollution associated with their operations as well as the documented environmental justice concerns. CEOs' reply brief, p. 2. The CEOs note that one of the directives issued by Governor Whitmer pursuant to ED 2020-10 requires the Michigan Department of Environment, Great Lakes, and Energy to include considerations of environmental justice and public health when issuing advisory opinions in IRP proceedings. *Id.*, pp. 2-3. The CEOs submit that they provided extensive evidence on the record showing the non-carbon air pollution emissions and environmental justice concerns associated with the BMPs, stating that:

[s]ome of these plants co-fire tire-derived fuels, and most of them have higher emission rates of PM_{2.5} and NO_x than even Consumers' coal plants. (Krieger, 7 TR 2383). Moreover, eight of nine plants are located in areas considered more low-income than the state median. (Krieger, 7 TR 2383). The 38,000 people living near the Genesee plant rank in the 89th percentile for low-income populations, 86th percentile for populations of color, and 83rd percentile on the EJ [Environmental Justice] Index. (Krieger, 7 TR 2384). "[B]iomass power plants are likely to have higher air pollutant emissions rates per unit energy produced."

CEOs' reply brief, p. 3 (quoting 7 Tr 2397) (emphasis omitted). The CEOs note that Dr. Bilsback concluded that the emissions rates of biomass plants are comparable to fossil-fuel fired plants. CEOs' reply brief, p. 4 (citing 7 Tr 2418). The CEOs contend that simply because a fuel source

may be renewable does not mean that it will not have health impacts; and they note that the BMPs did not rebut this testimony. CEOs' reply brief, p. 4.

The CEOs also regard the BMPs' argument that the settlement agreement is a ploy to allow for the construction of a natural gas plant as far-fetched. The CEOs point out that the settlement agreement (Section 6.b.ii.) limits the second tranche to "intermittent resources and dispatchable, nonintermittent clean capacity resources (including battery storage resources)," which could not be reasonably interpreted to include natural gas. *Id.* (quoting Settlement Agreement, p. 6). The CEOs further note that they would not be signatories to a settlement agreement that contemplates the construction of a new gas plant. CEOs' reply brief, p. 5 (citing 7 Tr 2354 and 10 Tr 4347). The CEOs contend that the land use concerns raised by the BMPs do not appear to relate to ED 2020-10. CEOs' reply brief, pp. 5-6.

The CEOs further argue that WPSC and the BMPs attempt to use scare tactics based on market information. The CEOs assert that Consumers used an appropriate capacity factor in its modeling, stating that, in reference to the BMPs' evidence, "[a]s Company witness Battaglia explained on rebuttal, the information shown in BMP-6 is presented in DC, rather than AC, and therefore does not present a comparable capacity factor to that used by the Company in modeling. (Battaglia Direct, 5 TR 1217:4-12)." CEOs' reply brief, p. 7. The CEOs also note that the BMPs focused on the wrong witness with respect to their ELCC arguments, as the solar capacity factor was covered by Mr. Kapala and not Mr. Battaglia (and this mistake was noted by the ALJ as well). *Id.*, p. 8 (citing 6 Tr 1296-1297; 7 Tr 1822). The CEOs further assert that WPSC's theory that Consumers will be unable to acquire 250 ZRCs of solar by 2025 was refuted by Mr. Lucas. CEOs' reply brief, p. 9 (citing 10 Tr 4382-4384). They also cite to the testimony of Mr. Clark and Mr. Jester refuting the notion that the ELCC poses an unreasonable risk to the settlement

agreement. CEOs' reply brief, p. 9 (citing 10 Tr 4236, 4367-4368). Finally, the CEOs point to Mr. Blumenstock's testimony that Karn Units 3 and 4 are unlikely to become system support resources. CEOs' reply brief, p. 10 (citing 10 Tr 4152).

The CEOs assert that Mackinac's arguments are improper and redundant. CEOs' reply brief, p. 10.

4. Consumers Energy Company

Consumers initially provides an overview of the arguments of the signatories to the settlement agreement reiterating its position that the settlement agreement is in the public interest, was the result of good-faith negotiation, and that the outcome is the most reasonable and prudent means of meeting the company's energy and capacity needs. Consumers' reply brief, pp. 3-5.

Consumers argues that issues raised by WPSC with regard to reliability and resource adequacy concerns have been addressed by the company's initial brief. Specifically, Consumers states that "[WPSC]'s claim . . . that the one-time solicitation will likely not create new [MISO LRZ] 7 capacity, is of no consequence" for the reasons set forth in its initial brief. *Id.*, p. 6. Consumers argues that "[t]he purpose of the one-time solicitation is to help replace the capacity and energy lost when Consumers Energy retires [Campbell] Units 1, 2, and 3 in 2025." *Id.* Consumers repeats that "[t]he Company is not required to provide capacity for [WPSC] or any other [LSEs] in LRZ 7." *Id.* Consumers states that WPSC's arguments that the settlement agreement will reduce reliability in LRZ 7 are "without merit" as outlined in its initial brief and WPSC has "failed to provide information showing any purported negative impact on [WPSC]" *Id.*, p. 7. Consumers reiterates that the settlement agreement will "bring at least 2,084 ZRCs into MISO's LRZ 7 and retire only approximately 1,400 ZRCs of capacity, with a net addition for LRZ 7 of nearly 700 ZRCs." *Id.* (footnote omitted). In response to WPSC's claims that the company's

PRMR will increase rather than decrease, Consumers argues that it has “fully supported its projected PRMR decrease” in its initial brief. *Id.* Consumers argues that WPSC’s claims that the one-time solicitation is “speculative and not supported by the record” are “meritless” and “Consumers Energy projects sufficient capacity for planning year 2025-2026, even without the additional 700 ZRCs of capacity proposed to be acquired via the solicitation, and many possible sources could fill the 700 ZRCs once the bidding commences.” *Id.*, p. 8 (quoting WPSC’s initial brief, p. 9).

Consumers addresses WPSC’s claim that the settlement agreement would “treat Consumers Energy as an ‘island,’ and that a capacity shortfall would affect [WPSC] and other LSEs in the state.” Consumers reply brief, p. 8 (quoting WPSC’s initial brief, p. 10). Consumers asserts that:

Michigan law contemplates that each electric provider plan to serve its own projected loads; it does not require electric providers to serve other electric providers’ loads, unless a utility is required to provide backup capacity under the state reliability mechanism in situations in which alternative electric suppliers fail to demonstrate compliance with their own four-year forward capacity obligations.

Consumers reply brief, p. 8 (citing MCL 460.6w). Consumers discredits WPSC’s claims that the record does not support the settlement agreement. *See*, Consumers’ reply brief, p. 9.

Turning to Energy Michigan’s arguments, Consumers first agrees with Energy Michigan’s contention that “the Commission Rule 431 standards for approving a contested settlement must harmonize with Section 6t(8) [of Act 341], and cannot overrule it or provide a ‘different and weaker approval standard.’” Consumers reply brief, p. 9 (quoting Energy Michigan’s initial brief, p. 2). Consumers posits that the settlement agreement “meets all criteria for approval contained in MCL 460.6t(8) and Commission Rule 431.” Consumers reply brief, p. 9.

Consumers addresses Energy Michigan’s assertion that company testimony stating “that ‘Consumers Energy is not responsible to ensure the reliability of Zone 7 beyond its own capacity

obligations’ indicates that the Company has changed its position, given that Mr. Clark described the IRP as the best plan ‘for Michigan.’” *Id.*, p. 10 (quoting Energy Michigan’s initial brief, p. 3).

Consumers asserts that it has not changed its position. Specifically, Consumers states that:

The IRP, as set forth in the Settlement Agreement, remains the best plan for Michigan, as it will meet its customers’ energy needs, will satisfy the Company’s PRMR obligations within LRZ 7, and further the Company’s goal to be carbon neutral by 2040 and retire all coal generation by 2025. Having the best plan for Michigan does not mean that Consumers Energy must single-handedly supply sufficient capacity for every other utility’s expected load in Michigan. It means having a plan that meets all of Consumers Energy’s customers’ capacity needs in a manner that avoids unnecessary environmental impacts that affect the whole state and benefits the state’s economy positively. An IRP that accomplishes these objectives is best for Michigan.

Consumers’ reply brief, p. 10.

Consumers replies to Energy Michigan’s claim that the one-time solicitation might ultimately lead to PPAs with CMS Enterprises. *Id.* Consumers responds that “[t]he Company has not yet issued the solicitation, thus Energy Michigan is merely speculating which resources will win.” *Id.* Consumers avers that “even in the scenario that Energy Michigan envisions, no adverse impact on resource reliability or adequacy would result.” *Id.*

Consumers refutes Energy Michigan’s claim “that it was never invited to a settlement meeting, that its comments on the draft settlement agreement were neither welcomed nor considered,” and that Energy Michigan was explicitly told that no changes it sent the company would be considered. *Id.*, p. 11. Consumers posits that “[a] settlement meeting was held with all parties on February 16, 2022, and Energy Michigan’s counsel participated in that meeting. Energy Michigan did not engage in settlement discussions after that meeting, even though such engagement was encouraged by the Company.” *Id.* Further, Consumers states that “[b]eyond the February 16, 2022 settlement meeting, Energy Michigan was also engaged by the Company

regarding settlement on numerous occasions including March 28, 2022, April 15, 2022, and April 19, 2022.” *Id.*, pp. 11-12.

Consumers avers that “Energy Michigan’s assertions regarding the settlement process is irrelevant and beyond the scope of this case” as “other potential settlement outcomes are not within the scope of issues to be decided by the Commission in a contested settlement proceeding” *Id.*, p. 12 (citing June 7, 2019 order in Case No. U-20165). Consumers also posits that the “[Commission]’s Rules of Practice and Procedure make clear that reaching a total consensus is not required for settlement.” Consumers’ reply brief, p. 12. Consumers adds that “Rule 431 makes clear that a settlement may be ‘proposed by some of the parties.’” *Id.* (quoting Mich Admin Code, R 792.10431(3)). Further, Consumers quotes Rule 431 as stating that “‘provisions of these rules shall not be construed in any way to prohibit settlements.’” Consumers’ reply brief, pp. 12-13 (quoting Mich Admin Code, R 792.10431(3)).

Turning to the claims of the BMPs, Consumers argues that “even though the BMPs are claiming that the Settlement Agreement is flawed, they are at the same time conceding that all of those purported flaws melt away if the BMPs just get what they want—to amend the Settlement Agreement to force Consumers Energy to extend PPAs with its member plants.” Consumers’ reply brief, p. 14. Consumers posits that “[t]he BMPs’ position illuminates the fact that there are not really flaws in the Settlement Agreement, as the BMPs’ [sic] claim, and that the BMPs’ position merely seeks to promote their own economic interests.” *Id.* Further, Consumers avers that the BMPs have not established that their member plants are an economic and reasonable option for Consumers’ customers following the expiration of the current PPAs for those plants. *Id.* Consumers further reiterates its positions from brief that the company does not have an obligation to enter into new contracts with the BMPs, that the BMPs were considered in the development of

the IRP, and that the BMPs have not produced evidence that they represent a viable economic option. *Id.* Consumers asserts that the BMPs’ alternative proposal under Section 6t(6) of Act 341 is not supported because “the BMPs have failed to address and meet the filing requirements for an alternative proposal, as provided in the Certificate of Necessity and Integrated Resource Plan Alternative Filing Requirements.” Consumers’ reply brief, p. 15 (citing December 20, 2017 order in Case No. U-18461, Exhibit B). Consumers opines that the BMPs requested relief should be rejected because “[t]he BMPs have not established that their member plants will be an economic and reasonable resource option for customers and therefore, there is no basis to support the BMPs’ request to force the Company to extend PPAs with those plants.” Consumers’ reply brief, p. 16.

In response to the BMPs’ claims that the settlement agreement fails to meet the resource adequacy and reliability requirements of Sections 6t(8)(a)(i) and (iv) of Act 341, Consumers asserts that “[t]he Settlement Agreement ensures resource adequacy and capacity that is sufficient in quantity to serve anticipated peak electric load plus applicable PRMR and Local Clearing Requirement” Consumers’ reply brief, p. 17. Consumers argues that the settlement agreement has “maintained a balance of resource additions and retirements—backfilling capacity lost to accelerated retirement with the addition of new baseload resources, expansion of demand-response resources, expansion of renewable resources, and deployment of battery storage resources.” *Id.* (citing 10 Tr 4121). Consumers also reiterated that the settlement agreement provides mechanisms to procure additional capacity if needed. Consumers’ reply brief, p. 17. Consumers posits that the settlement agreement provides for “electric reliability assurance” and that the “flexibility of phased-in modular resources provided for in the Settlement Agreement PCA also provides the Company adequate time to mitigate cost, assess reliability within the reconfigured portfolio, and to modify as necessary.” *Id.*, p. 18.

Consumers contests the BMPs' claim that the company used an incorrect capacity accreditation for its solar resources. Consumers restates that the company's PCA "uses the current MISO solar capacity accreditation practices which provide solar with a 50% capacity accreditation." *Id.* (citing 10 Tr 4142). Consumers reiterates its arguments that "that MISO solar capacity accreditation value is also only relevant to newly installed solar and not solar that is in actual operation. Capacity accreditation at the Company's existing solar facilities has been as high as 65%, based on actual performance." Consumers' reply brief, p. 19 (citing 10 Tr 4142). Consumers argues that the company has supported its modeled capacity factor for solar with projections from third-party resources. Consumers' reply brief, p. 19. Thus, Consumers opines that the BMPs' resource adequacy and reliability arguments should be rejected. *Id.*

Responding to the BMPs' claims that the settlement agreement fails to meet the requirements of Section 6t(8)(b) of Act 341 and Governor Gretchen Whitmer's MI Healthy Climate Plan pursuant to ED 2020-10, Consumers argues that "the record establishes that the Settlement Agreement is aligned with that plan, and will help promote its success." Consumers' reply brief, p. 20. Consumers adds that to the extent the BMPs are arguing that additional imports from the market violate ED 2020-10, the PCA, as modified by the settlement agreement, "reduced the need for market purchases" and "continues to maintain that reduced market dependence through the purchase of the Covert Plant and one-time solicitation" *Id.*

Addressing the BMPs' assertion that Karn Units 3 and 4 could be designated as an SSR, Consumers reiterates that "an SSR designation would result from an electric transmission system deficiency that must be mitigated and not due to a capacity or energy shortfall." *Id.*, p. 21. Reiterating its earlier testimony, Consumers argues that the risk of an SSR designation is unsupported. *Id.*, pp. 20-21.

In response to the BMPs' assertion that the settlement agreement fails to appropriately balance the diversity of generation resources with the impacts on commodity price risk, Consumers asserts that the settlement agreement provides for a diverse portfolio of resources as outlined in its testimony. *Id.*, p. 21. Consumers posits that "[t]his resource mix represents a balanced and modular supply plan which provides flexibility to adjust to changes in fuel costs, technology cost, electric demand, or the business environment and insulates the Company and its customers from commodity price risks." *Id.* Further, Consumers asserts that this approach will "provide further opportunities for the utilization of diverse supply resources and protects against high customer rates." *Id.*

Consumers reiterates its arguments, outlined above, regarding the scope of the contested settlement agreement in response to the BMPs. *See, id.*, pp. 23-26. Consumers reasserts that the BMPs attempt to propose another version of the settlement agreement is "improper and not supported." Consumers' reply brief, p. 25. On pages 26 through 33 of its reply brief, Consumers addresses the BMPs' appeal of the ALJ's rulings.

Consumers asserts that Mackinac's objections to the settlement failed to comport with the Commission's procedural rules and should thus be disregarded. *Id.*, pp. 32-33.

Consumers requests the Commission approve the settlement agreement in its entirety without any modifications or conditions. *Id.*, p. 33.

5. Wolverine Power Supply Cooperative

WPSC argues that the settlement agreement "has neither the facts nor the law on its side and the Commission must reject it." WPSC's reply brief, p. 1. WPSC contends that the Staff has reversed its stance on the importance of resource adequacy as the Staff now contends that the settlement agreement "should be approved because Zonal resource adequacy is not Consumers'

problem to solve.” WPSC’s reply brief, p. 3 (citing Staff’s initial brief, p. 5). WPSC avers that while it is not the sole responsibility of Consumers to “ensure resource adequacy for the Zone, a significant component of the IRP framework is to ensure that a utility retiring resources does not do so in a manner that adversely impacts the Zone, which Consumers does here” and that “although Consumers may not be required to address a shortfall caused by others, it certainly must be required to address a shortfall it is creating.” *Id.* (emphasis omitted).

WPSC again avers that the settlement agreement is not supported by substantial evidence and that the company has not disputed the negative ZRC values for 2022-2023 and 2025-2026. *See, id.*, p. 4. WPSC reiterates concerns regarding the ELCC for solar assets, arguing that the 50% is not an accurate benchmark as “[i]t simply does not reflect reality, even if some are willing to pretend that it does.” *Id.* WPSC further states that it has “identified actual impediments to Consumers’ contemplated solar development and Consumers offered no explanation as to how it will overcome these hurdles, except to say there is time to address in future IRPs. [WPSC] identified the issues; Consumers identified no solutions.” *Id.*, p. 5.

Finally, WPSC argues that the Staff’s briefing lacks confidence “[m]uch like Consumers’ failure to explain its solution to the hurdles related to solar development, Staff appears to be counting on speculative ‘other resources’ that are not identified in brief or the record.” *Id.* Therefore, WPSC avers that the settlement agreement is speculative and should be denied under Rule 431(5).

6. The Biomass Merchant Plants

In reply to Consumers, the BMPs reference their initial brief to respond to the claim that the BMPs’ “requested relief is beyond the scope of these proceedings” averring that “[i]t is not.” BMPs’ reply brief, p. 2. The BMPs reiterate that while “PURPA may no longer require

Consumers to purchase generation from the Biomass Plants [that] does not mean that such purchases are not reasonable and prudent as a matter of state law” and that Consumers has done everything possible “to exclude the Biomass Plants from the IRP, regardless of whether or not including them would be reasonable and prudent.” *Id.* (citing to BMPs’ initial brief, p. 29-38). Reiterating the testimony and briefing, the BMPs state that the company never requested cost information from the BMPs and failed to explain why the cost of new construction was utilized for biomass generation. *See*, BMPs’ reply brief, pp. 2-4.

Responding to Consumers’ contention that the BMPs would be eligible to bid into the first tranche of the one-time solicitation, the BMPs aver that:

[w]hile the Biomass Plants can be dispatched within their operational limits, they cannot be dispatched within one hour if they are not running. That fact, in addition to the fact that all of the Biomass Plants’ current contracts extend into the 2025 to 2030 time period will exclude them from bidding in that solicitation.

Id., p. 4 (referencing Consumers’ initial brief, p. 45). The BMPs again reference objections and excluded evidence which they aver were inappropriately ruled upon by the ALJ. The BMPs aver that Consumers failed to discuss “whether [Consumers] is likely to sign power purchase agreements with [the CMS plants] as a result of the first tranche of the One Time Solicitation, which is probable.” *Id.*, pp. 5-6. Further, the BMPs restate record testimony to aver that Consumers has still failed to rebut the BMPs’ testimony regarding the overstated solar capacity factor the company has utilized, and the risk associated with proposed solar additions. *See, id.*, pp. 6-10. The BMPs argue that Consumers’ dismissal of the risks relating to the solar additions, and “its refusal to add the 188 MW of baseload, net zero carbon, renewable generation from the Biomass Plants to its IRP” are invalid and raise “serious questions as to whether the Biomass Plants are being excluded from the IRP for some other undisclosed commercial reason.” *Id.*, pp. 10-11.

V. Discussion

The Commission finds that the contested settlement agreement at issue in this case should be approved.

As stated above, Commission approval of a contested settlement agreement is appropriate where the Commission determines the following requirements have been met: (1) that the objecting parties have been given a reasonable opportunity to present evidence and arguments in opposition to the settlement agreement, (2) the public interest is adequately represented by the parties who entered into the settlement agreement, (3) the settlement agreement is in the public interest, (4) the settlement agreement represents a fair and reasonable resolution of the proceeding, and (5) the settlement agreement is supported by substantial evidence on the record as a whole.

Mich Admin Code, R 792.10431.

The Commission finds that all the requirements of Rule 431 have been met. The Commission has provided a reasonable opportunity to those parties that objected to the settlement agreement to present evidence and argument in opposition to the settlement agreement. The parties were given the opportunity to submit direct and rebuttal testimony, file initial and reply briefs, and appear at an evidentiary hearing regarding the contested settlement agreement before a presiding officer. As the parties to this case observed, the principal record in this case consists of 4,094 pages of transcript and over 500 exhibits admitted into evidence. The record on the contested settlement alone consists of 315 additional pages of transcript and 22 additional exhibits admitted into evidence.

With respect to the second criterion, the record shows that the signatories to the settlement agreement represent a broad cross-section of interests, including residential customers, commercial and industrial customers, businesses in Michigan's advanced energy sector, environmental groups,

a transmission company, and third-party developers. *See*, 10 Tr 4407-4408. The Commission also notes that the Court of Appeals has affirmed the Commission's determination that the public interest is adequately represented by the Staff when the Staff is party to a contested settlement agreement. *Attorney General v Mich Pub Serv Comm*, 237 Mich App 82, 93-94; 602 NW2d 225 (1999). Accordingly, the Commission finds that the public interest is adequately represented by the parties who entered into the settlement agreement.

Rule 431(5)(c) requires the Commission to make a three-part finding that: (1) the settlement agreement is in the public interest, (2) represents a fair and reasonable resolution of the proceeding, and (3) is supported by substantial evidence on the record as a whole.

The Commission finds that the settlement agreement is in the public interest. The Commission finds persuasive the testimony by Consumers and others that the settlement agreement was the result of good-faith negotiation that resulted in significant compromises for all involved. The negotiation of the parties is evident when comparing the details of Consumers' initial IRP filing with the terms of the proposed settlement agreement. Signatory parties to this case highlighted the following provisions as compromises reached by settlement that are in the public interest, represent a fair and reasonable resolution of the proceeding, and are supported by substantial evidence on the record as a whole:

- The agreement that Consumers retire Campbell Units 1, 2, and 3 in 2025, which will result in savings to ratepayers, reduce the production of environmental pollutants, such as SO₂, NO_x, and particulate matter, and advance Michigan's clean energy goals as outlined in the MI Healthy Climate Plan as well as provide additional public health benefits;

- The agreement that Consumers will purchase the Covert plant in 2023, which will add 1,114 ZRCs to MISO Zone 7 to support reliability for Consumers as well as overall resource adequacy of the Zone;
- The agreement to conduct a one-time solicitation for 200 ZRCs of capacity and associated energy and RECs, which will provide additional clean capacity resources for Consumers' portfolio;
- The agreement that Consumers will deploy the battery program outlined in the rebuttal testimony in the principal case which will formalize an important component of a cleaner energy grid while enhancing reliability and resource adequacy;
- The agreement to seek recovery of the unrecovered book value and decommissioning costs of retiring coal units through regulatory asset treatment, rather than continued recovery through traditional ratemaking, which provides the potential for customer savings;
- The agreement that Consumers will donate \$5 million dollars in shareholder funds to support bill assistance for lower-income customers along with continued annual donations;
- The agreement that Consumers will provide beneficial modeling in its next IRP, including total emissions, annual particulate matter health impacts, an environmental justice screening tool, projected low-income energy efficiency participation levels, publicly available rooftop solar adoption rates, and transmission import analysis; and
- The agreement that Consumers will take steps to engage and gather input from the public prior to the filing of its next IRP with the Commission, which will ensure that additional information and perspectives are available to inform both the company's assessment of its future resource options as well as Commission and stakeholder review of its proposals.

Energy Michigan, WPSC, the BMPs, and Mackinac disagree with the conclusion that the settlement is in the public interest and represents a reasonable resolution to the proceeding. The objecting parties' concerns involve the resource adequacy, reliability, and competitive pricing in MISO Zone 7. Specifically, the objecting parties argue that: (1) the settlement agreement does not meet the resource adequacy needs of MISO Zone 7 and (2) the one-time competitive solicitation will not adequately replace the capacity from retiring coal-fired generation. Each of these concerns are addressed in turn.

A. The Resource Adequacy of Zone 7

The parties objecting to the settlement agreement claim that the settlement agreement does not address the need for incremental capacity replacements in MISO Zone 7 following the retirement of Campbell Units 1, 2, and 3 to meet the resource adequacy requirements of the zone. As such, the objecting parties conclude that Consumers' PCA fails to meet the resource adequacy requirements of Section 6t(8)(a)(i) and (iv) that the Commission must balance "[r]esource adequacy and capacity to serve anticipated peak electric load, applicable planning reserve margin, and local clearing requirement" and "reliability" to determine that the integrated resource plan is the most reasonable and prudent means of meeting energy and capacity needs. The Commission disagrees.

The Commission finds the testimony of the Staff, MNS, and Consumers compelling. As Consumers testifies, the settlement agreement continues the annual solicitation process adopted by the company in its 2018 IRP. 10 Tr 4121. By preserving the solar ramp-up proposed in the original PCA, the settlement agreement adds 250 ZRCs of new solar generation by the 2025/2026 PY, increasing to 852 ZRCs by the 2028/2029 PY. 10 Tr 4350. The settlement agreement provides that Consumers will deploy a new utility-scale battery storage program which will add

approximately 71 ZRCs of new capacity to the zone. 10 Tr 4350. Finally, preserving the EWR and DR provisions from Consumers’ original PCA, the settlement provides 94 ZRCs of demand-side resources by the 2025/2026 PY, increasing to 2031 ZRCs by the 2028/2029 PY. The settlement also provides for increases in both the demand-side resources and solar resources in later years. 10 Tr 4350.

In addition to these new resources, the settlement agreement provides for the acquisition of the Covert plant, which will transfer approximately 1,114 ZRCs from PJM into MISO Zone 7. 10 Tr 4123, 4225, 4230, 4331. The settlement agreement has the effect of adding approximately 770 ZRCs through the continued operation of Karn Units 3 and 4 until May 31, 2031, consistent with the design lives of those units. 10 Tr 4225, 4334.

MNS provides that “the settlement [agreement] will result in a projected net increase of at least 127 ZRCs. By 2028/29, the projected net increase will be at least 923 ZRCs.” 10 Tr 4350. The Staff further contends that, “[t]he Company was originally proposing to retire approximately 2800 MW (nameplate) generation from MISO Zone 7 . . . ,” meanwhile the settlement agreement “only retires a portion of that amount, approximately 1500 MW” 10 Tr 4405. The projections by both MNS and the Staff are in addition to any resources that may be acquired through the one-time solicitation, discussed below. 10 Tr 4351-4352, 4406. As Consumers observes, the settlement agreement provides for more capacity in Zone 7 than was included in the company’s originally filed PCA. 10 Tr 4230. The Commission thus finds that the settlement agreement provides a reasonable and prudent plan for meeting resource adequacy requirements.

The Commission acknowledges the larger resource adequacy concerns of the objecting parties as valid and timely. The broader resource adequacy of Zone 7 and the MISO region has an impact on both Consumers’ customers and the state as a whole. The Commission observes that the

2022/2023 MISO PRA results indicate a capacity shortfall for the MISO North and Central Regions.⁵ These auction results indicate that many LSEs in MISO will experience a greater risk of implementing involuntary conservation measures even though many of them would appear to be resource adequate when viewed as a stand-alone entity. While the market construct within MISO allows for the pooling of resources to lower the total cost to customers, this market construct means that the planned retirements and resource decisions of one utility impact the customers of other utilities within the Zone and the greater regional transmission organization (RTO).

While the Commission agrees with Consumers' assertion that the company is not responsible for the reliability of the entirety of MISO Zone 7, it is also clear that a deficiency in any part of Zone 7 would increase the likelihood of grid outages for all customers in Zone 7, including those served by Consumers.

As noted above, however, the approval of the settlement agreement enhances zonal resource adequacy in the short, medium, and long term(s). In the short term, the acquisition of the Covert plant will transfer approximately 1,114 ZRCs from PJM into MISO, providing much needed additional capacity to LRZ 7 for the next MISO PY. In the long term, as noted by Mr. Jester, "[c]ontinuing to operate Karn 3-4 supports Consumers' attainment of planning reserve margin requirements by maintaining more than 780 ZRCs in the Company's portfolio." 10 Tr 4334. And as the Staff noted, the settlement agreement represents "a resource adequacy improvement over the Company's original PCA[.]" and provides for approximately 400 ZRCs of new resources within

⁵ The resources in the MISO region operate as a shared pool of resources to meet the PRMR. As demonstrated in the MISO 2022/2023 PRA results, capacity shortfalls in four MISO Zones resulted in the entirety of the MISO North/Central Regions having a slightly increased risk of needing to implement temporary controlled load sheds. The 2022/2023 PRA results are available at: <https://cdn.misoenergy.org/2022%20PRA%20Results624053.pdf> (accessed, June 17, 2022).

MISO Zone 7 by 2025, in addition to the one-time solicitation for 700 MW set forth in the settlement agreement. 10 Tr 4405, 4406. Finally, while acknowledging the challenges to resource adequacy that were highlighted in MISO's recent PRA results, the Commission notes Consumers' testimony that it "will file at least one, if not multiple, IRPs" between now and when any projected shortfalls are likely to occur, and that it will have "ample time to respond and adjust the PCA" if necessary. 10 Tr 4143-4144. As such, the Commission is satisfied that the approval of the settlement agreement will enhance resource adequacy in Zone 7 in both the near-term and long-term.

In order to ensure future IRPs appropriately consider zonal resource adequacy in addition to the resource requirements of a particular utility, the Commission directs the Staff to include a requirement for each utility to consider the impacts of its PCA on the resource adequacy of its own customers, the LRZ in MISO or its equivalent in PJM, and also assess the potential impacts, if any, of its decisions on customers in neighboring Zones, regions, or RTOs in the upcoming IRP filing requirements update in Case No. U-18461 in order to better enable the Commission to determine whether future PCAs meet resource adequacy needs of the LRZ.

B. The One-Time Solicitation

The parties objecting to the settlement agreement also express concerns regarding the one-time solicitation as it is outlined in the settlement agreement. Among the concerns, Energy Michigan asserts that the 500 ZRC capacity need that Consumers is seeking to fill through the first tranche of the one-time solicitation will result in capacity that is not additional to what is already being counted toward MISO Zone 7's resource adequacy requirements. 10 Tr 4297. The BMPs and WPSC express concerns that the timing and framing of the one-time solicitation will not result in new resources being added to the market. Specifically, these two parties assert that it will not

be possible for new generation to obtain a MISO Interconnection Services Agreement, complete project engineering, obtain financing, and construct a new plant by 2025, as the settlement agreement requires the generation to provide Consumers with a capacity credit in MISO Zone 7 by 2025. The Commission finds that this reasoning for denying the settlement agreement is speculative. As several parties contended, the terms of the settlement agreement require that the resources acquired be competitively sourced. The Commission finds persuasive testimony that “respondents to the solicitation could be from some of the projects currently in the MISO queue . . . that makes up nearly 1,800 MW of projects that are currently in Study Phase 2 or 3.” 10 Tr 4404 (footnote omitted). And further that “there are more than 13,011 MWs of solar, battery, and solar/battery hybrid projects located in MISO Zone 7 that have an application in-service date by or before June 1, 2025 Of these projects, 5,365 MW of solar, 499 MW of solar/battery hybrid, and 370 MW of battery have completed Phase 2 or Phase 3 interconnection studies and are therefore highly likely to proceed if the developer has an offtake or build-transfer agreement.” 10 Tr 4363-4364 (footnotes omitted). The Commission finds that the one-time solicitation is in the public interest as it is likely to contribute to—or at a minimum not be detrimental to—the overall resource adequacy of MISO Zone 7.

However, to clarify, the Commission does not interpret the language of the settlement agreement to mean that it is pre-judging any approval requests it may receive from Consumers as a result of this one-time solicitation or any other approval requests that Consumers may file following the implementation of its PCA. The language of the settlement reads:

[T]he actual selected bid(s) will be submitted in Case No. U-21090 for Commission approval subsequent to the completion of the One-Time Solicitation;

In that approval proceeding, the Commission shall: (i) confirm whether the solicitation process followed by the Company is consistent with the requirements of the Settlement Agreement; (ii) grant approval of the recovery

of the costs associated with the selected project(s) pursuant to applicable law or make a preliminary finding that the costs associated with the project(s) that prevail in the solicitation are reasonable and prudent; and (iii) grant any other approvals or findings necessary as required or provided by applicable law.

Settlement Agreement, pp. 6-7. As such, the Commission will examine the results of the one-time solicitation carefully and will scrutinize any effects it may have on resource adequacy and competitive pricing in Zone 7.

Having addressed each of the arguments as to whether the settlement agreement is in the public interest and represents a fair and reasonable resolution of the proceeding, the Commission finds that, for all the reasons set forth, the settlement agreement is in the public interest. The Commission also finds that the proposed settlement agreement is a fair and reasonable resolution of this proceeding. In addition, having read the record, the Commission likewise finds the settlement agreement to be supported by substantial evidence on the record as a whole. Moreover, as agreed to by the parties in paragraph 1 of the settlement agreement and supported by the record, the Commission finds that Consumers' PCA as amended by the settlement agreement is the most reasonable and prudent means of meeting Consumers' energy and capacity needs and otherwise meets the requirements of MCL 460.6t(8).

THEREFORE, IT IS ORDERED that:

- A. The settlement agreement, attached as Exhibit A, is approved.
- B. Unless otherwise provided in the settlement agreement, the terms of the approved settlement agreement shall take effect immediately upon issuance of this order.
- C. The Commission Staff shall include a requirement for each affected utility to consider the impacts of its proposed course of action on the resource adequacy of its own customers, the Midcontinent Independent System Operator, Inc. Local Resource Zone or respective PJM

Interconnection, L.L.C. Zone, and neighboring Zones, regions, or regional transmission organizations in the updated integrated resource plan filing requirements to be filed on June 30, 2022, in Case No. U-18461, as outlined in this order.

D. In accordance with paragraph 11(g) of the settlement agreement, Consumers Energy Company shall file, within 30 days of this order, revised Standard Offer tariff sheets and a revised Standard Offer contract, to reflect the Standard Offer construct and rates approved as part of the approved settlement agreement. Also pursuant to paragraph 11(g), parties shall have 14 calendar days subsequent to these filings to provide comments to the Commission in this docket.

The Commission reserves jurisdiction and may issue further orders as necessary.

Any party desiring to appeal this order must do so in the appropriate court within 30 days after issuance and notice of this order, under MCL 462.26. To comply with the Michigan Rules of Court's requirement to notify the Commission of an appeal, appellants shall send required notices to both the Commission's Executive Secretary and to the Commission's Legal Counsel. Electronic notifications should be sent to the Executive Secretary at mpscedockets@michigan.gov and to the Michigan Department of the Attorney General – Public Service Division at pungpl@michigan.gov. In lieu of electronic submissions, paper copies of such notifications may be sent to the Executive Secretary and the Attorney General – Public Service Division at 7109 W. Saginaw Hwy., Lansing, MI 48917.

MICHIGAN PUBLIC SERVICE COMMISSION




Daniel C. Scripps, Chair



Tremaine L. Phillips, Commissioner

By its action of June 23, 2022.



Lisa Felice, Executive Secretary

STATE OF MICHIGAN

BEFORE THE MICHIGAN PUBLIC SERVICE COMMISSION

In the matter of the application of	)	
CONSUMERS ENERGY COMPANY	)	
for Approval of an Integrated Resource Plan	)	Case No. U-21090
under MCL 460.6t, certain accounting	)	
approvals, and for other relief.	)	
_____	)	

SETTLEMENT AGREEMENT

Pursuant to MCL 24.278 and Rule 431 of the Michigan Administrative Hearing System's Rules of Practice and Procedure before the Michigan Public Service Commission ("MPSC" or the "Commission"), the undersigned parties agree as follows:

WHEREAS, on June 30, 2021 Consumers Energy Company ("Consumers Energy" or the "Company") filed an Application requesting approval of the Company's Integrated Resource Plan ("IRP") pursuant to Section 6t of 2016 PA 341, MCL 460.6t, the Commission's June 7, 2019 Order Approving Settlement Agreement in Case No. U-20165, and all other orders and applicable law. The Company filed testimony and exhibits in support of its positions concurrently with its Application.

WHEREAS, the initial prehearing conference was held on July 22, 2021 before Administrative Law Judge ("ALJ") Sally L. Wallace. Beyond the Company, the parties to the IRP are: the MPSC Staff ("Staff"); the Attorney General; Hemlock Semiconductor Operations, LLC ("HSC"); the Biomass Merchant Plants ("BMPs")¹; Michigan Environmental Council, Natural Resources Defense Council, and Sierra Club ("MNS"); Great Lakes Renewable Energy

¹ The BMPs consist of: Cadillac Renewable Energy, LLC, Genesee Power Partners Limited Partnership, Decker Energy-Grayling, LLC, Hillman Power Company, LLC, Tondur Corporation, National Energy of Lincoln, LLC, f/k/a Viking Energy of Lincoln, LP and National Energy of McBain, f/k/a Viking Energy of McBain, LLC.

Association (“GLREA”), Environmental Law and Policy Center, the Ecology Center, Vote Solar, and the Union of Concerned Scientists (collectively, the Clean Energy Organizations (“CEO”)); Residential Customer Group (“RCG”); Association of Businesses Advocating Tariff Equity (“ABATE”); Michigan Energy Innovation Business Council, Institute for Energy Innovation, and the Clean Grid Alliance (collectively, “Michigan EIBC/IEI/CGA”); Energy Michigan, Inc. (“Energy Michigan”); Midland Cogeneration Venture Limited Partnership (“MCV”); Michigan Electric Transmission Company, LLC (“METC”); Michigan Public Power Agency (“MPPA”); Wolverine Power Supply Cooperative (“Wolverine”); the Citizens Utility Board (“CUB”); the Mackinac Center for Public Policy (“Mackinac”); and the Urban Core Collective (“UCC”). 1 TR 11-12, 22.

WHEREAS, Consumers Energy filed testimony and exhibits requesting approval of the Company’s IRP Proposed Course of Action (“PCA”) in its entirety, as the most reasonable and prudent means of meeting the Company’s energy and capacity needs through 2040. The Company specifically requested the Commission to make the following determinations:

- (i.) Approve Consumers Energy’s PCA, which is inclusive of all proposals presented by the Company in this case, including the battery deployment program, as the most reasonable and prudent means of meeting the energy and capacity needs of the Company and its customers;
- (ii.) Approve the Company’s acquisition and proposed purchase costs for the New Covert Generating Facility (“Covert Plant”) and Dearborn Industrial Generation (“DIG Plant”), the Livingston Generating Station (“Livingston Plant”), and the Kalamazoo River Generating Station (“Kalamazoo Plant”), in the manner proposed by the Company, and proposed Energy Waste Reduction (“EWR”), Demand Response (“DR”), and Conservation Voltage Reduction (“CVR”) costs which will be commenced by the Company within three years following the Commission’s expected approval of the Company’s IRP;
- (iii.) Approval of the selection and proposed purchase of the DIG, Kalamazoo, and Livingston plants, by the Company from its affiliate, CMS Enterprises. The transaction was a result of a competitive solicitation and is compliant with the Commission’s Code of Conduct requirements. In the alternative, while complying with all other provisions of the Code of Conduct, the Company

requests a waiver of the asset transfer provision of the Code of Conduct, Mich Admin Code R 460.10108(4), for the acquisition of the DIG, Livingston, and Kalamazoo plants, from CMS Enterprises;

- (iv.) Approve the Company's proposal to recover the unrecovered book balances of D.E. Karn ("Karn") Units 3 and 4 and J.H. Campbell ("Campbell") Units 1, 2, and 3, including decommissioning costs, through regulatory asset treatment, with full return, over the design lives of those units;
- (v.) Approve the Company's proposals to: (i) defer employee retention costs related to the proposed accelerated retirements of Karn Units 3 and 4 and Campbell Units 1, 2, and 3, and (ii) defer retirement transition costs for future recovery;
- (vi.) Approve the Company's proposed modifications to its Public Utility Regulatory Policies Act of 1978 ("PURPA") construct and the Company's proposed competitive procurement process and the use of that competitive procurement process for: (i) determining PURPA avoided costs rates, and (ii) determining and addressing the Company's capacity position under PURPA;
- (vii.) Determine that the Company has no PURPA capacity need so long as the Company is implementing the PCA, with the competitive procurement process proposed by the Company; and
- (viii.) Approve the Company's proposed Financial Compensation Mechanism ("FCM") for any new, or newly amended, Power Purchase Agreements ("PPAs") entered into by the Company.

Staff and other intervening parties filed testimony and exhibits addressing various issues.

NOW THEREFORE, for purposes of settlement of Case No. U-21090, the undersigned parties agree as follows:

1. The parties agree that the Company's PCA, as modified in this Settlement Agreement, should be approved as the most reasonable and prudent means of meeting the Company's energy and capacity needs over the 5-year, 10-year, and 15-year time horizons. The parties agree that the Company will file its next IRP consistent with the requirements of MCL 460.6t.

2. The parties agree that the PCA shall include the Company's proposed purchase of the Covert Plant in 2023 but shall not include the ownership of the DIG, Kalamazoo, and

Livingston plants. The parties agree that the identified capital costs that the Company will incur for DR (\$23,751,000), CVR (\$9,736,315), and the purchase of the Covert Plant (\$815 million) in the next three years (June 2022 – June 2025) are reasonable and prudent and approved for cost recovery purposes and will be included in rates in a future Company rate case consistent with MCL 460.6t(11) and (17). The parties further agree to the approval of the projected capacity value provided by the Covert Plant and the DR (projected to achieve a total of 641 MW (657 Zonal Resource Credits (“ZRCs”)) by 2025), CVR (projected to achieve 136,351 MWh savings by 2025, 56.81 MW savings by 2025), and EWR (projected to achieve 545,305 MWh savings in 2025, 879 MW savings by 2025) resources included in the PCA during the next three years. The parties further agree that the Company shall continue to file an annual reporting template with the Commission addressing the implementation of the approved DR and CVR resources above.

3. The parties agree to the approval of the battery deployment program as proposed by Company witness Richard T. Blumenstock. The parties agree that the Company will conduct stakeholder outreach to solicit feedback regarding the battery deployment program prior to the issuance of the first battery deployment program competitive solicitation. The approval to recover the costs associated with the batteries acquired in the battery deployment program will be sought in future electric rate cases.

4. The parties agree that (i) Karn Units 3 and 4 will be retired on or before May 31, 2031, absent extraordinary circumstances that require prolonged operation, such as a System Support Resource designation by Midcontinent Independent System Operator, Inc. (“MISO”) or other emergent issues within the Company’s generation portfolio which require continued

operation of Karn Units 3 and 4 to maintain sufficient supply; and (ii) Campbell Units 1, 2, and 3 will be retired on or before May 31, 2025.

5. The parties agree that the Company will not file an application for a financing order for the unrecovered book balance and decommissioning costs of Campbell Units 1, 2, and 3. The parties agree that the Commission will permit Consumers Energy to recover the unrecovered book balance of Campbell Units 1, 2, and 3 through the Company's proposed regulatory asset treatment, with a return equal to the Company's weighted average cost of capital ("WACC") premised on the return on equity approved by the Commission in rate cases prior to the retirement date of those units and a 9.0% return on equity after the retirement date of those units, as part of the Company's electric rates over the current design lives of those units. The 9.0% return on equity will be used to modify the capital structure filed with each rate case and the return on equity will be the only modification to the capital structure used to calculate the return on the regulatory asset after the retirement date of the units. The parties further agree that the Company will be permitted to record a regulatory asset for actual decommissioning spending for Campbell Units 1, 2, and 3, with a return on the regulatory asset, with subsequent rate recovery in a rate case after a review of the reasonableness and prudence of the expenses. Recovery of the associated decommissioning and ash disposal costs will be treated as follows:

- a. The decommissioning costs, less salvage value, related to Campbell Units 1, 2, and 3 and the ash disposal costs related to Campbell Units 1, 2, and 3 will be recorded, as spent, to a regulatory asset; and
- b. The Company may request recovery in future base rate proceedings, and upon Commission determination that the Company has incurred those costs as the result of reasonable and prudent actions, they shall be included in rates. The Company will ensure that the amounts recovered through a regulatory asset account are net of any accumulated depreciation amounts.

6. The parties agree that subsequent to the Commission's order approving this Settlement Agreement, the Company shall issue a competitive solicitation ("the One-Time Solicitation") which will include the following parameters:

- a. The One-Time Solicitation will seek projects which will provide the Company with capacity credit in the MISO Zone 7 starting in the 2025 Planning Year;
- b. The One-Time Solicitation will include two all source tranches:
 - i. The first tranche will seek up to 500 ZRCs of capacity and associated energy and renewable energy credits ("RECs"), if applicable, from PPAs with terms up to 10 years. This tranche will seek dispatchable, non-intermittent generation capable of dispatching up or down in every hour of the year in response to wholesale energy market signals, providing capacity which meets the Local Clearing Requirement of MISO Zone 7; and
 - ii. The second tranche will seek up to 200 ZRCs of capacity and associated energy and RECs, if applicable, secured from unaffiliated third parties via PPAs or other third-party agreements that do not result in Company ownership with terms up to 25 years, at the discretion of the bidder. This tranche will seek intermittent resources and dispatchable, non-intermittent clean capacity resources (including battery storage resources), providing capacity which meets the Local Clearing Requirement of MISO Zone 7. This tranche will furthermore take into consideration the ability of the offered capacity to meet the Local Clearing Requirement of MISO Zone 7 for the duration of the contract length. Prior to the issuance of the second tranche portion of the One-Time Solicitation, the Company shall hold a stakeholder meeting including parties to this case and energy storage developers to discuss methods to improve RFPs and response to solicitations with respect to stand-alone storage projects and hybrid-storage projects.
- c. The Company's acquisition of the 700 ZRCs and associated energy and RECs, if applicable, sought in the One-Time Solicitation shall be considered incorporated into the PCA approved in Paragraph 1 of this Settlement Agreement. However, the actual selected bid(s) will be submitted in Case No. U-21090 for Commission approval subsequent to the completion of the One-Time Solicitation;
 - i. In that approval proceeding, the Commission shall: (i) confirm whether the solicitation process followed by the Company is consistent with the requirements of the Settlement Agreement; (ii) grant approval of the recovery of the costs associated with the selected project(s) pursuant to applicable law or make a preliminary finding that the costs associated

with the project(s) that prevail in the solicitation are reasonable and prudent; and (iii) grant any other approvals or findings necessary as required or provided by applicable law.

- d. The One-Time Solicitation will not be used to set the Company's avoided costs rates or capacity needs under PURPA.

7. The parties agree to the approval of the Company's proposed accounting request to defer expense related to the Campbell site severance and retention agreement, utilizing a regulatory asset to record the deferred amounts. The deferred amounts for 2022 will be capped at \$26 million. All amounts deferred for 2022 and beyond will be reviewed in future rate cases. This Settlement Agreement does not permit the Company to defer amounts related to the Campbell site severance and retention agreement outside of 2022.

- a. Consumers Energy will publicly file in Case No. U-21090 its community transition plan for Karn Units 1 through 4 within 150 days of all four Karn Units ceasing operation; and
- b. Consumers Energy will develop a draft community transition plan for the Campbell site. During the development of this draft community transition plan for the Campbell site, Consumers Energy will consult with community-based organizations and community members living in the area surrounding the retired assets on the community transition plan before finalizing and filing it for informational purposes in Case No. U-21090.

8. The parties agree to the extension of the annual competitive bidding process used to acquire the supply-side resource technologies specified in the PCA, as approved in Case No. U-20165 (collectively the "Annual Solicitations" and individually an "Annual Solicitation"), with certain modifications included below:

- a. Qualifying Facilities ("QFs") that the Company has a legal obligation to purchase from under PURPA (such facilities are referred to as "QFs" in this Settlement Agreement), may bid any technology into the Annual Solicitation but will be required to submit an offer consistent with the PPA terms sought in the Annual Solicitation;
- b. The competitive bid process shall be administered by an independent third party. The evaluation criteria and process is to be made available to all bidders submitting responses for the specific technology requested by the

Company, as part of the RFP, to ensure transparency. QFs may bid any technology that meets the requirements of PURPA. A ranking of proposals is to be used by the independent third party and provided to the Company for selection;

- c. In its September 9, 2021 Order in Case No. U-20852 the Commission adopted competitive bidding guidelines titled “Competitive Procurement Guidelines for Rate-Regulated Electric Utilities (Not for PUPRA Compliance) and “Competitive Procurement Guidelines For Rate-Regulated Electric Utilities for PURPA Avoided Cost and Capacity Determination.” The “Objective” of the adopted guidelines provides that when the guidelines are utilized by utilities, it is presumed that resulting projects and contracts are reasonable and prudent and in the event utilities diverge from the guidance provided in the guidelines, it is expected that the utility will provide sufficient justification in order to receive Commission approval and recovery. In the Annual Solicitation process, the Company will follow the Commission’s adopted guidelines, including the ability to diverge from the guidance as provided in the guidelines;
- d. The first competitive solicitation for the Company pursuant to this Settlement Agreement will be conducted no later than December 31, 2022. New full avoided cost rates stemming from each competitive solicitation will be filed with the Commission for review and approval within 30 days of the conclusion of each competitive solicitation;
- e. The Company will seek term lengths for competitively bid projects up to 25 years, at the discretion of the bidder;
- f. The Company will seek to acquire the target amount of capacity identified in the PCA for each Annual Solicitation period and may exceed that target amount depending on the amount of bids, the size of projects bid, cost and value, and variations in project commercial operation dates. Total newly acquired capacity will be reconciled against the amount of capacity projected in the PCA in the Company’s next IRP. (For example, if the Company acquired more capacity than planned, the proposed resource plan in the next IRP would incorporate that additional capacity with a potential reduction in the capacity needed going forward.);
- g. If the Company is unable to meet the target capacity amount identified in the PCA in any given Annual Solicitation, the remaining "open" capacity will not be offered to QFs. The remaining capacity would instead be addressed through the process described in Paragraph 8.f.;
- h. The parties agree and acknowledge that there are supply chain, energy security, labor, and environmental benefits associated with robust, local clean energy manufacturing capabilities. As part of the Company’s competitive bidding process, the parties agree that the Company will, to the extent

reasonably possible, incorporate clear, fair, and transparent criteria in the bid evaluation process to recognize value associated with clean energy supply chain diversification and sustainability, including intended use of Michigan manufactured components and low-carbon manufacturing as verifiable by life cycle assessment and/or disclosure using public, third-party verified environmental product declarations. The Company agrees to consult with parties to the settlement on the details of such bid evaluation criteria. Nothing in this settlement alters the opportunity for stakeholders and potential bidders to review and comment on any new proposed bidding criteria through the process as set forth in the MPSC's competitive bidding guidelines approved in MPSC Case No. U-20852 on September 9, 2021;

- i. The parties agree that the Annual Solicitation process does not restrict the Company's ability to make short-term capacity additions to address capacity shortfalls which cannot reasonably be addressed through the Annual Solicitation process; and
- j. The Company may pursue supply-side resource pilots for new and emerging technologies outside of an Annual Solicitation subject to cost and project approval in its future rate cases.

9. The parties agree that the new capacity that the Company intends to procure through the PCA, in each Annual Solicitation, shall be: (i) acquired through a competitive bidding process; and (ii) approximately 50% will be from PPAs and other third-party agreements that do not result in Company ownership and approximately 50% will be owned by the Company, as acquired through a competitive bidding process. The new capacity acquired from PPAs or other third-party agreements that do not result in Company ownership will not compete against the new capacity which will be owned by the Company. The Company will use commercially reasonable efforts to maintain the 50%/50% proportion for new IRP resources from 2022 through the Company's next IRP proceeding, and in no event shall any given annual solicitation result in the Company owning more than 60% of the new capacity acquired in such solicitation. The Company, in its sole discretion, may also choose to acquire more than 50% of its new capacity from third parties. The parties further agree that the Company's affiliates will

be prohibited from bidding on the portion of the Company's new capacity acquired from third parties.

10. The parties agree to the approval of the extension of the Company's FCM approved in Case No. U-20165 equal to the product of: (i) the annual PPA payment, and (ii) the Company's after-tax WACC based on its total capital structure, which is currently 5.62%, as updated from time to time by the MPSC in electric rate case final orders. The FCM will be applicable to all new PPAs, but will not apply to PPA amendments, PURPA PPAs, and Voluntary Green Pricing PPAs. The Company shall also not receive an FCM on any PPAs executed under the Company's Renewable Energy Plan. The FCM will be subject to the cap, as provided in Attachment A of the Settlement Agreement. The parties agree that nothing in this Settlement Agreement is intended to waive the requirements of MCL 460.6t(15).

11. The parties agree to the extension of the Company's PURPA avoided cost construct, as approved in Case No. U-20165 (based on the Company's Annual Solicitations), with certain modifications included below:

- a. The Company's PURPA avoided cost construct will be subject to review in the Company's future IRP filings, as opposed to separate biennial filings;
- b. QFs 150 kWac and below are eligible to receive full avoided cost rates regardless of the Company's capacity needs;
- c. Within 180 days subsequent to the Commission's approval of this Settlement Agreement, the Company shall initiate stakeholder outreach to develop a simplified agreement, tariff-based program, or other mechanism which will allow QFs 150 kWac and below to receive full avoided cost rates. Subsequent to the completion of the stakeholder outreach, at the earliest practicable date, the Company will file a proposal with the Commission for approval;
- d. When the Company does not have a PURPA capacity need, QFs above 150 kWac, that the Company has a legal obligation to purchase from under PURPA, are eligible to receive the Company's energy-only avoided cost rates. The Company's energy-only avoided cost rates shall be based on a forecast of LMPs for the first 5 years and actual LMPs for years 6 through 10. The

Company's energy-only avoided cost rates shall not include a payment for capacity;

- e. Current existing QFs, at or below the Company's PURPA must-purchase obligation MW threshold, with a PURPA-based PPA with the Company as of January 1, 2019 shall receive new PPAs, regardless of the Company's capacity need, upon the expiration of their current PPAs based on the Company's full avoided cost rates at the time of PPA expiration. QFs that entered a PPA with the Company prior to January 1, 2019 at an amount less than full avoided cost rates, such as reduced avoided cost rates based on the Planning Resource Auction ("PRA") rate and forecasted or actual LMPs and energy-only rates which only include an energy rate and do not provide a payment for capacity, shall not automatically receive a new PPA at the full avoided cost rate when their current PPA expires. QFs that have entered a PPA with the Company after January 1, 2019 are not eligible to receive a new full avoided cost rate PPA with the Company regardless of the Company's capacity need;
- f. QFs that the Company has a legal obligation to purchase from under PURPA, and which are eligible for full avoided cost rates, may select PPA terms up to 20 years; and
- g. QFs up to 5 MWac, that the Company has a legal obligation to purchase from under PURPA, are eligible for the Company's PURPA Standard Offer Tariff and Standard Offer Contract. The terms of the Standard Offer Contract will also be updated from using the MISO methodology for capacity accreditation at the time of PPA execution, to the average of the MISO methodologies at the time of PPA execution and delivery under the PPA. Within 30 days following the Commission's approval of this Settlement Agreement, the Company shall file revised Standard Offer tariff sheets and a revised Standard Offer contract, to reflect the Standard Offer construct and rates approved as part of this Settlement Agreement. Parties shall be given 14 calendar days subsequent to the Company's filing to provide comments to the Commission.

12. The Company has no PURPA capacity need so long as the Company is implementing the Commission-approved PCA, as provided in Paragraph 1, including the competitive Annual Solicitation process for future capacity needs.

13. The parties agree that the Company will donate \$5 million in 2022 to a low-income fund that provides bill assistance to Consumers Energy's electric customers. The Company will also donate \$2 million annually to the same low-income fund each year during the amortization period for the regulatory asset, provided in Paragraph 5 of this Settlement

Agreement, with each annual donation contingent on the Company filing and the Commission approving a Voluntary Revenue Refund (“VRR”). The donations described in this paragraph will not be recovered in rates and Consumers Energy will consult with the Attorney General and Staff on the low-income fund receiving the donations. The Company will provide an annual report to the Commission each year a donation is made. If known, the report will include the number of households served, the number of households over 150% of the federal poverty level (“FPL”), and number under 150% of the FPL. For those households 150% of FPL and under, the report will explain, if known, whether they are receiving the funds because they exhausted other benefits such as the Michigan Energy Assistance Program or State Emergency Relief.

14. In future IRPs, beginning with its next IRP, the Company will (i) collect the necessary data to compute marginal line losses and report these with average line losses and (ii) include marginal line losses and avoided transmission and distribution costs in its evaluation of all distributed resources, including residential DR potential.

15. Consumers Energy agrees to develop a distributed generation as a resource model approach that considers economic distribution connected solar to be modeled by bundling resources installed at the customer level to compare the total economic costs to the utility of distributed generation as a resource to other selectable supply-side resources, consistent with the methodology used for EWR. The Company will develop a model that accounts for all utility costs and/or incentives associated with participating and non-participating distributed generation customers. The Company agrees to present the model approach for stakeholder review and feedback prior to the next IRP. The model approach, including any incorporated stakeholder feedback, will be included into the Company’s next IRP.

16. The parties agree that Consumers Energy's IRP set forth a proposal to be Carbon Neutral by 2040 and retire all coal generation by 2025, 14 years ahead of the original timeline. These retirements include two substantial coal and gas units totaling approximately 2,000 MW. To replace the capacity, Consumers Energy has proposed adding existing natural gas-fired generation and plans to add about 8,000 MW of solar generation by 2040, to dramatically reduce the use of fossil fuel resources. The next IRP should consider transmission and how it can facilitate the mitigation of reliability and economic impacts to the electric system. The parties also agree that strategic investment in electric transmission needs continual assessment to understand the role of transmission in allowing for the most economic path to meeting the state's energy goals while complementing Michigan's Load Serving Entities' ("LSE") objectives. Michigan is transitioning its generation portfolio and must take the appropriate steps to increase system reliability, resiliency, flexibility, and affordability. Michigan will be better positioned by taking a forward-looking approach regarding resource adequacy. The state should continue to recognize and support the value of a multitude of resources such as Solar, Wind, DR, and Distributed Energy Resources which assist in an "all of the above" approach. Transmission is essential in delivering the reliability of these resources. The value of transmission can be even further realized by leveraging those transmission resources to better assist the Consumers Energy IRP. This will allow MISO LRZ 7 to access broader pools of generation resources, be better situated for future demands placed on the system, mitigate unnecessary risks, and increase performance of those "all of the above" resources to serve the demands of Michigan's customers reliably and economically.

17. The parties agree that the Company will include the following analysis in its next IRP:

- a. The Company will provide total emissions, in lbs or tons, and rate of emissions, in lbs or tons per MWh and per MMBtu, for each owned power plant unit, or units that the Company has a power purchase agreement with, for the last 5 years of operation (for existing units) and projected for the next 5 years (for all units) for the following pollutants: carbon dioxide, nitrogen oxides, sulfur dioxide, volatile organic compounds (“VOCs”), and primary particulate matter (“PM2.5”);
- b. The Company will calculate the annual PM2.5-related health impacts associated with each power plant’s emissions. The modeling will include the impacts from primary PM2.5 emissions and PM2.5 precursors emissions (nitrogen oxides, sulfur dioxide, VOCs). The Company will use one model to evaluate the number and economic value of PM2.5-related health impacts of these emissions. The Company may use COBRA or BenMAP (which will require pollutant change inputs from another model such as InMAP) for these calculations, or models that are of equal or greater complexity and accuracy. The Company will report the total number and economic value of PM2.5-related health impacts across the US for the chosen model and spatially by Michigan county or at a higher resolution;
- c. The Company will use the MiEJScreen mapping and screening tool, or, if the MiEJScreen tool is not yet finalized, the EPA Environmental Justice Screening and Mapping Tool (“EJSCREEN”), to assess populations in a 1-mile and 3-mile buffer around each power plant location, including reporting total populations and any indicators and total index results above the 75th percentile;
- d. The Company will report projected low-income energy efficiency participation levels, low-income load-reduction data, and publicly available rooftop solar adoption rates. If available, information on rooftop solar adoption by low-income customers will be provided;
- e. The Company will include a narrative discussion of how the data obtained in a-d were considered by the utility; and
- f. To the extent that the Commission formally adopts revised Integrated Resource Plan Filing Requirements and/or revised Michigan Integrated Resource Planning Parameters that address environmental emissions, health impacts from emissions, or environmental justice, such filing requirements will supersede the terms of this Paragraph 17.

18. The parties agree that the Company will take the following steps to engage and gather input from the public prior to the filing of its next IRP with the Commission:

- a. Host meetings about the topic of the filing at a variety of times, during the daytime and the evening, with the Company providing equivalent content and equivalent and sufficient time for robust public response at each session;
- b. Host meetings about the topics in the filing with a roughly equal mix between (i) in-person meetings and (ii) virtual or hybrid meetings;
- c. For the duration of the proceedings before the MPSC, make available on its website recordings of (i) all virtual or hybrid meetings and (ii) to the extent feasible, any portion of an in-person meeting in which the Company is (a) addressing all participants in the meeting and/or (b) receiving public feedback and/or questions in a format intended to be heard by all participants in the meeting at the same time;
- d. When requested 10 business days prior to a meeting, provide translations of materials for the benefit of those communities whose first language is not English, based on the demographics of the community;
- e. When requested within 30 days subsequent to a meeting, the Company will use best efforts to provide a translation of recordings of the community meeting in a language specified by the person requesting the translation. Such translation recordings will be provided within 15 business days, subject to the Company's best efforts, after the request is received. If the Company is unable, after a good faith effort, to find or reasonably engage the services of a translator capable of translating the recording into the language requested, the Company will not be obligated to provide the translation;
- f. When requested at least 10 business days prior to an in-person meeting, the Company will use best efforts to include at least one live interpreter who can translate in the requested language. If the Company is unable, after a good faith effort, to find or reasonably engage the services of a translator capable of translating the meeting into the language requested, the Company will not be obligated to provide the translation;
- g. Coordinate with community-based organizations when organizing and promoting meetings about the filing. The Company will solicit input regarding the time, place, and manner of the meetings from the community organizations, in addition to any other meetings the Company wishes to hold of its own accord;
- h. Use best efforts to present the details of the integrated resource planning process in accessible, non-technical language that includes, but is not limited to, descriptions of the impacts of the Company's plans on communities, the environment, and public health;
- i. Include in its filings a concise general statement of the basis and purpose of the comments received by the Company and how the Company considered,

addressed, or rejected the issues raised in those comments in the IRP (as practicable); and

- j. Subsequent to the issuance of the Commission's order approving this Settlement Agreement, the Company agrees to meet with UCC to discuss potential stakeholder outreach prior to or subsequent to future electric rate case filings.

19. The parties agree that the Company will do the following with respect to combined heat and power ("CHP") resources:

- a. Within 180 days of the effective date of the Commission's order approving the settlement, the Company will initiate a voluntary survey among its commercial and industrial customers to gauge interest in CHP (the "CHP survey"), with survey responses intended to be used by the Company to support the evaluation of: (1) the types of CHP that customers prefer, with regard to size, technology and overall configuration, on both the demand side and supply side, including co-ownership arrangements and other potential partnerships with the Company, and: (2) non-confidential information regarding locations within the Consumers Energy territory that may be most appropriate for deployment of CHP. The CHP survey will be conditioned on respondent approval of the public release of all information provided by the respondent in response to the survey. Nothing in this section is intended to require the public release of any confidential and/or commercially sensitive customer or Company information;
- b. Within 360 days of the effective date of the Commission's order approving the settlement, the Company will share the results of the CHP survey in the Case No. U-21090 e-docket, including a summary of the types of CHP that customers prefer, with regard to size, technology, and overall configuration, on both the demand side and supply side, including co-ownership arrangements and other potential partnerships with the Company; and a summary of non-confidential information regarding locations within the Company's territory that may be most appropriate for deployment of CHP, according to the CHP survey results;
- c. In its next IRP proceeding, the Company will model behind-the-meter CHP representative of a demand-side resource based upon the results from the CHP survey as appropriate; and
- d. In its next IRP proceeding, the Company will model front-of-the-meter CHP configurations based upon the results from the CHP survey as appropriate.

20. This settlement is entered into for the sole and express purpose of reaching a compromise among the parties. All offers of settlement and discussions relating to this settlement are, and shall be considered, privileged under MRE 408. If the Commission approves this Settlement Agreement without modification, neither the parties to this Settlement Agreement nor the Commission shall make any reference to, or use, this Settlement Agreement or the order approving it, as a reason, authority, rationale, or example for taking any action or position or making any subsequent decision in any other case or proceeding; provided, however, such references may be made to enforce or implement the provisions of this Settlement Agreement and the order approving it.

21. This Settlement Agreement is based on the facts and circumstances of this case and is intended for the final disposition of Case No. U-21090. So long as the Commission approves this Settlement Agreement without any modification, the parties agree not to appeal, challenge, or otherwise contest the Commission order approving this Settlement Agreement. Except as otherwise set forth herein, the parties agree and understand that this Settlement Agreement does not limit any party's right to take new and/or different positions on similar issues in other administrative proceedings, or appeals related thereto.

22. This Settlement Agreement is not severable. Each provision of the Settlement Agreement is dependent upon all other provisions of this Settlement Agreement. Failure to comply with any provision of this Settlement Agreement constitutes failure to comply with the entire Settlement Agreement. If the Commission rejects or modifies this Settlement Agreement or any provision of the Settlement Agreement, this Settlement Agreement shall be deemed to be withdrawn, shall not constitute any part of the record in this proceeding or be used for any other purpose, and shall be without prejudice to the pre-negotiation positions of the parties.

23. The parties agree that approval of this Settlement Agreement by the Commission would be reasonable and in the public interest.

24. The parties agree to waive Section 81 of the Administrative Procedures Act of 1969 (MCL 24.281), as it applies to the issues resolved in this Settlement Agreement, if the Commission approves this Settlement Agreement without modification.

WHEREFORE, the undersigned parties respectfully request the Commission to approve this Settlement Agreement on an expeditious basis and to make it effective in accordance with its terms by final order.

MICHIGAN PUBLIC SERVICE COMMISSION STAFF

By: **Spencer Sattler**
Digitally signed by Spencer Sattler
Date: 2022.04.19 14:00:30 -04'00'

Date: April 19, 2022

Spencer A. Sattler, Esq.
Amit T. Singh, Esq.
Nicholas Q. Taylor, Esq.
Assistant Attorneys General
7109 West Saginaw Highway
Post Office Box 30221
Lansing, MI 48909

CONSUMERS ENERGY COMPANY

By:  Digitally signed by
Robert W. Beach
Date: 2022.04.19
11:44:05 -04'00'

Date: April 19, 2022

Shaun M. Johnson (P69036)
Bret A. Totoraitis (P72654)
Robert W. Beach (P73112)
Anne M. Uitvlugt (P71641)
Gary A. Gensch (P66912)
Theresa A. G. Staley (P56998)
Michael C. Rampe (P58189)
Ian F. Burgess (P82892)
One Energy Plaza
Jackson, Michigan 49201
Attorneys for Consumers Energy Company

ATTORNEY GENERAL, DANA NESSEL

By: **Celeste R. Gill** Digitally signed by
Celeste R. Gill
Date: 2022.04.19
15:03:37 -04'00'

Date: _____

Celeste Gill, Esq.
Assistant Attorney General
Michigan Dept. of Attorney General,
Special Litigation Unit
6th Floor Williams Building
Post Office Box 30755
Lansing, MI 48909

Tracy Jane Andrews, Esq.
Olson, Bzdok & Howard, P.C.
420 East Front Street
Traverse City, MI 49686

GREAT LAKES RENEWABLE ENERGY ASSOCIATION

By: *Don L. Keskey*
Don L. Keskey, Esq.
Brian W. Coyer, Esq.
Public Law Resource Center PLLC
333 Albert Avenue, Suite 425
East Lansing, MI 48823

Date: April 19, 2022

MICHIGAN ENVIRONMENTAL COUNCIL

By:  Digitally signed by
Christopher M. Bzdok
Date: 2022.04.19
12:05:00 -04'00'

Christopher M. Bzdok, Esq.
Lydia Barbash-Riley, Esq.
Olson, Bzdok & Howard, P.C.
420 East Front Street
Traverse City, MI 49686

Date: April 19, 2022

NATURAL RESOURCES DEFENSE COUNCIL



Digitally signed by
Christopher M. Bzdok
Date: 2022.04.19
12:05:50 -04'00'

By:

Christopher M. Bzdok, Esq.
Lydia Barbash-Riley, Esq.
Olson, Bzdok & Howard, P.C.
420 East Front Street
Traverse City, MI 49686

Date: April 19, 2022

SIERRA CLUB

Michael C. Soules
Digitally signed by
Michael C. Soules
Date: 2022.04.19
12:08:37 -04'00'

By:

Michael C. Soules
Earthjustice
1001 G Street NW, Suite 1000
Washington, DC 20001

Date: April 19, 2022

Christopher M. Bzdok, Esq.
Lydia Barbash-Riley, Esq.
Olson, Bzdok & Howard, P.C.
420 East Front Street
Traverse City, MI 49686

CITIZENS UTILITY BOARD OF MICHIGAN



Digitally signed
by Holly L., Hillyer
Date: 2022.04.19
12:29:05 -04'00'

By:

Abigail R. Hawley, Esq.
Holly L. Hillyer, Esq.
Olson, Bzdok & Howard, P.C.
420 East Front Street
Traverse City, MI 49686

Date: April 19, 2022

MICHIGAN ENERGY INNOVATION BUSINESS COUNCIL, INSTITUTE FOR ENERGY
INNOVATION, AND CLEAN GRID ALLIANCE

By: **Laura A. Chappelle**
Laura A. Chappelle, Esq.
Justin K. Ooms, Esq.
Timothy J. Lundgren, Esq.
Potomac Law Group
120 N. Washington Square, Suite 300
Lansing, MI 48933

Digitally signed by
Laura A. Chappelle
Date: 2022.04.19
12:42:00 -04'00'

Date: April 19, 2022

MICHIGAN ELECTRIC TRANSMISSION COMPANY, LLC

By: **Richard**
Aaron
Richard J. Aaron, Esq.
Dykema Gossett PLLC
201 Townsend Street, Suite 900
Lansing, MI 48933

Digitally signed by: Richard Aaron
DN: CN = Richard Aaron email =
raaron@dykema.com C = US O =
Dykema
Date: 2022.04.19 12:07:55 -04'00'

Date: April 19, 2022

Lisa Agrimonti, Esq.
Fredrikson & Bryon, P.A.
115 West Allegan, Suite 700
Lansing, MI 48933

Amy Monopoli, Esq.
ITC Holdings Corp.
27175 Energy Way
Novi, MI 48377

ENVIRONMENTAL LAW & POLICY CENTER, VOTE SOLAR, ECOLOGY CENTER, AND
UNION OF CONCERNED SCIENTISTS

By: 
Margrethe Kearney, Esq.
Environmental Law & Policy Center
146 Monroe Ctr St. NW, Ste 422
Grand Rapids, Michigan 49503

Date: April 19, 2022

HEMLOCK SEMICONDUCTOR OPERATIONS LLC

By: **Jennifer
Utter
Heston**  Digitally signed by
Jennifer Utter
Heston
Date: 2022.04.19
13:15:32 -04'00'

Jennifer Utter Heston, Esq.
Fraser Trebilcock Davis & Dunlap, P.C.
124 West Allegan, Suite 1000
Lansing, MI 48933

Date: April 19, 2022

URBAN CORE COLLECTIVE



By:

Nicholas Leonard, Esq.
Andrew Bashi, Esq.
Great Lakes Environmental Law Center
Local Counsel for Urban Core Collective
4444 2nd Avenue
Detroit, MI, 48201

19-April-2022

Date:

Mark N. Templeton, Esq.
Robert A. Weinstock, Esq.
University of Chicago Law School –
Abrams Environmental Law Clinic
6020 South University Avenue
Chicago, IL 60637

The following parties do not wish to be signatories to this Settlement Agreement; however they have agreed to sign below to indicate non-objection to the Settlement Agreement.

MICHIGAN PUBLIC POWER AGENCY

By: Nolan J. Moody Digitally signed by Nolan J. Moody
Date: 2022.04.19 12:19:10 -04'00'

Date: April 19, 2022

Nolan J. Moody, Esq.
Peter H. Ellsworth, Esq.
Dickinson Wright PLLC
123 W. Allegan Street, Suite 900
Lansing, MI 48933

MIDLAND COGENERATION VENTURE LIMITED PARTNERSHIP

By: **John**
Janiszewski
Digitally signed by: John Janiszewski
DN: CN = John Janiszewski email
= jjaniszewski@dykema.com C =
US O = Dykema Gossett, PLLC
Date: 2022.04.20 09:49:53 -04'00'

John A. Janiszewski, Esq.
Dykema Gossett PLLC
201 Townsend Street, Suite 900
Lansing, MI 48933

Date: April 20, 2022

ATTACHMENT A

ATTACHMENT A

Contract Year	Total Rate (\$/MWh)
2019	\$ 55.54
2020	\$ 57.49
2021	\$ 59.38
2022	\$ 61.28
2023	\$ 63.25
2024	\$ 65.24
2025	\$ 67.24
2026	\$ 69.24
2027	\$ 71.23
2028	\$ 73.18
2029	\$ 75.08
2030	\$ 76.95

PROOF OF SERVICE

STATE OF MICHIGAN)


Case No. U-21090

County of Ingham)

Brianna Brown being duly sworn, deposes and says that on June 23, 2022 A.D. she electronically notified the attached list of this **Commission Order via e-mail transmission**, to the persons as shown on the attached service list (Listserv Distribution List).


Brianna Brown

Subscribed and sworn to before me
this 23rd day of June 2022.



Angela P. Sanderson
Notary Public, Shiawassee County, Michigan
As acting in Eaton County
My Commission Expires: May 21, 2024

Service List for Case: U-21090

Name	Email Address
Abigail Hawley	abbie@envlaw.com
Amit T. Singh	singha9@michigan.gov
Amy Monopoli	amonopoli@itctransco.com
Andrew Bashl	andrew.bashl@glelc.org
Anne M. Uitvlugt	anne.uitvlugt@cmsenergy.com
Bret A. Totoraitis	bret.totoraitis@cmsenergy.com
Brian W. Coyer	bwcoyer@publiclawresourcecenter.com
Brian W. Coyer	bwcoyer@publiclawresourcecenter.com
Celeste R. Gill	gillc1@michigan.gov
Christopher M. Bzdok	chris@envlaw.com
Christopher M. Bzdok	chris@envlaw.com
Christopher M. Bzdok	chris@envlaw.com
Consumers Energy Company 1 of 2	mpsc.filings@cmsenergy.com
Consumers Energy Company 2 of 2	michael.torrey@cmsenergy.com
Derk A. Wilcox	wilcox@mackinac.org
Don L. Keskey	donkeskey@publiclawresourcecenter.com
Gary A. Gensch Jr.	gary.genschjr@cmsenergy.com
Holly Hillyer	holly@envlaw.com
Ian F. Burgess	ian.burgess@cmsenergy.com
Jacob Pavlecic	jpavlecic@lawclinic.uchicago.edu
James J. Fleming	jfleming@clarkhill.com
Jason T. Hanselman	jhanselman@dykema.com
Jennifer U. Heston	jheston@fraserlawfirm.com
John A. Janiszewski	jjaniszewski@dykema.com
Joseph J. Baumann	jbaumann@wpsci.com
Justin K. Ooms	jooms@potomaclaw.com
Justin K. Ooms	jooms@potomaclaw.com
Justin K. Ooms	jooms@potomaclaw.com
Justin K. Ooms	jooms@potomaclaw.com
Laura A. Chappelle	lchappelle@potomaclaw.com
Laura A. Chappelle	lchappelle@potomaclaw.com
Laura A. Chappelle	lchappelle@potomaclaw.com
Laura A. Chappelle	lchappelle@potomaclaw.com
Lisa M. Agrimonti	lagrimonti@fredlaw.com
Lydia Barbash-Riley	lydia@envlaw.com
Lydia Barbash-Riley	lydia@envlaw.com
Lydia Barbash-Riley	lydia@envlaw.com
Margrethe Kearney	mkearney@elpc.org
Margrethe Kearney	mkearney@elpc.org
Margrethe Kearney	mkearney@elpc.org
Margrethe Kearney	mkearney@elpc.org

Mark N. Templeton	templeton@uchicago.edu
Michael C. Rampe	michael.rampe@cmsenergy.com
Michael C. Soules	msoules@earthjustice.org
Michael J. Pattwell	mpattwell@clarkhill.com
Nicholas Leonard	nicholas.leonard@glelc.org
Nicholas Q. Taylor	taylorn10@michigan.gov
Nolan J. Moody	nmoody@dickinsonwright.com
Olivia R.C.A. Flower	oflower@dykema.com
Peter H. Ellsworth	pellsworth@dickinson-wright.com
Richard J. Aaron	raaron@dykema.com
Robert A. Weinstock	rweinstock@uchicago.edu
Robert W. Beach	robert.beach@cmsenergy.com
Sally Wallace	wallaces2@michigan.gov
Sean P. Gallagher	sean@legalspg.com
Shaun M. Johnson	shaun.m.johnson@cmsenergy.com
Stephen A. Campbell	scampbell@clarkhill.com
Theresa A.G. Staley	theresa.staley@cmsenergy.com
Thomas J. Waters	tjw@runningwise.com
Thomas J. Waters	tjw@runningwise.com
Thomas J. Waters	tjw@runningwise.com
Thomas J. Waters	tjw@runningwise.com
Thomas J. Waters	tjw@runningwise.com
Thomas J. Waters	tjw@runningwise.com
Thomas J. Waters	tjw@runningwise.com
Timothy J. Lundgren	tlundgren@potomaclaw.com
Timothy J. Lundgren	tlundgren@potomaclaw.com
Timothy J. Lundgren	tlundgren@potomaclaw.com
Timothy J. Lundgren	tlundgren@potomaclaw.com
Tracy Jane Andrews	tjandrews@envlaw.com

Attachment GG

DOE, Air Quality and Environmental Justice
Memorandum (2021)



Department of Energy
Washington, DC 20585

October 1, 2021

Enclosed is the final special environmental analysis (DOE/SEA-05) prepared by ICF, Incorporated (ICF) under direction of the Department of Energy (DOE) pursuant to the National Environmental Policy Act of 1969 (NEPA), 42 U.S.C. 4331 et seq., and DOE's implementing regulations, 10 CFR 1021.343(a).

On February 14, 2021, DOE issued an emergency order pursuant to section 202(c) of the Federal Power Act (FPA), 16 U.S.C. § 824a(c), and section 301(b) of the DOE Organization Act, 42 U.S.C. § 7151(b), DOE Order No. 2020-21-1, to the Electric Reliability Council of Texas (ERCOT) authorizing specific electric generating units located within the ERCOT area to operate at their maximum generation output levels under limited circumstances due to extreme weather conditions and to preserve the reliability of bulk electric power system (Order).

DOE issued the Order after determining that the emergency situation underlying ERCOT's request demanded immediate action consistent with DOE's NEPA regulations (10 CFR 1021.343(a)). As described in DOE's notice of emergency action (86 FR 18046; April 7, 2021), DOE reviewed the final data report received from ERCOT on March 31, 2021, and determined that a special environmental analysis would be the appropriate level of NEPA review. DOE has prepared special environmental analyses in other emergency situations that required immediate action. (See <https://www.energy.gov/nepa/special-environmental-analyses>). This special environmental analysis examines potential impacts resulting from issuance of the Order on air quality and environmental justice. DOE has independently reviewed the analysis provided by ICF and agrees with its conclusions. No further analysis will be conducted.

U.S. Department of Energy, Office of Electricity

Air Quality and Environmental Justice Analysis Memorandum,

July 21, 2021

Introduction

During 5 days in February 2021 (February 15–19), the Electric Reliability Council of Texas (ERCOT) requested the Department of Energy (DOE) to authorize the emergency use of power generation under Section 202(c) of the Federal Power Act. This resulted in air emissions at times exceeding their permitted emissions levels for 28 power units located in East Texas, with most power units (20) located in Harris County. At the request of the DOE Office of Electricity (OE), ICF has examined whether these additional emissions from these power units covered by the Section 202(c) authorization may have led to an exceedance of the National Ambient Air Quality Standards (NAAQS). Further, ICF conducted an environmental justice analysis of the communities potentially affected by any additional emissions during this 5-day period.

We determined at the outset that for one power unit, ERCOT was unable to obtain any information on its air emissions. Therefore, our analyses included 27 units. Although the ERCOT Section 202(c) permit covered 27 power units, only 14 of the 27 power units were at unique locations.

1 Air Quality Analysis Approach

To assess whether emissions from the power units could potentially contribute to a NAAQS violation, ICF gathered the air quality monitoring data for stations in East Texas. The Texas Commission on Environmental Quality (TCEQ) maintains an extensive network of air monitoring stations throughout the state.¹ This hourly air monitoring and meteorological data, resultant wind speed and direction, outdoor temperature, standard deviation in wind direction, and solar radiation were downloaded from TCEQ. In addition, ERCOT provided the locations for each power generating unit. Using this collected data, ICF determined if any exceedances occurred during the emergency period (February 15–19, 2021) for air pollutants having short-term ambient air quality standards. This included 1- and 8-hour CO, 1-hour NO₂, 1-hour SO₂, and 24-hour PM² standards. No assessment was made for mercury or CO₂ emissions.

ERCOT provided DOE with hourly air emission rates for each unit above its permitted levels, along with the location of each power unit. This information was used to pair air quality monitoring stations with power units. We examined pairings using proximate radial distances of 10 km and 15 km. To determine if an air monitoring station was downwind of the power unit, we used each hour's wind direction to determine if the air monitoring station aligned in a downwind direction within a ± 20 -degree window.

To further strengthen conclusions, we compared the 5-day average temperature with historical average February temperatures using climatological data from Houston International Airport as an overall representative site. Lower than average temperatures are favorable for increased

¹ https://www.tceq.texas.gov/cgi-bin/compliance/monops/select_month.pl

² Although PM₁₀ is the reported emission rate, we used the PM_{2.5} standard, as nearly all (>97 percent by mass) of the power plant emissions have a mean mass diameter of less than 2.5 microns.

buoyancy from the exhaust stack, which means the plume will rise higher, favoring lower ground-level air concentrations. A similar analysis was performed for wind speeds but using the Houston Aldine site (EPA AIRS ID 48_201_0024). Here, higher wind speeds led to increased ventilation, which decreases residence time of air pollutants, leading to lower air pollutant concentrations.

Lastly, we discuss the concept of mixing height. The *mixing height* (or depth) is defined as the height above the Earth's surface through which vertical mixing occurs. The concept of a mixing layer is well-founded on theoretical principles. The mixing height acts as a lid on air pollutants, tending to prevent further vertical mixing of emissions higher into the atmosphere. Thus, we calculated the mixing heights during the 5-day emergency period and compared them to the average February mixing heights based on the Holzworth method (U.S. Environmental Protection Agency, 1972). Mixing heights can be determined from twice daily upper-air soundings performed at 6 a.m. and 6 p.m. The nearest upper-air station to Harris County is Lake Charles, Louisiana.

Review of ERCOT Emission Rates Against Total Emissions Rates During the Emergency Use Period

We reviewed the hourly emission rate data provided by ERCOT for each power unit. The dataset is intended to report the incremental emissions for each hour that exceeded the power units' maximum permitted emission rates. To compare these incremental emissions against the total emissions from each power unit, we downloaded the Continuous Emission Monitoring System (CEMS) from EPA's Air Markets Program Data (ampd.epa.gov/ampd). CEMS data reports the total emissions for each power unit on an hour-by-hour basis either as directly measured or as calculated from other measured parameters. The ERCOT data reported hourly emissions for SO₂, NO_x, CO, PM₁₀, and CO₂; however, CEMS does not report emissions for CO and PM₁₀, so the only pollutants that can be cross-referenced between the two datasets are SO₂, NO_x, and CO₂. However, SO₂ and CO₂ are rarely reported in the ERCOT-supplied data, likely because SO₂ emission rates are well below permitted levels even during the emergency period, and CO₂ emission rates are likely not specified in operating permit levels.

Because the ERCOT emission rates are in, we expected that in most cases the ERCOT incremental increase would only be a small fraction of the total CEMS rates and that the ERCOT rates could never be greater than CEMS rates because CEMS emissions are the total emissions from the power units. To see if our understanding is consistent with the reported data, we made a graphical presentation between the NO_x incremental emission rate versus the CEMS emissions rate for each hour in which ERCOT reported an emission rate over the 5-day emergency period.

1.1 Findings – Potential for NAAQS Exceedances

We discuss a series of analyses undertaken using available air quality and meteorological data to present a weight-of-evidence approach in trying to answer the principal question—*Could the power units' excess air emissions during this emergency period have caused an exceedance of the NAAQS?*

No one analysis can definitively answer this question, so we performed a series of analyses to provide a more defensible and robust conclusion and instill greater confidence in the answer.

1.1.1 Air Quality Monitoring Stations

A review of air quality monitoring stations in all air quality modeling regions in East Texas showed no violations of the NAAQS during the emergency period. However, many of the air quality monitoring stations failed to operate during the emergency period, presumably because of power outages. Tables 1a and 1b below show the daily percentage of missing air quality data during the emergency period for power units and air quality stations that we could pair using a 10-m radius. Only 14 of the 27 power units had unique locations, and of the 14 locations, only 10 had an air quality station within 10 km. The pollutant most widely monitored, as well as the pollutant most widely reported as having emissions exceeding permit levels, is NO_x. Of the 14 locations, seven had NO₂ monitors.³ However, as highlighted in light blue and indicated with an asterisk (*), about half have missing data (likely as a result of power outages), particularly on the first 3 days of the emergency period. Other air pollutants have less air monitoring coverage but also show considerable missing data, particularly during the first 3 days of the emergency period.

The power unit codes shown in the rest of this report are defined in Appendix 1.

³ Although the emitted pollutant is NO_x, the air quality standard is for NO₂. Typically, about 10 percent of the in-stack NO_x is in the form of NO₂, and the rest is emitted as NO. However, NO is converted to NO₂ in the atmosphere with a reaction rate on the order of minutes to hours, depending on available ozone and atmospheric mixing.

Table 1a. Ambient Air Quality Monitoring Stations (CO and NO₂) Within 10 km of the Power Generation Units

Power Unit Name	Pollutants of Interest Monitored				Data Coverage by Day					Data Coverage by Day				
	CO	NO ₂	PM _{2.5}	SO ₂	CO					NO ₂				
					2/15	2/16	2/17	2/18	2/19	2/15	2/16	2/17	2/18	2/19
BOSQUE_CC1														
DDPEC_CC1	X	X	X	X	100%	21%*	0%*	50%	100%	100%	21%*	75%	100%	100%
FREC_CC2				X										
TXCTY_CC1				X										
CHAMON_CTG_0101		X								75%	0%*	17%*	100%	100%
CALHOUN_UNIT1														
THW_THWGT32		X								100%	92%	38%*	100%	100%
WAP4_WAP4														
GBY_GBYGT74		X	X							100%	96%	50%	100%	100%
PHR_CLCWA_5UNITS		X								8%*	88%	42%*	100%	96%
LH_LYN_30UNITS		X								75%	0%*	17%*	100%	100%
DSN_NEWP_10UNITS														
SOE_SEWP_10UNITS	X	X	X	X	100%	21%*	0%*	50%	100%	100%	21%*	75%	100%	100%
FEGC_UNIT1				X										

See Appendix 1 for definition of the unit codes.

Table 1b. Ambient Air Quality Monitoring Stations (PM25, SO2) Within 10 km of the Power Generation Units

Power Unit Name	Pollutants of Interest Monitored				Data Coverage by Day					Data Coverage by Day				
	CO	NO ₂	PM _{2.5}	SO ₂	PM _{2.5}					SO ₂				
					2/15	2/16	2/17	2/18	2/19	2/15	2/16	2/17	2/18	2/19
BOSQUE_CC1														
DDPEC_CC1	X	X	X	X	100%	17%*	71%	100%	83%	100%	21%*	67%	100%	100%
FREC_CC2				X						0%*	0%*	0%*	46%*	100%
TXCTY_CC1				X						100%	100%	100%	100%	100%
CHAMON_CTG_0101		X												
CALHOUN_UNIT1														
THW_THWGT32		X												
WAP4_WAP4														
GBY_GBYGT74		X	X		100%	92%	33%*	0%*	50%					
PHR_CLCWA_5UNITS		X												
LH_LYN_30UNITS		X												
DSN_NEWP_10UNITS														
SOE_SEWP_10UNITS	X	X	X	X	100%	17%*	71%	100%	83%	100%	21%*	67%	100%	100%
FEGC_UNIT1				X						0%	0%	0%	0%	25%

Increasing the search radius from 10 km to 15 km picked up two additional air quality monitoring stations; however, the influence from the power station at that distance is substantially diminished, particularly in urban environments, where other sources of emissions will affect the monitor.

Tables 2a and 2b show the three highest monitored concentrations for NO₂, PM_{2.5}, and SO₂ over the 5-day period.⁴ The only pollutant within 50 percent of the air quality standard was PM_{2.5}, although the PM_{2.5} standard is an average over 24 hours, whereas those for NO₂ and SO₂ are 1-hour standards. No exceedances of any air quality standard occurred at these stations, nor at any air quality monitoring stations in the region of study. The highest concentration, to any air quality standard, was for the 24-hour PM_{2.5} standard at 56 percent.

The highest elevated PM_{2.5} concentrations all occurred during the late evening hours (8 p.m.–11 p.m.) on February 19, 2021. Many sources contribute to PM_{2.5} pollution, including buses, trucks, cars, and off-road sources (e.g., construction equipment, portable generators). In addition, meteorology and atmospheric chemistry play a significant role in determining the air concentration. However, it is not possible from this analysis to estimate the source contribution from the power units without additional air quality modeling analysis.

Table 2a. Top 3 Highest Air Concentrations Monitored Within 10 km of the Power Generation Units

Power Unit	NO ₂ (ppb)			PM _{2.5} (µg/m ³)			SO ₂ (ppb)		
Unit Code	First	Second	Third	First	Second	Third	First	Second	Third
DDPEC_CC1	37	33	29	17	12	11	1	1	1
FREC_CC2							0	0	0
TXCTY_CC1							3	2	2
CHAMON_CTG_0101	31	30	29						
THW_THWGT32	37	37	36						
GBY_GBYGT74	40	36	35	20	14	14			
PHR_CLCWA_5UNITS	27	18	17						
LH_LYN_30UNITS	31	30	29						
SOE_SEWP_10UNITS	37	33	29	17	12	11	1	1	1
FEGC_UNIT1							0	0	0

Note: For NO₂ and SO₂ these are 1-hour averages; PM_{2.5} is a daily average.

Table 2b. Top 3 Highest Air Concentrations (as Percentage of Air Quality Standard^a) Monitored Within 10 km of the Power Generation Units

Power Unit	NO ₂			PM _{2.5}			SO ₂		
Unit Code	First	Second	Third	First	Second	Third	First	Second	Third
	37%	33%	29%	48%	34%	30%	1%	1%	1%
FREC_CC2							0%	0%	0%
TXCTY_CC1							3%	3%	3%
CHAMON_CTG_0101	31%	30%	29%						
THW_THWGT32	37%	37%	36%						
GBY_GBYGT74	40%	36%	35%	56%	40%	39%			
PHR_CLCWA_5UNITS	27%	18%	17%						

⁴ CO is not shown because the values were <1 percent of the NAAQS.

Power Unit	NO ₂			PM _{2.5}			SO ₂		
Unit Code	First	Second	Third	First	Second	Third	First	Second	Third
LH_LYN_30UNITS	31%	30%	29%						
SOE_SEWP_10UNITS	37%	33%	29%	48%	34%	30%	1%	1%	1%
FEGC_UNIT1							0%	0%	0%

^a The 1-hour NO₂ standard is 100 ppb, 1-hour SO₂ standard is 75 ppb, and 24-hour PM_{2.5} standard is 35 µg/m³.


1.1.2 Downwind Air Quality Monitoring Sites

Besides being in close proximity to the power unit, an air quality monitoring station must also be oriented in the downwind direction of the power unit. Table 3 shows the percentage of time that the air quality monitoring station was downwind of the power unit. As shown, only one air quality monitoring site was downwind more than 50 percent of the hours. All other pairs of air quality monitoring stations and power units only had the correct alignment window 25 percent or less of the time. The air quality monitoring unit paired with the Deer Park Energy Center (DDPEC_CC1) power unit was downwind more than half the hours. This was the best pairing of any power unit and air quality station and shows good supporting evidence that the power units' excess emissions were unlikely to have caused an exceedance of the NAAQS (except on February 16, 2021, when the monitoring stations only had valid measurements for 20 percent of the hours that day). All other meteorological/air quality station pairs had too few hours to draw a conclusion. Figure 1 shows the locations of three of the power units relative to the air monitoring stations in Harris County.

Table 3. Power Unit Pairings With Nearby Meteorological Stations and Percentage of Time Downwind

Power Unit Code	Distance to MET Station (km)	AQ Station Direction – Lower Bound	AQ Station Direction – Upper Bound	% of MET Station Data Within +/-20 Degree Range of AQ Station Location
DDPEC	4.9	320°	360°	58%
FREC	10.3	320°	360°	25%
TXCTY	1.4	220°	260°	3%
CHAMON	8.6	0°	40°	6%
THW	17.5	220°	260°	<1%
GBY	5.6	345°	25°	25%
PHR	11.1	135°	175°	<1%
LH	1.2	100°	140°	10%
SOE	5.0	185°	225°	1%
FEGC	3.5	25°	65°	3%

Figure 1. Location of Three Power Units Operating in Harris County and the Paired Air Monitoring Station



1.1.3 Meteorological Conditions Conducive to High Concentrations

Wind Speed

As discussed, lower wind speeds result in poorer dispersive conditions that lead to higher air concentration levels. Average wind speeds for February, based on the 23-year average (1998–2020) from the Houston Aldine site (EPA Airs ID# 48-201-0024), is 6.2 mph. During the 5-day emergency-use period, the winds were slightly higher (14 percent) than the average wind speed of 7.0 mph. Thus, the slightly higher wind speeds are favorable to having lower air concentrations.

Temperature

As discussed, lower temperatures will lead to increased buoyancy, resulting in lower air concentrations. The climatological average air temperature for February at the Houston International Airport is 57.7°F. During the 5-day event, the average air temperature was 28.4°F, almost 30°F below average. These substantially colder temperatures are favorable to having lower ground-level air concentrations, assuming the plume rise from the power units is sufficiently high that these concentrations are not trapped in a shallow stable layer (i.e., temperature inversion) near the surface.

Mixing Heights

We determined mixing height by using the same method as the historical data from Lake Charles (the closest upper air station to Harris County). The February morning mean mixing height during the 5-day emergency event was 530 m, and the afternoon mixing height was 607 m. This compares with a climatological morning mixing height of 319 m in February and a climatological afternoon mixing height of 822 m. The higher mixing height observed during the event reduced the tendency for the trapping of air pollutants in a shallow layer near the Earth's surface, so air concentrations should be lower due to higher mixing height. The lower mixing heights observed during the event in the afternoon relative to the climatological average is the reverse of the morning, but the mean depth of the mixed layer is still higher than the morning period, so in general, concentrations are lower in the afternoon than the morning if emissions are the same.

1.1.4 Emission Rates: ERCOT versus CEMS

To better understand the emissions data, we graphically displayed the ratio of the ERCOT emission rates for NO_x to the CEMS NO_x emission rates for every hour using three representative emission profiles observed during our review of the ERCOT dataset. We report results for three representative types of findings. These are:

1. Peaking Plant, where the ERCOT is thought to be a large fraction of the CEMS data
2. Large amount of volatility in the ERCOT dataset
3. Does not make sense (ERCOT emission rate >> CEMS emission rate)

In no case should the ERCOT to CEMS ratio be greater than 1.

The three representative stations are:

1. Port Comfort Peaking Unit 2
2. Chamon Power Unit 1
3. Bosque CCP-GT-1

Figure 2 shows the ratio of the ERCOT NO_x emission rate to the CEMS NO_x emission rate for Port Comfort Peaking unit, with most hours reporting a ratio between 60 to 80 percent of the CEMS emission rate and with the unit off during most of February 18, 2021. A few anomalous hours occur where the ERCOT-to-CEMS ratio exceeds 1. Overall, this pattern appears to be a reasonable behavior.

Figure 2. Port Comfort Peaking Unit Hourly ERCOT/CEMS Emission Ratio During Emergency Period




Figure 3 shows the ratio of the ERCOT NO_x emission rate to the CEMS NO_x emission rate for the Port Chamon unit, with most hours having a value of less than 100 percent. There are a few hours with a ratio excursion that well exceeds a ratio of 1. Overall, this pattern can likely be explained if further information can be obtained from the plant about the few hourly ratio excursions that were much greater than 1.

Figure 3. Chamon Unit 1 Hourly ERCOT/CEMS Emission Ratio During Emergency Period





Figure 4 shows the ratio of the ERCOT NO_x emission rate to the CEMS NO_x emission rate for the BOSQUE unit, with all hours having a ratio in excess of 1, or less than 100 percent, but a few hours having a ratio excursion that well exceeds a ratio of 1. In fact, no ratio is less than 2, with a maximum of 13. Overall, these high values in comparison to the CEMS data are irregular. We suspect that incorrect values may have been reported by BOSQUE, as well as other units that exhibited similar behavior. However, further discussion with the plant is needed to clarify this finding.

Figure 4. BOSQUE Unit 1 Hourly ERCOT/CEMS Emission Ratio During Emergency Period



1.2 Conclusions – Air Quality Analysis

We reviewed ambient air quality monitoring data, meteorological data, and emission information for the power units that operated in exceedance of their permitted levels during the emergency use of power generation authorization under Section 202(c). We paired air quality monitoring stations with power units that were near each other. We found pairings for 10 of the 14 unique power generation units, most often for NO₂. We found no exceedances of the NAAQS standards; however, many of the air quality stations were missing air quality measurements on February 16 and 17, 2021. The highest concentration, to any air quality standard, was for the 24-hour PM_{2.5} standard at 56 percent of the exceedance threshold value. Further review of the air quality monitoring station and power unit data showed just one air quality monitoring station downwind of the power unit for the majority of hours during the emergency use period. A review and discussion of the meteorological conditions (e.g., wind speeds, temperature, mixing heights)

during the emergency period showed that the meteorology was conducive to better mixing and dispersion than average conditions in February. Reported incremental emissions did not compare favorably with the CEMS data available for NO_x.

Although no exceedances for the NAAQS occurred during the emergency use period, the large percentage of missing data, particularly on February 16 and 17, 2021, make it difficult to conclusively conclude that no violation of the NAAQS may have occurred. Furthermore, the limited number of downwind air quality monitors in close proximity to the power units makes it difficult to definitively conclude there were no air quality exceedances. However, based on the weight-of-evidence approach presented herein, it appears unlikely that the power units may have caused an exceedance of the NAAQS.

2 Environmental Justice Implications for the Affected Population

This section highlights the potential environmental justice (EJ) implications of the affected population in the region of interest. Our evaluation was based on data from U.S. Environmental Protection Agency's (EPA) EJSCREEN tool, available at ejscreen.epa.gov/mapper. EJSCREEN is a tool EPA has developed over the years to allow users to evaluate potential EJ impacts in different parts of the country using a GIS-based mapping platform. The tool allows users to combine demographic and environmental information on a user-selected area. The data used for these purposes in EJSCREEN are based on publicly available data sources, such as the American Community Survey from the Census Bureau for demographic data and various EPA data sources for environmental indicators. We used this screening tool for this analysis because it provides a method consistent with EPA's approach for defining EJ vulnerabilities for affected populations.

2.1 Analyzing Demographic Characteristics of Nearby Population

In order to identify the vulnerable population around these 14 unique power plants and 27 units that are likely to be impacted by any potential exceedances during the 5-day period, we extracted the demographic and environmental characteristics of those living with a pre-specified 5- and 10-km radius around each power plant. Note that we conducted this analysis at the plant level (as opposed to the unit level) because the unique location coordinates were available only at the plant level.

Figure 5 below overlays the 5-km circles around the individual power plants. Most of the plants are located around the Houston area, with a few farther away. Populations living around plants in the Houston area are likely to be more susceptible to potential EJ concerns. There is an overlap between the Lynchburg (LH) and Deer Park Energy Center (DDPEC) plant radii, as well as between the DDPEC and Southeast WPP (SOE) plant radii. Individuals in the intersections may experience EJ effects from both plants, and therefore may be more affected.

Figure 5. 5-km Radius Around Plants






Figure 6 below overlays 10-km circles around the individual power plants. Using a 10-km radius around these plants captures a greater share of the potentially affected population and is consistent with the air quality analysis discussed above. It also creates more overlapping areas, which increases the EJ concerns for the people living in those areas. This is discussed in more detail below.

Figure 6. 10-km Radius Around Plants



Given the relative proximity of some of these plants, particularly those in the Houston area, several of the 10-km circles tended to have some overlapping areas among them, which suggests that some members of the population are likely to be affected by activities from multiple plants and are therefore exposed to higher EJ risks than others. In order to analyze those risks, Figure 7 below focuses on the plants around Houston to identify intersecting circles.

Figure 7. Intersecting Areas With 10-Km Radius Around the Plants



Using these custom boundaries, ICF extracted demographic and environmental data from EJSCREEN to identify potential EJ vulnerabilities for the population living around these plants. Table 4 indicates the age ranges of populations in both the 5- and 10-km radii from the power plant indicated. As the table shows, there is a wide variability of the exposure in the 5- and 10-km ranges around these plants. The total population exposed to any potential EJ concerns within a

5-km radius of these plants can range from about 50 people to over 100,000 people, with FREC being the lowest and FEGC being the highest. Similar patterns hold for the 10-km radii, except the range is from about 900 to over 500,000 people.

Table 4. Distribution of the Affected Population by Age

Power Plant	5-Km Radius					10-Km Radius				
	Total Population	0 to 4	5 to 17	18 to 64	65+	Total Population	0 to 4	5 to 17	18 to 64	65+
BOSQUE	1,989	5%	12%	55%	29%	4,176	4%	13%	55%	28%
CALHOUN	751	10%	17%	65%	8%	11,735	7%	17%	59%	17%
CHAMON	10,469	6%	20%	60%	15%	90,052	9%	21%	62%	8%
DDPEC	53,680	7%	21%	61%	10%	276,938	8%	22%	61%	9%
DSN	67,599	8%	22%	61%	9%	201,458	7%	21%	61%	11%
FEGC	112,417	7%	18%	63%	12%	568,858	8%	18%	64%	10%
FREC	56	4%	20%	61%	16%	868	5%	16%	65%	14%
GBY	79,700	9%	21%	62%	8%	258,116	8%	22%	61%	9%
LH	12,839	9%	21%	57%	14%	128,113	8%	22%	61%	10%
PHR	18,722	9%	19%	62%	10%	93,580	8%	19%	61%	12%
SOE	56,345	6%	18%	63%	13%	394,451	8%	20%	62%	10%
THW	107,393	7%	20%	63%	10%	461,570	7%	20%	63%	10%
TXCTY	43,452	8%	19%	59%	15%	71,729	7%	18%	60%	16%
WAP	745	8%	20%	61%	11%	54,391	7%	23%	61%	10%

The majority of the people living in these areas seem to fall into what is likely the least vulnerable from an age perspective for EJ concerns. As the table above shows, more than 50 percent of the population falls within the 18–64 age group. However, some of these plants do have a relatively large share of the population that can be considered to be more susceptible to EJ problems. For example, BOSQUE has the highest percentage of people age 65+ in a 5- and 10-km radius, but is among the lowest in total population. Also, four of these plants have roughly 30 percent of the population below the age of 18, with about 20 percent or so in the 5–17 age group and the remaining 10 percent or so in the 0–4 age group.

Table 5 shows the distribution of the population by household incomes in both the 5- and 10-km radii. Note that the income data presented below are for households and not in per capita terms, which is different from how the data are shown in the other demographic tables.

Many of these plants have a relatively large share (20–30 percent) of the households that have incomes less than \$25,000 or close to the federal poverty line. Among them, GBY and TXCTY have the highest percentage (13 percent for the 10-km radius) of people with incomes below \$15,000 for a household, which is likely to exacerbate potential EJ concerns for this region. Correspondingly, GBY and TXCTY have the lowest percentage of people with a household income above \$50,000, falling between 40 and 50 percent for both radii. This indicates that the majority of people in these radii have household incomes below \$50,000, and both of these power plants are among those with a larger surrounding population.

Table 5. Distribution of the Affected Households by Income

Power Plant	5-Km Radius					10-Km Radius				
	Total Households	< \$15,000	\$15,000–\$25,000	\$25,000–\$50,000	\$50,000 +	Total Households	< \$15,000	\$15,000–\$25,000	\$25,000–\$50,000	\$50,000 +
BOSQUE	809	10%	14%	23%	52%	1,812	11%	15%	22%	52%
CALHOUN	285	7%	7%	20%	65%	4,137	11%	8%	27%	53%
CHAMON	3,418	7%	8%	23%	62%	28,248	7%	7%	20%	66%
DDPEC	16,779	7%	9%	21%	63%	85,473	9%	10%	24%	56%
DSN	22,212	4%	4%	13%	78%	67,417	6%	5%	15%	74%
FEGC	39,063	11%	8%	21%	59%	207,938	12%	11%	22%	55%
FREC	30	10%	17%	17%	57%	533	10%	20%	19%	51%
GBY	24,514	11%	11%	30%	48%	77,689	13%	13%	30%	45%
LH	4,234	12%	10%	23%	55%	39,892	10%	9%	23%	59%
PHR	6,527	11%	12%	21%	56%	34,256	9%	8%	18%	64%
SOE	19,748	7%	7%	19%	68%	130,051	9%	8%	23%	60%
THW	34,429	7%	9%	25%	59%	155,731	8%	8%	24%	60%
TXCTY	15,489	15%	13%	30%	41%	26,149	13%	12%	27%	48%
WAP	307	2%	1%	9%	88%	16,375	3%	2%	8%	86%

The table below shows the breakdown of the population in these regions by race, in both the 5-km and 10-km radii. Race information is broken down to show populations that self-identify as Black, Hispanic, Other non-White (i.e., American Indian, non-Hispanic Asian, Pacific Islander, or another race), and White.

Not surprisingly, some of the regions with the lowest income distribution also have the largest minority populations. For example, the area around GBY, which had one of the largest shares of the low-income population, also has around 90 percent Black and Hispanic populations. TXCTY, which also had a high proportion of the low-income population around it, is about two-thirds Black and Hispanic. Among the others, the population around FEGC, THW, and LH is also high in non-White or minority populations.

Table 6. Distribution of Population by Race

Power Plant	5-Km Radius					10-Km Radius				
	Total Population	Black	Hispanic	Other Non-white	White	Total Population	Black	Hispanic	Other Non-white	White
BOSQUE	1,989	1%	7%	1%	91%	4,176	1%	7%	1%	90%
CALHOUN	751	5%	29%	9%	57%	11,735	4%	55%	7%	34%
CHAMON	10,469	21%	39%	3%	38%	90,052	18%	46%	4%	32%
DDPEC	53,680	2%	55%	2%	41%	276,938	4%	65%	2%	29%
DSN	67,599	17%	27%	6%	51%	201,458	15%	25%	5%	54%
FEGC	112,417	32%	39%	7%	22%	568,858	31%	35%	11%	23%
FREC	56	13%	7%	4%	77%	868	24%	7%	4%	65%
GBY	79,700	30%	59%	2%	9%	258,116	29%	61%	2%	9%
LH	12,839	7%	51%	3%	40%	128,113	14%	53%	4%	29%
PHR	18,722	4%	33%	7%	55%	93,580	9%	27%	5%	59%
SOE	56,345	3%	42%	10%	45%	394,451	6%	55%	7%	32%
THW	107,393	20%	40%	16%	24%	461,570	21%	39%	12%	29%
TXCTY	43,452	29%	32%	5%	34%	71,729	27%	29%	4%	40%
WAP	745	19%	22%	11%	48%	54,391	11%	13%	34%	41%

2.2 Combining Demographic Information With Environmental Indicators

In order to understand the EJ vulnerabilities of the population living around these power plants, we analyzed various pollutant indicators from EJSCREEN and used their estimated percentile rankings to compare the potential vulnerabilities across the various plants. The estimated percentile rankings, developed by EPA, combine the environmental indicator with the appropriate demographic data to account for the vulnerable groups in the calculation of the EJ indicator. In this context, EPA defines the vulnerable groups as the average of the count of minorities and low-income households. In terms of the individual percentile rankings, a low number signifies that this group is relatively better off than the rest of the state population, whereas a high ranking signifies a relatively worse off situation than the rest of the state. As an example, if a certain ranking is 80, it means that this place is at the 80th percentile, which implies that only 20 percent of the state population experiences pollution that is higher than those experienced by people in this region. Thus, as a general principal, percentile rankings that are on the high side generally imply the region in question is comparatively worse off than other places in the state.

Table 7 shows the relative rankings of the various populations around these plants that are exposed to the various environmental indicators of interest (see Table 7 notes for definitions of these pollutant indicators). We present the percentile rankings for both the 5- and 10-km radii around each power plant. Table 7 also presents a calculated average percentile ranking in order for us to easily compare across the various plants. Average percentile rankings greater than 50 percent are highlighted in light blue and indicated with an asterisk (*). Note that these averages are simple arithmetic means, which essentially puts equal weights on each environmental indicator, irrespective of their implications on human health. Thus, one could argue that these averages are not reflective of the individual pollutants' effect on the vulnerable populations. We included them here for easy comparison across the groups without any value judgement on the individual pollutants.

Table 7. Percentile Ranking of Various Environmental Indicators

Power Plant	5-Km Radius					
	Particulate Matter (PM _{2.5} in ug/m3)	NATA Diesel PM (ug/m3)	NATA Air Toxics Cancer Risk (risk per MM)	NATA Respiratory Hazard Index	Hazardous Waste Proximity (facility count/km distance)	Average Percentile Ranking
BOSQUE	26	30	28	28	35	29.4
CALHOUN	40	38	40	40	50	41.6
CHAMON	57	59	69	62	60	61.4*
DDPEC	52	62	64	54	85	63.4*
DSN	16	16	12	15	25	16.8
FEGC	80	87	83	81	93	84.8*
FREC	31	33	31	31	32	31.6
GBY	91	92	95	95	96	93.8*
LH	62	67	84	68	95	75.2*
PHR	41	40	40	40	49	42
SOE	44	51	50	46	66	51.4*
THW	83	90	83	85	93	86.8*
TXCTY	62	61	61	61	92	67.4*
WAP	11	13	12	12	20	13.6
Power Plant	10-Km Radius					
	Particulate Matter (PM _{2.5} in ug/m3)	NATA Diesel PM (ug/m3)	NATA Air Toxics Cancer Risk (risk per MM)	NATA Respiratory Hazard Index	Hazardous Waste Proximity (facility count/km distance)	Average Percentile Ranking
BOSQUE	22	27	23	23	33	25.6
CALHOUN	51	48	48	47	46	48
CHAMON	81	80	94	87	94	87.2*
DDPEC	70	77	85	79	95	81.2*
DSN	30	32	28	30	50	34
FEGC	77	86	80	78	87	81.6*
FREC	48	44	48	48	42	46
GBY	89	91	95	94	97	93.2*
LH	78	80	92	87	96	86.6*
PHR	31	26	26	30	58	34.2
SOE	66	75	77	69	86	74.6*
THW	78	86	79	80	87	82*
TXCTY	56	56	56	56	87	62.2*
WAP	50	54	49	49	48	50

Particulate Matter (PM_{2.5} in ug/m3) – PM_{2.5} levels in the air, measured in µg/m3 annual average.

NATA Diesel PM (ug/m3) – Diesel particulate matter level in the air, measured in µg/m3.

NATA Air Toxics Cancer Risk (risk per MM) – Lifetime cancer risk from inhalation of air toxics.

NATA Respiratory Hazard Index – Air toxics respiratory hazard index (the ratio of exposure concentration to health-based reference concentration).

Hazardous Waste Proximity (facility count/km distance) – The count of hazardous waste facilities (TSDFs and LQGs) within 5 km (or nearest beyond 5 km), each divided by the distance in kilometers.

In order to identify which of these regions may have a vulnerable population exposed to disproportionately higher environmental justice concerns than the rest of the state, we chose an arbitrary 50-percent threshold and highlighted in the tables above those regions that are above that threshold. The results imply that the vulnerable populations living in these regions are experiencing higher levels of EJ concerns than a majority of the rest of Texas. Unsurprisingly, among these regions around power plants that are of higher EJ concerns, the ones that we identified above as having the most vulnerable populations are the ones with the highest average ranking. This includes populations around power plants GBY, FEGC, and THW as the most at-risk, with an average percentile ranking of over 80. Following those are SOE, LH, and TXCTY, with rankings between 60 and 70. Some power plants seem to jump considerably, moving from the 5-km to the 10-km radii. These include CHAMON and DDPEC, where the rankings jump from the 60s to 80s when we move from the 5-km to 10-km radius. Thus, when we analyze the vulnerable population within a 10-km radius of these plants, the majority of these power plants (i.e., 8 out of 14) have a baseline EJ vulnerability, higher than the rest of the state, affecting the population living near these power plants.

2.3 Population in Close Proximity to Multiple Plants

As discussed previously (see Figure 7), several of these power plants, particularly those around the Houston area, have significant overlapping regions when we analyze the populations within a 10-km radius around these plants. Populations living in these “intersecting circles” are likely to face even higher EJ concerns, given that they may have been exposed to higher emissions from multiple power plants. Here we present data for these population groups in these intersecting circles and their potential for higher EJ concerns.

Table 8 below shows the age distribution of the population living in these intersecting regions with two or more 10-km radii. The intersecting radii are of different sizes, which is part of the reason for the differences in population between areas. Overall, the percentage of people in each intersecting region that are between ages 0 and 4 are comparable to those 65+, with the latter only a slightly higher percentage in most areas. In total, approximately 12 percent, or about 325,000 of the 2.6 million total population living within a 10-km radius of all power plants, live in these intersecting regions and are thus likely to face higher levels of baseline EJ concerns than those that live outside of these intersecting regions. Most of this population group lives in an area that has two plants within 10 km, but about 20 percent of them live in areas that are close to three or more power plants.

Table 8. Distribution of the Affected Population in the Intersecting Regions by Age

	10-Km Radius Intersections				
Power Plants	Total Population	0 to 4	5 to 17	18 to 64	65+
CHAMON & DSN	14,817	10%	19%	65%	5%
GBY & CHAMON	21,330	10%	21%	63%	6%
GBY & DDPEC	22,002	9%	23%	60%	8%
LH & CHAMON	11,605	7%	20%	61%	12%
LH & DDPEC	6,337	10%	20%	60%	10%
LH & GBY	1,073	3%	22%	66%	10%
PHR & TXCTY	8,678	7%	17%	61%	16%
SOE & DDPEC	175,158	8%	21%	61%	10%
DDPEC & LH & GBY	28,277	8%	25%	59%	8%
GBY & LH & CHAMON	10,371	8%	25%	62%	6%
LH & DDPEC & CHAMON	3,495	9%	24%	56%	10%
LH & DDPEC & SOE	15,072	5%	19%	65%	11%
DDPEC & LH & GBY & CHAMON	7,275	7%	25%	62%	5%

Table 9 shows the household income of populations living in intersections of two or more 10-km radii. Household incomes for the intersecting regions are comparable to the incomes of the 5- and 10-km radii. Two intersecting areas have a majority of households with incomes less than \$50,000, which are the LH/DDPEC/CHAMON intersection and the GBY/DDPEC intersection. Alternatively, the highest percentage of households with incomes over \$50,000 is 81 percent, in the intersection of CHAMON and DSN.

Table 9. Distribution of the Affected Population in the Intersecting Regions by Income

	10-Km Radius Intersections				
Power Plants	Total Households	< \$15,000	\$15,000–\$25,000	\$25,000–\$50,000	\$50,000 +
CHAMON & DSN	4,652	3%	4%	12%	81%
GBY & CHAMON	6,424	4%	5%	26%	65%
GBY & DDPEC	6,320	12%	15%	29%	44%
LH & CHAMON	3,972	9%	11%	24%	56%
LH & DDPEC	1,989	11%	12%	24%	54%
LH & GBY	281	2%	2%	20%	76%
PHR & TXCTY	3,095	13%	9%	25%	53%
SOE & DDPEC	55,947	10%	10%	24%	57%
DDPEC & LH & GBY	7,730	7%	12%	29%	52%
GBY & LH & CHAMON	2,873	6%	3%	20%	71%
LH & DDPEC & CHAMON	959	13%	20%	21%	46%
LH & DDPEC & SOE	4,917	2%	5%	17%	75%
DDPEC & LH & GBY & CHAMON	2,081	8%	5%	20%	67%

Table 10 below shows the racial composition of the population living in intersections of two or more 10-km substation radii. Most of these intersecting regions have a predominantly minority population, with the Hispanic population comprising the bulk. The intersection with the highest total population is also among the highest in percentage of non-Whites, SOE/DDPEC. With a population over 100,000 greater than the next largest population, 69 percent of the population is either Black, Hispanic, or another non-White race. Other areas with a high percentage of non-White races are GBY/LH/CHAMON, DDPEC/LH/GBY/CHAMON, and LH/GBY.

Table 10. Distribution of the Affected Population in the Intersecting Regions by Race

Power Plants	Race of Population				
	10-Km Radius Intersections				
	Total Population	Black	Hispanic	Other Non-White	White
CHAMON & DSN	14,817	21%	28%	5%	46%
GBY & CHAMON	21,330	24%	54%	6%	16%
GBY & DDPEC	22,002	4%	82%	1%	13%
LH & CHAMON	11,605	7%	47%	1%	44%
LH & DDPEC	6,337	0%	56%	1%	43%
LH & GBY	1,073	37%	44%	7%	12%
PHR & TXCTY	8,678	19%	28%	4%	48%
SOE & DDPEC	175,158	2%	64%	3%	31%
DDPEC & LH & GBY	28,277	11%	72%	1%	16%
GBY & LH & CHAMON	10,371	22%	66%	3%	9%
LH & DDPEC & CHAMON	3,495	0%	67%	2%	31%
LH & DDPEC & SOE	15,072	0%	29%	6%	65%
DDPEC & LH & GBY & CHAMON	7,275	25%	65%	2%	9%

Table 11 below shows the EJ indexes in intersections of two or more 10-km substation radii. As discussed above, the environmental indicator listed in the Table 11 incorporates the value of the pollutant within the radius, as well as the percentage of minority people and low-income people in the radius. The table also presents the “average” percentile ranking as a way to ordinaly rank these intersecting circles. Average percentile rankings greater than 50 percent are highlighted in light blue and indicated with an asterisk (*).

Table 11. Environmental Justice Index in State Percentiles for People Living in the Intersecting Points of Two or More Substations in a 10-km Radius

Power Plants	10-Km Radius Intersections					Average Percentile Ranking
	Particulate Matter (PM 2.5 in ug/m3)	NATA Diesel PM (ug/m3)	NATA Air Toxics Cancer Risk (risk per MM)	NATA Respiratory Hazard Index	Hazardous Waste Proximity (facility count/km distance)	
CHAMON & DSN	42	44	43	43	41	42.6
GBY & CHAMON	94	93	97	96	94	94.8*
GBY & DDPEC	78	85	89	94	98	88.8*
LH & CHAMON	54	60	71	59	75	63.8*
LH & DDPEC	64	69	90	72	97	78.4*
LH & GBY	68	73	81	79	94	79*
PHR & TXCTY	65	62	65	63	87	68.4*
SOE & DDPEC	64	74	78	68	92	75.2*
DDPEC & LH & GBY	88	89	97	96	99	93.8*
GBY & LH & CHAMON	96	95	99	98	99	97.4*
LH & DDPEC & CHAMON	78	80	97	84	98	87.4*
LH & DDPEC & SOE	13	10	2	10	0	7
DDPEC & LH & GBY & CHAMON	95	93	99	97	99	96.6*

Using the same 50 percent threshold, the table shows which of these intersecting circles have a value higher than 50 percent, which implies that the population living in these intersecting regions have a higher level of exposure to EJ concerns than a majority of the rest of the population in Texas. Only two intersections have an average state percentile under 50 percent, which are LH/DDPEC/SOE and CHAMON/DSN. Thus, almost 85 percent of the population living in these intersecting regions have higher exposure to EJ concerns than the rest of the state. Given that these population groups, consisting mostly of minority populations, live near multiple power plants (and presumably other stationary sources), it is not surprising that these groups are more vulnerable when it comes to environmental justice considerations compared to the rest of the state.

2.4 Conclusion – Environmental Justice Analysis

Using data from EPA's EJSCREEN, it appears that people of color and those with limited socioeconomic means in and around the Houston area are more vulnerable to environmental justice considerations compared to the rest of Texas. Given the paucity of data discussed in the air quality analysis above, we could not determine whether the EJ concerns for these groups were exacerbated during those 5 days in February 2021, when DOE authorized the emergency use of power generation under Section 202(c) of the Federal Power Act. However, analyzing the *baseline, business-as-usual* EJ concerns for the population around these power plants does indicate that a majority of the population living here are minority with limited socioeconomic opportunities and that they are also vulnerable to higher levels of pollution under those baseline conditions.

3 References

U.S. Environmental Protection Agency. 1972. *Mixing Heights, Wind Speeds, and Potential for the Urban Air Pollution Throughout the Contiguous United States*. Prepared by George Holzworth. Research Triangle Park, NC: Office of Air Program, AP-101.

Appendix – Generators

Generator Name	Fuel Type	Resource Owner Name	County	Unit Code
East Water Plant	Distillate Fuel Oil	NRG Energy Services	Harris	CL_EWP_30UNITS
Lynchburg Pump Station	Distillate Fuel Oil	NRG Energy Services	Harris	LH_LYN_30UNITS
Northeast Water Plant	Distillate Fuel Oil	NRG Energy Services	Harris	DSN_NEWP_10UNITS
Southeast Water Plant	Distillate Fuel Oil	NRG Energy Services	Harris	SOE_SEWP_10UNITS
Clear Lake City WWTP	Distillate Fuel Oil	NRG Energy Services	Harris	PHR_CLCWA_5UNITS
Texas City Power Plant	Natural Gas	Calpine Corporation	Galveston	TXCTY_CC1
Freestone Energy Center Block 1	Natural Gas	Calpine Corporation	Freestone	FREC_CC2
W. A. Parish G4	Natural Gas	NRG Energy Services	Fort Bend	WAP_WAP_G4
T. H. Wharton GT54	Natural Gas	NRG Energy Services	Harris	THW_THWGT54
T. H. Wharton GT56	Natural Gas	NRG Energy Services	Harris	THW_THWGT56
Deer Park Energy Center	Natural Gas	Calpine Corporation	Harris	DDPEC_CC1
Texas City Power Plant	Natural Gas	Calpine Corporation	Galveston	TXCTY_CC1
Freestone Energy Center Block 2	Natural Gas	Calpine Corporation	Bosque	FREC_CC2
Bosque Energy Center Block 1	Natural Gas	Calpine Corporation	Bosque	BOSQUESW_CC1
Bosque Energy Center Block 2	Natural Gas	Calpine Corporation	Bosque	BOSQUESW_CC2
Chamon CT1	Natural Gas	Chamon Power LLC	Harris	CHAMON_CTG_0101
Chamon CT2	Natural Gas	Port Comfort Power LLC	Harris	CHAMON_CTG_0301
Port Comfort CT1	Natural Gas	Chamon Power LLC	Calhoun	CALHOUN_UNIT1
Port Comfort CT2	Natural Gas	Port Comfort Power LLC	Calhoun	CALHOUN_UNIT2
Friendswood Energy Genco	Natural Gas	Friendswood Energy Genco LLC	Harris	FEGC_UNIT1

Source: "ERCOT_DOE_202(c)_Exhibit_A_2-17-2021_2100," ERCOT.

Attachment H

Case 21585 Blumenstock Direct Testimony

STATE OF MICHIGAN
BEFORE THE MICHIGAN PUBLIC SERVICE COMMISSION

In the matter of the application of)
CONSUMERS ENERGY COMPANY)
 for authority to increase its rates for)
 the generation and distribution of)
 electricity and for other relief.)
 _____)

Case No. U-21585

DIRECT TESTIMONY

OF

RICHARD T. BLUMENSTOCK

ON BEHALF OF

CONSUMERS ENERGY COMPANY

May 2024

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. Please state your name and business address.**

2 A. My name is Richard T. Blumenstock, and my business address is 1945 West Parnall Road,
3 Jackson, Michigan, 49201.

4 **Q. By whom are you employed?**

5 A. I am employed by Consumers Energy Company (“Consumers Energy” or the “Company”).

6 **Q. What is your position with Consumers Energy?**

7 A. I am currently the Executive Director of Electric Supply Engineering. I began employment
8 at the Company in May 1994 in the electric transmission planning area where I performed
9 planning studies on the Company’s distribution and transmission systems. In April 2002,
10 I was assigned to the electric operations area where I oversaw engineering operations for
11 the distribution and transmission systems. In August 2009, I was assigned to the fuel
12 supply area where I oversaw the Company’s purchasing and transport functions for fuel
13 for electric generation. In June 2011, I assumed additional responsibilities including
14 oversight of the Company’s interaction in the Midcontinent Independent System Operator,
15 Inc. (“MISO”) markets; wholesale settlements and transactions functions; Power Supply
16 Cost Recovery (“PSCR”) activities; and planning for electric supply necessary to satisfy
17 customers’ energy and capacity needs. In September 2019, I assumed the role of Executive
18 Director of Electric Planning, overseeing the company-wide efforts for all electric
19 planning. In September 2022, I assumed my current position as Executive Director of
20 Electric Supply Engineering.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. What are your responsibilities as Executive Director of Electric Supply Engineering?**

2 A. My responsibilities as Executive Director of Electric Supply Engineering include oversight
3 of all activities associated with planning and design for the Company's electric generation
4 portfolio.

5 **Q. What is your formal educational experience?**

6 A. I received a Bachelor of Science degree in 1992 and a Master of Science degree in 1994,
7 both in Electrical Engineering from Michigan Technological University.

8 **Q. Have you previously provided testimony before the Michigan Public Service**
9 **Commission ("MPSC" or the "Commission")?**

10 A. Yes, I provided testimony in the following MPSC cases:

- 11 • Case No. U-16045-R: Reconciliation of PSCR Costs and Revenues for the
12 Calendar Year 2010;
- 13 • Case No. U-16432-R: Reconciliation of PSCR Costs and Revenues for the
14 Calendar Year 2011;
- 15 • Case No. U-16890: Approval of a PSCR Plan and for Authorization of Monthly
16 PSCR Factors for the Year 2012;
- 17 • Case No. U-16890-R: Reconciliation of PSCR Costs and Revenues for the
18 Calendar Year 2012;
- 19 • Case No. U-17429: Approval of a Certificate of Necessity for the Thetford
20 Generating Plant pursuant to MCL 460.6s and for related accounting and
21 ratemaking authorizations;
- 22 • Case No. U-17317: Approval of a PSCR Plan and for Authorization of Monthly
23 PSCR Factors for the Year 2014;
- 24 • Case No. U-17317-R: Reconciliation of PSCR Costs and Revenues for the
25 Calendar Year 2014;
- 26 • Case No. U-17752: Authority to amend its renewable energy plan approved in
27 Case Nos. U-15805, U-16543, U-16581, and U-17301;
- 28 • Case No. U-17678: Approval of a PSCR Plan and for Authorization of Monthly
29 PSCR Factors for the Year 2015;

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

- Case No. U-17678-R: Reconciliation of PSCR Costs and Revenues for the Calendar Year 2015;
- Case No. U-18250: Application of Consumers Energy for a financing order approving the securitization of qualified costs and related approvals associated with the early termination of the Palisades Nuclear Energy Plant Power Purchase Agreement;
- Case No. U-20134: Application of Consumers Energy for authority to increase its rates for the generation and distribution of electricity and for other relief;
- Case No. U-20165: Application of Consumers Energy for approval of its Integrated Resource Plan (“IRP”) pursuant to MCL 460.6t and for other relief;
- Case No. U-20697: Application of Consumers Energy for authority to increase its rates for the generation and distribution of electricity and for other relief;
- Case No. U-20963: Application of Consumers Energy for authority to increase its rates for the generation and distribution of electricity and for other relief;
- Case No. U-21090: Application of Consumers Energy for Approval of an IRP under MCL 460.6t, certain accounting approvals, and for other relief;
- Case No. U-21224: Application of Consumers Energy for authority to increase its rates for the generation and distribution of electricity and for other relief; and
- Case No. U-21389: Application of Consumers Energy for authority to increase its rates for the generation and distribution of electricity and for other relief.

Q. What is the purpose of your direct testimony in this proceeding?

A. The purpose of my direct testimony is to support the Generation Department (“Generation”) requests in this case, and to provide other information that the Company has committed to provide. Toward that end I will:

- Describe Consumers Energy’s coal-, oil-, and gas-fired generation assets, and its hydroelectric and renewable generation assets, including their projected retirement dates;
- Support the Company’s generation asset strategy to: (1) focus continued investment in those generating units (Zeeland Generating Station (“Zeeland Plant”, “ZGS” or “Zeeland”), New Covert Generating Facility (“Covert Plant” or “Covert”), and Jackson Generating Station (“Jackson Plant”, “JGS” or “Jackson”)) which provide the most long-term economic benefit for customers; and (2) sustain safe and environmentally compliant operations for its coal

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

generating units (J.H. Campbell (“Campbell”) Units 1, 2, and 3 through their retirement dates;

- Support the periodic outage plans and the Generation Unit Availability and Random Outage Rate (“ROR”) projections for coal generation, oil- and gas-fired peaking generation, and certain hydroelectric power generation, for the projected test year ending February 28, 2026;
- Support the reasonableness and prudence of the capital expenditures for coal generation, oil- and gas-fired peaking generation, and certain hydroelectric power generation for the historical test year ended December 31, 2023, the 14-month bridge period beginning January 1, 2024 and ending February 28, 2025, and the projected test year ending February 28, 2026;
- Support the reasonableness and prudence of the projected investment for Company-owned Solar Generation for the historical test year ended December 31, 2023, the 14-month bridge period beginning January 1, 2024 and ending February 28, 2025, and the projected test year ending February 28, 2026;
- Support the reasonableness and prudence of the Operation and Maintenance (“O&M”) and fuel handling expenses for coal generation, oil- and gas-fired peaking generation, and hydroelectric power for historical test year ended December 31, 2023, the 14-month bridge period beginning January 1, 2024 and ending February 28, 2025, and the projected test year ending February 28, 2026;
- Support the reasonableness and prudence of the O&M expenses for the D.E. Karn (“Karn”) Units 1 and 2 retention and separation incentives for the historical test year ended December 31, 2023;
- Support the reasonableness and prudence of the O&M expenses for the Campbell Units 1, 2, and 3 retention and separation incentives for the historical test year ended December 31, 2023, 14-month bridge period beginning January 1, 2024 and ending February 28, 2025, and the projected test year ending February 28, 2026; and
- Describe the environmental regulations with which the Company’s electric generating fleet must comply.

Q. How is your direct testimony related to the direct testimony of other Company witnesses?

A. Company witness Megan L. Metz’s testimony supports the PSCR costs planned to be incurred, taking into account the periodic outages identified in Exhibit A-41 (RTB-1) and the generating unit availability projections in Exhibit A-42 (RTB-2). Company witness

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

Metz also supports the capacity value of the Company's generation assets for the seasonal construct in the MISO Planning Resource Auction ("PRA") in Table 2.

Company witness Thomas P. Clark supports the IRP competitive solicitation process and timeline associated with the IRP solar initiative investment, including the build transfer agreements ("BTAs") and their associated projected capital expenditures. In addition, Mr. Clark supports the competitive solicitation process and timeline associated with the proposed battery energy storage system ("BESS") projected capital expenditures.

Company witness Adam J. Monroe supports capital investments in River Hydro facilities, including the Hardy Dam.

Company witness Josnelly C. Aponte supports the regulatory asset balances and amortization for the recovery of retention and separation expenses at both the Karn and Campbell sites in her direct testimony.

Q. Are you sponsoring any exhibits with your direct testimony?

A. Yes, I am sponsoring the following exhibits:

Exhibit A-41 (RTB-1)	Generating Unit Periodic Outages;
Exhibit A-42 (RTB-2)	Generating Unit Availability Projections;
Exhibit A-12 (RTB-3) Schedule B-5.2	Summary of Actual and Projected Electric Capital Expenditures for the Years 2023 through February 2026;
Exhibit A-43 (RTB-4)	Summary of the Generation O&M Expense for the Years 2023 through February 2026;
Exhibit A-44 (RTB-5)	Muskegon River Economic Impact Studies;
Exhibit A-45 (RTB-6)	Karn Unit 3 Cooling Tower Internal Structure Replacement Concept Approval; and

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

Exhibit A-46 (RTB-7)

Zeeland Phase I Gas Turbine
Upgrade Concept Approval.

Q. Were these exhibits prepared by you or under your direction and supervision?

A. Yes.

Q. How are the following sections of your direct testimony organized?

A. My direct testimony is divided into four sections. Section I will present exhibits and supporting testimony on the Company's generating assets, its generating asset strategy, and its generating asset projected performance metrics. Included in this section is a discussion of the Company's River Hydro strategy, its compliance with the Settlement Agreement in Case No. U-21224 and the March 1, 2024 Order in Case No. U-21389, the Request for Proposals ("RFP") for the divestiture of the River Hydro facilities, the Company's community outreach activities, and the Company's pursuit of external funding. Section II will describe the environmental regulations with which the Company's electric generating fleet must comply. Section III presents exhibits and supporting testimony for the historical and projected generation capital expenditures. Section IV will present exhibits and supporting testimony for the historical and projected generation O&M expense. This section will include support of the reasonableness and prudence of the O&M expenses for both the Karn Units 1 and 2 retention and separation incentives and also the reasonableness and prudence of the O&M expenses for Campbell Units 1, 2, and 3 retention and separation incentives.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

SECTION I

GENERATION ASSETS

Q. Please provide an overview of the Company's generation assets.

A. As of January 2, 2024, the Company's total projected owned generation assets for the 2023/2024 Planning Year had a Generator Verification Test Capacity ("GVTC") of 5,612 MW, comprised of the following units:

TABLE 1

RESOURCE	MICHIGAN LOCATION	IN-SERVICE DATE	RETIREMENT DATE	NET GENERATING CAPABILITY (MW)
COAL FIRED				
JH Campbell 1	West Olive, MI	1962	2025	261
JH Campbell 2	West Olive, MI	1967	2025	356
JH Campbell 3*	West Olive, MI	1980	2025	784 (owned share)
OIL OR GAS FIRED				
Covert	Covert, MI	2004	2040	1089
DE Karn 3	Essexville, MI	1975	2031	594
DE Karn 4	Essexville, MI	1977	2031	606
Zeeland CC	Zeeland, MI	2002	2041	532
Zeeland 1A	Zeeland, MI	2002	2041	159
Zeeland 1B	Zeeland, MI	2002	2041	159
Jackson	Jackson, MI	2002	2041	538
HYDROELECTRIC				
Alcona	Alcona County, MI	1924	n/a	3
Allegan	Allegan County, MI	1936	n/a	1
Cooke	Iosco County, MI	1911	n/a	7
Croton	Newaygo County, MI	1907	n/a	2
Five Channels	Iosco County, MI	1912	n/a	6
Foote	Iosco County, MI	1918	n/a	3
Hardy	Newaygo County, MI	1931	n/a	32
Hodenpyl	Wexford County, MI	1925	n/a	5
Loud	Iosco County, MI	1913	n/a	5
Mio	Oscoda County, MI	1916	n/a	2
Rogers	Mecosta County, MI	1906	n/a	2
Tippy	Manistee County, MI	1918	n/a	6
Webber	Ionia County, MI	1907	n/a	1
RENEWABLES				
Lake Winds	Mason County, MI	2012	2042	101
Cross Winds (Phase I)	Tuscola County, MI	2014	2044	231
Cross Winds (Phase II)	Tuscola County, MI	2018	2048	
Cross Winds (Phase III)	Tuscola County, MI	2018	2048	
Crescent Wind	Jonesville, MI	2021	2051	150
Gratiot Farms Wind	Alma, MI	2021	2051	150
Heartland Farms Wind Park	Ithaca, MI	2024	2054	201
Solar Gardens- GVSU	Grand Rapids, MI	2016	2046	1.6
Solar Gardens- WMU	Kalamazoo, MI	2016	2046	0.6
Cadillac Solar Garden	Cadillac, MI	2021	2051	0.2
Circuit West	Grand Rapids, MI	2019	2049	0.3
ENERGY STORAGE				
Ludington Units 1-6**	Ludington, MI	1973	2069	1169 (owned share)

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. What does “owned share” mean when used with respect to Campbell Unit 3?**

2 A. The Company owns approximately 93% of Campbell Unit 3. Michigan Public Power
3 Agency and Wolverine Power Supply Cooperative, Inc. own the remaining 7%. Thus, the
4 784 MW capacity reported is 93% of the Campbell Unit 3 GVTC, reflecting the Company’s
5 share of ownership.

6 **Q. What does “owned share” mean when used with respect to Ludington Pumped
7 Storage Plant (“LPS” or “Ludington”) Units 1 through 6?**

8 A. The Company owns 51% of LPS and DTE Electric Company (“DTE”) owns the remaining
9 49%. Thus, the 1,169 MW capacity reported is 51% of the total LPS GVTC, reflecting the
10 Company’s share of ownership.

11 **Q. Do any of the Company’s owned generation units reflect retirement dates which are
12 different from those sponsored in the Company’s previous electric rate case, Case No.
13 U-21389?**

14 A. No. There have been no changes to the retirement dates for the Company’s owned
15 generation units. The only change to the Company’s owned generation units was the
16 addition of Heartland Wind Park which began commercial operation on December 29,
17 2023.

18 **Q. How will the Company continue to meet its load requirements with the retirement of
19 the Campbell units in 2025?**

20 A. The Settlement Agreement approved in the Company’s 2021 IRP reflects the replacement
21 of the Campbell unit capacity through a number of different resources including continued
22 growth of its solar generation assets, demand response, energy waste reduction, the
23 acquisition of the Covert Plant on June 1, 2023, continued operation of Ludington and Karn

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

Units 3 and 4, and the addition of Zonal Resource Credits (“ZRCs”) by June 1, 2025, through a one-time solicitation approved as part of the Settlement Agreement.

The IRP one-time solicitation resulted in the Company’s January 12, 2024, filing of the Tibbits Energy Storage, LLC Power Purchase Agreement (“PPA”), a 100-MW battery storage project which the MPSC approved in its April 11, 2024 Order. The term of the PPA is 20 years, with deliveries expected to commence by May 31, 2025 with an expected PPA termination date of May 31, 2045. The IRP one-time solicitation also resulted in the Company’s May 13, 2024 filing of the Century Oaks Energy Storage LLC PPA, a 200-MW battery storage energy project. The Century Oaks Energy Storage LLC PPA also has a term of 20 years and, with deliveries expected to commence by May 31, 2026, with an expected PPA termination date of May 31, 2046.

GENERATION ASSET STRATEGY

Q. Please describe the Company’s asset strategy for its generating units.

A. The Company’s generation asset strategy is focused on providing safe, reliable, regulatory compliant, and economic energy and capacity for its customers. This strategy will be implemented within the construct of the Company’s clean energy goals and its IRPs, as approved by the MPSC.

Q. How does the Company’s generation asset strategy apply to the Company’s various generating units?

A. Consistent with Consumers Energy’s strategy, the Company’s generating asset investments will focus on onboarding renewable energy resources, including BESSs as well as those generating assets that provide the most economic benefit to customers through their energy and capacity value in the respective MISO markets. In addition, the Company will also

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 ensure it complies with all state and federal regulations. A detailed discussion of River
2 Hydro compliance is discussed in the direct testimony of Company witness Monroe.

3 Consistent with the approval of the Company's Proposed Course of Action
4 ("PCA") in its 2021 IRP, the Company will concentrate investment in new renewable
5 energy resources, and continue investment in the existing gas-fired units as this strategy
6 will provide the greatest long-term customer benefit. The coal-fired Campbell units will
7 have less investment as they approach retirement in 2025. During 2023, the Company's
8 Zeeland and Jackson Plants produced over 41% of the energy value and approximately
9 25% of the capacity value realized by the Company's electric generating fleet (excluding
10 renewables). The addition of the Covert Plant on June 1, 2023 significantly increased the
11 energy and capacity value for the Company's gas-fired generation. During its seven
12 months of operation during 2023, the Covert Plant contributed almost 28% of the total
13 energy value of the Company's electric generating fleet (excluding renewables) and
14 represents over 18% of the generation fleet's capacity value. As such, the Company's
15 investment focus and associated performance projections have been correspondingly set
16 for these generating units. The figures below reflect the 2023 net energy and capacity value
17 by asset type:

FIGURE 1

2023 Net Energy Value





FIGURE 2

Capacity



1 **Q. How does the Company's generation asset strategy apply to the balance of the**
2 **Company's generating units?**

3 **A.** The Company's generation asset strategy with respect to the remaining generating units
4 will vary depending on each unit's energy value, capacity value, and consistency with the
5 Company's currently approved IRP expected retirement dates. The Company will continue

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 to maintain its generating units, including the River Hydro facilities, to ensure safe and
2 environmentally compliant operations. With the exception of the River Hydro facilities,
3 I will provide additional detail regarding the Company's generation asset strategy for each
4 of the generating units, or group of generating units, in the portion of this direct testimony
5 describing projected generating unit availability. Company witness Monroe will provide
6 additional detail regarding the Company's generation asset strategy for the River Hydro
7 facilities.

8 **Q. Has the Company's existing generation asset strategy changed as a result of the 2023**
9 **Michigan energy legislation?**

10 A. No. While Public Act ("PA") 235 of 2023 requires the Company to achieve a 50%
11 renewable portfolio standard ("RPS") by 2030, the Company had already committed to an
12 aggressive change in its generation asset portfolio mix through its 2018 and 2021 IRPs.
13 Pursuant to PA 235 of 2023, the Company will be filing a renewable energy plan
14 amendment no later than November 15, 2024, which will reflect its plans to comply with
15 the new renewable energy laws.

16 **PERIODIC OUTAGE PLANS, AVAILABILITY, ROR PROJECTIONS,**
17 **AND NET ENERGY VALUE**

18 **Q. Please describe Exhibit A-41 (RTB-1).**

19 A. Exhibit A-41 (RTB-1) identifies the major outages (28 days or longer in duration) that are
20 scheduled during the projected test year ending February 28, 2026, for the Company's
21 fossil-fueled and Ludington Generating Units. The Company's generation asset strategy
22 is a key input to the scheduling of planned outages, and outage duration directly informs
23 the periodic factors ("PFs") reflected on Exhibit A-42 (RTB-2).

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. Please describe Exhibit A-42 (RTB-2), Generating Unit Availability Projections.**

2 A. Exhibit A-42 (RTB-2) details Generating Unit Availability Projections for Consumers
3 Energy's coal generation, peaking generation, and hydraulic power generation for the
4 projected test year beginning March 1, 2025 and ending February 28, 2026. Column (a)
5 identifies Consumers Energy's generating units or category of generating units.
6 Column (b) identifies the five-year historical ROR of the generating unit or category of
7 generating unit. Column (c) identifies the projected ROR of the unit or category of
8 generating unit. Column (d) identifies the PF of the generating unit or category of
9 generating unit. Column (e) identifies the projected availability of the generating unit or
10 category of generating unit. Column (f) identifies the five-year historical Net Energy Value
11 ("NEV") of the generating unit or category of generating unit.

12 **Q. Please define ROR.**

13 A. ROR is a measure of the percent of MWh unavailability due to forced or unplanned
14 generating unit outages and forced or unplanned generating unit de-rates.

15 **Q. What factors cause an increase or decrease in ROR?**

16 A. The frequency and/or duration of a forced or unplanned generating unit outage or
17 generating unit de-rate directly affects ROR. Reducing the frequency and/or duration of
18 forced or unplanned generating unit outages and generating unit de-rates decreases ROR.
19 Conversely, increasing the frequency and/or duration of forced or unplanned generating
20 unit outages and generating unit de-rates degrades ROR.

21 **Q. How are ROR projections for the Generating units developed?**

22 A. The ROR projections for the projected test year ending February 28, 2026 were developed
23 from the five-year (2019-2022) average. These five-year averages were then adjusted to

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 reflect current operating conditions and projected unit investment. The projected unit
2 investment is developed in accordance with the Company's generation asset strategy.
3 These five-year historical ROR average values are presented in Exhibit A-42 (RTB-2),
4 column (b).

5 **Q. Please define PF.**

6 A. PF is a measure of the percent of lost availability that results from planned outages, planned
7 outage extensions, planned de-rates, and planned de-rate extensions. Planned derates can
8 be taken for a variety of reasons, including the performance of necessary maintenance work
9 which does not require an outage to perform, or the combustion of a coal blend with a
10 lower heat content than is required to achieve the net demonstrated capability of the unit.

11 **Q. What strategy does the Company employ to minimize the impact of planned outages**
12 **on its customers?**

13 A. Consistent with the Company's generation asset strategy, the Company endeavors to
14 schedule planned generating unit outages during periods in which the margin between the
15 generating unit production cost and the projected MISO energy market price is lowest.
16 This strategy results in creating greater total NEV as I will discuss in more detail later in
17 this direct testimony. In general, the projected MISO energy market pricing is lower in the
18 shoulder months of spring and fall due to historically lower demand. However, with the
19 introduction of seasonal capacity in the MISO market, the Company will also consider the
20 impact of outage scheduling on capacity accreditation for the four capacity seasons.
21 Company witness Metz describes seasonal capacity in more detail in her testimony.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. Please define Projected Availability.**

2 A. Projected Availability is a measure of the percent of time that a generating unit or category
3 of generating units is projected to be available to generate electricity.

4 **Q. How is Projected Availability determined for each generating unit or category of**
5 **generating units?**

6 A. The Projected Availability for each generating unit or category of generating unit is
7 calculated as $(100\% - PF) * (100\% - ROR)$. Projected Availability is the key performance
8 metric for implementation of the Company's generation asset strategy for each generating
9 unit or category of generating unit.

10 **Q. How does the Company's generation asset strategy inform Projected Availability?**

11 A. As I previously discussed, the Company's generation asset strategy and associated
12 generation investment will focus on each unit's ability to provide economic value to
13 customers through the unit's ability to produce energy and capacity value in the respective
14 MISO markets. As such, those generating units or category of generating unit providing
15 the greatest amount of economic value to customers will be targeted to achieve the highest
16 projected availabilities.

17 **Q. How can the Company impact Projected Availability for a generating unit?**

18 A. The Company can directly impact Projected Availability for a generating unit by
19 minimizing both PF and ROR for that unit. With respect to minimizing PF, the Company
20 can employ incremental resources during a planned outage to ensure that the critical path
21 for the outage is as short as possible. This strategy could include working 24-hours, seven
22 days a week, for the duration of the outage. Similarly, when a unit experiences an
23 unplanned outage, the Company can employ necessary resources to ensure the unit is

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 returned to available status as quickly as practical. In addition to minimizing unforced
2 outage length, the Company could invest in a generating unit to increase its reliability and,
3 as a result, decrease the generating unit's projected ROR.

4 **Q. Does the Company attempt to maximize availability for all its generating units or**
5 **category of generating units?**

6 A. No. Consistent with the Company's generation asset strategy, the Company focuses on
7 sustaining availability for those generating units which provide the greatest economic
8 benefit to customers through the energy value provided. The Company's generating units
9 get dispatched by MISO as part of the MISO energy market. Based upon the Company's
10 projected dispatch likelihood for each unit, the Company will rank the generating units
11 from highest economic value to least economic value, and manage the PF and the ROR,
12 and therefore the unit's Availability, to allow for the highest customer value. Or, stated
13 differently, the PF and ROR values may be allowed to be higher (lower unit Availability)
14 for the lower economic value units, and will be managed to lower values (higher unit
15 Availability) for higher economic value units.

16 **Q. How does the Availability projection reflect the customer benefit?**

17 A. An improvement in Availability can translate to a customer benefit in several ways. The
18 immediate benefit is that the generating unit or the category of generating unit is available
19 for dispatch for a greater number of hours throughout the year, likely leading to increased
20 generation, and consequently higher NEV, on an annual basis. Additionally, higher
21 availability increases the ZRCs, increasing the capacity value of the unit.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. How does the Company measure the customer benefit resulting from increased**
2 **generation?**

3 A. The Company utilizes NEV to quantify this customer benefit. At a high level, NEV of a
4 generating unit is the difference between the market value of energy and the cost of
5 producing and supplying that energy. NEV is the net customer benefit of a generator's
6 energy production expressed in dollars. These values are presented in Exhibit A-42
7 (RTB-2), column (f), which identifies five-year (2019-2023) actual NEV amounts.

8 **Q. What can the Company do to positively affect NEV?**

9 A. Typically, economic investments that improve the reliability and availability of the
10 generating unit or category of unit will result in increasing NEV. Economic investments
11 that result in a reduction in the cost to generate will also result in increasing NEV, all else
12 being equal. Positive NEV increases when a generating unit operates more frequently
13 during periods in which market pricing exceeds the cost of production for that unit.
14 Historically, market pricing has tended to be higher in the summer and winter, although
15 there is variability to market conditions. As discussed earlier in my testimony, this is the
16 reason that periodic outages are generally scheduled in the shoulder months of spring and
17 fall. Market prices are typically lower during this time period, thereby reducing the PSCR
18 impact of each scheduled outage.

19 **Q. Does the cost of production vary for the Company's generating units?**

20 A. Yes. The basis for the Company's generation asset strategy is directly related to this
21 actuality. The Company's investment strategy is focused on those units with the lowest
22 variable production costs to maximize NEV for its customers. As the Company
23 strategically invests additional funds in a generating unit to increase its reliability, the

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 expectation is for the generating unit's reliability to be higher than otherwise possible
2 absent the investment. Higher reliability, in turn, increases the likelihood the unit is
3 available during periods when market prices exceed the production cost of the unit, thus
4 increasing the NEV of the unit.

5 **Q. Why is the measurement of NEV important to the Company and its customers?**

6 A. Positive NEV reflects a direct and immediate reduction to customer power supply costs
7 and consideration of NEV provides a basis for making operational and financial decisions
8 in order to maximize the customer value of the generating unit.

9 **Q. What is another measure the Company uses to evaluate economic projects for its**
10 **generating units?**

11 A. In addition to measuring NEV for a generating unit, the Company also considers the impact
12 a higher availability (specifically ROR) will have on the amount of capacity available from
13 a particular generating unit which receives a monetary credit in the MISO Resource
14 Adequacy Market. Table 2 below summarizes the capacity value of the Company's
15 generating units in the 2023-2024 PRA for Zone 7. Company witness Metz discusses the
16 capacity value of the Company's generating units in the PRA in her testimony in this case.
17 I will discuss the projected impact of the Company's generation asset strategy and
18 associated capital expenditures and major maintenance on the projected availabilities,
19 NEV, and capacity value for each of the generating units later in this direct testimony.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

TABLE 2

RESOURCE	MICHIGAN LOCATION	MISO ISAC ¹ MW	MISO SUMMER SAC ² MW (ZRCs)	CAPACITY VALUE ZONE 7 (SETTLEMENT) ³	CAPACITY VALUE ZONE 7 (75% CONE) ⁴
COAL FIRED					
JH Campbell 1	West Olive, MI	261.3	239.5	\$ 1,311,263	\$ 19,023,796
JH Campbell 2	West Olive, MI	355.5	265.2	\$ 1,451,970	\$ 21,065,181
JH Campbell 3	West Olive, MI	784.3 (owned share)	647.8	\$ 3,546,705	\$ 51,455,596
OIL OR GAS FIRED					
Covert	Covert, MI	1088.6	1028.5	\$ 5,631,038	\$ 81,695,092
DE Karn 3	Essexville, MI	593.5	308.2	\$ 1,687,395	\$ 24,480,727
DE Karn 4	Essexville, MI	606.3	389.3	\$ 2,131,418	\$ 30,922,605
Zeeland CC	Zeeland, MI	532.1	525.3	\$ 2,876,018	\$ 41,725,262
Zeeland 1A	Zeeland, MI	159.4	164.1	\$ 898,448	\$ 13,034,676
Zeeland 1B	Zeeland, MI	158.8	163.5	\$ 895,163	\$ 12,987,018
Jackson	Jackson, MI	537.7	527	\$ 2,885,325	\$ 41,860,295
HYDROELECTRIC					
Alcona	Alcona County, MI	3	3	\$ 16,425	\$ 238,294
Allegan	Allegan County, MI	1.1	1.1	\$ 6,023	\$ 87,374
Cooke	Iosco County, MI	7.1	6.8	\$ 37,230	\$ 540,133
Croton	Newaygo County, MI	2.3	2.3	\$ 12,593	\$ 182,692
Five Channels	Iosco County, MI	6.3	6.1	\$ 33,398	\$ 484,531
Footte	Iosco County, MI	2.9	3	\$ 16,425	\$ 238,294
Hardy	Newaygo County, MI	32.4	31.1	\$ 170,273	\$ 2,470,313
Hodenpyl	Wexford County, MI	4.5	4.5	\$ 24,638	\$ 357,441
Loud	Iosco County, MI	4.9	4.7	\$ 25,733	\$ 373,327
Mio	Oscoda County, MI	1.5	1.6	\$ 8,760	\$ 127,090
Rogers	Mecosta County, MI	2.3	2.4	\$ 13,140	\$ 190,635
Tippy	Manistee County, MI	6.2	6.2	\$ 33,945	\$ 492,474
Webber	Ionia County, MI	1	1	\$ 5,475	\$ 79,431
RENEWABLES					
Lake Winds	Mason County, MI	100.8	14.7	\$ 80,483	\$ 1,167,640
Cross Winds (Phase I, II, III)	Tuscola County, MI	230.6	38.1	\$ 208,598	\$ 3,026,333
Crescent Wind	Jonesville, MI	150	19.2	\$ 105,120	\$ 1,525,081
Gratiot Farms Wind	Alma, MI	150	29.9	\$ 163,703	\$ 2,374,996
Heartland Farms Wind Park	Ithaca, MI	201	36.4	\$ 199,290	\$ 2,891,299
Solar Gardens- GVSU	Grand Rapids, MI	1.6	1.7	\$ 9,308	\$ 135,033
Solar Gardens- WMU	Kalamazoo, MI	0.6	0.6	\$ 3,285	\$ 47,659
Cadillac Solar Garden	Cadillac, MI	0.2	0.2	\$ 1,095	\$ 15,886
Circuit West	Grand Rapids, MI	0.3	0.3	\$ 1,643	\$ 23,829
ENERGY STORAGE					
Ludington Units 1-6	Ludington, MI	1168.8 (owned share)	1138.6	\$ 6,233,835	\$ 90,440,478
¹ ISAC = Intermediate seasonal accredited capacity ² SAC = Seasonal accredited capacity and is converted from ISAC based upon offered availability during RA and non-RA hours ³ 2023-2024 PRA Settlement price of \$15/MW-day for Zone 7. ⁴ 2023-2024 PRA 75% CONE price of \$217.62/MW-day for Zone 7.					

Q. Please provide an overview of the generation asset strategy for Campbell Units 1 and 2.

A. The strategic plan for Campbell Units 1 and 2 is predicated on their planned retirement on May 31, 2025, as reflected in the Company's 2021 IRP Settlement Agreement. The overall remaining life objective for Campbell Units 1 and 2 is to maintain economic dispatch and capacity value from the customer's perspective. The major maintenance expenses in the plan are targeted to provide safe and regulatory compliant units. Critical reliability investments required to keep the units available will be included in the plan. Projects that are targeted to improve reliability will not be considered.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. How will the Company's generation asset strategy for Campbell Units 1 and 2 impact**
2 **their projected performance?**

3 A. It is anticipated that the unit performance will degrade from current performance for both
4 Campbell Units 1 and 2, and this risk will be accepted to limit new investment as the units
5 near retirement. Based upon the Campbell Units 1 and 2 major maintenance projects that
6 I will discuss later in this direct testimony, the Company's generation asset strategy is
7 expected to result in an ROR of 16.00% at Campbell Unit 1 and 15.00% at Campbell Unit 2
8 in the test year, as shown on Exhibit A-42 (RTB-2), lines 1 and 2, column (c). During the
9 five-year historical period from 2019 through 2023, Campbell Unit 1 had an ROR of
10 16.89% and Campbell Unit 2 had an ROR of 30.27% as shown on Exhibit A-42 (RTB-2),
11 lines 1 and 2, column (b).

12 **Q. How is this strategy reflected in the Projected Availability for Campbell Units 1 and 2**
13 **in the test year?**

14 A. The Projected Availabilities for Campbell Units 1 and 2 in the test year are 28.30% and
15 85.00%, respectively, as shown on Exhibit A-42 (RTB-2), lines 1 and 2, column (e). The
16 Projected Availability for Campbell Unit 1 reflects a projected ROR of 16.00% and a PF
17 of 66.30%, as shown on Exhibit A-42 (RTB-2), line 1, columns (c) and (d). The planned
18 Campbell Unit 1 outage for the test year is scheduled to begin on April 1, 2025 and last for
19 60 days, as reflected on Exhibit A-41 (RTB-1), line 5. Projected Availability for Campbell
20 Unit 2 reflects a projected ROR of 15.00% and a PF of 0.00%, as shown on Exhibit A-42
21 (RTB-2), line 2, columns (c) and (d). No outages are planned at Campbell Unit 2 for the
22 test year ending February 28, 2026.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. How does the availability for Campbell Units 1 and 2 translate into customer value?**

2 A. As reflected on Exhibit A-42 (RTB-2), lines 1 and 2, column (f), during the five-year
3 historical period from 2019 through 2023, Campbell Unit 1 had an NEV of \$94.3 million
4 and Campbell Unit 2 had an NEV of \$83.3 million. The 2023 NEV for each of these units
5 was \$6.0 million and \$2.8 million for Campbell Units 1 and 2, respectively.

6 **Q. Please quantify the capacity value for Campbell Units 1 and 2.**

7 A. As reflected in Table 2, the capacity value based upon the settlement price for Zone 7 in
8 the 2023-2024 PRA is \$1.311 million for Campbell Unit 1 and \$1.452 million for Campbell
9 Unit 2. The hypothetical capacity value upon which the Company plans its capacity
10 resources (75% of Cost of New Entry ("CONE")) for Zone 7 in the 2023-2024 PRA is
11 \$19.0 million for Campbell Unit 1 and \$21.1 million for Campbell Unit 2.

12 **Q. Please provide an overview of the generation asset strategy for Campbell Unit 3.**

13 A. The strategic plan for Campbell Unit 3 is predicated on its planned retirement on May 31,
14 2025 as reflected in the Company's 2021 IRP Settlement Agreement. The overall
15 remaining life objective for Campbell Unit 3 is to maintain economic dispatch and capacity
16 value from the customer's perspective. The major maintenance expenses in the plan are
17 targeted to provide safe and regulatory compliant units. Critical reliability investments
18 required to keep the units available will be included in the plan. Capital projects that are
19 targeted to improve reliability will not be considered.

20 **Q. How will the Company's generation asset strategy for Campbell Unit 3 impact its**
21 **projected performance?**

22 A. It is anticipated that unit performance will remain relatively consistent with current
23 performance. Based upon the Campbell Unit 3 capital and major maintenance projects

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

discussed later in this testimony, the Company's generation asset strategy is expected to result in an ROR of 8.00% at Campbell Unit 3 in the projected test year, as shown on Exhibit A-42 (RTB-2), line 3, column (c). During the five-year historical period from 2019 through 2023, Campbell Unit 3 had an actual ROR of 14.29%, as shown on Exhibit A-42 (RTB-2), line 3, column (b).

Q. How is this strategy reflected in the Projected Availability for Campbell Unit 3 in the test year?

A. The Projected Availability for Campbell Unit 3 in the test year is 92.00%, as shown on Exhibit A-42 (RTB-2), line 3, column (e). This Availability for Campbell Unit 3 reflects a projected ROR of 8.00% and a PF of 0.00%, as shown on Exhibit A-42 (RTB-2), line 3, columns (c) and (d). No outages are planned at Campbell Unit 3 for the test year ending February 28, 2026.

Q. How does the Campbell Unit 3 Availability translate into customer value?

A. As reflected on Exhibit A-42 (RTB-2), line 3, column (f), during the five-year historical period from 2019 through 2023, Campbell Unit 3 had an NEV of \$347.2 million. The 2023 NEV for Campbell Unit 3 was \$29.2 million.

Q. Please quantify the capacity value for Campbell Unit 3.

A. As reflected in Table 2, the Campbell Unit 3 capacity value based upon the settlement price for Zone 7 in the 2023-2024 PRA is \$3.5 million and the Campbell Unit 3 hypothetical capacity value based upon 75% of CONE for Zone 7 in the 2023-2024 PRA is \$51.5 million.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. Please provide an overview of the generation asset strategy for Karn Units 3 and 4.**

2 A. The strategic plan for Karn Units 3 and 4 is predicated on their planned retirement on
3 May 31, 2031 as reflected in the Company's 2021 IRP Settlement Agreement. The overall
4 remaining life objective for Karn Units 3 and 4 is to maintain economic dispatch and
5 capacity value from the customer's perspective. The capital expenditures and major
6 maintenance expenses in the plan are targeted to provide safe and regulatory compliant
7 units. Critical reliability investments required to keep the units available will be included
8 in the plan. Projects that are targeted to improve reliability will not be considered.

9 **Q. How will the Company's generation asset strategy for Karn Units 3 and 4 impact their**
10 **projected performance?**

11 A. It is anticipated that unit performance for Karn Units 3 and 4 will slightly degrade from
12 current performance. Based upon the Karn Units 3 and 4 capital and major maintenance
13 projects that I will discuss later in this direct testimony, the Company's generation asset
14 strategy is expected to result in an ROR of 18.00% at Karn Unit 3 and 18.00% at Karn
15 Unit 4 in the test year, as shown on Exhibit A-42 (RTB-2), lines 4 and 5, column (c).
16 During the five-year historical period from 2019 through 2023, Karn Unit 3 had an ROR
17 of 38.70% and Karn Unit 4 had an ROR of 24.76%, as shown on Exhibit A-42 (RTB-2),
18 lines 4 and 5, column (b).

19 **Q. How is this strategy reflected in the Projected Availability for Karn Units 3 and 4 in**
20 **the test year?**

21 A. The projected availabilities for Karn Units 3 and 4 in the test year are 72.34% and 71.44%,
22 respectively, as shown on Exhibit A-42 (RTB-2), lines 4 and 5, column (e). The
23 availability for Karn Unit 3 reflects a projected ROR of 18.00% and a PF of 11.78%, as

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 shown on Exhibit A-42 (RTB-2), line 4, columns (c) and (d). The planned outage for the
2 test year is scheduled to begin on March 1, 2025 and last for 42 days, as reflected on Exhibit
3 A-41 (RTB-1), line 2. The availability for Karn Unit 4 reflects a projected ROR of 18.00%
4 and a PF of 12.88%, as shown on Exhibit A-42 (RTB-2), line 5, columns (c) and (d). The
5 planned outage for the test year is scheduled to begin on March 22, 2025 and last for
6 46 days, as reflected on Exhibit A-41 (RTB-1), line 4.

7 **Q. How does the Projected Availability for Karn Units 3 and 4 translate into customer**
8 **value?**

9 A. As reflected on Exhibit A-42 (RTB-2), lines 4 and 5, column (f), during the five-year
10 historical period from 2019 through 2023, Karn Unit 3 had a NEV of -\$8.1 million and
11 Karn Unit 4 had a NEV of -\$10.4 million. The 2023 NEV for each of these units
12 was -\$1.7 million and -\$0.4 million for Karn Units 3 and 4, respectively.

13 **Q. Please explain why the NEVs for Karn Units 3 and 4 are negative.**

14 A. The NEVs for Karn Units 3 and 4 are negative due to required operation in support of
15 capacity demonstration testing, unit performance validation, and operator training. During
16 this operation, the units are operated as Must-Run resources in the MISO Energy Market
17 and as such, they are price takers. In order to minimize the impact of the required operation
18 of the units, the Company performs those activities during periods in which operation is
19 most economic. However, despite the fact that the NEVs are slightly negative, the units
20 provide a significant amount of capacity value, which far outweighs the negative NEV
21 values. In addition, the Company's ability to have these units dispatched during tight
22 generation days provides reliability benefits for the Company's customers and the MISO
23 energy market.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. Please quantify the capacity value for Karn Units 3 and 4.**

2 A. As reflected in Table 2, the capacity value based upon the settlement price for Zone 7 in
3 the 2023-2024 PRA is \$1.7 million for Karn Unit 3 and \$2.1 million for Karn Unit 4. The
4 hypothetical capacity value based upon 75% of CONE for Zone 7 in the 2023-2024 PRA
5 is \$24.5 million for Karn Unit 3 and \$30.9 million for Karn Unit 4.

6 **Q. Please provide an overview of the generation asset strategy for the Zeeland Plant.**

7 A. The strategic plan for the Zeeland Plant is predicated on plant operation through Planning
8 Year 2040. The overall long-term objective for the Zeeland Plant is to maintain economic
9 dispatch and capacity from the customer's perspective. The units provide significant value
10 to customers in both the energy and resource adequacy markets. The capital expenditures
11 and major maintenance expenses in the plan are targeted to provide a safe, regulatory
12 compliant, and reliable unit. Critical reliability investments required to keep the units
13 available will be included in the plan. Projects that are targeted to improve reliability will
14 be included in the plan if they provide value to customers.

15 **Q. How will the Company's generation asset strategy for the Zeeland Plant impact its**
16 **projected performance?**

17 A. It is anticipated that site performance will remain relatively consistent with current
18 performance. Based upon the Zeeland Plant capital and major maintenance projects that
19 I will discuss later in this testimony, the Company's generation asset strategy is expected
20 to result in an ROR of 4.0% at the Zeeland Plant in the test year, as shown on Exhibit A-42
21 (RTB-2), lines 13 through 15, column (c). During the five-year historical period from 2019
22 through 2023, the Zeeland Plant had ROR values at or below 7.48% for all units, as shown
23 on Exhibit A-42 (RTB-2), lines 13 through 15, column (b).

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. How is this strategy reflected in the Projected Availability for the Zeeland Plant in**
2 **the test year?**

3 A. The Projected Availability for the combined cycle generating units (Units 1 and 2) at the
4 Zeeland Plant in the test year is 83.90%, as shown on Exhibit A-42 (RTB-2), line 13,
5 column (e). The Zeeland Combined Cycle (Units 3, 4, and 5) Generating Unit availability
6 is based upon a projected ROR of 4.0% and a PF of 12.60%, as shown on Exhibit A-42
7 (RTB-2), line 13, columns (c) and (d). The Projected Availabilities for each of the simple
8 cycle generating units at the Zeeland site in the projected test year are 86.79%, as shown
9 on Exhibit A-42 (RTB-2), lines 14 and 15, column (e). Each of the Zeeland simple cycle
10 generating unit Projected Availabilities are based upon projected RORs of 4.0% and PFs
11 of 9.59%, as shown on Exhibit A-42 (RTB-2), lines 14 and 15, columns (c) and (d). There
12 are no outages greater than 28 days scheduled for the Zeeland combined cycle units
13 (Units 3, 4, and 5) in the projected test year ending February 28, 2026, however there are
14 several shorter duration outages of 10 days each scheduled in May and October. The
15 planned outage for the test year for Zeeland Unit 1 is scheduled to begin on March 10, 2025
16 and last for 34 days, as reflected on Exhibit A-41 (RTB-1), line 3. The planned outage for
17 the test year for Zeeland Unit 2 is scheduled to begin on April 21, 2025 and last for 34
18 days, as reflected on Exhibit A-41 (RTB-1), line 6. These outages are scheduled during
19 periods in which energy prices are projected to be lower, thereby reducing the impact of
20 the outages on customers. In addition, the outages are scheduled to maximize future
21 capacity attribution for the units given the MISO seasonal resource adequacy construct.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. How does the Zeeland Plant Projected Availability translate into customer value?**

2 A. As reflected on Exhibit A-42 (RTB-2), lines 13 through 15, column (f), during the five-year
3 historical period from 2019 through 2023, the Zeeland Plant provided a total NEV of
4 \$220.5 million. The 2023 NEV for Zeeland was \$49.4 million.

5 **Q. Please quantify the capacity value for the Zeeland Plant.**

6 A. As reflected in Table 2, the Zeeland Plant capacity value based upon the settlement price
7 for Zone 7 in the 2023-2024 PRA is \$4.7 million and the Zeeland Plant hypothetical
8 capacity value based upon 75% of CONE for Zone 7 in the 2023-2024 PRA is
9 \$67.7 million.

10 **Q. Please provide an overview of the generation asset strategy for the Jackson Plant.**

11 A. The strategic plan for the Jackson Plant is predicated on plant operation through Planning
12 Year 2040. The overall long-term objective for the Jackson Plant is to maintain economic
13 dispatch and capacity from the customer's perspective. The units provide significant value
14 to customers in both the energy and resource adequacy markets. The capital expenditures
15 and major maintenance expenses in the plan are targeted to provide a safe, regulatory
16 compliant, and reliable unit. Critical reliability investments required to keep the units
17 available will be included in the plan. Projects that are targeted to improve reliability will
18 be included in the plan if they provide value to customers.

19 **Q. How will the Company's generation asset strategy for the Jackson Plant impact its
20 projected performance?**

21 A. It is anticipated that site performance will remain relatively consistent with current
22 performance. Based upon the Jackson Plant capital and major maintenance projects that
23 I will discuss later in this direct testimony, the Company's generation asset strategy is

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 expected to result in an ROR of 4.50% at the Jackson Plant in the test year, as shown on
2 Exhibit A-42 (RTB-2), line 16, column (c). During the five-year historical period from
3 2019 through 2023, the Jackson Plant had an actual ROR of 8.22%, as shown on Exhibit
4 A-42 (RTB-2), line 16, column (b).

5 **Q. How is this strategy reflected in the Projected Availability for the Jackson Plant in**
6 **the test year?**

7 A. The Projected Availability for all of the generating units at the Jackson site in the test year
8 is 81.63%, as shown on Exhibit A-42 (RTB-2), line 16, column (e). The Projected
9 Availability for the Jackson site reflects a projected ROR of 4.50% and a PF of 14.52%, as
10 shown on Exhibit A-42 (RTB-2), line 16, columns (c) and (d). There are no major planned
11 outages in excess of 28 days for the Jackson units in the test year, however a short 12-day
12 outage is scheduled to begin October 10, 2025. In addition, several derates are scheduled
13 to perform inspections and maintenance on various generating units in April and September
14 2025.

15 **Q. How does the Jackson Plant Projected Availability translate into customer value?**

16 A. As reflected on Exhibit A-42 (RTB-2), line 16, column (f), during the five-year historical
17 period from 2019 through 2023, the Jackson units provided a total NEV of \$158.4 million.
18 The 2023 NEV for the Jackson Plant was \$24.1 million.

19 **Q. Please quantify the capacity value for the Jackson Plant.**

20 A. As reflected in Table 2, the Jackson Plant capacity value based upon the settlement price
21 for Zone 7 in the 2023-2024 PRA is \$2.9 million and the Jackson Plant hypothetical
22 capacity value based upon 75% of CONE for Zone 7 in the 2023-2024 PRA is
23 \$41.9 million.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. How will the Company's generation asset strategy for the Covert Plant impact its**
2 **projected performance?**

3 A. It is anticipated that site performance will remain relatively consistent with past
4 performance under different ownership. Based upon the Covert Plant capital and major
5 maintenance projects that I will discuss later in this direct testimony, the Company's
6 generation asset strategy is expected to result in an ROR of 7.00% for all three units at the
7 Covert Plant in the test year, as shown on Exhibit A-42 (RTB 2), lines 17 through 19,
8 column (c).

9 **Q. How is this strategy reflected in the Projected Availability for the Covert Plant in the**
10 **test year?**

11 A. The Projected Availability for each of the combined cycle generating units at the Covert
12 Plant in the test year ranges from 75.16% to 82.55%, as shown on Exhibit A-42 (RTB-2),
13 lines 17 through 19, column (e). The Covert Unit 1 unit availability of 80.77% is based
14 upon projected ROR of 7.00% and a PF of 13.15%, as shown on Exhibit A-42 (RTB-2),
15 line 17, columns (c) and (d), the Covert Unit 2 unit availability of 82.55% is based upon
16 projected ROR of 7.00% and a PF of 11.23%, as shown on Exhibit A-42 (RTB-2), line 18,
17 columns (c) and (d), and the Covert Unit 3 unit availability of 75.16% is based upon
18 projected ROR of 7.00% and a PF of 19.18%, as shown on Exhibit A-42 (RTB-2), line 18,
19 columns (c) and (d). The Company will conduct major inspections at all three of the Covert
20 Units during the bridge period/test year. The planned outage for the test year for Covert
21 Unit 1 is scheduled to begin on February 1, 2026 and last for 59 days (beyond the test year),
22 as reflected on Exhibit A-41 (RTB-1), line 8. The planned outage for the test year for
23 Covert Unit 2 is scheduled to begin on February 1, 2025 and last for 59 days, as reflected

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 on Exhibit A-41 (RTB-1), line 1. The planned outage for the test year for Covert Unit 3 is
2 scheduled to begin on November 1, 2025 and last for 59 days, as reflected on Exhibit A-41
3 (RTB-1), line 7. These outages are scheduled for periods in which energy prices are
4 projected to be lower, thereby reducing the impact of the outages on customers. In addition,
5 the outages are scheduled to maximize future capacity attribution for the units given the
6 MISO seasonal resource adequacy construct.

7 **Q. How does the Covert Plant Projected Availability translate into customer value?**

8 A. As reflected on Exhibit A-42 (RTB-2), lines 17 through 19, column (f), during the
9 seven-month historical period in 2023, the Covert units provided a total NEV of
10 \$49.4 million.

11 **Q. Please quantify the capacity value for the Covert Plant.**

12 A. As reflected in Table 2, the Covert Plant capacity value based upon the settlement price for
13 Zone 7 in the 2023-2024 PRA is \$5.6 million and the Covert Plant hypothetical capacity
14 value based upon 75% of CONE for Zone 7 in the 2023-2024 PRA is \$81.7 million.

15 **Q. Please provide an overview of the generation asset strategy for the River Hydro units.**

16 A. A full discussion of the Company's River Hydro generation asset strategy is included in
17 the direct testimony of Company witness Monroe. In addition, Company witness Monroe
18 will discuss the capital investments for the River Hydro projects which are necessary for
19 continued safe and reliable operation. Regardless of the future of the River Hydro
20 facilities, Consumers Energy will maintain safe operation of its hydroelectric dams as long
21 as they are licensed by the Company. As all of the River Hydro facilities are currently
22 licensed through at least 2034, the Company needs to continue to invest in these assets to

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

maintain its licenses and the Company's commitment to dam safety as long as the Company holds the Federal Energy Regulatory Commission ("FERC") licenses.

Q. Did the Order in the Company's 2023 Electric Rate Case (Case No. U-21389) establish any specific requirements for the River Hydro facilities?

A. Yes. Paragraph D on page 309 of the March 1, 2024 Order in Case No. U-21389 required the following:

"If cost recovery for work on the Hardy Dam is sought in its next general electric rate case, Consumers Energy Company shall file a full evaluation of all alternative options and pricing for the work that must be done in order to remain in compliance with Federal Energy Regulatory Commission standards, with projected total costs."

As reflected in Exhibit A-12 (RTB-3), Schedule B-5.2, page 9, line 27, the Company intends to invest \$53.854 million in the Hardy Dam Auxiliary Spillway Project in the projected test year with construction beginning in the fall of 2025. Company witness Monroe is supporting the full evaluation of the alternative options for the Hardy Dam in order to remain in Compliance with FERC requirements and its operating license.

Q. What is the status of the requirements included in the Settlement Agreement in the Company's 2022 Electric Rate Case (Case No. U-21224) for the Muskegon River?

A. The Company has fulfilled the requirements reflected in the Settlement Agreement in the Company's 2022 Electric Rate Case (Case No. U-21224). The Settlement Agreement reached in Case No. U-21224 required the Company to "work with Staff and the Attorney General to scope and conduct the following analyses of all reasonable options prior to commencing construction of the Hardy Dam upgrades:

"a. Economic business cases performed by an outside engineering firm with experience in dam engineering, construction, and decommissioning, that will compare the

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 projected capital and O&M costs through the end of Hardy
2 Dam's current Federal Energy Regulatory Commission
3 ("FERC") license term, with the value of the energy and
4 capacity that Hardy Dam will provide customers, under a
5 variety of reasonable assumptions. These assumptions will
6 be inclusive of at least the current long-term forecast for
7 energy prices and replacement capacity priced at a range of
8 percentages of the Cost of New Entry. The business case
9 shall utilize best available assumptions and consider, at a
10 minimum, the feasibility and impacts of (i) divestiture, (ii)
11 permanently lowering the reservoir height, (iii) full
12 decommissioning and removal, and (iv) other options that
13 avoid or minimize the impact of the Hardy Dam on customer
14 rates. In addition, the Company will perform, or cause to be
15 performed, an economic assessment of the impact of each of
16 these scenarios on the Muskegon River Hydroelectric Dam
17 communities.

18 b. The Company shall engage in discussions with affected
19 local communities on the costs and timing of the proposed
20 Muskegon River Hydroelectric Dam projects, the need for
21 additional funding from those Muskegon River
22 Hydroelectric Dam impacted communities and possible
23 mechanisms for funding to ensure FERC compliance and
24 dam safety at the Hardy Dam, and the impact to the Hardy
25 Dam and reservoir (as well as the Rogers and Croton dams
26 and reservoirs) if this additional funding is not already
27 recovered in Consumers Energy rates or received from other
28 sources. Prior to construction of the Hardy Dam upgrades,
29 the Company agrees to report on these discussions and
30 inform the Commission whether additional funding from the
31 communities or other sources is feasible (both as to amounts
32 and timing) and provide a best-efforts estimate of the total
33 revenue, if any, that could potentially be available from such
34 sources."

35 **Q. What is the status of the Company's progress on the business cases?**

36 A. Consistent with the terms of the Settlement Agreement, the Company has commissioned
37 the performance of business cases for the Muskegon River Hydro facilities (Croton, Hardy
38 and Rogers) by an outside engineering firm that has experience in dam engineering,
39 construction, and decommissioning. The business cases utilized best available assumptions

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 and considered divestiture (as will be discussed later in this direct testimony), full
2 decommissioning and removal utilizing all three decommissioning options, and a
3 permanent lowering of the reservoir height. **Confidential** Exhibit A-149 (AJM-7) includes
4 the results of the business cases for the Muskegon River Hydro facilities.

5 In addition, the Company commissioned the performance of an economic
6 assessment of the impact of each of these scenarios on the Muskegon River Hydro facilities
7 communities. The results of these economic assessments are presented in Exhibit A-44
8 (RTB-5).

9 **Q. Did the Company engage the MPSC Staff and the Attorney General in the**
10 **development of the business cases and the economic assessments?**

11 A. Yes. The Company met regularly with the MPSC Staff and the Attorney General to review
12 the scope and receive input on both the business cases and the economic assessments.
13 Through a non-disclosure agreement (“NDA”), the Company shared all relevant
14 information related to each of the scope items, met to both present and discuss the inputs,
15 scope, and results of each of the analyses. The Company provided formal responses to
16 interrogatories regarding the process, data, and the results, facilitated a tour of Hardy Dam
17 for the Attorney General, and also facilitated specific discussions on topics such as
18 probable maximum flood (“PMF”) to ensure understanding of the Hardy project design
19 was as complete as possible.

20 **Q. What is the status of the RFP for River Hydro divestiture?**

21 A. The Company launched an RFP to identify potential buyers for its 13 River Hydro facilities
22 on February 15, 2024. The RFP participants will move through a two-stage evaluation and
23 bidding process that is expected to be complete by the end of 2024.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. Has the Company received responses from the February 15, 2024 RFP?**

2 A. Yes. As part of the first phase of the RFP, which involves bidder screening based on,
3 among other things, qualifications and indicative pricing, the Company received responses
4 to the RFP on March 15, 2024. The Company has evaluated the bids and moved to the
5 second phase of the RFP in April of 2024.

6 **Q. What is the scope of Phase 2 of the RFP process?**

7 A. Phase 2 involves engaging with seven selected entities in due diligence, negotiations, and
8 potential sale agreement(s). Due diligence will be completed during the summer, and
9 negotiations will take place for the remainder of the year.

10 **Q. What is the status of the Company's discussions with affected local communities and**
11 **their ability to provide funding to maintain the River Hydros?**

12 A. To identify the potential for community funding, the Company met with local elected
13 officials and other key community stakeholders (chamber of commerce, economic
14 development, homeowners associations, parks department, etc.) at each River Hydro
15 facility. The Company met several times with each community, the first meeting was to
16 introduce the concept of community funding to the community and gauge their interest and
17 initial thoughts on capacity. If favorable, we asked them to spend some time researching
18 the initial options we discussed to better understand their potential capacity for funding.

19 The Company revisited each community four-to-six weeks later to discuss those
20 options and truly understand the community's capacity to support its operations. At the
21 second meeting the Company did not ask for any commitments. As a result of the meetings,
22 the Company did identify some funding in most communities, but the available funding

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 was not significant when compared to the Company's current gap between relicensing and
2 decommissioning cost estimates.

3 **Q. What are your thoughts regarding the Company's compliance with the requirements**
4 **of the Settlement Agreement?**

5 A. As a result of the Company's collaboration with the MPSC Staff and the Attorney General,
6 its commissioning of business cases and economic impact studies, and its economic
7 outreach and identification of external funding, it is my opinion that the Company has
8 satisfied the requirements of the Settlement Agreement.

9 **Q. Has the MPSC imposed additional requirements on the Company before moving**
10 **forward with construction on the Hardy Dam?**

11 A. Yes. The March 1, 2024 Order in the Company's 2023 Electric Rate Case (Case No.
12 U-21389) included the following requirement in ordering paragraph D:

13 "If cost recovery for work on the Hardy Dam is sought in its
14 next general electric rate case, Consumers Energy Company
15 shall file a full evaluation of all alternative options and
16 pricing for the work that must be done in order to remain in
17 compliance with Federal Energy Regulatory Commission
18 standards, with projected total costs."

19 Company witness Monroe addresses this requirement in his direct testimony as the
20 Company has included projected project costs for work on the Hardy Dam in this
21 proceeding.

22 **Q. Please describe the Company's anticipated timeline for deciding whether each River**
23 **Hydro will be relicensed, sold, or decommissioned.**

24 A. The Company intends to make a decision on the divestiture of the River Hydros by the end
25 of 2024. Should the Company make a decision to not divest the assets, the Company

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 would revisit the decision to relicense or decommission the River Hydros, with the
2 intention of making a decision in the 1st quarter of 2025.

3 **Q. Will the Company's decision affect the need for the River Hydro investments and**
4 **expenses requested in this case?**

5 A. No. Regardless of the ultimate decision on whether to relicense, sell, or decommission the
6 respective River Hydro facilities, the investments and expenses requested in this case are
7 needed to appropriately maintain those facilities in order to ensure they are safe and legally
8 compliant. The required diligence which needs to be undertaken in order to make a decision
9 on the future of the River Hydros (e.g., adequate evaluation of the bids submitted by the
10 seven entities which are part of Phase 2 of the RFP process and analysis of the community
11 impact study) means that a decision on the future of the River Hydros cannot be reasonably
12 made until late 2024 at the earliest. Subsequent activities to implement the decision(s) will
13 extend into and beyond the test year for this case. The River Hydro investments and
14 expenses requested in this case are needed to reasonably operate those facilities regardless
15 of the ultimate decision on whether to relicense, decommission, or sell one or more of
16 them.

17 **Q. Would it be reasonable to delay approval of the River Hydro investments and**
18 **expenses requested in this case?**

19 A. No, it would not. Delaying approval of the River Hydro cost recovery in this case would
20 mean denying the Company's ability to execute the investments and operations and

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 maintenance activities necessary to keep the River Hydro facilities safe and compliant with
2 FERC regulations.

3 **Q. Please provide an overview of the generation asset strategy for Ludington.**

4 A. The strategic plan for Ludington is predicated on retiring the units by July 30, 2069. The
5 Ludington units recently underwent a major overhaul that was intended to provide
6 increased capacity and generation, increased efficiency, reduced maintenance, and an
7 extended service life which supported the 50-year FERC license extension granted in 2019.
8 Ludington is a FERC-regulated hydroelectric facility for which dam safety investments are
9 identified and initiated as a result of regulatory compliance and adherence to FERC
10 processes, including the FERC Part 12 process discussed in Mr. Monroe's direct testimony.

11 **Q. How will the Company's generation asset strategy for Ludington impact its projected**
12 **performance?**

13 A. Based upon the Ludington capital and major maintenance projects that I will discuss later
14 in this direct testimony, the Company's generation asset strategy is expected to result in an
15 ROR of 3.50% for the Ludington units in the test year, as shown on Exhibit A-42 (RTB-2),
16 lines 6 through 11, column (c). During the five-year historical period from 2019 through
17 2023, the Ludington units had average ROR values ranging from 4.94% to 7.75%, as
18 shown on Exhibit A-42 (RTB-2), lines 6 through 11, column (b).

19 **Q. How do the Ludington Units factor into the Company's future renewable energy**
20 **strategy as outlined in the IRP?**

21 A. Given the intermittent nature of solar and wind generation and the Company's plans to
22 move to a zero net carbon future, Ludington is becoming a more critical component of the
23 Company's generation portfolio since it can deliver a significant amount of energy in a

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 short time period; providing energy supply from the reservoir during periods when the
2 wind doesn't blow and/or the sun doesn't shine. Additionally, when there is an
3 over-abundance of wind and/or solar generation, Ludington can utilize the excess energy
4 to fill the reservoir. Ludington's large energy storage capability greatly enables the
5 transition to renewable energy. However, defective and non-confirming work performed
6 by Toshiba during recent overhaul efforts must be resolved to ensure Ludington can fully
7 provide these intended benefits over its remaining life.

8 **Q. How is this strategy reflected in the Projected Availability for Ludington in the test**
9 **year?**

10 A. The Projected Availabilities for all of the Ludington units in the projected test year ranges
11 from 74.03% to 88.30%, as shown on Exhibit A-42 (RTB-2), lines 6 through 11,
12 column (e). The Projected Availabilities for the Ludington generating units reflect a
13 projected ROR of 3.50% and PFs ranging from 8.49% to 23.29%, as shown on Exhibit
14 A-42 (RTB-2), lines 6 through 11, columns (c) and (d). There are currently no major
15 outages planned for the Ludington units in the test year; shorter outages on all six
16 Ludington units are scheduled throughout the test period, primarily in the spring and fall.
17 These outages will be used, in part, to evaluate and monitor ongoing issues with the
18 Toshiba work. The outages are scheduled during periods in which the likelihood of
19 Ludington unit dispatch is lower, thereby reducing the impact of the outages on customers.

20 **Q. Please provide an overview of the generation asset strategy for the Renewable Energy**
21 **Assets.**

22 A. The Company's strategic plan for Renewable Energy Assets, both wind and solar, has been
23 entirely driven by the Company's MPSC-approved 2021 IRP Settlement Agreement.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 Consistent with the IRP, the strategy for the wind assets is to complete construction and
2 have all wind assets in service in 2024 with the completion of Heartland Wind Farm. With
3 respect to solar, the Company plans to continue to add incremental solar resources in
4 accordance with its Clean Energy Plan and Renewable Energy Plan. These solar resources
5 are being added pursuant to the Company's 2018 IRP and 2021 IRP annual solicitations,
6 as discussed in more detail later in this direct testimony. In addition, the Company
7 anticipates that it will also add up to 1,000 MW of wind and solar assets through 2027¹ in
8 support of the Company's Voluntary Green Pricing Program, and their costs will be
9 reconciled through the Company's Renewable Energy Plan. The overall investment
10 objective for the Company-owned assets is to provide funding for projects as appropriate
11 to maintain economic dispatch and capacity from the customer's perspective. The
12 Company has a time-based availability target of 97% for its renewable energy wind assets.
13 This availability target considers those periods during which the wind is sufficient to
14 produce energy. The capital expenditures and major maintenance expenses in the plan are
15 targeted to maintain the designed performance level.

16 **Q. How will the enactment of PA 235 of 2023 impact the Company's renewable energy**
17 **portfolio?**

18 A. As previously discussed in this direct testimony, the Company will be filing a Renewable
19 Energy Plan Amendment no later than November 15, 2024. PA 235 of 2023 has
20 established both renewable and clean energy targets for the future beginning with a
21 renewable energy compliance target of 50% in 2030. The newly passed law became

¹ The Settlement Agreement in the Company's 2021 Renewable Energy Plan Amendment, Case No. U-20984, reflected the addition of up to 500 MW of solar and 500 MW of wind over the period from 2024 through 2027 to support the Company's Large Customer Renewable Energy Program.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

effective on February 27, 2024 and provides for the utilization of renewable energy assets from anywhere within the MISO footprint.

Q. How do the Company's renewable assets translate into customer value?

A. Similar to the Company's River Hydro units, the production cost of the Company's renewable energy assets is zero. As such, all energy sold into the MISO energy market has value provided that the MISO locational marginal prices are positive. Additionally, renewable assets provide the Company's customers with renewable energy credits. As reflected on Exhibit A-42 (RTB-2), lines 20 through 21, column (f), during the five-year historical period from 2019 through 2023, the Cross Winds Energy Park and the Lake Winds Energy Park provided a total NEV of \$166.7 million. The 2023 NEVs for Cross Winds Energy Park and Lake Winds Energy Park were \$18.6 million and \$7.0 million, respectively. As reflected on Exhibit A-42 (RTB-2), lines 22 through 23, column (f), during the two-year historical period from 2022 through 2023, Gratiot Farms Wind and Crescent Wind were provided total NEV of \$68.5 million. The 2023 NEVs for Gratiot Farms Wind and Crescent Wind were \$9.7 million and \$10.7 million, respectively. Heartland Farms Wind Park began commercial operation on January 2, 2024, and as reflected on Exhibit A-42 (RTB-2), line 24, column (f), generated \$0.4 million in NEV in 2023 following its December 29, 2023 commercial operation date. The Company began to measure the NEV for its solar assets in 2020 and the 2020 through 2023 NEV for its Solar Garden Assets totaled \$1,140,655.

Q. Please quantify the capacity value for renewable energy assets.

A. As reflected in Table 2, the renewable asset capacity value based upon the settlement price for Zone 7 in the 2023-2024 PRA is \$0.8 million and the renewable asset hypothetical

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

capacity value based upon 75% of CONE for Zone 7 in the 2023-2024 PRA is \$11.2 million.

Q. Why have you included a hypothetical capacity value for each of the generating units or category of generating units?

A. I have included these hypothetical values to reflect the capacity values that the Company uses in its capacity planning process. Company witness Metz provides additional information regarding the capacity value of the Company's generation assets in MISO's PRA as well as the projected capacity margin in future years for Zone 7.

Q. How will the Company determine the reasonableness and prudence of additional investments in the electric generating fleet?

A. Additional investment in the remaining units over and above those necessary to maintain safety and regulatory compliance would require some level of economic benefit for customers, otherwise the investment does not make sense. The generating unit periodic outage plans, projected RORs and, ultimately, projected availability for each generating unit or category of generating units reflects the Company's generation asset strategy.

SECTION II
ENVIRONMENTAL REGULATIONS
OVERVIEW

Q. Can you please list the environmental regulations with which Consumers Energy is required to comply and that are relevant to expenditures for which the Company is seeking recovery in this case?

A. Yes. The Company's fossil-fueled Electric Generating Units ("EGUs") are subject to numerous complex and overlapping air, water, and waste regulations.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

Current (On-going) Environmental Compliance

Environmental Regulations – Air Quality

Q. Describe Consumers Energy’s Existing Air Quality Compliance Strategy (“AQCS”).

A. Over the past decade, Consumers Energy has had expenditures to comply with a variety of air quality-related regulations, including the Cross State Air Pollution Rule, the Mercury and Air Toxics Standards, and the Michigan Mercury Rule, among others. The background and purpose of each such rule has been discussed in the testimony of prior rate cases, including Case No. U-17735. To comply with these regulations, Consumers Energy created the AQCS. Cost recovery reflecting the Company’s AQCS was approved in the November 19, 2015 Order in the Company’s 2014 Electric Rate Case (Case No. U-17735). This AQCS has prudently ensured compliance with applicable state and federal air-quality related regulations. The Company’s actions and investments to achieve such compliance have been performed in a manner which has minimized, to the extent reasonably possible, the associated costs for customers. The investments made to ensure environmental compliance have allowed the continued operation of coal generation while the Company transitions to carbon-free generation sources like solar.

Q. Are there any updates to the air quality-related regulations for which the Company’s existing AQCS complies?

A. Yes. In April 2022 the Environmental Protection Agency (“EPA”) proposed the “Federal Implementation Plan Addressing Regional Ozone Transport for the 2015 Ozone National Ambient Air Quality Standard.” The EPA’s rule was finalized, effective March 15, 2023. The rule resulted in very little impact to the Company in the short term. The rule does contain a budget re-allocation provision which will ratchet down the nitrogen oxide

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 (“NOx”) allowances allocated to the Company, so the Company will continue to monitor
2 the rule and evaluate the various options for compliance.

3 **Q. What are the capital investments and/or O&M expenses the Company is seeking**
4 **recovery of in this case that are specifically related to air quality control?**

5 A. Any capital and/or O&M required for the operation of the air quality control systems that
6 the Company is seeking recovery can be found in Exhibits A-12 (RTB-3), Schedule B-5.2
7 and A-43 (RTB-4).

8 **Q. Are you seeking recovery of any expenses related to the regulation of greenhouse**
9 **gases from EGUs?**

10 A. No, not at this time. The EPA released proposed greenhouse gas (“GHG”) regulations for
11 power plants under Section 111 of the Clean Air Act in May 2023. The proposed
12 regulation covered GHG emissions from existing coal-fired and some existing natural
13 gas-fired units. The rule does not impact the Company’s remaining coal-fired units due to
14 the May 2025 retirement date for all coal-fired units. The EPA announced in March 2024
15 that when the proposed Section 111 rule is finalized, scheduled for April 2024, it will no
16 longer cover existing natural-gas fired units. EPA states that existing natural-gas fired
17 units will be covered in a future regulation.

18 **Environmental Regulations and Compliance Strategy – Waste**

19 **Q. Can you please describe the relevant parts of the Resource Conservation and**
20 **Recovery Act (“RCRA”) as related to Coal Combustion Residuals (“CCR”)**
21 **management?**

22 A. On April 17, 2015, the EPA published 40 CFR Parts 257 and 261, Disposal of CCRs from
23 Electric Utilities, in the Federal Register under Subtitle D of the RCRA. The rules establish

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 minimum national criteria for purposes of determining which CCR solid waste disposal
2 facilities and solid waste management practices pose a reasonable probability of adverse
3 effect on health or the environment under RCRA. The rule is considered
4 self-implementing, meaning that affected facilities must certify compliance with the
5 published standards and schedules. By codifying standards under Subtitle D, Owners and
6 Operators are not required to obtain permits, and states are not required to adopt and
7 implement the new rules. Instead, the rules' only enforcement mechanism is for a state or
8 citizen group to bring a RCRA citizen suit in federal district court against any facility that
9 is alleged to be in noncompliance with the newly promulgated minimum standards. In
10 December 2016, the Water Infrastructure Improvements for the Nation ("WIIN") Act was
11 passed. This bill provides authority for state implementation of coal ash management
12 through a state permit program in lieu of the current enforcement of the CCR Rule through
13 the RCRA citizen-suit authority. States may elect to submit a CCR permit program to the
14 EPA for approval. The State of Michigan revised its solid waste statute in late 2018 to
15 outline a state CCR permitting program. Michigan has submitted its application to the EPA
16 for a permit program and is awaiting the EPA's review of administrative completeness. In
17 the interim, the EPA has enforcement authority over the RCRA-CCR Rule as provided in
18 the WIIN Act.

19 The existence of a state permitting program allows Department of Environment,
20 Great Lakes, and Energy ("EGLE") to issue permits under Michigan's solid waste
21 management statute (Part 115 of the Natural Resources and Protection Act of 1994
22 ("NREPA"), as amended) to regulate compliance schedules and activities for CCR landfills
23 and surface impoundments. Although the current state CCR permitting program was

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 passed into law and Consumers Energy is obligated to comply with the associated statute,
2 permits, and licenses, the program must be approved by the EPA on the basis that it is “as
3 protective as” the CCR Rule to avoid dual state and federal regulation. Thus, similar
4 compliance standards are required within the state permitting program, including
5 requirements to make compliance documentation publicly available, completing the work,
6 and then self-reporting by providing notifications to EGLE and posting to a publicly
7 accessible compliance website.

8 **Q. What are the capital and/or O&M investments Consumers Energy is seeking**
9 **recovery of in this case that are specifically related to RCRA compliance and/or**
10 **overall CCR Management?**

11 A. The Company’s CCR management compliance strategy was approved in Case No.
12 U-18322. The major capital work for compliance has been completed. The Cost of
13 Removal (“COR”) and/or O&M required for the management of CCRs under the RCRA
14 that the Company is seeking recovery of can be found in Exhibits A-122 (JJK-3) and A-42
15 (RTB-4). The COR expenses represent historical expenses only. Separately, there are
16 closure activities that will continue throughout the bridge period and test year and beyond;
17 however, those expenses are COR and are not included in this filing.

18 **SECTION III**
19 **GENERATION CAPITAL EXPENDITURES**
20 **OVERVIEW**

21 **Q. What factors does the Company consider in determining the capital investments that**
22 **it will make at its generating plants?**

23 A. The major drivers in the determination of generation capital investments are plant safety,
24 compliance with regulations, and reliability. Consumers Energy’s strategy for complying
25 with environmental regulations was previously discussed in this direct testimony.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. Please describe Exhibit A-12 (RTB-3), Schedule B-5.2, Generation Capital**
2 **Expenditures.**

3 A. This exhibit presents the capital expenditures for Generation, 2023 through the projected
4 test year - 12 months ending February 28, 2026. Exhibit A-12 (RTB-3), Schedule B-5.2,
5 is a nine-page exhibit. Page 1 of this exhibit presents a summary of Generation capital
6 expenditures for the Historical Period ended December 31, 2023, the Projected 14-month
7 Bridge Period beginning January 1, 2024 and ending February 28, 2025, and the projected
8 test year beginning March 1, 2025 and ending February 28, 2026. This summary
9 information is broken down by Steam Power Generation, Hydraulic Power Generation,
10 Pumped Storage Generation, and Other Production Plant. Pages 2 through 5 of this exhibit
11 capture the same Historical Year, Bridge Period, and Test Year Generation capital
12 expenditures information, but is presented by generating sites and environmental
13 categories. This information is further detailed by Contractor, Labor, Materials, Business
14 Expenses, Contingency, and Other. Page 6 of this exhibit represents a summary of pages 2
15 through 5 of this exhibit. Finally, pages 7 through 9 of this exhibit identify the capital
16 projects and associated expenditures that are greater than \$1 million that contribute to the
17 overall capital expenditures summarized on pages 1 through 6 of this exhibit. Specifically,
18 page 7 of this exhibit presents capital projects for the Historical Period ended December 31,
19 2023; page 8 of this exhibit presents capital projects for the Projected 14-month Bridge
20 Period beginning January 1, 2024 and ending February 28, 2025; and page 9 of this exhibit
21 presents capital projects for the projected test year ending February 28, 2026.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. What project information is presented on Exhibit A-12 (RTB-3), Schedule B-5.2,**
2 **pages 7 through 9?**

3 A. Exhibit A-12 (RTB-3), Schedule B-5.2, pages 7 through 9, presents the generation type,
4 the generation unit, project type, project classification, project description, and project cost
5 information. The project type identifies whether the project is routine or non-routine.
6 Routine projects include work that is performed regularly; whereas, non-routine projects
7 are typically undertaken once every 10 years or longer. The budget approval reflects the
8 status of internal approval for the project, including projected cost amount. Exhibit A-12
9 (RTB-3), Schedule B-5.2, page 7, includes both projected and actual capital project cost;
10 whereas, Exhibit A-12 (RTB-3), Schedule B-5.2, pages 8 and 9, includes only the project
11 projected amount.

12 **Q. What level of capital spending for generating plants does the Company request the**
13 **Commission to incorporate into rates in this case?**

14 A. The Company's rate relief request in this case reflects capital spending on projects for its
15 generating plants of \$859.095 million for the historical test year ended December 31, 2023
16 as shown on Exhibit A-12 (RTB-3), Schedule B-5.2, page 1, line 17, column (b);
17 \$463.548 million in the projected 14-month Bridge Period ending February 28, 2025 as
18 shown on Exhibit A-12 (RTB-3), Schedule B-5.2, page 1, line 17, column (e); and
19 \$600.484 million in the projected test year ending February 28, 2026 as shown on Exhibit
20 A-12 (RTB-3), Schedule B-5.2, page 1, line 17, column (f).

21 **Q. Has the Company included any contingency in the requested capital expenditures for**
22 **Generation?**

23 A. No. The Company no longer includes contingency in its generation projects.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. Please explain how the Company prioritizes its capital investments within**
2 **Generation.**

3 A. In evaluating capital investments, the Company's first priority is addressing safety,
4 regulatory, compliance, and continued operation related projects. These projects are
5 considered a mandatory cost of doing business. Safety, regulatory, compliance, and
6 continued operation-related projects provide economic value to customers in that they
7 allow the units to remain in service and avoid potential derates and/or shutdown due to an
8 intervention by various regulators including Occupational Safety and Health
9 Administration ("OSHA"), EGLE, the EPA, and FERC. In order to minimize the impact
10 of these projects on customers, the Company utilizes a least cost/best fit ("LCBF") analysis
11 for the investments necessary to satisfy service quality, safety, and Federal and State policy
12 requirements.

13 **Q. How does the Company determine whether other projects get approved for funding?**

14 A. In accordance with the Company's generation asset strategy for each generating unit or
15 category of generating units, economic projects that are expected to reduce ROR,
16 maintenance cost or heat rate, all else being equal, are evaluated to ensure that their
17 implementation results in a net benefit to the customer. For a project to receive approval
18 for implementation, the projected benefits of the work must have a greater value than the
19 cost of implementing the project. In other words, the implementation of the project should,
20 at a minimum, result in a marginal customer benefit.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. How does the Company evaluate other capital investments, such as economic**
2 **projects?**

3 A. The Company uses two financial measures, Internal Rate of Return (“IRR”) and Present
4 Value Ratio (“PVR”), as a means to evaluate and prioritize projected economic projects
5 within Generation. A complex financial model was developed in-house that allows the
6 Company to calculate and measure the numerous changes that result when improvements
7 (both O&M and Capital) are made to its rate-based generating units.

8 **Q. Does the Company calculate IRRs or PVRs for all projects?**

9 A. No. The Company calculates IRRs or PVRs for economic projects that are not considered
10 required but would yield net benefits to customers. Projects required for regulatory,
11 compliance, and/or continued operations are reviewed to assure that the project is cost
12 effective and result from a reasonable evaluation of alternatives, but because the project
13 must be done for compliance and continued operation, IRR or PVR may not be calculated.
14 When evaluating project alternatives related to regulatory, compliance, and/or continued
15 operations, IRRs or PVRs may be used to rank alternatives.

16 **Q. Please explain what you mean by projects for continued operations.**

17 A. Projects for continued operations refers to projects which are necessary to allow the
18 generating unit to continue to operate through its retirement date. Alternatives for projects
19 necessary for continued operation will generally be evaluated based upon LCBF. For this
20 evaluation, one of the alternatives will include a decision to not perform the project and
21 either retire the unit earlier than projected or operate the unit at a permanent derate.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. How does the Company evaluate customer benefits associated with**
2 **generation-related capital investments?**

3 A. The Company uses replacement power cost estimates and PSCR impacts when evaluating
4 customer benefits. The Company also evaluates ROR and heat rate improvements, which
5 result in increased and/or lower cost generation.

6 **Q. How does the Company evaluate historical events which have impacted availability?**

7 A. The cause of each of the historical events impacting availability are evaluated and
8 measured, and the actions necessary to avoid the same or similar events are considered for
9 implementation. In many cases, actions necessary to prevent the event from recurring are
10 cost beneficial. The availability projections, including ROR, simply reflect the Company's
11 best estimate of the operational benefits of those corrective actions that have already been
12 taken or are planned to be taken, through the projected test year ending February 28, 2026.

13 **Q. Does the Company evaluate customer benefits associated with Outage Schedules?**

14 A. Yes, the Company uses historical market prices to evaluate timing around outages in an
15 effort to ensure the unit is available during periods in which market pricing is projected to
16 be high.

17 **Q. Is it possible that the Company could experience changes to its scheduled outages and**
18 **forecasted capital expenditures in the future?**

19 A. Yes. The Company often forecasts future actions and capital expenditures based on
20 currently available information, many months before the work is completed. To provide
21 some perspective, the outage schedule used in this case was approved in August 2023.
22 A review of the outage schedule used in this case identifies eight scheduled outages that
23 begin in March 2025 (18 months after the schedule was approved) and run through

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 February 28, 2026, 29 months later. During each of these eight scheduled outages,
2 Consumers Energy has scheduled a number of tasks to be performed. Because of the long
3 lead times, the number of outages scheduled during the test year, and the fact that several
4 different tasks will be performed during each outage, it is inevitable that some scheduled
5 outages and forecast capital expenditures will change. However, the Company has a
6 history of prudent capital investments in its generating facilities, which have been
7 consistently supported by the Commission.

8 **Q. Are there other reasons why outage schedule changes occur?**

9 A. Yes. Some of the reasons why outage schedule changes occur are: contractor availability,
10 parts availability, changes in regulations, design changes, outage scope changes, changes
11 in unit condition, and spot market prices.

12 **Q. Can you provide an example of when circumstances changed?**

13 A. Yes. The Company's fall 2023 outage for Campbell Unit 1 was originally scheduled from
14 October 13, 2023 through November 12, 2023. The unit was placed into economic reserve
15 status on February 19, 2023 and subsequently began a maintenance outage on March 7,
16 2023. The maintenance outage lasted for 14 days, ending on March 21, 2023. During this
17 timeframe, all priority work scope that was scheduled for the fall outage was completed,
18 obviating the need for the planned outage scheduled to begin on October 13, 2023.

19 **Q. Please describe how the Company determines its generation projected capital**
20 **expenditure amounts.**

21 A. Consistent with the Company's generation asset strategy, generation projected capital
22 investments support the continued safe, regulatory compliant, and reliable operations of
23 the Company's electric generating fleet. Projected capital investments are informed by

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 historical and anticipated performance of the units. The reasonableness of the generation
2 capital investments is indicated by the sustained or improved performance of the
3 Company's electric generating fleet relative to: (1) the safety of the employees, contractors,
4 and community at and around the generating facilities; (2) compliance with rules and
5 regulations; and (3) reliably participating in the energy, resource adequacy, and ancillary
6 services markets.

7 **Q. How are projects identified that are discussed later in this direct testimony?**

8 A. Generation System Planners assess the equipment performance and compare that
9 assessment with the generation asset strategy for the generating unit. Upon identification
10 of a potential project, the Planner will complete a project initiation document ("PID"). This
11 document defines the issue, alternatives considered for resolution, intended benefits or
12 consequences avoided, and suggested timing and a cost estimate. The document is
13 reviewed by multiple groups for alignment and ultimately routed for approval for inclusion
14 in the Long-Term Financial Plan ("LTFP"). PIDs entered into the LTFP will typically be
15 scheduled three to five years in the future to align with outages and provide the project
16 execution teams ample time to plan and engineer.

17 **Q. How were the projected capital expenditure amounts developed for each of the**
18 **projects discussed later in this direct testimony?**

19 A. Each project begins with the creation of a PID. The Planner will provide an initial cost
20 estimate for the project within the PID. The Planner utilizes past experience, contractor
21 cost estimates, internal estimates, Original Equipment Manufacturer ("OEM") data, and
22 studies to provide the best estimate of the costs. This activity typically takes place three to
23 five years prior to the start of project execution.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. How are PIDs related to Concept Approval Documents (“CADs”)?**

2 A. The PID is the mechanism utilized to allow projects to be considered for the LTFP. Once
3 the project is included in the LTFP and the project is within a year of start of execution,
4 the CAD is created. The CAD is templated from the PID and updated as necessary. The
5 CAD is then routed for approval to the designated level of management based on project
6 amount and, once approved, the project will be initiated.

7 **Q. Do adjustments to the projected capital investment amounts for each of the projects**
8 **occur prior to project implementation?**

9 A. Yes. As the project team progresses through the life cycle of a project, there are multiple
10 opportunities to better define project costs. Activities such as detailed engineering,
11 bidding, contractor involvement, and construction all allow for budgets to be better defined.
12 As this definition evolves, the projected capital investments are updated accordingly.

13 **2023 HISTORICAL TEST YEAR CAPITAL EXPENDITURES**

14 **Q. How does the 2023 actual capital expenditure amount of \$859.095 million compare to**
15 **the amount of capital expenditures reflected in the Company’s request in Case No.**
16 **U-21389?**

17 A. The 2023 actual capital expenditure amount of \$859.095 million is \$430.277 million below
18 the Company’s requested amount in Case No. U-21389. The reduction in the Company’s
19 actual capital expenditure amount is directly attributable to the removal of the capital
20 expenditures for IRP solar projects and the actual accounting treatment of the Covert
21 purchase. While the Covert total purchase cost was consistent with projections, the total
22 amount was not recorded as an addition to plant in service. The actual amount recorded as
23 capital was \$151.858 million less than the projected purchase amount as can be seen on

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 Exhibit A-12 (RTB-3), Schedule B-5.2, page 7, line 3, columns (g) and (h). The projected
2 amounts for the 2019 and 2020 IRP Solar Bid Events totaled \$355.250 million in the
3 Company's 2023 Electric Rate Case No. U-21389 (see Exhibit A-12 (RTB-3), Schedule
4 B-5.1, page 9, lines 38 and 39, column (n)), however these amounts were removed from
5 the case due to their project status. The projected solar project capital expenditures were
6 not projected to close by the end of the projected test year and were offset by the allowance
7 for funds used during construction ("AFUDC"). As such, the underspend did not impact
8 the revenue requirement. A compilation of the 2023 projects which have actual capital
9 expenditure amounts greater than \$1 million is presented on Exhibit A-12 (RTB-3),
10 Schedule B-5.2, page 7.

11 **Q. How does the compilation of capital projects on Exhibit A-12 (RTB-3), Schedule**
12 **B-5.2, page 7, compare with the 2023 capital projects reflected on Case No. U-21389,**
13 **Exhibit A-12 (RTB-3), Schedule B-5.1, page 9?**

14 A. A comparison of the projects on Exhibit A-12 (RTB-3), Schedule B-5.2, page 7, with the
15 2023 projects reflected on Case No. U-21389, Exhibit A-12 (RTB-3), Schedule B-5.1,
16 page 9, reveals that there are seven projects on Exhibit A-12 (RTB-3), Schedule B-5.2,
17 page 7, which were not reflected on Case No. U-21389, Exhibit A-12 (RTB-3), Schedule
18 B-5.1, page 9. In addition, there were twenty projects for 2023 that were reflected on Case
19 No. U-21389, Exhibit A-12 (RTB-3), Schedule B-5.1, page 9, that are not presented on
20 Exhibit A-12 (RTB-3), Schedule B-5.2, page 7.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

Q. Please discuss the 2023 capital projects that were included on Case No. U-21389, Exhibit A-12 (RTB-3), Schedule B-5.1, page 9, that are not presented on Exhibit A-12 (RTB-3), Schedule B-5.2, page 7.

A. The following projects are not presented on Exhibit A-12 (RTB-3), Schedule B-5.2, page 7, due to the fact that their actual 2023 capital expenditure amount was less than \$1 million, the project was disallowed, reduced in cost, or not pursued in 2023. The disposition of these capital projects is provided below:

Below is a list of projects whose projected bridge period costs were disallowed in the final order in Case No. U-21389:

Project Description	Projected Amount
Covert Non LTSA Capital - Extras not included in contract	\$ 3,942,510
Karn Tank Farm Storage Tank Heating Line Replacement	\$ 1,253,971
Karn Sync Wire Replacement	\$ 1,450,000
Alcona Core Wall Remediation Project	\$ 1,810,370
Rogers Probable Maximum Flood Project	\$ 1,898,708
2019 Solar Bid Event – Mustang Mile	\$ 233,064,275
2020 Solar Bid Event – Washtenaw	\$ 122,186,164

Below is a list of projects whose projected bridge period costs were reduced or deferred by the Company and their projected amounts approved in the final order in Case No. U-21389 were less than \$1 million:

Project Description	Projected Amount	Project Reduction
Webber Unit 1 Generator Rewind	\$ 1,020,000	\$ 1,020,000
Zeeland Milestone Outage Capital to GE - Part of LTSA Contract	\$ 7,870,000	\$ 7,870,000
Zeeland Unit 4 Field Rewind of Generator Rotor	\$ 1,205,357	\$ 1,205,357
Zeeland Unit 3 Field Rewind of Generator Rotor	\$ 1,205,357	\$ 1,205,357
Cooke Spillway Hoist Replacement	\$ 2,100,000	\$ 1,492,000
Zeeland Phase 2 599 699 345kV Breaker Replacement	\$ 1,222,915	\$ 773,000
Ludington Oil Water Separator Replacement	\$ 1,162,917	\$ 679,000
Ludington Unit 1-6 DCS Control Relay Replacement	\$ 1,347,516	\$ 727,000

Below is a discussion of the remaining million-dollar projects whose actual 2023 capital expenditures were less than projected:

- Zeeland Heat Recovery Steam Generator (“HRSG”) Casing Replacement (\$2,803,333). This project is scheduled to be completed in 2024. The Company

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

spent a total of \$699,676 in 2023 and \$2,097,620 is scheduled for the projected bridge period ending February 28, 2025;

- Zeeland Generator Step Up Transformer Replacement (Spare) (\$2,883,33). During 2023, the Company spent a total of \$758,314 on this project, \$589,607 is planned for the bridge period ending February 28, 2025, and \$6.449 million is planned for the test year ending February 28, 2026;
- Five Channels Dead Bay and Log Chute Remediation (\$1,981,666). This project was completed in 2023; however, the project was entirely a removal project. As such, a total of \$2,134,312 was recorded to cost of removal and a negative \$331,235 was recorded to capital;
- Ludington Replace Barrier Net Panels (\$1,088,614). The Company spent a net total of \$705,769 in 2023 as a result of an offset of \$747,499 from the Ludington co-owner; and
- Karn Units 3 and 4 Separation (\$1,789,545). The separation work was performed in 2023; however, a large portion of the expense was recorded to cost of removal. The Company pursued a separate project (Karn Units 3 and 4 boiler plant heating) as an alternative to upgrading the auxiliary boilers as part of the utility separation. I will discuss that project later in this direct testimony.

Q. Please discuss the 2023 capital projects that were not included in Case No. U-21389, Exhibit A-12 (RTB-3), Schedule B-5.1, page 9, that are presented on Exhibit A-12 (RTB-3), Schedule B-5.2, page 7.

A. The disposition of these capital projects is presented below:

- Covert Information Technology (“IT”) Room (\$2,059,520). The scope of this project was to provide the plant connectivity to the Consumers Energy’s SCADA and corporate networks while keeping the plant fully operational during the transition from the legacy network to Consumers Energy networks. The North American Electric Reliability Corporation (“NERC”) Critical Infrastructure Protection (“CIP”) regulation requires that the SCADA and corporate networks be separate from each other and, due to the legacy network needing to remain operational during the transition, IT required a new IT Room to be built to house the corporate network infrastructure;
- Covert Security and Network (\$2,208,169). The scope of this project was to ensure the plant is meeting the physical security requirements for CIP Low assets. Due to the plant having minimal CIP Low physical security assets in place, Consumers Energy’s corporate security team was required to install new cameras and card readers throughout the site where all CIP Low assets reside;

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

- 1 • Covert Spare Generator Stepup (“GSU”) Transformer (\$1,722,987). The scope
2 of this project is the procurement of a spare transformer for the Covert
3 Generating Station. The 2023 capital expenditure reflects a milestone payment
4 to the best identified bidder and internal loadings. This project will be discussed
5 in more detail later in this direct testimony;
- 6 • Karn Units 3 and 4 Boiler Plant Heating (\$4,836,052). The Karn Units 3 and
7 4 Plant Heating Boilers Project was a strategic initiative aimed at upgrading the
8 plant heating system at Karn Power Station. The project involved the
9 procurement and installation of two smaller, more efficient boilers for
10 continuous plant heating. Prior to implementing this project, the existing
11 auxiliary boilers were utilized, and the auxiliary boilers were both inefficient
12 and unreliable for continuous plant heating. Originally, the auxiliary boilers
13 were to be used for plant heating and were to be addressed as part of the Karn
14 Units 3 and 4 separation as previously discussed in this direct testimony;
- 15 • Karn Unit 3 Exciter Rewind (\$1,038,719). The scope of this project was to
16 remove the Karn Unit 3 Exciter Rotor and send it out to be rewound. This work
17 was required as a result of the main lead in the exciter rotor failing open. Once
18 the exciter was disassembled at the vendor facility, the broken lead and the
19 resulting inability to excite was identified. To repair the broken main lead, a
20 full rewind was needed because the main lead was buried under the windings;
- 21 • Jackson Multimedia Filtration Pilot Skid (\$2,441,755). The scope of this
22 project was to perform testing and calibration as well as provide system
23 improvements to the treatment systems for the well water. The specific scope
24 of the project includes the installation of larger bleach pumps in order to pump
25 a higher flowrate of bleach to counteract the bleach degradation, replacement
26 of caustic pumps on caustic injection system due to issues with pump
27 performance, replacement of variable frequency drive and breaker damaged by
28 caustic injection system, replacement of control valve on well water forwarding
29 pump to increase the flowrate up to the required 1,150 gpm, adjustment of the
30 logic in the reverse osmosis pretreatment system to remove ability for all
31 (4) beds to backwash at the same time, run various scenarios to optimize the
32 throughput of the greensand filters, the caustic in the pretreatment, and the
33 bleach in the pretreatment, and other system improvement activities;
- 34 • Zeeland Unit 5 GSU Transformer Rewind (\$13,884,854). The scope of this
35 project was to remove the failed Zeeland Unit 5 GSU transformer, movement
36 and installation of the spare GSU transformer, and sending out the failed
37 Zeeland Unit 5 GSU transformer for overhaul which included milestone
38 payments for the overhaul. In addition, the scope reflected the monthly lease
39 of a spare transformer to provided continued operation of the unit for customers.
40 Zeeland Unit 5 was taken out of service on December 17, 2022 and was returned
41 to service on January 23, 2023 upon installation of the leased transformer which
42 was moved from Zeeland Unit 1; and

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

- Croton 1 and 2 Wicket Gate (\$4,329,769). This projected was originally expected to be completed in 2022 however during project implementation a significant amount of additional work was identified during project execution.

PROJECTED 14-MONTH BRIDGE PERIOD CAPITAL EXPENDITURES

Q. How does the projected 14-month bridge period capital expenditure of \$464 million compare to the amount of capital approved by the MPSC in Case No. U-21389 for 2024?

A. The 14-month bridge period projected capital expenditure amount of \$463.548 million is \$5 million less than the projected test year amount of \$468.684 million requested in the Company's last electric rate case (Case No. U-21389). The difference between the 14-month bridge amount requested in Case No. U-21389 and the amount requested in this proceeding includes changes in the projects for which recovery is being requested. For example, the inclusion of projected capital expenditures for BESSs is offset by the reduction in projected costs for IRP solar projects. Each of these project areas are discussed in more detail in witness Clark's direct testimony. A compilation of the 14-month bridge period projects which have projected capital expenditure amounts greater than \$1 million is presented on Exhibit A-12 (RTB-3), Schedule B-5.2, page 8.

Q. How does the compilation of 14-month bridge period capital projects on Exhibit A-12 (RTB-3), Schedule B-5.2, page 8, compare with the test year capital projects reflected on Case No. U-21389, Exhibit A-12 (RTB-3), Schedule B-5.1, page 10?

A. A comparison of the 14-month bridge period capital projects on Exhibit A-12 (RTB-3), Schedule B-5.2, page 8, with the test year projects reflected on Case No. U-21389, Exhibit A-12 (RTB-3), Schedule B-5.1, page 10, reveals that there are 26 projects on Exhibit A-12 (RTB-3), Schedule B-5.2, page 8, which were not reflected on Case No. U-21389, Exhibit

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

A-12 (RTB-3), Schedule B-5.1, page 8. In addition, there were 17 projects for the 12-month period ending February 28, 2025 that were reflected on Case No. U-21389, Exhibit A-12 (RTB-3), Schedule B-5.1, page 10, that are not presented on Exhibit A-12 (RTB-3), Schedule B-5.2, page 8.

Q. Please discuss the test year capital projects that were included on Case No. U-21389, Exhibit A-12 (RTB-3), Schedule B-5.1, page 10, that are not presented on Exhibit A-12 (RTB-3), Schedule B-5.2, page 8.

A. The following projects are not presented on Exhibit A-12 (RTB-3), Schedule B-5.2, page 8, due to the fact that the projected bridge period capital expenditure amounts are now less than \$1 million or the project is not being pursued in the bridge period. The disposition of these capital projects is presented in the table below:

Site	Project	Disposition
Alcona	Risk Informed Decision Making Resolution	Disallowed in U-21389 Final Order
Cooke	Head Gate Replacement Project	Reflected in Test Year Investment
Covert	Non Long Term Service Agreement Capital - Extras	Disallowed in U-21389 Final Order
Five Channels	Trash Rack Ergonomics Project	Reflected in Test Year Investment
Foote	Unit 2 Wicket Gates Replacement Project	Project Deferred by Company in U-21389
Foote	ADA Ramp Investigation and replacement	Project Deferred by Company in U-21389
Hardy	Electrical Safety Project	Project Deferred by Company in U-21389
Hardy	Hardy Splash Wall Replacement	Disallowed in U-21389 and moved to test year
Hodenpyl	Downstream Wall	Reflected in Test Year Investment
Jackson	LM 1 - 6 SAC Extended Life Combustor	Project Deferred by Company in U-21389
Ludington	Administrative Building Addition	Project Deferred by Company in U-21389
Ludington	Replace Barrier Net Panels	Staff reduced project spend to \$0.476 million
Ludington	Intake Gate and Gate House Mechanical Replacement	Staff reduced project spend to \$0.700 million
Solar	Solar - 2019 Bid Event (Mustang Mile 150 MW)	Disallowed in U-21389 Final Order
Solar	Solar - 2020 Bid Event (Washtenaw Solar) (150 MW)	Disallowed in U-21389 Final Order
Webber	Unit 1 Generator Rewind	Project Deferred by Company in U-21389
Zeeland	Purchase of Site Spare GSU	Reflected in Test Year Investment

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

Q. Please identify the 14-month bridge period capital projects that were not included on Case No. U-21389, Exhibit A-12 (RTB-3), Schedule B-5.1, page 10, that are presented on Exhibit A-12 (RTB-3), Schedule B-5.2, page 9.

A. The bridge period capital projects that were not included on Case No. U-21389, Exhibit A-12 (RTB-3), Schedule B-5.1, page 10, are presented in the table below:

Line No.	Project Description
1	Covert Purchase of site spare GSU
2	Covert Cooling Tower Gearboxes
3	Covert SCR/CO Catalyst Replacement - Unit 2
4	Covert SCR/CO Catalyst Replacement - Unit 3
5	Covert 1-3 Emerson DCS Evergreen
6	Jackson GE LTSA Historical Extra Work Expected
7	Zeeland 2C GSU Rewind
8	Zeeland Phase I Gas Turbine Advanced gas path replacement and axial fuel staging
9	Zeeland LTSA - Extras not included in contract (cranes, mobile equipment)
10	Zeeland Long Term Service Agreement - Running Capital Contract
11	Zeeland HRSG Casing Replacement
12	Karn 3 DCS Evergreen
13	Karn 3&4 Sync Wire Replacement
14	Karn 4 Replacement of Ductwork Insulation and Lagging
15	Karn 4 DCS Evergreen
16	LPS - LPEJ Chamber water stop replacement
17	Alcona Artesian Design Study
18	Foote Spillway Hoist Replacement
19	Hardy Auxiliary Spillway Replacement
20	Hodenpyl - Emergency Spillway Project
21	Hodenpyl Spillway Hoist Replacement
22	Tippy - Unit 1 Thrust Bearing Replacement
23	Solar - 2022 Bid Event (Spring Creek)
24	Armstrong BESS (IIJA Grant App)
25	Iosco BESS (IRP)
26	Weadock BESS (IRP)

The basis for projects 1 through 16 will be discussed in more detail later in this direct testimony, the basis for projects 17 through 22 will be discussed in the direct testimony of Company witness Monroe, and the basis for projects 23 through 26 will be discussed in the direct testimony of Company witness Clark.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. Is the projected capital expenditure amount of \$463.548 million for the 14-month**
2 **bridge period ending February 28, 2025, on Exhibit A-12 (RTB-3), Schedule B-5.2,**
3 **page 1, column (e), consistent with the Company's generation asset strategy?**

4 A. Yes. Based upon a review of the projected capital expenditure presentation on Exhibit
5 A-12 (RTB-3), Schedule B-5.2, pages 2 and 3, lines 1 through 99, column (h),
6 \$249.572 million of that capital will fund solar projects pursuant to the Company's IRP,
7 \$39.672 million will fund BESS projects, \$118.854 million of that total capital expenditure
8 amount will be used at the Company's natural gas generating facilities which includes
9 Covert, Jackson, Zeeland, and Karn Units 3 and 4. In addition, \$10.279 million will fund
10 various projects at the LPS facility, and \$42.376 million will fund various hydro safety,
11 reliability, and regulatory compliance projects. With the exception of the solar, BESS, and
12 the River Hydro projects, a detailed discussion of the various projects for each generating
13 unit or group of generating units will be provided later in this direct testimony. The River
14 Hydro projects will be discussed in the direct testimony of Company witness Monroe and
15 the solar projects will be discussed in the direct testimony of Company witness Clark.

16 **PROJECTED TEST YEAR CAPITAL EXPENDITURES**

17 **Q. Is the projected capital expenditure amount of \$600.484 million for the test year**
18 **ending February 28, 2026, on Exhibit A-12 (RTB-3), Schedule B-5.2, page 1,**
19 **column (f), consistent with the Company's generation asset strategy?**

20 A. Yes. Based upon a review of the projected capital expenditure presentation on Exhibit
21 A-12 (RTB-3), Schedule B-5.2, pages 2 and 3, lines 1 through 99, column (j),
22 \$275.959 million of that capital will fund solar projects pursuant to the Company's IRP,
23 \$78.921 million will fund BESS projects, \$134.664 million of that total capital expenditure

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 amount will be used at the Company's natural gas generating facilities which includes
2 Covert, Jackson, Zeeland, and Karn Units 3 and 4. In addition, \$15.587 million will allow
3 the Company to complete various regulatory, reliability, and infrastructure projects
4 necessary to support the 50-year license extension at Ludington granted by FERC in 2019
5 and \$92.258 million will fund various hydro safety, reliability, and regulatory compliance
6 projects. Except for the solar projects and the River Hydro projects, a detailed discussion
7 of the various projects for each generating unit or group of generating units will be provided
8 later in this direct testimony. The River Hydro projects will be discussed in the direct
9 testimony of Company witness Monroe and the solar projects will be discussed in the direct
10 testimony of Company witness Clark.

11 **Campbell Units 1, 2, and 3**

12 **Q. Please explain the Company's projected capital investment for the 14-month**
13 **projected bridge period ending February 28, 2025 and projected test year ending**
14 **February 28, 2026 for Campbell Units 1, 2, and 3.**

15 **A.** The Company does not plan to invest any capital in the Campbell units during the bridge
16 period or test year, as reflected on Exhibit A-12 (RTB-3), Schedule B-5.2, page 2, lines 1
17 and 8. As presented on Exhibit A-43 (RTB-4), lines 1 and 2, and as discussed later in this
18 direct testimony, the Company has projected modest amounts of major maintenance to
19 ensure that these units are able to operate through their retirement date of May 31, 2025.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

Covert Plant

Q. Please explain the Company's projected capital investment for the 14-month projected bridge period ending February 28, 2025 and projected test year ending February 28, 2026 for Covert.

A. The Company plans to invest a total of \$34.087 million in the 14-month bridge period and \$61.483 million in the test year at the Covert Plant. These capital investments will be facilitated by nine-day outages at Covert Units 1 through 3 in the spring and fall of 2025 as well as longer unit outages for major inspections. Covert Unit 1 has a 58-day outage scheduled to begin on February 1, 2026, Covert Unit 3 has a 59-day outage scheduled to begin on November 1, 2025, and Covert Unit 2 has a 58-day outage scheduled to begin on February 1, 2025.

Q. Please explain the Company's projected capital investment for the 14-month bridge period ending February 28, 2025 for the Covert Plant.

A. The Company plans to invest a total of \$34.087 million in the bridge period on the Covert Plant, as shown on Exhibit A-12 (RTB-3), Schedule B-5.2, page 2, line 43, column (h).

Q. What is the basis for the projected \$34.087 million capital investment in the 14-month projected bridge period?

A. The projected \$34.087 million capital investment in the projected bridge period will fund numerous projects at the Covert Plant. Six of these projects are greater than \$1 million, and are presented on Exhibit A-12 (RTB-3), Schedule B-5.2, page 8, lines 1 through 6.

The basis for these six projects is described below:

- Purchase of site spare GSU (1,000,000). This project spans the 14-month bridge period and the test year, and its basis is included in my discussion of the test year capital projects for Covert;

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

- Cooling Tower Gearboxes (\$1,161,732). This project spans the 14-month bridge period and the test year, and its basis is included in my discussion of the test year capital projects for Covert;
- Selective Catalytic Reduction (“SCR”)/Carbon Monoxide (“CO”) Catalyst Replacement - Unit 2 (\$1,041,667). This project spans the 14-month bridge period and the test year, and its basis is included in my discussion of the test year capital projects for Covert;
- SCR/CO Catalyst Replacement - Unit 3 (\$1,041,667). This project spans the 14-month bridge period and the test year, and its basis is included in my discussion of the test year capital projects for Covert;
- Covert Units 1 through 3 Emerson Distributed Control System (“DCS”) Evergreen (\$1,041,250). This project spans the 14-month bridge period and the test year, and its basis is included in my discussion of the test year capital projects for Covert; and
- Covert Plant Long-Term Service Agreement (“LTSA”) (\$20,400,000). This project spans the 14-month bridge period and the test year, and its basis is included in my discussion of the test year capital projects for Covert.

The following projects are less than \$1 million, but are important to reliability:

- Covert Plant (Units 1, 2, and 3) LTSA extra work (\$1,748,333 total). The LTSA extra work is defined as the work that is not covered under normal planned maintenance in the LTSA. Based on historical outage experience there are typical discovery items found on this style of gas turbines that are not part of the LTSA planned maintenance scope. Some of the typical items not covered under the LTSA that need to be addressed are labor and material to replace the following: blading, ammonia delivery system, SCR catalyst, turbine rotors, cooling towers, and turbine cooling air cooler;
- Excitation Replacement (\$340,000). This project spans the 14-month bridge period and the test year, and its basis is included in my discussion of the test year capital projects for Covert;
- Office Space Consumers Energy Warehouse with Loading Dock (\$493,333). This project spans the 14-month bridge period and the test year, and its basis is included in my discussion of the test year capital projects for Covert;
- Plant Replace Sulfuric Sodium Hypo and Building (\$410,000). The Sodium Hypochlorite system is original, in poor condition, and has experienced multiple failures, creating a safety hazard for the operators. Additionally, this equipment is housed in the same building as the sulfuric acid dosing system with only a fiberglass dividing wall. If both systems were to experience a leak at the same time, that situation could generate poisonous chlorine gas;

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

- Gas Turbine Generator (“GTG”)/ Steam Turbine Generator (“STG”) Replace Covert Units 1 through 3 Rollup Doors (\$535,000). The Covert Plant faces a significant operational challenge due to the absence of overhead roll-up doors on the south side of the power block building. This infrastructure limitation necessitates the removal of building panels to facilitate the ingress and egress of large equipment, such as STGs and GTGs, during major outages. This project will install insulated rollup doors with electrical power. By installing insulated roll-up doors, the Covert Plant can eliminate the time-consuming and costly process of panel removal and reinstallation. This upgrade streamlines access for large equipment, reducing downtime and associated labor costs. In addition, the insulated design and weather stripping of the Model 625 doors provide significant protection against cold air infiltration, safeguarding critical equipment during outage periods in cold weather;
- Netmation (Operating System & 4S) - Unit 2 (\$391,667). This project spans the 14-month bridge period and the test year, and its basis is included in my discussion of the test year capital projects for Covert;
- Netmation (Operating System & 4S) - Unit 3 (\$300,833). This project spans the 14-month bridge period and the test year, and its basis is included in my discussion of the test year capital projects for Covert;
- Gas Compressor Controls Replacement (Programmable Logic Controller (“PLC”) replacement) (\$424,4000). Gas Compressors (two in total) operate using a local control network consisting of a human machine interface (“HMI”) (Panel View 1000) and Allen Bradley PLC five controllers. This equipment has reached end of life and replacements are no longer available. The Covert site currently has one failed board in service. This project would utilize existing panels and replace the equipment with an Allen Bradley ControlLogix solution and PanelView Plus 7;
- Covert Units 1, 2, and 3 – MV90 Revenue Meters for MISO (\$570,000). The scope of this project is the replacement of the existing meters utilized to record power flows for purposes of reporting to MISO for market settlement;
- Linear Variable Differential Transformers (“LVDT”) Positioning Sensor – Unit 1 Fuel Control Valves (\$737.930). The scope of this project is to replace the Yokogawa 5516 mechanical type position sensors with LVDTs. The replacement is to include the following devices, Main “A” pressure control fuel valve sensor, Main “B” pressure control fuel valve sensor, Main flow control fuel valve sensor, Pilot pressure control fuel valve sensor, and the pilot flow control fuel valve sensor and compressor bypass actuator. The benefits of this project include reduced maintenance, improved accuracy, and higher long-term reliability due to the removal of the mechanical linkages and converting to a non-contact mechanism;

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

The Covert Mitsubishi Power Gas turbines are equipped with Yokogawa 5516 mechanical linkage type position sensors. The Yokogawa position sensors are used to detect the position of the fuel control valves, bypass valve actuators, and the Inlet Guide Vanes. These valves and their position are critical as they control turbine output which allows more load on the generator and meets load demand. The Yokogawa 5516 position sensors are obsolete, and Yokogawa has announced that the 5516 position sensors are no longer manufactured as of March 31, 2015, no longer supported, and parts are no longer available. Mitsubishi Power recommends eliminating the Yokogawa mechanical linkage position sensors;

- Covert Base Outage Capital (\$443,333). Base outage capital covers the replacement parts and issues found during turbine/generator inspections and the major discovery issues found during annual unit outages; and
- Twenty additional projects at Covert totaling \$1.650 million which support safety, security, and reliability, with each project representing \$201,667 or less in capital expenditures. These projects include load commutated inverter Replacements, Unit 2 Power Distribution Center ("PDC") Battery Replacement, Electronic Overspeed protection, site small capital, LVDT Positioning Sensor – Unit 2, and SCR/CO Replacement - Unit 1.

Q. What is the basis for the projected \$61.483 million capital investment in the projected test period?

A. The projected \$61.483 million capital investment in the projected test period will fund numerous projects at the Covert Plant. Ten of these projects are greater than \$1 million, and are presented on Exhibit A-12 (RTB-3), Schedule B-5.2, page 9, lines 1 through 10. The basis for these projects is described below:

- Purchase of site spare GSU transformer (\$4,500,000). Covert Generating Station consists of three gas turbine powered plants and three steam turbine powered plants placed in a one-on-one combined cycle configuration. The units transmit their power to the grid via GSU transformers. Each gas turbine powered unit feeds the secondary winding of a three-winding transformer, while the associated steam powered unit feeds the tertiary winding of the transformer. The GSU is rated for 500 MVA with forced oil and forced air. If a GSU were to fail, then the associated turbines would not be able to transmit power and would not be able to generate market value for Consumers Energy and its customers. The lead time for a GSU is currently three-to-four years and spare units at other facilities typically do not exist, especially for this more unique design application;

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

This project provides a spare GSU for Covert which: 1) Greatly reduces unit downtime in the event of GSU issues or failure requiring removal and lowers the total financial losses in such events; 2) Allows for easier engineering design and planning to install a spare or replacement GSU ahead of any emergent installation needs; 3) Mitigates potential issues from installing GSUs not specifically designed for this location, system or application and/or doing it multiple times in a short time period; 4) Would allow for Consumers Energy to enter lease agreements with other utilities who may be in need of a spare to recover some costs of the spare purchase over time; and 5) The oil analysis of Covert transformers revealed the presence of chemicals for corrosive sulfur. Mitigating actions are being taken, however, this failure mode puts these transformers at increased risk of failure;

- Office Space Consumers Energy Warehouse with Loading Dock (\$1,816,667). The scope of this project is to build out the existing warehouse and add a loading dock. The existing warehouse does not meet the needs for the upcoming major outages, or plant maintenance in the future. The addition of a loading dock will provide for safer and efficient loading/unloading of trucks. In addition, the current onsite office space is inadequate, and it will be expanded;

Cooling Tower Gearboxes (\$1,039,192). The Covert Generating Station Cooling Tower Fan Gearbox Replacement Project addresses critical operational issues stemming from the end-of-life status of gearboxes after over 20 years of service. These gearboxes are essential for cooling tower fan operations, affecting the station's overall efficiency and reliability. The scope of this project is to replace the existing cooling tower gearboxes with gearboxes from the same manufacturer, an alternative that avoids additional modifications. Covert operates three 6-cell cooling towers corresponding to each of its units. These cooling towers play a crucial role in the station's operational efficiency by facilitating the removal of residual heat from circulating water. This process is essential after the water has been utilized for condensing steam produced by the steam turbines. Operational challenges with the gearboxes include increased gearbox failures, inadequate heat removal due to malfunctioning cooling tower fans, and obsolete motor starters;

- Netmation (Operating System & 4S) - Unit 2 (\$1,458,333). The Covert gas generating station, operational since 2004, faces critical challenges with its outdated control systems. These challenges impact both operational efficiency and cybersecurity, necessitating an urgent upgrade to modern standards. The scope of this project is an extensive upgrade of the Covert Mitsubishi Turbine Control System to the latest version of Netmation, which includes the replacement of hardware, I/O modules, servers, workstations, network switches, and software to the latest architecture;
- Covert Units 1 through 3 Emerson DCS Evergreen (\$2,448,750). The scope of this project is to upgrade the DCS to the latest version in order to enhance security, gain compliance with enterprise standards, and achieve technological

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 advancement. Covert, which has been operational since 2004, faces significant
2 challenges with its Emerson Ovation DCS. The system's obsolescence,
3 cybersecurity risks, and operational inefficiencies necessitate an urgent upgrade
4 to the latest version to enhance reliability, security, and compliance with
5 regulatory standards. The DCS that controls all equipment in the plant (along
6 with the Mitsubishi gas turbine controls), is Emerson Ovation DCS. It was
7 upgraded about 10 years ago to the current version. Emerson Ovation version
8 3.5.1 is no longer supported by Emerson or Microsoft. The Emerson Ovation
9 version 3.5 system entered a retired status in June 2019. The Windows
10 operating systems that are used by this version of Ovation are Windows 7 and
11 Windows Server 2008R2. Microsoft ended extended support of Server 2008R2
12 in January 2020.

13 The generation plant control systems are an important part of the nation's
14 Critical Infrastructure and fall under NERC CIP requirements. To keep the
15 Company's control systems secure, Consumers Energy must patch the
16 operating systems and applications that run its plants. The Company is no
17 longer able to patch and maintain these operating systems, such as Microsoft
18 Windows, or applications, such as Ovation, when they are no longer supported
19 by the manufacturers. The systems at Covert do not meet corporate
20 cybersecurity standards and are operating with security exception to the
21 Company's standards.

22 The cybersecurity tools (Power Water Cybersecurity Suite ("PWCS"))
23 being utilized for the Covert control network device patching and antivirus
24 protection require replacement to allow continued patching and protection with
25 a new DCS version. The current version of PWCS is nearing end of support
26 and requires updating to allow support of the latest Ovation versions.

27 The Balance of Plant ("BOP") control is achieved with the Ovation DCS.
28 Its architecture is comprised of controller and operator "drops" (processors and
29 PCs) that provide the control of the equipment with input/output ("I/O")
30 modules. Some of these I/O modules are in the same electrical cabinets that
31 contain the "controller drops" (processors). Other I/O is in "remote" electrical
32 cabinets, away from the "controller drops." The existing plant control is
33 comprised of many remote I/O cabinets throughout the site. The
34 communication modules to these cabinets have experienced failures in the past
35 that can trip the generating units offline. Power supplies in the Ovation cabinets
36 have reached the end of their recommend life and need to be replaced. The
37 architecture and components need to be upgraded and replaced with the latest
38 Ovation design.

39 The main controller drop that operates a large part of the BOP equipment
40 has had equipment and data link controls added to it over the years. It controls
41 equipment for all three (3) generating units. The controller drop needs to have
42 part of its I/O and logic split off to new controller drops. The partitioning of I/O

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 to other drops should allow the upgrade and maintenance procedures to occur
2 and reduce the need of a site outage to perform these activities. Risk to unit
3 trips should be reduced to individual generating units instead of all units on the
4 site;

- 5 • Netmation (Operating System and 4S) – Unit 3 (\$1,504,167). The Covert gas
6 generating station, operational since 2004, faces critical challenges with its
7 outdated control systems. These challenges impact both operational efficiency
8 and cybersecurity, necessitating an upgrade to modern standards. The scope of
9 this project is an extensive upgrade of the Covert Mitsubishi Turbine Control
10 System to the latest version of Netmation, which includes the replacement of
11 hardware, I/O modules, servers, workstations, network switches, and software
12 to the latest architecture;

- 13 • Covert Plant LTSA (\$14,700,000). This is the capital portion for Mitsubishi
14 negotiated services that cover the planned normal maintenance of each
15 generating unit. The projected capital expenditures are based upon variable fees
16 paid to Mitsubishi for maintenance services which are based on an Effective
17 Fired Hour basis pursuant to the LTSA. Unlike the GE LTSAs for the Jackson
18 and Zeeland plants, there are no milestone payments associated with the fee
19 structure for the Mitsubishi LTSA. Based on the OEM's operating and
20 historical experience, if the Company executes the normal planned maintenance
21 and inspections according to the recommended schedules, the Company will
22 mitigate unexpected pre-mature failures of the equipment. This will help
23 maximize availability and, as a result, optimize customer value for the site.
24 Normal maintenance will ensure the Company continues reliable operation of
25 the units. During the bridge period and test year, the Company will be
26 conducting major inspections on all three generating units, and a portion of the
27 work to be performed is not covered in the LTSA, rather it is covered in the
28 LTSA extra work as described below;

- 29 • Covert Unit 1 LTSA extra work (\$1,437,717). The LTSA extra work is defined
30 as the work that is not covered under normal planned maintenance in the LTSA.
31 Based on historical outage experience there are typical discovery items found
32 on this style of gas turbines that are not part of the LTSA planned maintenance
33 scope. Some of the typical items not covered under the LTSA that need to be
34 addressed are labor and material to replace the following: blading, ammonia
35 delivery system, SCR catalyst, turbine rotors, cooling towers, and turbine
36 cooling air cooler. The major inspection for Covert Unit 1 begins on
37 February 1, 2026, just prior to the end of the test year, and ends on March 31,
38 2026. As such, a large portion of the LTSA extra work will not be requested in
39 this proceeding;

- 40 • Covert Unit 2 LTSA extra work (\$12,609,633). The LTSA extra work is
41 defined as the work that is not covered under normal planned maintenance in
42 the LTSA. Based on historical outage experience there are typical discovery
43 items found on this style of gas turbines that are not part of the LTSA planned

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 maintenance scope. Some of the typical items not covered under the LTSA that
2 need to be addressed are labor and material to replace the following: blading,
3 ammonia delivery system, SCR catalyst, turbine rotors, cooling towers, and
4 turbine cooling air cooler. The major inspection on Covert Unit 2 begins on
5 February 1, 2025, and major work includes generator inspection, replacement
6 of the generator hydrogen seals, generator rewedge, diaphragm repairs, steam
7 turbine and generator bearing repairs, and HP stop and control valve
8 disassembly, inspection, cleaning, and repair. The Company's LTSA with
9 Mitsubishi Electric Power Products, Inc. ("MEPPI") does not cover this scope
10 of work; and

- 11 • Covert Unit 3 LTSA extra work (\$10,609,633). The LTSA extra work is
12 defined as the work that is not covered under normal planned maintenance in
13 the LTSA. Based on historical outage experience there are typical discovery
14 items found on this style of gas turbines that are not part of the LTSA planned
15 maintenance scope. Some of the typical items not covered under the LTSA that
16 need to be addressed are labor and material to replace the following: blading,
17 ammonia delivery system, SCR catalyst, turbine rotors, cooling towers, and
18 turbine cooling air cooler. The major inspection on Covert Unit 3 begins on
19 November 1, 2025, and major work includes generator inspection, replacement
20 of the generator hydrogen seals, generator rewedge, diaphragm repairs, steam
21 turbine and generator bearing repairs, and HP stop and control valve
22 disassembly, inspection, cleaning, and repair. The Company's LTSA with
23 MEPPI does not cover this scope of work.

24 The following projects are less than \$1 million, but are important to reliability:

- 25 • Excitation Replacement (\$761,667). The scope of this project is the
26 replacement of the steam turbine exciters. The existing excitation equipment is
27 obsolete, and the gas turbine exciters have already been replaced. A failure of
28 the steam turbine exciter could lead to both generators on the unit being out of
29 service until replacements can be found with a typical lead time of
30 18-24 months;
- 31 • Electronic Overspeed protection (\$678,333). The scope of this project is the
32 installation of an electronic overspeed trip upgrade. The plant has experienced
33 issues with their overspeed trip device in the past. The backup electronic
34 overspeed trip is reliable but is not redundant so that a single component failure
35 would not disable the trip. The primary protection on the steam turbines are the
36 mechanical overspeed trip mechanisms. The mechanical overspeed trip
37 mechanism must be tested (offline) periodically to ensure that its setpoint has
38 not changed and that it can trip the unit;
- 39 • Flame Detectors for Gas Turbine Wheel temperature Digital replacement
40 (\$397,083). The scope of this project is to replace the existing mechanical
41 flame detection system with digital flame detection system. The existing

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 system is obsolete and has reliability issues that a new digital system would
2 resolve;

- 3 • SCR/CO Catalyst Replacement - Unit 2 (\$708,333). The scope of this project
4 is the replacement of the catalyst for the SCR. This replacement is based upon
5 the expected degradation of the exiting catalyst and effective operation of the
6 SCR is required to meet environmental regulations;

- 7 • SCR/CO Catalyst Replacement – Unit 3 (\$708,333). The scope of this project
8 is the replacement of the catalyst for the SCR. This replacement is based upon
9 the expected degradation of the exiting catalyst and effective operation of the
10 SCR is required to meet environmental regulations;

- 11 • Netmation (Operating System and 4S) – Unit 1 (\$375,000). The Covert gas
12 generating station, operational since 2004, faces critical challenges with its
13 outdated control systems. These challenges impact both operational efficiency
14 and cybersecurity, necessitating an urgent upgrade to modern standards. The
15 scope of this project is an extensive upgrade of the Covert Mitsubishi Turbine
16 Control System to the latest version of Netmation, which includes the
17 replacement of hardware, I/O modules, servers, workstations, network
18 switches, and software to the latest architecture;

- 19 • Balance Of Plant Valves – Unit 2 (\$590,000). The scope of this project is the
20 repair and/or replacement of balance of plant valves. The plant has a long list
21 of valves that require attention. The condenser bypass valves will be addressed
22 in the major outage scheduled for March 1, 2025 through March 31, 2025 and
23 they represent a large expense;

- 24 • Balance Of Plant Valves – Unit 3 -(\$590,000). The scope of this projects is the
25 repair and/or replacement of balance of plant valves. The plant has a long list
26 of valves that require extensive maintenance. The condenser bypass valves will
27 be addressed in the major outage scheduled for November 1, 2025 through
28 December 30, 2025 and they represent a large expense;

- 29 • Positioning Sensor – Unit 3 (\$687,500). The scope of this projects is to replace
30 the Yokogawa 5516 mechanical type position sensors with LVDTs. The
31 replacement to include the following devices, Main “A” pressure control fuel
32 valve sensor, Main “B” pressure control fuel valve sensor, Main flow control
33 fuel valve sensor, Pilot pressure control fuel valve sensor, and the pilot flow
34 control fuel valve sensor and compressor bypass actuator. The benefits of this
35 project include reduced maintenance, improved accuracy, and higher long-term
36 reliability due to the removal of the mechanical linkages and converting to a
37 non-contact mechanism. The Covert Mitsubishi Power Gas turbines are
38 equipped with Yokogawa 5516 mechanical linkage type position sensors. The
39 Yokogawa position sensors are used to detect the position of the fuel control
40 valves, bypass valve actuators, and the Inlet Guide Vanes. These Valves and
41 their position are critical as they control turbine output which allows more load

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

on the generator and meets load demand. The Yokogawa 5516 position sensors are obsolete, and Yokogawa has announced that the 5516 position sensors are no longer manufactured as of March 31, 2015, are no longer supported and parts are no longer available. Mitsubishi Power recommends eliminating the Yokogawa mechanical linkage position sensors;

- SCR/CO Catalyst Replacement – Unit 1 (891,667). The scope of this project is the replacement of the catalyst for the SCR. This replacement is based upon the expected degradation of the exiting catalyst and effective operation of the SCR is required to meet environmental regulations;
- Covert Base Outage Capital (\$383,333). Base outage capital covers the replacement parts and issues found during turbine/generator inspections and the major discovery issues found during annual unit outages;
- LVDT Positioning Sensor - Unit 2 (645,833). The scope of this projects is to replace the Yokogawa 5516 mechanical type position sensors with LVDTs. The replacement to include the following devices, Main "A" pressure control fuel valve sensor, Main "B" pressure control fuel valve sensor, Main flow control fuel valve sensor, Pilot pressure control fuel valve sensor, and the pilot flow control fuel valve sensor and compressor bypass actuator. The benefits of this project include reduced maintenance, improved accuracy, and higher long-term reliability due to the removal of the mechanical linkages and converting to a non-contact mechanism.

The Covert Mitsubishi Power Gas turbines are equipped with Yokogawa 5516 mechanical linkage type position sensors. The Yokogawa position sensors are used to detect the position of the fuel control valves, bypass valve actuators, and the Inlet Guide Vanes. These Valves and their position are critical as they control turbine output which allows more load on the generator and meets load demand. The Yokogawa 5516 position sensors are obsolete, and Yokogawa has announced that the 5516 position sensors are no longer manufactured as of March 31, 2015, no longer supported, and parts are no longer available. Mitsubishi Power recommends eliminating the Yokogawa mechanical linkage position sensors; and

- Eighteen additional projects at Covert totaling \$1.941 million which support safety, security, and reliability, with each project representing \$408,333 or less in capital expenditures. These projects include BOP Valves - Unit 1 MI, Unit 1 and Unit 3 PDC Battery Replacement (NERC), Load Commutated Inverter replacements, Gas Turbine - Units 1 through 3 Evaporator Media, and site small capital.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

Karn Units 1 and 2

Q. Please explain the Company's projected capital investment for the 14-month projected bridge period ending February 28, 2025 and the projected test year ending February 28, 2026 for Karn Units 1 and 2.

A. The Company does not plan to make any capital investments on Karn Units 1 and 2 in the 14-month projected bridge period ending February 28, 2025 or the projected test period ending February 28, 2026, as shown on Exhibit A-12 (RTB-3), Schedule B-5.2, page 2, line 15, columns (h) and (j), respectively, due to their retirement on May 31, 2023.

Karn Units 3 and 4

Q. Please explain the Company's projected capital investment for the 14-month projected bridge period ending February 28, 2025 and the projected test year ending February 28, 2026, for Karn Units 3 and 4.

A. The Company plans to invest \$17.119 million in the projected bridge period and \$7.287 million in the projected test period, as shown on Exhibit A-12 (RTB-3), Schedule B-5.2, page 2, line 22, columns (h) and (j), respectively.

Q. What is the basis for the projected \$17.119 million capital investment in the 14-month projected bridge period?

A. The projected \$17.119 million capital investment will fund numerous safety, regulatory compliance, reliability, and infrastructure projects at Karn Units 3 and 4. There are six projects which are greater than \$1 million, and these projects are presented on Exhibit A-12 (RTB-3), Schedule B-5.2, page 8, lines 14 through 19.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. Did the Order in the Company's 2023 Electric Rate Case (Case No. U-21389) establish**
2 **any specific requirements for any of the Karn site projects?**

3 A. Yes. Paragraph C on page 309 of the March 1, 2024 Order in Case No. U-21389 required
4 the following:

5 "Consumers Energy Company shall file in its next general
6 electric rate case an alternatives analysis addressing the
7 replacement of the Karn Unit 3 Cooling Tower internal
8 structure, including information on the most cost-efficient
9 solution and alternatives to full replacement as described in
10 this order."

11 **Q. What is the scope of the project?**

12 A. The scope of this project is the replacement of the structural timbers, remaining stacks, and
13 fan blades on Karn Unit 3's cooling tower. The wooden structure is original equipment
14 and has decayed since its installation. The cooling tower provides cooling water for the
15 condenser. The wooden cooling tower structure supports 18 large fans that pull air through
16 the water to drive the evaporation process to cool the water. The wooden structure also
17 supports large water pipes that carry the cooling water to the fill. The water flow to the
18 tower is approximately 240,000 gallons per minute. The entirety of this weight is
19 supported by the wooden structure as it is conveyed to the tower and cascades over the fill.
20 Implementation of this project will provide for reliable operation of Karn Unit 3 through
21 its retirement in 2031. The projected cost for this project in the 14-month bridge period is
22 \$6.0 million.

23 **Q. Has the Company performed an alternative analysis?**

24 A. Yes. The Company has created a concept approval to document its evaluation of the project
25 and the potential alternative. The concept approval is presented as Exhibit A-45 (RTB-6).

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

As established in Exhibit A-45 (RTB-6), the cooling tower internal structure was in poor condition and viable options were limited.

Q. Please discuss the basis for the remaining projects for Karn Units 3 and 4.

A. The basis for the remaining projects greater than \$1 million are described below:

- Karn Units 3 and 4 Sync Wire Replacement (\$1,260,000). The scope of this project is the replacement of the existing copper communication cables between the plant and Hampton Substation. The replacement will consist of fiber optic communication cable from Hampton Substation to the plant and the replacement of Karn Units 3 and 4 generating unit line protection relays, pilot wire differential line protection relaying, telemetry, and control communication at Hampton Substation. Telemetry and control include but are not limited to breaker position indication, breaker control, transfer trip, bus voltage, and current indication. The Karn Units 3 and 4 auto-synchronizing relay is obsolete. This project will provide a modern reliable communication medium between Karn Units 3 and 4 and Hampton Substation, where the generator synchronization breakers reside. This medium will allow for a reliable means of communication between Karn Units 3 and 4 and the Hampton Substation, thereby reducing the risk of possible failure of the units to synchronize correctly or to trip the units offline for a fault event; potentially causing damage to the generator and turbine, resulting in decreased plant reliability and increased expense;
- Karn Units 3 and 4 Plant Heating Boiler (\$1,760,000). The scope of this project is the continuation of the installation of boilers for heating Karn Units 3 and 4. The remaining work to be accomplished in the bridge period includes the following:
 1. Installation of Gas Regulators which required modifications to the already installed gas piping;
 2. Installation new Steam Check Valve;
 3. Conduct Preliminary Air Check prior to hydro to identify any leaks before the State Boiler Inspector was on site;
 4. Install Sump Drains at multiple locations;
 5. Replace Day Tank Steam System Valves;
 6. Install additional Steam Traps;
 7. Install stack extension and stack drains;
 8. Install additional heat trace and insulation; and
 9. Install enclosure around Deaerator.

The Plant Heating Boilers Project is a strategic initiative aimed at upgrading the plant heating system at Karn Power Station. The project involves the procurement and installation of two smaller, more efficient boilers for continuous plant heating. Prior to implementing this project, the existing

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

auxiliary boilers were utilized, and the auxiliary boilers were both inefficient and unreliable for continuous plant heating. Originally, the auxiliary boilers were to be used for plant heating and were to be addressed as part of the Karn Units 3 and 4 separation as previously discussed in this direct testimony;

- Karn Unit 3 Combustion Air Heaters (\$2,200,000). The combustion air heaters A and B had excessive tube leaks that were pressure tested and plugged during the fall 2022 outage. The B section has the worst damage with an estimated 50% of the tubes out of service. The scope of work for this project includes the replacement of two sections of the combustion air heater. The heater condition is causing a 68 MW derate on the unit;
- Karn Unit 4 DCS and Simulator Upgrade Evergreen (\$1,363,000). This project replaces the Karn Unit 4 Ovation DCS with the latest version available at the time of the project. The system is currently running on a VMware virtualized system. The system was installed in 2015 and software upgraded in 2019. This Evergreen will replace the existing Ovation Software, Operating Systems, and miscellaneous upgrades, the controller drops, and rack-mounted servers will be replaced for this upgrade. The DCS must be upgraded at a four-to-five-year upgrade cycle to maintain reliable control and provide recent operating systems and applications that are patchable. Vendor life cycle for DCS versions is generally a five-year cycle. After five years they enter a retired state and are no longer patched. Microsoft Operating Systems are on a limited life basis, and they reach the end of “extended support” and no longer get security patches. Corporate policies require all systems to be patched regularly along with Anti-Virus updates; and
- Karn Unit 3 DCS and Simulator Evergreen (\$1,507,000). This project replaces the Karn Unit 3 Ovation DCS with the latest version available at the time of the project. The system is currently running on a VMware virtualized system which was installed in 2019. This Evergreen will only replace the existing Ovation Software, Operating Systems, and miscellaneous upgrades. The controller drops and rack-mounted servers will not be replaced for this upgrade. The DCS must be upgraded at a four-to-five-year upgrade cycle to maintain reliable control and provide recent operating systems and applications that are patchable. Vendor life cycle for DCS versions is generally a five-year cycle. After five years they enter a retired state and are no longer patched. Microsoft Operating Systems are on a limited life basis, and they reach the end of “extended support” and no longer get security patches. Corporate policies require all systems to be patched regularly along with Anti-Virus updates.

The following projects are less than \$1 million, but are important to reliability:

- Karn Units 3 and 4 Ductwork Expansion Joint Replacement – Induction Draft (“ID”) Fans to Stack (\$710,667). This project spans the 14-month bridge period and the test year, and its basis is included in my discussion of the test year capital projects for Karn Units 3 and 4;

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

- 1 • BOP Capital tooling/valves/instrumentation (\$933,333). This project spans the
2 14-month bridge period and the test year, and its basis is included in my
3 discussion of the test year capital projects for Karn Units 3 and 4;
- 4 • Karn Units 3 and 4 - 250v Battery Bank Replacement (\$360,000). Replace the
5 250V battery with an equivalent and replace the charger with greater ampacity
6 to handle full load if batteries die. New battery bank will make Karn Units 3
7 and 4 more reliable and safer to operate. New battery bank and battery charger
8 will be in operation until the retirement of Karn Unit 3 and 4. New battery bank
9 will improve availability of backup DC bearing and seal oil pumps. Karn Units
10 3 and 4 utilizes a 250-volt battery bank to run emergency bearing oil pumps &
11 seal oil pumps in case of an emergency, like loss of AC power while the turbine
12 is hot. The 250-volt Battery bank was installed in 2014. Design life of these
13 batteries is approximately 10-12 years. The current batteries are rated for
14 910 amp hours. Based on the historical data, the 250-volt battery bank has been
15 depleted/discharged a number of times. This has caused battery cells to
16 operate/perform beyond their duty. A load test was conducted on this battery
17 bank in 2022 and the results were marginal. A battery bank can serve the
18 worst-case scenario load for approximately one hour only, which is less than
19 the Company's recommended time for the turbine generator to come to stand
20 still;
- 21 • Karn Unit 4 voltage regulator (\$400,000). The scope of this project is the
22 installation of a "Digital Front End" upgrade to the GE Automatic Voltage
23 Regulator on Karn Unit 4. The existing voltage regulator was installed around
24 2004 and was phased out of production in 2011. It became legacy equipment
25 on March 1, 2021 and is no longer available. The software used to configure
26 the existing system runs on Windows XP and is no longer patched or
27 supported. The hardware will be upgraded from EX2100 to EX2100e
28 architecture. This also includes ethernet switches, operator interface, GE
29 project management, operation manuals, drawings, technical direction of
30 installation and design package. Post maintenance testing and MOD-26 testing
31 are also being included; and
- 32 • Five additional projects at Karn Units 3 and 4 totaling \$0.625 million which
33 support safety, security, and reliability, with each project representing \$310,000
34 or less in capital expenditures. These projects include rewind of the Karn Unit 4
35 house service air compressor motor, replacement of the processors for the Karn
36 Unit 3 automatic voltage regulator, Karn Units 3 and 4 tank farm storage tank
37 heating line replacement, Karn Units 3 and 4 plant heating boilers, and
38 replacement of the Karn Units 3 and 4 stack ladder fall protection system.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. What is the basis for the projected \$7.287 million capital investment in the projected**
2 **test period?**

3 A. The projected \$7.287 million capital investment in the projected test period will fund five
4 projects. Two of these projects are greater than \$1 million and are presented on Exhibit
5 A-12 (RTB-3), Schedule B-5.2, page 9, lines 18-19. The basis for these projects is
6 described below:

- 7 • Karn Unit 4 Replacement of Ductwork Insulation and Lagging (\$4,800,000).
8 The scope of this project is to replace the lagging and insulation on all the
9 ductwork from the building out to the stack. The existing lagging and insulation
10 needs to be removed, the underlying steel fixed as necessary, and new insulation
11 and lagging installed. The steel structure that the ductwork lagging is attached
12 to is severely corroded. This has allowed multiple random failures of the
13 lagging, resulting in a safety concern due to pieces of lagging falling to the
14 ground or becoming airborne during wind events; and
- 15 • Ductwork Expansion Joint Replacement – ID Fans to Stack (\$1,900,000). This
16 project will replace all expansion joints and entry doors between the ID Fans
17 and the stack. All expansion joints between the ID Fans and the Stack are
18 beyond their end of life and suspected to be severely degraded based upon the
19 condition of expansion joints found during the Karn Unit 3 Breaching project.
20 Failed expansion joints will need to be replaced to maintain environmental
21 compliance. This scope of work will make the ductwork air-tight again to
22 maintain environmental compliance.

23 The following projects are less than \$1 million, but are important to reliability:

- 24 • Capital tooling/valves/instrumentation (\$500,000). This project supports
25 capital expenditures for replacement of small valves, instrumentation, tools,
26 equipment, pumps, and motors at Karn Units 3 and 4 during the projected test
27 year; and
- 28 • Two additional projects at Karn Units 3 and 4 totaling \$0.087 million which
29 support reliability, with each project representing \$66,667 or less in capital
30 expenditures. These projects include overhaul of the Karn Unit 4 condenser
31 circulating water pumps and project closeout of Karn Units 3 and 4 sync wire
32 replacement.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

Zeeland Plant

Q. Please explain the Company's projected investment for the 14-month projected bridge period ending February 28, 2025 and projected test year ending February 28, 2026 for the Zeeland Plant.

A. The Company plans to invest \$48.518 million in the 14-month projected test period and \$50.929 million in the projected test year at the Zeeland Plant, as shown on Exhibit A-12 (RTB-3), Schedule B-5.2, page 2, line 29, columns (h) and (j), respectively. These capital expenditures will be facilitated, in part, by short outages in the spring and fall of the 14-month projected test period and the projected test year. The Company has an LTSA with GE that covers many reliability investments at the Zeeland Plant.

Q. What is the basis for the projected \$48.518 million capital investment in the 14-month projected bridge period?

A. The projected \$48.518 million capital investment will fund numerous safety, regulatory compliance, reliability, and infrastructure projects at the Zeeland Plant. There are five projects which are greater than \$1 million, and these projects are presented on Exhibit A-12 (RTB-3), Schedule B-5.2, page 8, lines 9 through 13. The basis for these projects is described below:

- Phase I Gas Turbine Advanced gas path replacement and axial fuel staging (\$20,356,250). This project spans the projected bridge period and the projected test year, and its basis is included in my discussion of projected test year capital projects for the Zeeland Plant;
- Zeeland Plant LTSA (\$9,520,000). This project spans the projected bridge period and the projected test year, and its basis is included in my discussion of projected test year capital projects for the Zeeland Plant;
- Zeeland Unit 5 GSU Rewind (\$5,546,538). The scope of this project will remove the failed Zeeland Unit 5 GSU transformer and send it out for rewind and overhaul to support long-term reliable operation. This project also installs a leased GSU transformer. The Zeeland Unit 5 GSU Transformer, which

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 outputs electricity from the generator to the grid, was showing signs of
2 imminent failure as indicated by hydrocarbon gasses being continuously
3 generated at rates above Institute of Electrical and Electronics Engineers (IEEE)
4 recommended levels. The time to failure could not be predicted and could have
5 been catastrophic in nature. Previous intrusive internal inspection and testing
6 work in fall of 2022 was able to identify and replace some degraded parts but
7 ultimately not able to locate the source of gas generation;

- 8 • Zeeland Plant HRSG Casing Replacement (\$2,097,620). The HRSG is
9 designed to recover and recycle heat energy from a gas turbine exhaust.
10 A HRSG produces steam that is used to drive a steam turbine. During recent
11 inspections of the HRSGs at the Zeeland Plant, extensive outer casing corrosion
12 has been identified in particular sections of the units. This condition creates the
13 risk of the studs, which hold on the insulation and liner panels, breaking loose
14 and liberating both insulation and liner sheets. The insulation then blows
15 downstream and fouls the HRSG tubes, requiring the unit to be shut down and
16 cleaned, then subsequent casing, insulation, and liner repairs. The affected
17 areas of casing need to be cut out and replaced with new casing; and
- 18 • Zeeland Plant LTSA supplementals not included in contract (\$3,925,000). This
19 project spans the projected bridge period and the projected test year, and its
20 basis is included in my discussion of projected test year capital projects for the
21 Zeeland Plant.

22 The following projects are less than \$1 million but are important to regulatory compliance
23 and reliability:

- 24 • Main Steam Non-return Valve Replacement (\$705,309). The scope of this
25 project is to replace both main steam check valves. During inspections in the
26 Fall 2018 outage, cracking was noted on both of the main steam stop-check
27 valve body internals. With continued plant operation, the cracks are expected
28 to continue to grow, potentially extending through the valve seat, making the
29 valve unable to seal completely. The cracks can also grow to a through-wall
30 crack, resulting in a steam leak. This cracking is a known issue with these types
31 of valves, and is driven by expansion differentials primarily on startup and
32 shutdown. This cracking had initially been noted during a pipe borescope
33 inspection in 2011;
- 34 • Zeeland - Purchase of Site Spare GSU Transformer (\$589,607). This project
35 spans the projected bridge period and the projected test year, and its basis is
36 included in my discussion of projected test year capital projects for the Zeeland
37 Plant;
- 38 • 199 and 499 345kV Breaker Replacement (\$623,483). The scope of this project
39 is to replace the 199 and 499 circuit breakers with a type which does not exhibit
40 the failure modes exhibited by the existing design. The existing breakers have
41 a critical design flaw such that an individual pole or poles may not latch open

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 when required. The pole's failure to latch open has the potential to result in lost
2 generation, loss of power to the entire Zeeland Substation, and/or equipment
3 damage;

- 4 • Site Commons Road Resurfacing (\$554,167). This project spans the projected
5 bridge period and the projected test year, and its basis is included in my
6 discussion of projected test year capital projects for the Zeeland Plant;
- 7 • Gas Turbine Inlet Filters Replacement (\$390,000). The scope of this project is
8 to replace canister filters. The filters are required to be replaced every five years
9 and must be accomplished during an outage. The purpose of the project is to
10 maintain the integrity of the filters to prevent material ingress to the turbines;
- 11 • ZGS – GE DCS Evergreen (\$600,000). The scope of this project is to upgrade
12 the Zeeland Plant Turbine Controls DCS with the latest version available at the
13 time of the project. The system is currently running on a VMware virtualized
14 system which was installed in 2020. This Evergreen will only replace the
15 existing GE Software, Operating Systems, and miscellaneous upgrades. This
16 project will allow the latest versions of control software and operating systems
17 to be used for reliable operation and control of the generating units. The latest
18 feature enhancements are also available for operation. This will also allow the
19 latest patches to be applied by the cyber security Emerson PWCS application.
20 The DCS must be upgraded at a four-to-five-year upgrade cycle to maintain
21 reliable control and recent operating systems and applications that are patchable.
22 The vendor life cycle for DCS versions is generally five years. After five years
23 they enter a retired state and are no longer patched. Microsoft Operating Systems
24 are on a limited life basis, and they reach the end of "extended support" and no
25 longer get security patches;
- 26 • ZGS – 299 345kV Breaker Replacement (\$510,000). The scope of this project
27 is to replace the 299 circuit breaker with a type which does not exhibit the
28 failure modes exhibited by the existing design. The existing breaker has a
29 critical design flaw such that an individual pole or poles may not latch open
30 when required. The pole's failure to latch open has the potential to result in lost
31 generation, loss of power to the entire Zeeland substation, and/or equipment
32 damage;
- 33 • Zeeland Plant Base Outage Capital (\$482,555). Base outage capital covers the
34 replacement parts and issues found during turbine/generator inspections and the
35 major discovery issues found during annual unit outages; and
- 36 • Seventeen additional projects at the Zeeland Plant totaling \$2.617 million
37 supporting safety, reliability, regulatory compliance, infrastructure, and
38 operations, with each project representing less than \$337,200 or less in
39 expenditures. These projects include Install Combustion Turbine Overspeed
40 Software, Phase 2 599 and 699 345kV Breaker Replacement, Zeeland
41 combined cycle GT2A GT2B Air Filter Replacement, MarkVIe Controller
42 Replacement Project, 480V Circuit Breaker Coordination System Replacement,

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

CT Autotune Software Replacement, boiler feedwater pump, and small tools, pumps, motors, valves, and instrumentation.

Q. What is the basis for the projected \$50.929 million capital investment in the projected test year?

A. The projected \$50.929 million capital investment in the projected test year will fund numerous safety, regulatory compliance, reliability, and infrastructure projects at the Zeeland Plant. There are six projects which are greater than \$1 million, and they are presented on Exhibit A-12 (RTB-3), Schedule B-5.2, page 9, lines 12-17. The basis for these projects is described below:

- Zeeland Plant LTSA (\$8,181,333). This is the capital portion for negotiated services that cover the planned normal maintenance of each unit based on its equivalent operating factor fired hours. The planned maintenance includes the following support services (OEM on-site/off-site technical support, engineering, and labor). Typical activities include borescope inspections, capital repairs, unit tuning, addressing service bulletin requirements, and on-site inspections. Based on the OEM's operating and historical experience, if the Company executes the normal planned maintenance and inspections according to the recommended schedules, the Company will mitigate unexpected pre-mature failures of the equipment. This will help minimize ROR and it will optimize customer value for the site. Normal maintenance will ensure the Company continues reliable operation of the units;
- Zeeland Plant LTSA supplementals not included in contract (\$4,275,000). The LTSA supplemental work is defined as the work that is not covered under normal planned maintenance in the LTSA. Based on historical outage experience there are typical discovery items found on this style of gas turbines that are not part of the LTSA planned maintenance scope. Some of the typical items that need to be addressed are labor and material to replace the following: blading, combustion cans, ignitors, vanes/bushings, and any components on the compressor end as the compressor is not covered under the LTSA;
- Zeeland Site Spare GSU Transformer (\$6,449,004). The scope of this project is the procurement of a spare GSU transformer for the Zeeland site. The Zeeland Plant consists of four gas turbine powered plants and one steam turbine powered plant. The units transmit their power to the grid via GSU transformers. If a GSU were to fail, then the associated turbine would not be able to transmit power and would not be able to generate energy and capacity

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 market value for Consumers Energy and its customers. For the Zeeland
2 combined cycle plant, the combustion turbine requires the operation of the
3 steam turbine, therefore the loss of the steam turbine's GSU transformer would
4 effectively limit operation of two connected combustion turbine units. The
5 lead time for a GSU transformer is currently three-to-four years and spare units
6 at other facilities are not viable replacements due to compatibility and
7 installation challenges. This project would purchase a spare GSU transformer
8 that is sized to be able to replace any of the existing transformers on site and
9 develop redundancy for any minor power upgrades in the future. As previously
10 discussed, the GSU transformer for Zeeland Unit 1 has failed and is being sent
11 out for rewind;

- 12 • Phase I Gas Turbine Advanced gas path replacement and axial fuel staging
13 (\$25,743,740). The scheduled Major Inspection outages in 2025 for the Phase 1
14 gas turbines at Zeeland Generating Station present an ideal time for substantial
15 technological advancements. This project proposes the integration of Advanced
16 Gas Path ("AGP") and Axial Fuel Staging ("AFS") technologies during these
17 outages, aimed at boosting turbine performance and operational flexibility.
18 A more detailed analysis of this project is presented in Exhibit A-46 (RTB-7):
19 Zeeland Phase 1 Gas Turbine upgrades;
- 20 • Generator Rewinds (\$2,174,167). There are multiple Technical Information
21 Letters (Bulletins) from the OEM (GE) involving the brazed connections under
22 the retaining rings that need to be addressed as well as multiple turn shorts
23 potentially evident by the OEM 2021 health assessments for Zeeland Units 3
24 and 4. The impacts of turn shorts include: uneven heating of the rotor which
25 will lead to increased seismic vibrations that can create multiple failure
26 scenarios for a field and possible induced rotor bow, higher field current
27 required to match original design which can result in higher heating effects and
28 escalated failure modes, and damage to the retaining rings which will further
29 escalate the vibrational issues. During the major overhaul, the generator rotors
30 will be removed and replaced/rewound, correcting the issue with the
31 connections and shorted turn issue, allowing the units to run to the anticipated
32 end of life; and
- 33 • Phase II Turbine Replacements (\$1,884,167). The scope of this project replaces
34 the existing rotor with a new rotor, giving another 144,000 hours of operation
35 which would enable operation until the next rotor replacement out to
36 approximately the year 2045. Also included in this scope is new compressor
37 stator vanes due to the compressor being 20 years old; the best way to restore
38 the compressor to like-new condition is to replace the stationaries when the
39 blades will already be replaced. Lastly, the exhaust frame will be upgraded to
40 a robust exhaust frame due to reliability issues over the years, and the rotor
41 replacement being an appropriate time to replace the exhaust frame.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

Several other critical projects which are less than \$1 million but are important to reliability and infrastructure include:

- Zeeland combined cycle SCR Catalyst Replacement (\$417,500). The scope of this project is to replace the SCR catalyst to maintain NOx reduction on gas turbine emissions;
- Site Commons Road Resurfacing (\$395,833). The scope of this project is to perform continued resurfacing of site roads. Several roads require widening to ensure safe 2-way vehicle travel (e.g. road behind substation). Roads/driveways on site require continuous maintenance. The objective of the project is to ensure roadways are safe for both vehicle and pedestrian travel;
- Zeeland Plant Base Outage Capital (\$424,444). Base outage capital covers the replacement parts and issues found during turbine/generator inspections and the major discovery issues found during unit outages; and
- Nine additional projects at the Zeeland Plant totaling \$0.984 million support reliability and operations, with each project representing \$241,667 or less in expenditures. These projects include Unit 5 Battery Replacement, Phase II Unit 3 and 4 battery monitoring system, compressed air system replacement, boiler feedwater pump replacement, and small pumps, motors, valve, instrumentation, tools, and equipment.

Jackson Plant

Q. Please explain the Company's projected investment for the 14-month bridge period ending February 28, 2025 and test year ending February 28, 2026 for the Jackson Plant.

A. The Company plans to invest \$19.130 million in the 14-month projected bridge period and \$14.965 million in the projected test year at the Jackson Plant, as shown on Exhibit A-12 (RTB-3), Schedule B-5.2, page 2, line 36, columns (h) and (j), respectively. This will be facilitated by short outages in the fall of 2024 and 2025. The Company has a LTSA with GE to cover many reliability issues at the Jackson Plant.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. What is the basis for the projected \$19.130 million capital investment in the 14-month**
2 **projected bridge period?**

3 A. The projected \$19.130 million capital investment in the 14-month projected bridge period
4 will fund numerous safety, regulatory compliance, reliability, and infrastructure projects.
5 There are two projects which are greater than \$1 million, and they are presented on Exhibit
6 A-12 (RTB-3), Schedule B-5.2, page 8, lines 7-8. The basis for these projects is described
7 below:

- 8 • Jackson Plant LTSA (\$12,337,500). This project spans the 14-month projected
9 bridge period and the projected test year, and its basis is included in my
10 discussion of projected test year capital projects for the Jackson Plant; and
- 11 • Jackson Plant LTSA Extra Work (\$2,908,333). This project spans the
12 14-month projected bridge period and the projected test year, and its basis is
13 included in my discussion of projected test year capital projects for the Jackson
14 Plant.

15 Several other critical projects which are less than \$1 million but are important to reliability
16 and infrastructure include:

- 17 • Feedwater Desuperheater Valve Replacement (\$831,433). The scope of this
18 project is to install feedwater control valves and separate lance spray nozzle
19 assemblies that spray small amounts of water into steam flow continuously.
20 The HRSG 1-6 superheat (“SH”) Steam Desuperheater Feedwater valves have
21 had very short life spans since original construction. There are several issues
22 that cause the valves to wear out quickly. The valves inherently cycle frequently
23 open and closed due to the boiler running close to high pressure (“HP”) Steam
24 Outlet temperature setpoint at gas turbine baseload, without duct firing. This
25 has been reduced recently by a study completed by engineering and GE to allow
26 the HP Steam temperature to be increased from the original 750 degrees
27 Fahrenheit up to 770 degrees Fahrenheit. This change did cause the valves to
28 cycle open/close less frequently, but it did not result in a substantial
29 improvement in valve life. The brunt of the wear is absorbed by the HP FW
30 Autoblock valve, which when it begins to leak by, causes the SH Steam
31 temperature to fall. The HP FW Control Valve wears out quickly as well.
32 Typically, when this occurs the leak by accelerates quickly to the point which
33 the manual HP FW isolation valve upstream must be closed when the unit is
34 not duct firing in order to maintain adequate superheated steam temperature;

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

- LM6000 Beckwith Relay Replacement (\$391,667). The scope of this project seeks to replace the LM6000 Generator Protective Relays with direct replacement relay upgrades and install test facilities in a pre-planned fashion. This will protect the generation assets and avoid issues with the obsolescence of the existing equipment. Jackson Units 1 through 6 are currently protected with Beckwith M3420 Relays that are obsolete. The long lead time replacement M-3425A relays have been purchased, and are awaiting installation.

In addition to being obsolete, the existing relays have limited, or no means for communication, fault analysis, troubleshooting, and event recording following an electric fault event. The current relays also do not have external test facilities for periodic maintenance. Because of this, the relays need to be un-wired to test, and then rewired. This increases maintenance time, as well as exposes the plant to unplanned operations due to human error;

- Base Outage Capital (\$350,000). This project spans the 14-month projected bridge period and the projected test year, and its basis is included in my discussion of projected test year capital projects for the Jackson Plant;

- Jackson Site 480V Breaker (WavePro) Replacement (\$267,000). The 480V circuit breakers each have a small control box that senses the amount of current thru the breaker and trips the breaker for a fault. These trip modules have electronic components normally expected to last 10 years, and some are presently failing after 20 years of service. Since these trip modules are no longer made, a failure requires complete replacement of the module and current sensors at a qualified breaker repair shop. The scope of this project is to replace all 30 trip modules;

- Units 1-6 LM HP Start-up Vent Silencer Replacement (\$248,000). The degradation of the existing LM HP Start-Up Vent Silencers (original to plant) has resulted in exceeding the noise level limitations set forth in ST-001, Standard Technical and Site Data Specification. The specification states that the equipment shall not exceed 90 dBA when measured three feet from vent silencer opening at 90 degrees to the flow. The noise levels are disruptive to the surrounding neighborhood in addition to plant personnel. The replacement of three silencers will reduce the noise of current silencers, prevent additional excessive noise for plant personnel (OSHA) and surrounding community safety, and proactively avoid risk of violating city ordinances;

- JGS – Low Quality Sump Piping Replacement (\$256,535). The Jackson Plant has three sump pits to deal with wastewater throughout the plant. One of these sump pits is called the water treatment low-quality (“LQ”) sump, one the main low-quality sump, and one is the high-quality (“HQ”) sump. The water treatment LQ sump deals with most of the wastewater that comes from the plant including reverse osmosis backwash discharge, floor drains and miscellaneous sources. The main LQ sump takes transformer secondary containment drains. The HQ sump handles blow down condensate from the running units. Each

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 sump pit has two pumps that operate off a multi-float switch level indicator.
2 The level indicators are reaching end of life. The water treatment LQ pumps
3 have a mean time between failures of about one year. The HQ sumps were
4 upgraded in 2019 with no failures at this time. The failures on the water
5 treatment sumps are due to failed bearings, worn impellers, volutes, and
6 casings. There is a large amount of dirt, oil, and other debris that get into the
7 water treatment LQ sump leading to wear of pump components and bearing
8 failures. The scope of this project is to replace the two sump pumps in the water
9 treatment LQ sump and the level indication on both LQ sumps. It is
10 recommended to install pumps with upgraded wear materials to help with the
11 erosion issue and install sealed greased bearings. The level transmitters are also
12 beginning to fail as the switches do not always actuate when they are supposed
13 to. The level transmitters will be replaced with radar level transmitters. The
14 sumps are locally controlled with an audible alarm. This project would also
15 bring control and level indication into the DCS for the sump;

- 16 • JGS NOx Umbilical Replacements (\$300,728). The scope of this project is to
17 replace the heated sample line (umbilical) on Jackson Units 1 through 5 and 7
18 from the analyzer to the stack probe. The Continuous Emissions Monitoring
19 System (“CEMS”) and associated umbilicals have been in service since 2002.
20 As a result of the heat trace failure on the LM6 umbilical in 2020 and the visual
21 condition of the polyurethane jacket, the remaining umbilicals were inspected.
22 Similar cracking and poor installation practices were observed. To avoid unit
23 downtime in the future, the Company determined that a project should be
24 initiated to replace the remaining units’ umbilicals. A three-year
25 implementation plan, replacing two umbilicals per year, is proposed to mitigate
26 risk. The new umbilicals will utilize a PVC jacket that is more resistant to
27 degradation and chemical attack. Post maintenance testing will be required
28 upon replacement including a relative accuracy test audit (“RATA”) to recertify
29 the CEMS. The combined-cycle combustion turbines at Jackson are subject to
30 specific NOx emission limits and monitoring requirements originating from
31 several environmental rules. For purposes of demonstrating compliance with
32 the NOx emission limits, JGS relies upon CEMS for each unit;

- 33 • Jackson Combustion Turbine Inlet Canister Filter Replacement (\$230,000).
34 The Jackson Plant is comprised of nine generating units. Jackson Units 1
35 through 7 draw combustion air in through a filter house which has integrated
36 filters to prevent dust, dirt, and debris from being pulled into the compressor
37 section of the turbine. The canister filters require periodic replacement to
38 maintain proper air flow to the engine. Over time the filters plug and reduce
39 the efficiency of the combustion turbine. If air flow is restricted enough, the
40 engine can stall due to lack of sufficient air causing catastrophic failure; and

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

- Twelve additional projects at the Jackson Plant totaling \$1.009 million, with each individual project representing \$262,500 or less in expenditures. These projects include LM1-6 VIGV (variable inlet guide vane) Project, Major Motor and Pump Replacements, site small capital, DCS Evergreen replacement, and LM1-6 Steam injection trap replacements.

Q. What is the basis for the projected \$14.965 million capital investment in the projected test year?

A. The projected \$14.965 million capital investment in the projected test year will fund numerous safety, regulatory compliance, reliability, and infrastructure projects. There is one project which is greater than \$1 million, and it is presented on Exhibit A-12 (RTB-3), Schedule B-5.2, page 9, line 11. The basis for this project is described below:

- Jackson Plant LTSA (\$11,116,875). This is the capital portion for negotiated services that cover the planned normal maintenance of each unit based on its equivalent operating factor fired hours. The planned maintenance includes the following support services: OEM on-site/off-site technical support, engineering, and labor. Typical activities include borescope inspections, capital repairs, unit tuning, addressing service bulletin requirements, and on-site inspections. Based on the OEM's operating and historical experience, if the Company executes the normal planned maintenance and inspections according to the recommended schedules, the Company will mitigate unexpected pre-mature failures of the equipment. This will help maximize availability and, as a result, optimize customer value for the site. Normal maintenance will ensure the Company continues reliable operation of the units.

Several other critical projects which are less than \$1 million but are important to reliability and infrastructure include:

- Jackson Plant LTSA Supplemental Work (\$350,000). The LTSA supplemental work is defined as the work that is not covered under normal planned maintenance in the LTSA. Based on historical outage experience there are typical discovery items found on this style of gas turbines that are not part of the LTSA planned maintenance scope. Some of the typical items that need to be addressed are labor and material to replace the following: blading, combustion cans, ignitors, vanes/bushings, and any components on the compressor end as the compressor is not covered under the LTSA;

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

- 1 • Base Outage Capital (\$300,000). Base outage capital covers the replacement
2 parts and issues found during turbine/generator inspections and the major
3 discovery issues found during annual unit outages;
- 4 • JLM1-6 Variable Inlet Guide Vane (“VIGV”) Project (\$900,000). This project
5 will install new VIGV systems on six LM6000PC engines at the Jackson Plant.
6 The seventh LM6000PC engine has a partial installation already, and the project
7 will complete the VIGV system for this engine. For LM6000PC SPRINT gas
8 turbines, which the Jackson Plant has, the VIGV upgrade is expected to yield a
9 significant fuel efficiency improvement at part power. The average fuel
10 efficiency improvement at 70% of maximum power is greater than 2%. The
11 VIGV also helps minimize variable bypass valve (“VBV”) flow and pressure
12 levels, thereby reducing associated flow noise. The VIGV system improves
13 performance for both simple cycle and heat-recovery cycles when operating at
14 less than full load;
- 15 • GSU Transformer Site Spare (\$833,333). This project provides Jackson with a
16 reliable spare GSU to which it currently does not have access. The main
17 transformers (GSUs) are a single point of failure to delivering power from the
18 generators to the grid. For failure of one main transformer, lost generation
19 would be 47 MW to 104 MW, depending on which generator(s) are connected.
20 The lead time for a new transformer is three-to-four years, since every
21 transformer of this size is custom built, and a large quantity of special raw
22 materials is required. The Company’s spare transformers located at Campbell,
23 Karn, Lake winds, and Crosswinds do not have the correct voltage
24 (138kV-13.2kV-13.2kV) or correct winding configuration (WYE-DELTA) to
25 function at Jackson so they cannot be considered for use as spares;
- 26 • DCS Evergreen replacement (\$666,667). This project replaces the GE DCS
27 with the latest version available at the time of the project. The system is
28 currently running on a VMware virtualized system. The system was installed
29 in 2020. This Evergreen will only replace the existing GE Software, Operating
30 Systems, and miscellaneous upgrades. The controller drops and rack-mounted
31 servers will not be replaced for this upgrade. (Standard practice is to replace
32 virtualized system hardware every eight years to reduce costs.) The DCS must
33 be upgraded at a four-to-five-year upgrade cycle to maintain reliable control
34 and recent operating systems and applications that are patchable. Vendor life
35 cycle for DCS versions is generally a five-year cycle. After five years they
36 enter a retired state and are no longer patched. Microsoft Operating Systems
37 (O/S) are on a limited life basis, and they reach the end of “extended support”
38 and no longer get security patches. Corporate policies require all systems to be
39 patched regularly along with Anti-Virus updates; and
- 40 • Fourteen additional projects at Jackson Plant totaling \$1.098 million, with each
41 individual project representing \$225,000 or less in expenditures. These projects
42 include (13476) JGS - LM1-6 Steam injection trap replacements, generator

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

breaker replacements, breaker relay replacements, major motor and pump overhauls, and small valves, instrumentation, tools, equipment, pumps, and motors.

HYDRO UNITS

Q. Please explain the Company's projected capital expenditures for the 14-month projected bridge period ending February 28, 2025 and the projected test year ending February 28, 2026 for the Hydro Units.

A. The Company plans to invest \$42.376 million in the 14-month bridge period and \$92.258 million in the projected test year in the Hydro Units, as shown on Exhibit A-12 (RTB-3), Schedule B-5.2, page 3, line 64, columns (h) and (j), respectively.

Q. What is the basis for the projected \$42.376 million capital investment in the 14-month projected bridge period?

A. The projected \$42.376 million capital investment will fund numerous safety, regulatory compliance, reliability, and infrastructure projects. There are ten projects which are greater than \$1 million, and they are presented on Exhibit A-12 (RTB-3), Schedule B-5.2, page 8, lines 20 through 29. The basis for these projects is described in the direct testimony of Company witness Monroe.

Q. What is the basis for the projected \$92.258 million capital investment in the projected test year?

A. The projected \$92.258 million capital investment in the projected test year will fund numerous safety, regulatory compliance, reliability, and infrastructure projects. There are 13 projects which are greater than \$1 million, and they are presented on Exhibit A-12 (RTB-3), Schedule B-5.2, page 9, lines 21 through 33. The basis for these projects is described in the direct testimony of Company witness Monroe.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

LPS

Q. Please explain the Company's projected capital expenditures for the 14-month projected bridge period ending February 28, 2025 and the projected test year ending February 28, 2026 for the LPS.

A. The Company plans to invest \$10.279 million in the 14-month projected bridge period and \$15.587 million in the projected test year in the LPS, as shown on Exhibit A-12 (RTB-3), Schedule B-5.2, page 3, line 71, columns (h) and (j), respectively. These capital investments will be implemented in periodic outages in the spring of 2024 and 2025. It is important to note that none of these investments are associated with resolving the Toshiba defects. Those investments are being recorded to a regulatory asset pursuant to the MPSC's May 18, 2023 Order in Case No. U-21310.

Q. What is the basis for the projected \$10.279 million capital investment in the 14-month projected bridge period?

A. The projected \$10.279 million capital investment in the 14-month projected bridge period will fund numerous safety, regulatory compliance, reliability, and infrastructure projects. There are two projects which are greater than \$1 million, and they are presented on Exhibit A-12 (RTB-3), Schedule B-5.2, page 8, lines 30-31. The basis for those projects is described below:

- Ludington Units 1 through 6 DCS Control Relay Replacement (\$1,648,169). This project spans the 14-month projected bridge period and the projected test year, and its basis is included in my discussion of the projected test year capital projects for Ludington;
- LPS – Lower Penstock Expansion Joint (“LPEJ”) Chamber Waterstop replacement (\$2,716,000). The scope of this project is replacement of the LPEJ waterstop and potentially dewatering the surrounding groundwater. The engineering study was performed in 2020 at a cost of \$0.404 million and project

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 implementation began in 2021 and is planned to be completed in 2024. In 2021,
2 the engineering was completed, and the design was approved by FERC; and

- 3
- 4 • The LPEJ Chambers enclose the penstock expansion joints in concrete
5 chambers. The penstock expansion joints allow penstock expansion with
6 seasonal temperature changes. The waterstop is a membrane intended to
7 prevent groundwater from leaking into the LPEJ. Some joints have been
8 leaking since shortly following plant construction. In February 2017, a
9 depression was discovered upstream of Ludington Unit 3, which was caused by
10 transport of soil into the chamber by inflowing groundwater. Historically,
11 Consumers Energy sealed the leaks into the LPEJs using hydrophobic
12 polyurethane grout. However, the waterstops are at the end of their expected
13 life and grouting is no longer an effective solution. Failure to remedy the in
14 leakage is a threat to generation because if the settlement of the chambers
15 reaches a certain threshold, the generation unit(s) will remain in a forced outage
16 until the LPEJ chamber(s) can be stabilized. The implementation of this project
17 reduces current risk of a potential failure mode and supports Ludington unit
generation well into the relicensing period.

18 The following projects are less than \$1 million but are important to regulatory compliance
19 and reliability:

- 20
- 21 • Replace Barrier Net Panels (\$679,115). This project spans the 14-month
22 projected bridge period and the projected test year, and its basis is included in
my discussion of the projected test year capital projects for Ludington;
 - 23 • Replace 480V Dike Load Centers (\$993,800). This project spans the 14-month
24 projected bridge period and the projected test year, and its basis is included in
25 my discussion of the projected test year capital projects for Ludington;
 - 26 • LPS Oil Water Separator Replacement (\$780,249). This project spans the
27 14-month projected bridge period and the projected test year, and its basis is
28 included in my discussion of the projected test year capital projects for
29 Ludington;
 - 30 • LPS Intake Gate and Gate House Mechanical Replacement (\$409,099). This
31 project spans the 14-month projected bridge period and the projected test year,
32 and its basis is included in my discussion of the projected test year capital
33 projects for Ludington;
 - 34 • Governor Replacement (\$474,167). This project spans the 14-month projected
35 bridge period and the projected test year, and its basis is included in my
36 discussion of the projected test year capital projects for Ludington;
 - 37 • Ludington All Unit Critical Valve and Actuator Replacement (\$565,000). The
38 scope of this project is to replace valves, actuators, and associated equipment

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

critical to unit specific operation. There are also certain valves that provide routine tagging points that provide worker protection. Many of these valves have known issues such as damaged seals (leakage when the valve is closed), leaking packing (cannot be tightened further), and severely corroded valve stem extensions. Additionally, many of these valves are paired with pneumatic actuators which have also been identified with operational issues. Most of the handwheels are broken and do not provide a secondary means of operating the valve if the pneumatic actuator were to fail. This could present a particularly dangerous situation if a pipe were to fail. Additionally, damage to the actuator linkages and slides have been noted in previous inspections. The linkage damage has introduced play or slop into the mechanism which can be seen during operation and will lead to eventual failure of the mechanism; and

- Twenty-two additional projects at LPS totaling \$2.014 million, with each individual project representing \$256,896 or less in expenditures. These projects include LPS DAC 1 and 2 replacement, subdrainage and unwatering sump pump controls and pump replacement, CO2 Fire Protection System Replacement Centralized Grease System Replacement, and small tools, pumps, motors, valves, and instrumentation.

Q. What is the basis for the projected \$15.587 million capital investment in the projected test year?

A. The projected \$15.587 million capital investment in the projected test year will fund numerous safety, regulatory compliance, reliability, and infrastructure projects. There are five projects which are greater than \$1 million, and they are presented on Exhibit A-12 (RTB-3), Schedule B-5.2, page 9, lines 34 through 38. The basis for these projects is described below:

- DCS Control Relay Replacement (\$4,771,901). The scope of this project is to replace and eliminate worn and less reliable control relays with new electronic input/output modules and new relays where needed. The number of hardware control relays will be reduced due to the “control” being performed in logic instead of “hardwired” circuits. This will increase reliability and reduce outages and unit derates. Common control and monitoring of system equipment allows operation of the equipment from the Human Machine Interface (“HMI”) graphics and keeps the operator focused on one system instead of monitoring several systems from several areas of the control room.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 The LPS units are controlled by using the original hardwired
2 electromechanical relay control system to operate the units. A modern DCS
3 system will provide the LPS units with improved diagnostic and
4 troubleshooting capabilities. The DCS system will make it easier to automate
5 any updates of equipment and systems that are integrated with the unit
6 operation, and to implement, test, and verify changes to operating criteria.
7 Furthermore, the modern DCS has the capability to perform these functions at
8 a lower cost and requiring less time.

9 The existing relay control system is based on electromechanical devices that
10 wear and become less reliable over time. The relay contacts wear, and increased
11 resistance can cause intermittent failures. Troubleshooting these issues are
12 difficult and time-consuming. The relay control system will not last until end
13 of life of the units and need to be upgraded to a modern DCS control system.
14 The Emerson Ovation DCS infrastructure was installed as part of the 2019-2021
15 Data Acquisition System (“DAS”), Annunciator, PLC, and Sequence of Events
16 recorder replacement project. This provides a common historian, HMI graphics
17 control, alarm management system and modern control system for reliable
18 efficient unit operation. The DAS project provides the infrastructure to build
19 upon for full site/unit control at LPS;

- 20 • Replace 480V DLCs (\$1,566,400). The scope of this project is the replacement
21 of the 20 480V DLCs over a six-year period that began in 2020 at a capital
22 expenditure amount of \$0.671 million. The DLCs are original plant equipment
23 and suffer from corrosion and deterioration. The primary purpose of the DLCs
24 is to distribute power to 193 dike drain pumps and 34 pumping relief wells
25 located around the reservoir. The purpose of the dike drain pumps is to keep
26 the upstream face of the dike in a drained condition and to protect the asphalt
27 liner from damage due to differential pressure. The purpose of the pumping
28 relief wells is to keep groundwater at pre-construction levels, thereby
29 minimizing the likelihood of a downstream slope failure. Replacement of the
30 DLCs over a six-year period will provide high electrical system reliability and
31 ensure FERC compliance;
- 32 • LPS Commons Station Power Transformer (“SPT”) Life Cycle Management
33 (\$1,150,000). The scope of this project is to procure and replace all six SPTs
34 with new to suit size and configuration in current LPS footprint. The SPTs are
35 original to the site, and are in service outdoors on the LPS roof. The benefits
36 of the project are restoration of system voltage to rated, increase site equipment
37 life span, extension of life expectancy to that of site, enablement of the ability
38 to perform routine maintenance without risk of damage, and reduction in the
39 probability of failure and the associated risk of not having a spare;

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

- Governor Replacement (\$1,915,833). The scope of this project is to contract with a specialized vendor to inspect, repair as required, and modernize the unit governors. The LPS unit governors have not been overhauled in approximately 15 years and, as a result, show signs of significant wear; and
- Intake Gate and Gate House Mechanical Replacement (\$1,666,014). The LPS intake gates and associated hoist equipment are the primary form of mechanical protection for the LPS units. Their purpose is to isolate the stored energy from the reservoir's water against each unit's penstock when dewatering or during emergency conditions such as a penstock rupture or governor failure. Reliable operation of this system is critical to minimize damages from a unit run away condition or a penstock failure, acting as a last effort to control unit overspeed. The mechanical system of the intake gate hoist is all original (circa 1971) and recent OEM inspection revealed that its condition is poor and in need of refurbishment. Updates and repairs are required to support the current facility license extension of 2069. The electrical control system is well past its design service life. This outdated technology is obsolete, and certain critical components are no longer available for spare parts. Modern technology offers more reliable options that would give the system an additional 30 years of service. The head gate hoist is enclosed in a steel structure on top of the intake (head gate enclosure). The head gate hoist enclosures are original to the plant and have rusted out in many places. Significant corrosion has been noted on the steel frame, the connections, and the beams. These enclosures need to be replaced as they are beyond a repair option.

The following projects are less than \$1 million but are important to regulatory compliance and reliability:

- LPS Oil Water Separator ("OWS") Replacement (\$438,746). The scope of work for this project is to install a separate, parallel train OWS to that of the plant's existing OWS, modify existing support systems (station sump, station sump pumps, and metering devices) to support new OWS, and retrofit the existing OWS to improve oil separability. This will allow temporary use of the modified original OWS while servicing the anticipated new one as to not impact unit availability. The project is being performed in order to comply with requirements for effluent discharge during all modes of operation and process upset conditions. The failure to perform this project would likely lead to additional releases in excess of the National Pollutant Discharge Elimination System permit requirements throughout the facility's lifecycle. Although not quantified, cost for these releases could be significant in terms of potential fines, reputational damage, cleanup costs, and other intangibles;
- Centralized Grease System Replacement (\$303,604). The scope of this project is to replace end of service life components such as pumps, distributing blocks, and solenoid valves, and to modernize the control system to a self-diagnostic

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

PLC system. The current electro-pneumatic grease system(s) that service certain bushings are past their service life and of questionable reliability (original plant functionally equipment);

- Replace Barrier Net Panels (\$829,725). The panels are a regulatory required system to minimize fish entrainment. The panel replacements are primarily time based. LPS has extensive operating experience with these panels, which helps determine when a replacement is required; and
- Nineteen additional projects at Ludington totaling \$2.944 million, with each individual project representing \$298,332 or less in capital expenditures. These projects include north fabrication shop storage mezzanine and humidity control, pony motor isolation switch life cycle project, all unit critical valve and actuator replacement, cathodic protection system replacement, main transformer bank isophase cooling blower replacement, subdrainage and unwatering sump pump controls and pump replacement, flow transmitter replacement, and small tools, pumps, motors, valves, and instrumentation.

ADMINISTRATIVE AND OTHER

Q. Please explain the Company's projected capital expenditures for the 14-month projected bridge period ending February 28, 2025 and the projected test year ending February 28, 2026 for Administrative and Other.

A. The Company plans to invest \$2.795 million in the 14-month projected bridge period and \$3.096 million in the projected test year in Administrative and Other, as shown on Exhibit A-12 (RTB-3), Schedule B-5.2, page 3, line 78, columns (h) and (j), respectively.

Q. What is the basis for the projected \$2.795 million capital investment in the 14-month projected bridge period for Administrative and Other?

A. The projected \$2.795 million capital investment will support several projects during the 14-month bridge period. The basis for these projects is described below:

- Generation Operations – Ovation security center replacement evergreen (\$300,000). The Generation control systems cyber security tool that is used for control system security is the Emerson PWCS. This tool is comprised of multiple cyber security products used in the industry today. Because of the quickly changing technology and techniques used by hackers, the cyber security tools require an increased update cycle of two to three years. The Karn site has been using the PWCS tool for 10 years. It was last upgraded in 2017. To

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

support the latest version of Ovation DCS, the PWCS system must be upgraded. This replacement will support the protection of multiple components of the control system across multiple sites including Karn Units 3 and 4, Campbell, Jackson, Zeeland, and Ludington. The tools included are:

- Anti-Virus;
- Malware Prevention with Application Control;
- Patch Management;
- Device Control;
- Rogue System Detection;
- System Backup and Recovery;
- Security Incident and Event Manager; and
- Change Management.

- Fleet - Move the machine shop (\$616,667). This project spans the 14-month projected bridge period and the projected test year, and its basis is included in my discussion of the projected test year capital projects for Administrative and Other;

- Transformation - Enterprise Project Management Information System (\$850,010). The scope of this project is the continuing support of Unifier, the Company's project management information system ("PMIS"). During the bridge period, the Company is implementing a major upgrade to Unifier and Primavera P6 ("P6"). Specifically, the Company is moving from version 19.12 to 22.12 for both Unifier and P6. The upgrade reflects three years of upgrades from oracle which includes various enhancements. The scope of the project also includes the February 2024 procurement of 350 additional licenses to support the continued user growth the Company expects from the new functionality in the upgrade. The increased user growth includes expansion of the products to additional engineering personnel, some project management personnel, and some vendors. In addition to the upgrade and procurement of additional licenses, the Company has continued its quarterly implementation of continuous-improvement updates (new functionality that Company users identify) that include the creation and or configuration of new reporting and business processes; and

- Seven additional projects totaling \$1.028 for generation cyber security, ovation cyber security, laptop and capital business tool purchases for Generation Engineering, Electric Supply, Environmental Services, Lab Services, Business Services, and Enterprise Project Management.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. What is the basis for the projected \$3.096 million capital investment in the projected**
2 **test year?**

3 A. The projected \$3.096 million capital investment in the projected test year will fund various
4 projects. One of these projects is greater than \$1 million, and is presented on Exhibit A-12
5 (RTB-3), Schedule B-5.2, page 9, line 20. The basis for these projects is described below:

- 6 • Fleet - Move the machine shop (\$2,100,000). The scope of this project is to
7 move the machine shop. The existing machine shop is located at the Campbell
8 site and with the closure of the Campbell units on May 31, 2025, the Company
9 will likely have to relocate the existing machine shop. Options for the project
10 include (1) doing nothing and going to third parties for parts which will impact
11 both cost and timing of delivery, (2) purchasing another machine shop,
12 (3) section off the training center at Campbell and move the machine shop to
13 that building, and (4) Building a machine shop in a centralized location to better
14 service all generation sites.

15 The machine shop has proven its financial viability, with a positive variance
16 of \$67,978 in 2023. It has consistently demonstrated the ability to generate
17 revenue exceeding operational costs, a trend expected to continue based on
18 projections. The shop's ability to quickly turn around projects and fabricate
19 parts faster than external vendors has led to substantial savings, particularly in
20 replacement power costs, estimated at \$300k annually; and

- 21 • Eight additional projects for generation cyber security, laptop and capital
22 business tool purchases for Generation Engineering, Electric Supply,
23 Environmental Services, Lab Services, Business Services, and Enterprise
24 Project Management (\$996,250).

25 **COMPANY-OWNED SOLAR RESOURCES**

26 **Q. Please explain the Company's projected capital expenditures for the 14-month**
27 **projected bridge period ending February 28, 2025 and the projected test year ending**
28 **February 28, 2026 for Company-owned solar resources.**

29 A. The Company plans to invest \$249.572 million in the 14-month projected bridge period
30 and \$275.959 million in the projected test year in Company-owned solar resources, as

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 shown on Exhibit A-12 (RTB-3), Schedule B-5.2, page 2, line 50, columns (h) and (j),
2 respectively.

3 **Q. What is the basis for the projected \$249.572 million capital investment in the**
4 **14-month projected bridge period?**

5 A. The projected \$249.572 million capital investment in the 14-month projected bridge period
6 will fund the IRP-approved solar generation development. This entire investment amount
7 is reflected in two separate projects, Muskegon Solar and Spring Creek, which are each
8 greater than \$1 million and are presented on Exhibit A-12 (RTB-3), Schedule B-5.2,
9 page 8, lines 32 and 33. The basis for these projects is described in the direct testimony of
10 Company witness Clark.

11 **Q. What is the basis for the projected \$275.959 million capital investment in the**
12 **projected test year?**

13 A. The projected \$275.959 million capital investment in the projected test year will fund the
14 IRP-approved solar generation development. This entire investment amount is reflected in
15 three separate projects, Muskegon Solar, Washtenaw, and Spring Creek, which are each
16 greater than \$1 million and are presented on Exhibit A-12 (RTB-3), Schedule B-5.2,
17 page 9, lines 39 through 41. The basis for those projects is described in the direct testimony
18 of Company witness Clark.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

BATTERY ENERGY STORAGE SYSTEMS

Q. Please explain the Company's projected capital expenditures for the 14-month projected bridge period ending February 28, 2025 and the projected test year ending February 28, 2026 for BESS.

A. The Company plans to invest \$39.672 million in the 14-month projected bridge period and \$78.921 million in the projected test year in Company-owned battery resources, as shown on Exhibit A-12 (RTB-3), Schedule B-5.2, page 3, line 85, columns (h) and (j), respectively.

Q. What is the basis for the projected \$39.672 million capital investment in the 14-month projected bridge period?

A. The projected \$39.672 million capital investment in the 14-month projected bridge period will fund BESS. This entire investment amount is reflected in three separate projects, Armstrong, Iosco, and Weadock, which are each greater than \$1 million and are presented on Exhibit A-12 (RTB-3), Schedule B-5.2, page 8, lines 34 through 36. The basis for these projects is described in the direct testimony of Company witness Clark.

Q. What is the basis for the projected \$78.921 million capital investment in the projected test year?

A. The projected \$78.921 million capital investment in the projected test year will fund the BESS. This entire investment amount is reflected in three separate projects, Armstrong, Iosco, and Weadock, which are each greater than \$1 million and are presented on Exhibit A-12 (RTB-3), Schedule B-5.2, page 9, lines 42 through 44. The basis for those projects is described in the direct testimony of Company witness Clark.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. Are you supporting any other projected capital expenditures for generation related**
2 **projects in the test year ending February 28, 2026?**

3 A. Yes. I am also supporting an IT project, Generation Operations Digital Work Management.
4 The test year projected capital expenditure amount is \$713,873, and the test year projected
5 O&M expense amount is \$54,383. These amounts are reflected in the exhibits of Company
6 witness Shivaji Kandan. The scope of the project includes: the initial roll out for Electric
7 Generation at Ludington, and Renewable Generation, which would include: (1) purchase
8 of mobile field devices for Ludington, (2) purchase of additional mobile work management
9 software licenses, (3) development and configuration of forms and workflow for these
10 groups, and (4) enhancement of the wireless connection at Ludington.

11 **Q. What are the benefits of this technology project?**

12 A. This project provides the following value to the Company: (1) Productivity is improved,
13 and human struggle reduced by simplification of work tracking through the mobile
14 software. Time sheet charging is incorporated to the work order when someone on the
15 crew pushes the clock to start versus being separately entered through SAP Employee Self
16 Service. If there is more than one person on a crew, information is entered for the full crew
17 versus individually, including time tracking. Functionality is available to more easily
18 create a digital punch list in the field when a worker sees something instead of later writing
19 it on a punchboard and entering it separately into SAP; (2) Employee Engagement
20 improves as the more tech savvy candidate pool for these positions are looking for mobile
21 software to help them do their jobs; (3) Quality is improved by creating a digital punch list
22 when the technicians find an issue versus manually documenting it later. Accuracy
23 increases and rework decreases when updates are performed right at the time and place of

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 the work instead of afterwards. Productivity can also be tracked and measured for further
2 improvements. This level of tracking is not possible with the current process and
3 information; (4) Safety is improved as employees have remote access to manuals to
4 reference before moving forward with and during their work. The access to manuals
5 increases productivity and better supports error reduction training by having the manuals
6 available so a worker can move beyond “I think” and “I believe.” The project will mitigate
7 the risk of work and safety errors from using outdated procedures; (5) For Renewable
8 Generation, the improved maintenance program will reduce equipment downtime resulting
9 in an increase to Megawatt hours produced; and (6) For Ludington, the new mobile devices
10 will allow working with electronic Systems Operations Management System (“eSOMS”)
11 which will improve productivity and reduce non-premise time.

12 **Q. Did the Company consider alternatives for this project?**

13 A. Yes. The alternatives considered include: (1) Utilizing an SAP work management mobile
14 solution. An SAP work management solution is not preferred since it is a new solution and
15 requires additional project and support cost; (2) Continuing the manual paper-based
16 process. Continuing the manual paper-based process was not chosen because of process
17 waste, re-work, and human error; (3) Customizing the existing electronic eSOMS mobile
18 application to add work management functions. A custom eSOMS mobile application was
19 not chosen because it would require additional project cost and an ongoing support budget
20 for a custom solution that the eSOMS product was not intended to support; and (4) Utilizing
21 an out-of-the-box solution to minimize cost and risk to the Company and its employees.
22 The combined Service Suite and digital form solution is the preferred option because it is

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 a proven solution and provides the mobility and digital benefits at a lower cost than other
2 alternatives.

3 **GENERATION CAPITAL EXPENDITURES—SUMMARY**

4 **Q. Are the Company's capital expenditures in power generation reasonable and**
5 **prudent?**

6 A. Yes. As discussed, the proposed capital expenditures are directly aligned with the
7 Company's generation asset strategy and, as a result, will provide economic value for
8 power supply customers in the energy and resource adequacy markets. Other capital
9 expenditures in generation are related to regulatory and environmental compliance, and
10 thus are not discretionary. Company witnesses Clark and Monroe provide additional
11 discussion in their direct testimony.

12 **SECTION IV**

13 **GENERATION O&M EXPENSE**

14 **Q. What are the major drivers in determining the O&M expense levels you are**
15 **sponsoring in this proceeding?**

16 A. The major drivers are identifying the funding needed to support the daily operation and
17 maintenance of the Company's fleet of generating facilities and identifying the funding
18 needed for certain internal organizations that support Generation Operations.

19 **Q. For purposes of your direct testimony in this case, what does the Generation O&M**
20 **cost represent?**

21 A. In addition to the Company's generation fleet, I am sponsoring the O&M expenses for the
22 Electric Supply Operations and PSCR organization, Electric Regulation and Strategy
23 Implementation organization, Financial Planning organization, Renewable Energy

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

Department, Contracts and Settlements organization, Generation Asset Management organization, Electric Sourcing and Resource Planning organization, and Enterprise Project Management and Environmental Services organization.

Q. Please describe Exhibit A-43 (RTB-4), page 1, Generation Operation and Maintenance Expenses.

A. Exhibit A-43 (RTB-4), page 1, identifies the actual 2023 through 12 Months Ending February 28, 2026 projected Generation O&M expenses. Specifically:

- Column (a) identifies each O&M expense category;
- Column (b) identifies the Actual 2023 Generation O&M expense as \$118,848,652;
- Column (c) identifies the 14-Month Projected Bridge Period Generation O&M expense as \$165,164,491; and
- Column (d) identifies the Projected Test Year Generation O&M expense as \$111,850,689.

HISTORICAL O&M EXPENSE

Q. How does Consumers Energy determine the level of Generation O&M spending?

A. Consumers Energy tracks the history and projects future maintenance needs of each generating unit. Personnel at the plants provide information on maintenance for each site or specific units. Once costs to operate and comply with regulations are prioritized, the Asset Strategy and Generation Planning organizations evaluate the plans required to maintain and/or improve the condition of the plant – weighing the estimated benefit to the customer for each project. Using this combination of information, a preliminary plan is prepared and reviewed to ensure high-priority issues are addressed and adequate resources and funding are available. After all appropriate levels of management have reviewed and

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 approved the maintenance plan, a schedule is created. The overall objective is the safe,
2 reliable, and cost-effective generation of electricity.

3 **Q. How are Generation O&M expenses categorized?**

4 A. Generation O&M expenses are categorized into four primary components – “Base,”
5 “Environmental Operations,” “Major Maintenance,” and “Retention and Separation.”

6 **Q. What are Base O&M expenses?**

7 A. Base O&M expenses are comprised of two categories – labor and non-labor. Labor is the
8 primary component and typically has a predictable, stable rate of increase. Because most
9 of the Company’s generating units have been in service for years, the Company has an
10 excellent basis upon which to make accurate forecasts. Non-labor expenses also tend to
11 increase at a predictable rate and include items required to operate the plants. These items
12 include but are not limited to: (1) fuel (diesel and gasoline) for equipment and vehicles;
13 (2) material; (3) tools; (4) cleaning supplies; (5) facilities; (6) security; and (7) road and
14 grounds maintenance.

15 **Q. Please explain how the 2023 Actual O&M expenses were developed.**

16 A. The 2023 Actual O&M expenses were taken from Consumers Energy’s internal accounting
17 records.

18 **Q. Please explain how the 14-month projected bridge period and projected test year Base**
19 **O&M expenses were determined.**

20 A. Base O&M expenses for the projected bridge period ending February 28, 2025, and
21 projected test year ending February 28, 2026 shown on Exhibit A-43 (RTB-4), page 1,
22 line 1, columns (c) and (d), were determined by considering staffing levels and historical
23 spending. Total O&M expense for the years 2023 through the projected test year

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 demonstrates average annual decreases of approximately 2.7%. As discussed later in this
2 direct testimony, this average annual decrease reflects a change in the mix of the
3 Company's owned generating assets as well as focused cost reductions. Exhibit A-43
4 (RTB-4), page 1, lines 3 and 4, identify Adjusted O&M expenses which are new or
5 projected to change from past years' expense levels. These include items that are required
6 by law to maintain environmental compliance, for the safety of employees, and to support
7 the reliability of service to customers, specifically, Environmental Operations and Major
8 Maintenance. Exhibit A-43 (RTB-4), page 1, line 5, identifies Adjusted O&M expenses
9 which are related to Retention and Separation expenses associated with the Karn and
10 Campbell sites. These expenses were required for the safe and reliable operation of Karn
11 Units 1 and 2 through their May 2023 retirement and are required for the continued safe
12 and reliable operation of Campbell Units 1, 2, and 3 through their May 2025 retirement.

13 **Q. How do the historical and projected test year O&M expense amounts compare to**
14 **prior years?**

15 A. The 2023 historical O&M expense amount of \$118.849 million and the projected test year
16 O&M expense amount of \$111.851 million compare quite favorably to the actual O&M
17 expense amounts for 2021 and 2022. The 2021 generation O&M expense amount was
18 \$155.204 million, and the 2022 generation O&M expense amount was \$150.031 million.
19 As I previously stated, the O&M expense reductions reflect a mix of generation asset
20 changes as well as other focused cost reductions.

21 **Q. Please explain Exhibit A-43 (RTB-4), page 2.**

22 A. Exhibit A-43 (RTB-4), page 2, presents the amounts of the projected O&M expenses that
23 were developed by applying either an inflation rate or contract rate to historical O&M

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 expense. Column (b) presents the historical O&M expense. Column (c) presents the
2 amount of the historical O&M amount to which an inflation rate or contract rate applies.
3 Columns (e) and (g) present the amounts to which an inflation rate or contract rate were
4 applied for each period, respectively. Columns (d), (f), and (h) present contract and
5 inflation increases for each respective period. Amounts that were projected using other
6 methods are included in column (i). Column (j) is the projected test year O&M and is the
7 sum of columns (b), (d), (f), (h), and (i).

8 **Q. Please explain how the various inflation and contract rates were applied to Labor,**
9 **Material, Contractor, and Non-Labor Other O&M expense on Exhibit A-43 (RTB-4),**
10 **page 2.**

11 A. The historical labor on line 1, column (b) reflects a combination of both Operating
12 Maintenance and Construction ("OM&C") and non-represented labor. Inflation rates of
13 2.4%, 2.2%, and 2.2% were applied to labor on line 1, material on line 2, contractor on
14 line 3, and non-labor other on line 4 to develop the annual increase amounts in columns (d),
15 (f), and (h).

16 **Q. Please discuss how the adjustments on Exhibit A-43 (RTB-4), page 2, column (i) were**
17 **determined.**

18 A. As previously discussed, the Company projects the future maintenance needs of each unit.
19 The test period projected O&M expense amount of \$111.851 million reflects that
20 evaluation. Within the test period projected amount of \$111.851 million, there are several
21 adjustments that result in a projected amount that differs from the amount that is calculated
22 based solely on inflation.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. Please discuss the adjustments that are reflected in the test year projected amount of**
2 **\$111.851 million.**

3 A. As previously discussed, the Settlement Agreement reached in the Company's 2018 IRP
4 reflects the retirement of Karn Units 1 and 2 on May 31, 2023 and the Settlement
5 Agreement reached in the 2021 IRP reflects the retirement of Campbell Units 1, 2, and 3
6 on May 31, 2025 and the addition of Covert Units 1, 2 and 3 on June 1, 2023.

7 **Q. Please discuss the decrease in O&M expense for Karn Units 1 and 2.**

8 A. The 2023 O&M expense for Karn reflects the fact that Karn Units 1 and 2 retired on
9 May 31, 2023, leaving only Karn Units 3 and 4 operational. The actual O&M expense for
10 the Karn site in 2023 was \$19.091 million versus the projected O&M for the test year at
11 \$13.106 million, with the biggest decrease reflected in base O&M. The 2023 environmental
12 operations expense for the Karn site was \$2.254 million and that has been reduced to
13 \$0.093 million in the projected test year. The 2023 base O&M expense was \$16.554
14 million whereas the projected test year base O&M drops to \$10.411 million. The Karn
15 major maintenance expense increases from \$0.283 million in 2023 to \$2.602 million in the
16 projected test year. This increase reflects the fact that the Company limited the amount of
17 major maintenance it planned for Karn Units 3 and 4 in 2023 since its 2021 IRP proposed
18 the coincident retirement of those units with Karn Units 1 and 2. When the 2021 IRP
19 settlement did not include Karn Units 3 and 4 retiring early, the Company needed to
20 perform the deferred major maintenance. A complete discussion of the test year major
21 maintenance for Karn Units 3 and 4 is described later in this direct testimony.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. Please discuss the decrease in O&M expense for Campbell Units 1, 2 and 3.**

2 A. The projected test year O&M expense for Campbell reflects the fact that the Campbell units
3 will only operate for three months, March through May 2025. The projected test year
4 expense for Campbell is \$13.935 million, a \$29.392 million reduction from the actual 2023
5 O&M expense of \$43.327 million. The biggest reduction from the historical year to the
6 projected test year is reflected in base O&M expense. The base O&M expense in the
7 projected test year is \$11.204 million, a \$23.653 million reduction from the historical
8 expense of \$34.858 million. The 2023 environmental operations expense for Campbell
9 was \$6.421 million and that has been reduced to \$2.186 million in the projected test year.
10 The Campbell major maintenance expense decreases from \$2.049 million in 2023 to only
11 \$0.545 million in the projected test year. A complete discussion of the test year major
12 maintenance for Karn Units 3 and 4 is described later in this direct testimony.

13 **Q. Please discuss the increase in O&M expense for Covert Units 1, 2, and 3.**

14 A. The 2023 O&M expense for Covert reflects the fact that the Company didn't take
15 ownership of the plant until June 1, 2023. The actual O&M expense for Covert Units 1, 2
16 and 3 in 2023 was \$7.413 million for the period from June 1, 2023 through December 31,
17 2023. The projected O&M for the test year is \$16.873 million, with the biggest increase
18 reflected in major maintenance. The 2023 expense for major maintenance was
19 \$2.144 million however it is project to total \$7.706 million in the test year. A complete
20 discussion of the test year major maintenance for Covert is described later in this direct
21 testimony. The 2023 environmental operations expense for Covert was \$0.072 million and
22 that expense is slightly lower at \$0.053 million in the projected test year. The base O&M

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

reflects an increase from \$5.196 million for the period from June 1, 2023 through December 31, 2023, to \$9.114 million in the test year.

Q. Are these generation asset changes the only reasons for the reduced O&M expense?

A. No. As I previously indicated, the Company has implemented other focused cost reductions that have directly impacted both the actual 2023 O&M expense and the projected test year expense. These cost reductions are primarily represented by headcount reductions during 2023 which have reduced both capital expenditures and O&M expense.

Q. Did the Company implement any projects that exclusively impacted capital expenditures?

A. Yes. The Company has implemented an improved governance process and key performance management metrics that will allow it to improve the efficiency of its capital expenditures. While the Company will not necessarily reduce its overall capital expenditures, it does expect that it will be able to accomplish more work with the same amount of capital.

Q. Did the Company implement any generation capital projects which reduce other customer costs?

A. Yes. The Company implemented a project at Jackson for the HRSG Burner Element Isolation Valves Addition (see Exhibit A-12 (RTB-3), Schedule B-5.2, page 7, line 9) in 2023 that will reduce both O&M and PSCR expense. The project involved the addition of automated low point drain and vent on each gas manifold, the addition of isolation valves on all burner elements, and burner management system ("BMS") logic changes to control drains and vents. The benefits of the project are the mitigation of condensation in burner piping and elements which leads to ignition failure, burner tube failure, and flame

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 impingement which would eventually lead to burner elements replacements because of
2 those issues. In addition, the project will increase generation production or capability due
3 to less duct burner down time because of the ability to isolate individual duct burners rather
4 than an entire HRSG. The increased generation production or capability is intended to
5 result in a reduction of PSCR costs, and the improved reliability of the burner elements
6 will result in reduced O&M expense.

7 **ENVIRONMENTAL OPERATIONS**

8 **Q. What are Environmental Operations expenses?**

9 A. Environmental Operations expenses consist of labor and materials supporting the
10 operations of the Company's AQCS. As Federal and State emissions standards require
11 cleaner air, Consumers Energy has installed AQCS to comply with these regulations.
12 Consumers Energy deployed its full suite of AQCS devices in 2016, with 2017 being the
13 first calendar year of operation. Now that the Company has experienced multiple calendar
14 years of operation, the Company anticipates these expenses to remain relatively consistent
15 going forward. However, because the cost to operate and maintain these critical pieces of
16 equipment is directly related to the operation of the coal-fired power plants they support,
17 yearly variances in the total Environmental Operations expense should be expected based
18 on the operation of the coal plants in a given year.

19 **Q. Please explain how the projected Environmental Operations expenses for the**
20 **projected bridge period ending February 28, 2025 and test year ending February 28,**
21 **2026 were calculated.**

22 A. Environmental Operations expenses are a combination of O&M costs related to the
23 environmental equipment at the Karn and Campbell sites. The operations component is

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 primarily calculated using labor costs for operations and environmental waste disposal.
2 The maintenance component is based on a combination of historical and estimated planned
3 maintenance costs on the specific components of environmental equipment. 2023 was the
4 seventh full year of operations of the environmental equipment at both Campbell and Karn,
5 and the Company now has robust historical data to use in projecting these expenses.
6 However, as reflected on Exhibit A-43 (RTB-4), page 1, line 3, columns (b) and (d), the
7 walk from the 2023 historical expense of \$9.225 million to the projected test year expense
8 of \$2.584 million reflects a cost reduction of \$6.641 million despite inflationary increases.
9 This cost reduction is a direct reflection of the retirement of Karn Units 1 and 2 on May 31,
10 2023 and the retirement of Campbell Units 1, 2 and 3 on May 31, 2025.

11 **MAJOR MAINTENANCE**

12 **Q. What are Major Maintenance expenses?**

13 A. Major Maintenance represents O&M projects that are based on asset condition or on
14 historic maintenance intervals over multiple years. To maintain and improve the
15 performance of generating fleet, the Company performs Major Maintenance on a regular
16 basis. However, completion of Major Maintenance work can be influenced by, among
17 other things, actual operations of the generating units, availability of parts and labor, and
18 energy market conditions.

19 **Q. Please explain how the Major Maintenance O&M expenses for the projected bridge**
20 **period ending February 28, 2025 and test year ending February 28, 2026 were**
21 **determined.**

22 A. Major Maintenance expenses are determined by tracking both the historical and future
23 maintenance needs for each site and unit, considering operation safety, unit reliability, and

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 maximum customer value. Individual projects are calculated in a manner similar to capital
2 projects, as discussed earlier in this direct testimony.

3 **Q. Please identify the 2023 test year Major Maintenance O&M expenses.**

4 A. The Company projects that it will incur \$31.203 million in Major Maintenance O&M
5 expenses during the test year, as identified by Exhibit A-43 (RTB-4), page 1, line 4,
6 column (d). Test year Major Maintenance expense by generating unit is presented on
7 Exhibit A-43 (RTB-4), page 3, column (d).

8 **Q. Why is Consumers Energy spending \$31.203 million in Total Major Maintenance**
9 **O&M expense during the projected test year ending February 28, 2026?**

10 A. The Company is spending the majority of its Total Major Maintenance expense during the
11 test year to maintain reliability. Reliability related Major Maintenance O&M expenses,
12 made predominantly during scheduled outages, allow the plants to avoid equipment issues
13 that would lead to more frequent random outages, exposing customers to potentially more
14 expensive replacement energy at market prices. Minimizing forced outages by maintaining
15 equipment improves the likelihood the unit will be available when needed and minimizing
16 damage that could result in the event of a catastrophic failure.

17 **Q. Are Major Maintenance expenses relatively consistent from year to year?**

18 A. No. Although the Company attempts to plan for controlled and consistent levels of Major
19 Maintenance, because Major Maintenance outages occur relatively infrequently, for an
20 individual unit, it is very possible to have significant year-by-year variations in the number,
21 duration, and magnitude of the required Major Maintenance work. Other factors such as
22 unforeseen equipment failure, emerging industry initiatives, unit dispatch, expected power

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 prices, unit performance, and simple timing variations can impact the cost and scheduling
2 of Major Maintenance.

3 **Q. Is it possible that changes to the Company's forecasted Major Maintenance plan**
4 **could occur?**

5 A. Yes. It is possible that the Company's forecasted Major Maintenance plan could change.
6 Equipment condition can change such that the timing of maintenance activities may need
7 to be accelerated or delayed. The Company attempts to make the best decision in balancing
8 the cost and risks associated with the operation of the equipment and attempts to minimize
9 the cost to customers. Factors such as weather, equipment and labor availability, energy
10 market conditions, and electrical system stability considerations can affect the actual
11 timing of an outage and maintenance spending.

12 **Q. Do Major Maintenance costs vary by individual generating unit(s)?**

13 A. Yes. As the Company's generating units vary in age, size, type, and design, so do the costs
14 to maintain these units. As an example, Major Maintenance of Campbell Unit 3 coal
15 pulverizers (785 MW) would be considerably larger in scope and cost than Major
16 Maintenance of Campbell Unit 1 coal pulverizers (260 MW), which is located on the same
17 site.

18 **Q. Is it common for an electric utility to have different sizes, types, designs, and dispatch**
19 **of generating units in its generation portfolio?**

20 A. Yes. Consumers Energy is not unique in that its fleet contains units of different size, type,
21 and design.

22 **Q. What are the categories of Major Maintenance?**

23 A. Major Maintenance is broken into two categories—outage and non-outage.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 **Q. Please describe what is included in the outage major maintenance O&M expense.**

2 A. Outage major maintenance O&M expenses are those associated with major overhauls and
3 require that the generating unit be removed from service for boiler and/or turbine
4 inspections and maintenance. These outages are typically scheduled on a periodic basis
5 and are required by law, insurance providers, and/or industry standards to ensure
6 operational safety and reliability. One example of a major maintenance outage is the
7 periodic disassembly and repair of turbine control and stop valves. The valves control the
8 amount of steam going to the turbine and are needed to control the unit output. During an
9 emergency situation, for example during unit electrical trip, the valves must react very
10 quickly to stop the steam going to the turbine to prevent it from overspeeding.
11 Overspeeding the turbine can result in severe mechanical damage resulting in a very long
12 duration outage to repair, further resulting in increased cost to customers for market priced
13 electricity during the outage. Periodic maintenance of turbine valves is required for
14 personnel and equipment safety. Maintaining the valves on a periodic basis ensures that
15 the clearances and internal components operate as designed and can reliably stop the
16 turbine quickly when needed to prevent turbine or generator damage.

17 **Q. Please describe the work completed in a boiler inspection.**

18 A. Boiler inspections assess the fire (outside) and steam (inside) sides of boiler tubing for
19 weaknesses that will ultimately result in water/steam leaks. After the boiler has been
20 properly opened, ventilated, and cleaned, scaffolding is constructed inside the boiler to
21 provide access to the boiler tubes. Inspections are completed using a number of different
22 methods – visual, non-destructive, and destructive. Visual and non-destructive testing are
23 the most common methods of inspection. Non-destructive testing incorporates the use of

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 ultrasonic, x-ray, magnetic particle, or like technologies to measure pipe wall thickness.
2 Boiler tubes that are in poor condition or exceed minimum wall thickness are repaired or
3 replaced. After all repairs are complete, boiler tubes are pressure tested. Each boiler is
4 inspected on a specific time schedule, with a one-, two-, or three-year maximum interval.
5 Internal components with known problems are inspected more frequently. External
6 inspections are performed daily by Generation Operations and annually by state inspectors.

7 **Q. Please describe the work completed in a turbine inspection.**

8 A. Turbine inspections consist of disassembling, inspecting, and cleaning the different
9 components of the turbine. During the inspection, worn or damaged parts are repaired or
10 replaced to specific tolerances. Because of the extreme conditions under which these units
11 operate, the demand for uninterrupted power, and dangers associated with operating these
12 large pieces of equipment, industry standards recommend that inspections be completed
13 every seven years.

14 **Q. Please define non-outage maintenance.**

15 A. Non-outage maintenance O&M costs typically do not require the generating unit be
16 removed from service, but they are still critical to the operation of the unit. An example of
17 non-outage maintenance is Mill/Pulverizer maintenance.

18 **Campbell Units 1 and 2 Major Maintenance**

19 **Q. Please describe Campbell Units 1 and 2 Major Maintenance expenses for the**
20 **projected test year ending February 28, 2026.**

21 A. As shown on Exhibit A-43 (RTB-4), page 3, line 1, column (d), Campbell Units 1 and 2
22 Major Maintenance expense is forecasted to be \$0.268 million in the projected test year
23 ending February 28, 2026, and includes:

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

- Campbell Units 1 and 2 Periodic Outage Major Maintenance (\$60,000). The scope of this project is to perform boiler maintenance activities during outages during the projected test year. Expenses include planning, engineering services, materials, and overtime labor;
- Campbell Unit 1 Pulverizer Maintenance (\$60,000). The scope of this project is the procurement of required parts to support the on-going maintenance of the coal pulverizers to maintain their operability. This maintenance work will allow the Company to keep the minimum number of mills in service and, as a result, avoid unit derates due to degraded conditions. The performance of this work will result in safe, reliable, and efficient unit operation;
- Campbell Unit 2 Mill Maintenance — Parts Only Boiler Plant Equipment (\$60,000). The scope of this project is the procurement of required parts to support the on-going maintenance on the coal mill/pulverizers to maintain their operability. This maintenance work will allow the Company to keep the minimum number of mills in service and, as a result, avoid unit derates due to degraded conditions. The performance of this work will result in safe, reliable, and efficient unit operation; and
- One project common to Campbell Units 1 and 2 totaling \$30,010 and two Site Common Major Maintenance projects totaling \$135,577 which are shared with Campbell Unit 3. Campbell Units 1 and 2 receive a 43% allocation totaling \$58,298 and Campbell Unit 3 receives a 57% allocation or \$77,279. These projects, all of which represent \$92,377 or less in expense, include fuel handling dumper outage repairs, deepwater intake screen inspection, and SDA O&M costs.

Campbell Unit 3 Major Maintenance

Q. Please describe Campbell Unit 3 Major Maintenance expenses for the projected test year ending February 28, 2026.

A. As shown on Exhibit A-43 (RTB-4), page 3, line 2, column (d), Campbell Unit 3 Major Maintenance expense is forecasted to be \$0.277 million in the test year and includes:

- Campbell Unit 3 Pulverizer Maintenance — Parts Only Mills-Boiler Plant Equipment (\$60,000). The scope of this project is the procurement of required parts to support the on-going maintenance on the coal pulverizers to maintain their operability. This maintenance work will allow the Company to keep the minimum number of mills in service and, as a result, avoid unit derates due to degraded conditions. The performance of this work will result in safe, reliable, and efficient unit operation;

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

- Campbell Unit 3 Periodic Outage Major Maintenance (\$94,384). The scope of this project is to perform boiler, turbine, and BOP maintenance activities during outages during the project test year. Expenses include planning, engineering services, materials, and overtime labor. Performance of this work will result in improved unit reliability and performance; and
- One other Campbell Unit 3 project totaling \$45,000 and two Site Commons projects that I discussed previously with the Campbell Unit 3 allocation totaling \$77,279.

Karn Units 1 and 2 Major Maintenance

Q. Please describe Karn Units 1 and 2 Major Maintenance expenses for the projected test year ending February 28, 2026.

A. As shown on Exhibit A-43 (RTB-4), page 3, line 3, column (d), Karn Units 1 and 2 Major Maintenance expense is forecasted to be \$0.100 million in the projected test year ending February 28, 2026. This forecasted expense for the projected test year ending February 28, 2026 is for vegetation removal.

Covert Plant Major Maintenance

Q. Please describe the Covert Plant Major Maintenance expenses for the projected test year ending February 28, 2026.

A. As shown on Exhibit A-43 (RTB-4), page 3, line 8, column (d), the Covert Plant Major Maintenance expense is forecasted to be \$7.706 million in the projected test year ending February 28, 2026, and includes:

- Covert Plant LTSA Major Maintenance (\$2,611,312). This is the major maintenance portion of the Mitsubishi negotiated services that cover the planned normal maintenance of each generating unit. The projected major maintenance expenses are based upon variable fees paid to Mitsubishi for maintenance services which are based on an effective fired hours basis pursuant to the LTSA. Unlike the GE LTSAs for the Jackson and Zeeland plants, there are no milestone payments associated with the fee structure for the Mitsubishi LTSA. Based on the OEM's operating and historical experience, if the Company executes the normal planned maintenance and inspections according to the recommended schedules, the Company will mitigate unexpected pre-mature failures of the equipment. This will help maximize availability and,

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

as a result, optimize customer value for the site. Normal maintenance will ensure the Company continues reliable operation of the units;

- Covert Plant LTSA extra work Major Maintenance (\$1,492,500). This is the major maintenance portion of the Mitsubishi negotiated services that are not covered in the planned normal maintenance of each generating unit. Based on historical outage experience, there are typical discovery items found on this style of gas turbines that are not part of the LTSA planned maintenance scope. Some of the typical items not covered under the LTSA that need to be addressed are labor and material to replace the following: blading, ammonia delivery system, SCR catalyst, turbine rotors, cooling towers, and turbine cooling air cooler;
- Covert Plant Capacity Factor Used For Water and Chemicals (\$1,216,667). This item provides for the city water used by the Covert Plant, and for the chemicals required to operate the water purification systems that are used to purify the makeup water prior to use;
- Reverse Osmosis System (“RO”), operation agreement (\$461,667). The scope of this project is to contract with a third party to operate and maintain the RO system;
- Covert Plant Base Outage Funding – Boiler plant equipment (\$483,333). Base outage capital covers the replacement parts and issues found during turbine/generator inspections and the major discovery issues found during annual unit outages;
- Covert Plant HEPS/FAC/DAST Inspections (\$913,333). This project will include the performance of regulatory required high energy piping surveillance (“HEPS”), deaerator and its storage tank (“DAST”) mid cycle inspection, and flow accelerated corrosion (“FAC”) inspection; and
- Four additional projects for Covert totaling \$527,500 in expenses, with each individual project representing \$275,000 or less in expenses. These projects include NERC relay and DC testing, ITC switchyard upgrades, gas turbine exhaust expansion joints repairs, and 345 kV transformer bushing power factor testing.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

Karn Units 3 and 4 Major Maintenance

Q. Please describe Karn Units 3 and 4 Major Maintenance expenses for the projected test year ending February 28, 2026.

A. As shown on Exhibit A-43 (RTB-4), page 3, line 4, column (d), Karn Units 3 and 4 Major Maintenance expense is forecasted to be \$2.502 million in the projected test year ending February 28, 2026, and includes:

- Karn Units 3 and 4 Periodic Outage Major Maintenance (\$355,833). The scope of this project is to perform boiler maintenance activities during scheduled periodic outages during the projected test year. Expenses include planning, engineering services, materials, and overtime labor;
- Karn Units 3 and 4 HEPS/FAC/DAST Inspections (\$375,000 per unit). This project will include the performance of regulatory required inspections;
- Karn Unit 3 Turbine Valve Inspections (\$241,667). The scope of this project is to perform the Karn Unit 3 turbine valve inspections;
- Karn Unit 4 Main Transformer Bladder Replacement (\$208,333). The scope of this project is to replace the bladder. The main transformer conservator bladder is broken and open to atmosphere, making the oil susceptible to air bubbles and increasing the risk of transformer failure; and
- Fourteen additional projects for Karn Units 3 and 4 totaling \$946,333 in expenses, with each individual project representing \$150,000 or less in expenses. These projects include critical motor major maintenance, forced draft and induced draft fan alignments, station power relay maintenance, and opacity critical equipment repairs.

Zeeland Plant Major Maintenance

Q. Please describe Zeeland Plant Major Maintenance expenses for the projected test year ending February 28, 2026.

A. As shown on Exhibit A-43 (RTB-4), page 3, line 6, column (d), Zeeland Plant Major Maintenance expense is forecasted to be \$5.232 million in the projected test year ending February 28, 2026, and includes:

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

- Zeeland Plant LTSA — Running Maintenance Contract (\$2,048,614). Consumers Energy has a long-term maintenance agreement with GE to perform the major maintenance and capital repairs necessary to maintain unit reliability. This item represents the O&M component of that service agreement;
- Zeeland Plant Capacity Factor Used for Water and Chemicals (\$1,255,417). This item provides for the city water used by the Zeeland Plant, and for the chemicals required to operate the water purification systems that are used to purify the makeup water prior to use;
- Base Outage — Boiler Plant Equipment (\$558,333). During planned and scheduled periodic outages, inspections and repairs are performed. Base boiler maintenance and outage is needed to complete condition assessment inspections of the boiler and major components, complete repairs on valves and large plant equipment, and complete repairs that are identified during shutdowns and condition assessments;
- Zeeland Site Commons Deep Well Injection Cleaning (\$323,333). The scope of this project is the third-party cleaning of the well. Cleaning the well allows Zeeland to continue to operate in the most economical means practical and maintain the required plant equipment. Failure to clean the well would require the plant to blowdown all cooling tower concentrate to the city sewer at a considerable expense. This activity is performed on a triennial basis; and
- Fourteen additional projects totaling \$1,045,984 in expenses, with each individual project representing \$208,333 or less in expenses. These include excitation and isolation transformer testing and maintenance, HEPS, FAC inspection, large oil-filled transformer maintenance, breaker maintenance, and NERC-required relay testing.

Jackson Plant Major Maintenance

Q. Please describe Jackson Plant Major Maintenance expenses for the projected test year ending February 28, 2026.

A. As shown on Exhibit A-43 (RTB-4), page 3, line 7, column (d), Jackson Plant Major Maintenance expense is forecasted to be \$3.852 million in the projected test year ending February 28, 2026. This forecasted expense consists of:

- Jackson Plant Capacity Factor Used for Water and Chemicals (\$1,900,000). This item provides for the city water used by the Jackson Plant, and for the chemicals required to operate the water purification systems that are used to purify the makeup water prior to use. The projected expense is based upon

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

historical monthly invoice values as well as consideration of the capital project previously discussed in this testimony for site generating water;

- Jackson Plant Non-LTSA Turbine and jet engine repairs (\$391,667). The scope of this major maintenance is to perform jet engine repairs including bushing replacements every 12,000 hours;
- Jackson Plant LTSA — Running Maintenance Contract (\$508,333). Consumers Energy has a long-term maintenance agreement with GE to perform the major maintenance and capital repairs necessary to maintain unit reliability. This item represents the O&M component of that service agreement;
- Jackson Plant Base Outage - Boiler plant equipment (\$250,000). During planned and scheduled periodic outages, inspections and repairs are performed. Base boiler maintenance and outage is needed to complete condition assessment inspections of the boiler and major components, complete repairs on valves and large plant equipment, and complete repairs that are identified during shutdowns and condition assessments; and
- Ten additional projects totaling \$801,565 with each individual project representing \$241,853 or less in expenses. These include HEPS, FAC, pre-Filter replacement, high voltage maintenance and NERC testing, and filter house roof maintenance.

LPS Major Maintenance

Q. Please describe LPS Major Maintenance expenses for the projected test year ending February 28, 2026.

A. As shown on Exhibit A-43 (RTB-4), page 3, line 9, column (d), LPS Major Maintenance expense is forecasted to be \$4.445 million in the projected test year ending February 28, 2026, including:

- Fish Barrier Net - Installation, cleaning, and repairs and removal (\$2,140,000). This is a FERC regulatory requirement. The net is installed annually and maintained to meet FERC license requirements (and the requirements of a Settlement Agreement with federal and state natural resource agencies) and minimizes the impact of LPS on fish in Lake Michigan;
- Nine Year Unit Mechanical Interval Inspection and Replacement (\$570,000). The scope of this project is to perform replacement of common wear elements and consumable items associated with the pump/turbine units. This work will

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 include the first nine-year maintenance interval for each of the six units as well
2 as up front planning and procurement funding in the first year;

- 3 • Reservoir remediation (\$535,833). This is FERC required and related to dam
4 safety to ensure the Company maintains the integrity of the Ludington pond;
5 and
- 6 • Twenty-two additional projects totaling \$1,199,508, with each individual
7 project representing less than \$161,000 in expenses. These include asphalt liner
8 inspection repairs, penstock condition assessment and monitoring study,
9 Depression Air Compressor Maintenance, periodic outage inspections and
10 non-destructive examination, lube oil room repair, Polychlorinated Biphenyl
11 removal and disposal, and powerhouse slope terrace drain cleanout.

12 **Hydro Major Maintenance**

13 **Q. Please describe Hydro Major Maintenance expenses for the projected test year ending**
14 **February 28, 2026.**

15 A. As shown on Exhibit A-43 (RTB-4), page 3, line 10, column (d), Hydro Major
16 Maintenance expense is forecasted to be \$5.776 million in the projected test year ending
17 February 28, 2026, and includes:

- 18 • Hydro License Initiatives (\$2,158,667). A FERC requirement, this item
19 resulted from the relicensing of Au Sable, Manistee, and Muskegon River dams,
20 with the main result being that the Company has annual license commitments.
21 License commitments include some recreation, fish payments, and water
22 quality such as upwelling systems licenses;
- 23 • Hydro annual FERC Dam Safety Requirements including Part 12 Inspections
24 (\$1,446,475). The scope of this project is to perform the FERC-required dam
25 safety inspections on an annual basis, and the FERC-required Part 12
26 inspections on each dam every five years (FERC Part 12 regulations are
27 discussed in Mr. Monroe's direct testimony). A similar level of expense is
28 budgeted annually from 2025 through 2028;
- 29 • Hardy Intake Tower Brick Repair (\$241,667). The scope of this project is to
30 replace all the deteriorated interior brick inside the intake tower for the full
31 height. The Hardy intake tower brickwork has been slowly deteriorating for the
32 last few years. The bricks are crumbling to the touch and has areas with
33 significant delamination throughout the entire height of the walls (34ft). If the
34 deterioration becomes significant enough, it may impact the headgate hoists and
35 the head gates installation safety of the Operations staff;

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

- Tippy Spillway Chamber Inspections and Repairs (\$202,500). The project scope includes performing spillway chamber inspections, engineering for spillway chamber repairs and construction of repairs. The Tippy spillway chambers are hollow chambers underneath the spillway. In the spillway chambers, the concrete is deteriorated, rebar is exposed, and there is seepage present;
- Hydro Concrete Repairs (\$206,958). The scope of this project is to make necessary repairs to deteriorating concrete at all 13 River Hydro facilities. This budgeted amount will allow for the performance of necessary repairs which are identified after spring flows or general deterioration. The identification of large concrete repairs will be considered in the annual budgeting process; and
- Twenty-six additional projects totaling \$1,520,083 with each individual project representing \$150,000 or less in expenses. These projects include Cooke Powerhouse Divider Pier, Foote Auxiliary Spillway Pilot Channel and Embankment Crest Grading Project, Tippy Log Chute Repairs, base outage funding, headgate evaluation and repairs, relief well piezometer cleaning, and condition/risk assessments.

Solar Major Maintenance

Q. Please describe Solar Major Maintenance expenses for the projected test year ending February 28, 2026.

A. As shown on Exhibit A-43 (RTB-4), page 3, line 11, column (d), Solar Major Maintenance expense is forecasted to be \$0.677 million in the projected test year ending February 28, 2026 and includes three projects, all to provide IT support for the Mustang Mile, Muskegon Solar, and Washtenaw Solar IRP solicitation projects. For each of the solar sites, the major maintenance funding includes plant setup in SAP, and payment of the OSISoft PI Historian and Bazefield SCADA overlay license fees.

Admin and Other Major Maintenance

Q. Please describe Admin and Other Major Maintenance expenses for the projected test year ending February 28, 2026.

A. As shown on Exhibit A-43 (RTB-4), page 3, line 12, column (d), Admin and Other Major Maintenance expense is forecasted to be \$0.150 million in the projected test year ending

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

February 28, 2026 and includes one project: Generation control systems cyber maintenance software support. Specifically, this project provides funding for software maintenance contracts from multiple vendor systems that are not part of the DCS control vendor service contracts.

Classic 7 Major Maintenance

Q. Please describe Classic 7 (B.C. Cobb (“Cobb”), J.C. Weadock (“Weadock”), and J.R. Whiting (“Whiting”) units) Major Maintenance expenses for the projected test year ending February 28, 2026.

A. As shown on Exhibit A-43 (RTB-4), page 3, line 5, column (d), Classic 7 Major Maintenance expense is forecasted to be \$0.218 million in the projected test year ending February 28, 2026.

Q. Why is Consumers Energy projecting to spend \$0.218 million in Major Maintenance on the Classic 7 units in the projected test year ending February 28, 2026?

A. Although the Classic 7 units were retired in 2016, environmental regulations require the continued maintenance of the on-site ash ponds, which includes Cobb landfill and ash pond O&M, Weadock landfill license and inspections, and Whiting ash pond post-closure care.

**KARN AND CAMPBELL RETENTION AND SEPARATION PLAN
EXPENSE**

Q. What are the projected costs for the Company’s Karn and Campbell Retention and Separation plans?

A. As reflected on Exhibit A-43 (RTB-4), page 1, line 5, the Company incurred actual expense of \$17.348 million in 2023, and is projecting expense of \$11.158 million in the 14-month projected bridge period, and \$4.621 million in the projected test year. The actual 2023 expense of \$17.348 million is based upon expense of \$1.501 million for Karn and

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 \$15.847 million for Campbell. The 14-month projected bridge period expense of
2 \$11.158 million is entirely based upon expense of \$11.158 million for Campbell. The
3 projected test year expense of \$4.621 million is based upon expense of \$4.621 million for
4 Campbell.

5 **Q. Is the Company requesting O&M recovery of the \$4.621 million projected amount**
6 **for the projected test year?**

7 A. No. The Company is not requesting approval of this projected amount in Generation O&M
8 expense. The Company received approval in electric rate case, Case No. U-20697, to defer
9 the recovery of the Karn Retention and Separation O&M amounts for 2021 through 2023.
10 The Company received approval to defer the recovery of the Campbell retention and
11 separation amounts in the Settlement Agreement in its 2021 IRP. As such, the projected
12 amounts for 2023 through the projected test year ending February 28, 2026 are not included
13 in the Total O&M amounts on Exhibit A-43 (RTB-4), page 1, line 6, columns (b), (c) and
14 (d). Company witness Aponte supports regulatory asset treatment of these expenses in her
15 direct testimony.

16 **Q. Please describe the Karn retention and separation plan.**

17 A. The Karn retention and separation plan is a people strategy that the Company has
18 implemented to ensure that it could retain the necessary qualified employees to operate
19 Karn Units 1 and 2 through their retirement date in May 2023, as well as during the cold
20 and dark time period following retirement. The cold and dark condition refers to the period
21 following plant retirement and prior to plant decommissioning. During this period, limited
22 environmental remediation and perhaps partial demolition is performed. The facility may
23 be physically secured with fencing and other measures to prevent vandalism or theft so as

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 to limit liability risks. On June 7, 2019, the MPSC approved the Company's 2018 IRP
2 Settlement Agreement, which included the retirement of Karn Units 1 and 2 in May 2023.
3 The Company's IRP included detailed support of the Company's need to implement a
4 retention and separation plan to ensure that it could operate the plants safely and reliably
5 through their retirement date.

6 **Q. What is the purpose of the retention component of the Company's plan?**

7 A. The Company had a strong interest in keeping qualified employees working at Karn Units 1
8 and 2 through their retirement date to ensure safe and reliable operations. The retention
9 component will allow the Company to retain employees that may seek employment at other
10 Company locations or outside of the Company. The Company's ability to hire new
11 employees at Karn Units 1 and 2 became increasingly difficult given the short remaining
12 lifespan of the units and, to the extent that the Company had the ability to hire new
13 employees, the training time necessary for any new hires provided a significant challenge
14 to operating the units both safely and reliably. The retention component utilized the best
15 practices that the Company employed in retiring the Classic 7.

16 **Q. What is the purpose of the separation component of the Company's plan?**

17 A. Now that Karn Units 1 and 2 are retired, the Company is following the terms of the
18 collective bargaining agreement for OM&C employees represented by the Utility Workers
19 Union of America ("UWUA"), and the terms of the employee handbook policy and
20 separation plan for non-represented exempt and non-exempt employees. The structure and
21 amount of the severance offers varies based on employee salary and classification due to
22 differences in the terms of the separation plan covering non-represented employees and the
23 bargaining agreement for UWUA-represented employees. In the event that exempt or

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 non-exempt employees cannot find placement within the Company within 60 miles from
2 their current location, they will be offered involuntary severance in accordance with the
3 terms of the Company's Salaried Separation Plan. The Company's Working Agreement
4 with the UWUA governs separation for OM&C employees who elect to leave the Company
5 rather than accept a new position as well as relocation expenses if they accept a position
6 more than 60 miles away from their current location.

7 **Q. What are the benefit types associated with the Karn retention and separation plan?**

8 A. The Karn retention and separation plan includes three benefit types: retention benefits,
9 severance benefits, and relocation and moving costs.

10 **Q. Please describe the retention benefits associated with the Karn retention and**
11 **separation plan.**

12 A. The retention benefits associated with the Karn retention and separation plan include three
13 payment components: a signing incentive, annual incentives, and a final retention
14 incentive.

15 Employees received a signing incentive equal to 15% of their base pay if they
16 signed a retention agreement in October 2019. By signing the retention agreement, the
17 employee agreed to forfeit their transfer rights under the current working agreement (for
18 union employees) or under Company policy (for exempt and non-exempt employees). The
19 employee had to stay at Karn until October 31, 2020 to receive the payment; if the
20 employee stayed until that date, the incentive was paid out to the employee within 30 days.
21 If the employee separated from the Company before October 31, 2020, the employee
22 forfeited the signing incentive.

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 Employees receive an annual incentive which graduated from 20% to 30% of their
2 base pay for service each November in years 2019, 2020, and 2021, for staying at Karn and
3 rendering service for the next 12 months. The employee had to stay at Karn until
4 October 31 of the following year to receive the payment; if the employee stayed until that
5 date, the incentive was paid out to the employee within 30 days. If the employee separated
6 from the Company before October 31 of the next year, the employee forfeited the annual
7 incentive. Eligible employees received their first annual incentive payment in November
8 2020, a second payment in November 2021, and a third payment in November 2022.

9 Employees received their final retention incentive equal to 60% of their base pay
10 following plant retirement if the employee was still at Karn. The payment was intended to
11 incentivize employees to stay until the plant goes cold and dark and compensate employees
12 for the service they rendered for the eight months (November 2022 through June 2023)
13 prior to the payment.

14 **Q. Please describe the severance benefits associated with the Karn retention and**
15 **separation plan.**

16 A. The severance benefits associated with the Karn retention and separation plan includes
17 initial recognition of a severance benefit to be paid, recognition of additional severance
18 earned (one week of pay per year of service), and recognition of the accretion of a final
19 severance benefit.

20 **Q. Why does the Company anticipate the need to make severance payments associated**
21 **with the retirement of Karn Units 1 and 2?**

22 A. The Company is proud of the fact that following the retirement of the Classic 7 in 2016,
23 all Company employees that desired to continue employment with the Company were able

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 to do so. However, the Company is also aware of the fact that it has fewer Company
2 locations (11 within 60 miles of the Karn site) to which employees can relocate, than it did
3 in 2016. As such, the Company anticipated the need to make severance payments to those
4 employees that cannot find placement. As I previously stated, the Company is following
5 the terms of the collective bargaining agreement for OM&C employees represented by the
6 UWUA, and the terms of the employee handbook policy and separation plan for
7 non-represented exempt and non-exempt employees.

8 **Q. Please explain the relevant details of the collective bargaining agreement for OM&C**
9 **employees.**

10 A. The collective bargaining agreement for OM&C employees, in Article VII, Section 17, and
11 the Generation Operations Coal Closing Agreement provide that employees will be placed
12 in either a corresponding position, or if none exists, in a vacant position he/she is qualified
13 to perform within 60 miles of his/her current headquarters. Per Article XVII of the
14 collective bargaining agreement, employees who are released due to lack of work, and are
15 not placed as described above, are provided a separation allowance consisting of straight
16 time pay for five regular workdays for each year of continuous service with the
17 Company. Due to the lack of Company locations within 60 miles of Karn Units 1 and 2,
18 as described above, it was anticipated that some employees would be eligible for a
19 separation allowance.

20 **Q. Please describe the Campbell retention plan.**

21 A. The Campbell retention plan is a people strategy that the Company has proposed in its 2021
22 IRP. As previously discussed, the Company's 2021 IRP PCA reflects the retirement of
23 Campbell Units 1, 2, and 3 on May 31, 2025. This retention plan was proposed in order to

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 retain employees through the closure of the three Campbell units. This strategy is
2 necessary to ensure that the Company can operate the Campbell units safely and reliably
3 through their retirement date. This incentive program is the same program that is currently
4 in place for employees at the Karn site.

5 **Q. What is the purpose of the retention component of the Company's plan?**

6 A. For similar reasons described in the Karn retention plan, the Company has a strong interest
7 in keeping qualified employees working at the Campbell site through their retirement date
8 to ensure safe and reliable operations. The retention component will allow the Company
9 to retain employees that may seek employment at other Company locations or outside of
10 the Company. Similar to the situation at the Karn site, it will be increasingly difficult to
11 hire new employees at the Campbell site given the short remaining lifespan of the units
12 and, to the extent that the Company has the ability to hire new employees, the training time
13 necessary for any new hires will provide a significant challenge to operating the three units
14 both safely and reliably.

15 **Q. What is the purpose of the separation component of the Company's plan?**

16 A. When the Campbell units are retired, the Company plans to follow the terms of the
17 collective bargaining agreement for OM&C employees represented by the UWUA, and the
18 terms of the employee handbook policy and separation plan for non-represented exempt
19 and non-exempt employees. The structure and amount of the severance offers will vary
20 based on employee salary and classification due to differences in the terms of the separation
21 plan covering non-represented employees and the bargaining agreement for
22 UWUA-represented employees. In the event that exempt or non-exempt employees cannot
23 find placement within the Company within 60 miles from their current location, they will

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 be offered involuntary severance in accordance with the terms of the Company's Salaried
2 Separation Plan. The Company's Working Agreement with the UWUA governs separation
3 for OM&C employees who elect to leave the Company rather than accept a new position
4 as well as relocation expenses if they accept a position more than 60 miles away from their
5 current location.

6 **Q. What are the benefit types associated with the Campbell retention plan?**

7 A. Similar to the Karn retention and separation plan, the Campbell retention plan includes
8 three benefit types: retention benefits, severance benefits, and relocation and moving costs.

9 **Q. Please describe the retention benefits associated with the Campbell retention plan.**

10 A. The retention benefits associated with the Campbell retention plan include three payment
11 components: a signing incentive, periodic incentives, and a final retention incentive. The
12 timeline for retention benefits reflects approval of the Settlement Agreement in the
13 Company's 2021 IRP in June 2022.

14 Employees received a signing incentive equal to 15% of their base pay if they
15 signed a retention agreement in July 2022. By signing the retention agreement, the
16 employee agreed to forfeit their transfer rights under the current working agreement (for
17 union employees) or under Company policy (for exempt and non-exempt employees). The
18 employee had to stay at Campbell until October 31, 2022 to receive the payment; if the
19 employee stayed until that date, the incentive was paid out to the employee within 30 days.
20 If the employee separated from the Company before October 31, 2022, the employee
21 forfeited the signing incentive.

22 Employees receive a periodic incentive which graduates from 20% to 30% of their
23 base pay for service each November in years 2022, 2023, and 2024, for staying at Campbell

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 and rendering service for a certain period. Specifically, for service provided July 2022
2 through October 2022, employees received 20% of their base pay. For service provided
3 November 2022 through October 2023, employees received 25% of base pay. For service
4 provided November 2023 through October 2024, employees will receive 30% of base pay.
5 The employee must stay at Campbell until October 31 of the given year to receive the
6 payment; if the employee stays until that date, the incentive was/will be paid out to the
7 employee within 30 days. If the employee separates from the Company before October 31
8 of the given year, the employee forfeits the annual incentive.

9 Employees receive a final retention incentive equal to 60% of their base pay on or
10 about October 31, 2025, if the employee is still at Campbell. The payment is intended to
11 incentivize employees to stay until the plant goes cold and dark and compensate employees
12 for the service they rendered for the 12 months prior to the payment.

13 **Q. Please describe the severance benefits associated with the Campbell retention plan.**

14 A. The severance benefits associated with the Campbell retention plan include initial
15 recognition of a severance benefit to be paid, recognition of additional severance earned
16 (one week of pay per year of service), and recognition of the accretion of a final severance
17 benefit.

18 **Q. Why does the Company anticipate the need to make severance payments associated**
19 **with the retirement of Campbell Units 1, 2, and 3?**

20 A. The Company is proud of the fact that following the retirement of the Classic 7 in 2016,
21 all Company employees that desired to continue employment with the Company were able
22 to do so. However, the Company is also aware of the fact that it has fewer Company
23 locations (seven within 60 miles of the Campbell site) to which employees can relocate,

RICHARD T. BLUMENSTOCK
U-21585 DIRECT TESTIMONY

1 than it did in 2016. In addition, the Company will also have retired at least two of the Karn
2 generating units in 2023, thereby further reducing the available positions. As such, the
3 Company has anticipated the need to make severance payments to those employees that
4 cannot find placement. As I previously stated, the Company plans to follow the terms of
5 the collective bargaining agreement for OM&C employees represented by the UWUA, and
6 the terms of the employee handbook policy and separation plan for non-represented exempt
7 and non-exempt employees, as previously discussed for the Karn retention and separation
8 plan.

9 **Q. Does this conclude your direct testimony?**

10 **A.** Yes, it does.

Attachment HH

DOE, Special Environmental Analysis (2006)

Special Environmental Analysis

**For Actions Taken under U.S. Department of Energy
Emergency Orders Regarding Operation of the
Potomac River Generating
Station in Alexandria, Virginia**



November 2006

U.S. Department of Energy
Washington, D.C.

COVER SHEET

Responsible Agency:

U.S. Department of Energy (DOE)

Cooperating Agency:

U.S. Environmental Protection Agency

Title:

Special Environmental Analysis for Actions Taken under DOE Emergency Orders Regarding Operation of the Potomac River Generating Station in Alexandria, Virginia

Location:

Alexandria, VA, and Washington, DC

Contacts:

For further information on this Special Environmental Analysis (SEA) or to provide comments contact:

Mr. Anthony J. Como
SEA Document Manager
U.S. Department of Energy
1000 Independence Avenue, SW
Washington, DC 20585
Call (202) 586-5935
Fax (202) 287-5736
email: anthony.como@hq.doe.gov

For further information on the DOE National Environmental Policy Act process contact:

Ms. Carol Borgstrom, Director
Office of NEPA Policy and Compliance
U.S. Department of Energy
1000 Independence Avenue, SW
Washington, DC 20585
Call (202) 586-4600 or leave message
at 1-800-472-2756
Fax (202) 586-7031
e-mail: askNEPA@hq.doe.gov

Abstract:

On December 20, 2005, the Secretary of Energy issued an emergency order, DOE Order 202-05-03, requiring Mirant's Potomac River Generating Station in Alexandria, Virginia, to operate under limited circumstances. On September 28, 2006, the Secretary extended the Order, including all of its terms and conditions, DOE Order 202-06-2, until December 1, 2006. This SEA includes descriptions of the DOE emergency orders; assessments of the direct, indirect, and cumulative impacts resulting from the emergency orders; and descriptions of alternative actions for potential future decision-making that include mitigation. This SEA covers a period of about 24 months beginning in December 2005.

Public Comment:

Simultaneously with issuance of this SEA, the Secretary is issuing another temporary extension of the emergency order, including all of its terms and conditions, DOE Order 202-07-1, until February 1, 2007. DOE is placing the document on DOE's internet websites (<http://www.oe.energy.gov/permitting/372.htm> and <http://www.eh.doe.gov/nepa/documents/pub.html>) and making it available at the public reading room at DOE headquarters. An announcement of the availability of the SEA is also being made in the *Federal Register*. Comments on this SEA are due on January 8, 2007, and will be considered in any future decision-making on this matter. Due to postal security procedures, comments sent through U.S. mail may be delayed, and DOE recommends that commentors use other means.

SUMMARY

On December 20, 2005, the Secretary of Energy issued an emergency order (“DOE Order” or “Order”) to Mirant Potomac River, LLC (Mirant) pursuant to Section 202(c) of the Federal Power Act (FPA). The Order directed Mirant to operate its Potomac River Generating Station (“the Plant”) in Alexandria, Virginia, in specific and limited circumstances in order to reduce the risk of a blackout in the Central Washington, D.C. area, while avoiding, to the extent possible, exceedances of the National Ambient Air Quality Standards (NAAQS) (text box). The Order was to expire on September 30, 2006, but DOE issued a temporary extension of the Order, until December 1, 2006, to allow for completion of this Special Environmental Analysis (SEA). This SEA assesses impacts resulting from the Orders and from potential future alternative actions DOE may take in this matter. DOE is accepting public comment on this SEA and will consider all comments submitted in any future decision-making.

In emergency situations, pursuant to 40 CFR 1506.11, the Council on Environmental Quality’s (CEQ) National Environmental Policy Act of 1969 (NEPA) regulations call for agencies to consult with CEQ to determine what alternative arrangements the agency will take in lieu of preparing an environmental impact statement (EIS) that might otherwise be required for the relevant action. DOE is issuing this SEA in compliance with the “alternative arrangements” plan agreed upon with CEQ.

National Ambient Air Quality Standards (NAAQS)

The Clean Air Act, which was last amended in 1990, requires the Environmental Protection Agency (EPA) to set NAAQS for pollutants considered harmful to public health and the environment. EPA has set NAAQS for seven “criteria” pollutants: sulfur dioxide (SO₂), nitrogen dioxide (NO₂), lead, carbon monoxide (CO), ozone, particulate matter less than or equal to 10 µm in aerodynamic diameter (PM₁₀), and particulate matter less than or equal to 2.5 µm in aerodynamic diameter (PM_{2.5}). Each NAAQS has a specific averaging time (e.g., 3-hour or 24-hour SO₂ standard) that represents the time period over which modeled air pollutant concentrations are analyzed for the purpose of determining attainment with the NAAQS. The NAAQS are implemented at the state level through State Implementation Plans (SIPs). SIPs use individual source emissions limitations to help attain and maintain the NAAQS.

Background

The Plant is a 482-MW electricity generating facility located on the Potomac River in Alexandria, Virginia, about five miles (8 km) from the U.S. Capitol building (Figure S-1). The Plant consists of five generating units, each with its own exhaust stack. Because the Plant is located three miles (5 km) from the Ronald Reagan Washington National Airport and is within the flight path of the airplanes that fly in and out of that airport, it has stacks that are shorter than

normal for similar facilities. The Plant uses oil to pre-heat each of its units and then burns coal, which it receives via rail car, to generate electricity. The generated electricity is transmitted to the central business district of Washington, D.C., many Federal institutions, the Georgetown area, as well as other portions of Northwest D.C. and the D.C. Water and Sewer Authority's Blue Plains Wastewater Treatment Plant (collectively called the "Central D.C. area").

The Plant site was relatively remote in 1949 when the Plant began operation. However, residential communities and commercial properties have grown up and around the Plant over the last 50 years, notably a condominium building, Marina Towers, built only 300 yards (270 m) from the Plant in the 1960s. Since 2001, residents of Marina Towers have complained about air quality impacts and associated health impacts of the Plant's operation. Since 2003, state and Federal environmental agencies have been working with Mirant to settle alleged violations of the Plant's operating permit limit for nitrogen oxide (NO_x) emissions. The alleged violations resulted in a judicial consent decree (EPA 2004) in September 2004 and an amended judicial consent decree in May 2006 (EPA 2006g). Part of the 2004 settlement required Mirant to perform a modeling analysis to predict the effect of "downwash"¹ from the Plant on ambient concentrations of several NAAQS pollutants. The study showed significant modeled exceedances of three NAAQS pollutants from downwash: sulfur dioxide (SO_2), nitrogen dioxide (NO_2), and particulate matter finer than $10\ \mu\text{m}$ in aerodynamic diameter (PM_{10}). As a result of the study, on August 19, 2005, the Virginia Department of Environmental Quality (VDEQ) issued a letter to Mirant requesting that Mirant "undertake such action as is necessary to ensure protection of human health and the environment, in the area surrounding the Potomac River Generating Station, including the potential reduction of levels of operation, or potential shutdown of the facility." On August 24, 2005, in response to VDEQ's August 19, 2005, letter, Mirant decided to shut down all five generating units at the Plant.




Figure S-1. The location of the Plant in relation to the central Washington, D.C. area.

¹ The September 23, 2004, judicial consent decree (EPA 2004) defined downwash as "the effect that occurs when aerodynamic turbulence induced by nearby structures causes pollutants from an elevated source (such as a smokestack) to be mixed rapidly towards the ground resulting in higher ground-level concentrations of pollutants."

DOE Action

On August 24, 2005, the District of Columbia Public Service Commission (DCPSC) filed an Emergency Petition and Complaint (“Petition”) with DOE pursuant to Section 202(c) of the FPA. The Petition requested the Secretary of Energy to find that an emergency existed under Section 202(c) of the FPA and to issue an order directing Mirant to continue operation of the Plant. Section 202(c) of the FPA authorizes DOE, upon determination that an emergency exists, to “require by order such temporary connections of facilities and such generation, delivery, interchange, or transmission of electric energy as in its judgment will best meet the emergency and serve the public interest.” The basis of the DCPSC’s Petition was that the shutdown of the Plant had a drastic and potentially immediate effect on the reliability of the electricity supply of the Central D.C. area.

After receiving the Petition, DOE spent four months reviewing the facts to gather information on the shutdown of the Plant and its effect on the reliability of the Central D.C. electricity system. DOE met with private entities responsible for electricity transmission in the Central D.C. area and the regional electricity system to determine the role of the Plant in electricity reliability. DOE also met with officials from the Environmental Protection Agency (EPA) to understand the environmental situation posed by the Plant’s operation, particularly with regard to the NAAQS. Meanwhile, on September 21, 2005, Mirant unilaterally restarted the Plant’s unit 1 in an 8-8-8 capacity (that is, in any given 24-hour period, the unit ran for 8 hours at its maximum level, 8 hours at its minimum level, and did not run for 8 hours). Mirant also began experimental use of measures to control SO₂, specifically combustion of low-sulfur coal and injection of trona (a substance similar to baking soda) into flue gases.

During its investigation, DOE learned of the Plant’s key role in providing electricity reliability to the Central D.C. area. The Plant is one of only three sources of electricity to the Central D.C. area. The other sources are two 230-kV transmission lines that deliver electricity from other regional generating sources. The Potomac Electric Power Company (Pepco) is in the process of installing two additional 230-kV transmission lines to the Central D.C. area that will provide a high level of electricity reliability to the area even in the absence of the Plant. These lines are currently expected to be placed in service in June 2007. Until then, if the Plant is not available to generate electricity and one of the two existing transmission lines goes out of service (either unexpectedly or for maintenance), the Central D.C. area would only be served by the remaining line. If the remaining line then failed, a blackout would occur, affecting many government agencies; a large number of residents and workers; and hospitals, police, and fire facilities. Since 2000, there have been 34 one-line planned outages, seven one-line unplanned outages, and two times where both lines failed simultaneously. Indeed, on December 15, 2005, during DOE’s investigation, one of the 230-kV transmission lines failed unexpectedly, and the supply of electricity to the Central D.C. area depended solely on the remaining line until the morning of December 16, 2005.

After DOE's investigation, on December 20, 2005, the Secretary issued the Order stating:

I find that in the circumstances presented here, an emergency exists that justifies the issuance of a section 202(c) order. My determination is not based on any single factor, but on the combination of all relevant facts and circumstances. In particular, I find that an emergency exists because of the reasonable possibility an outage will occur that would cause a blackout, the number and importance of facilities and operations in our Nation's Capital that would be potentially affected by such a blackout, the extended number of hours of any blackout that might in fact occur, and the fact that the current situation violates applicable reliability standards.

DOE's Order did not direct Mirant to simply generate full power at the Plant, even though continuous, unrestricted, operation of the Plant, at all times, was requested in the Petition and would have assured a high level of electricity reliability to the Central D.C. area. Instead, the Order sought to strike an appropriate balance between environmental concerns and electricity reliability by directing Mirant to operate the Plant, but only in certain circumstances and only to limited capacity. Specifically, the Order required Mirant to (1) operate the Plant to produce the amount of power necessary to meet demand in the Central D.C. area during a planned or unplanned outage of one of the 230-kV lines and (2) in situations where both 230-kV lines are functioning, keep as many generating units in operation and take all other measures to reduce the start-up time of units not in operation for the purpose of providing electricity reliability, without causing an exceedance of the NAAQS. The Order further required Mirant to utilize pollution control equipment and measures to the maximum extent possible to minimize the magnitude and duration of any exceedance of the NAAQS during a planned or unplanned transmission line outage. The Order also contemplated continued DOE cooperation with EPA and suggested that DOE would modify the Order at a later date if EPA decided to issue an order to Mirant.

On June 1, 2006, EPA issued an Administrative Compliance Order (ACO) to Mirant. The ACO directs Mirant to operate the Plant under conditions specified in the DOE Order during line outage situations, but requires Mirant to take all reasonable steps to limit SO₂, PM₁₀, and NO_x emissions and to optimize use of trona to minimize SO₂ emissions. In non-line outage situations (i.e., in the normal course of operation), the ACO authorizes Mirant to operate the Plant under "daily predictive modeling" after certain conditions are met. Under daily predictive modeling Mirant is to model a specific operating mode for the Plant based on predicted weather conditions for the following day and operate under that mode only where the daily modeling run demonstrates that the Plant will not cause or contribute to a modeled exceedance of the 3-hr and 24-hr SO₂ and PM₁₀ NAAQS. The ACO also requires Mirant to maintain alarms that alert the Plant operators if monitored average concentrations reach 80% of the standards for SO₂, including the annual SO₂ standard. In addition, the ACO requires Mirant to install and operate six new SO₂ ambient monitoring stations in the vicinity where elevated pollutant concentrations have been predicted and to conduct actual monitoring of ambient SO₂ concentrations. On

June 2, 2006, DOE directed Mirant to operate under the ACO during non-line outage situations, for the purpose of providing electricity reliability, and to continue operation in accordance with the DOE Order in line-outage situations.

DOE believes that the Order and the ACO are the product of the best available balance between providing electricity reliability to the Central D.C. area and protecting the environment and human health in Alexandria, Virginia, until the additional 230-kV lines are in service. The Order and the ACO both contain provisions to prevent NAAQS exceedances in the normal course of operation of the Plant. The only time a possible exceedance of the NAAQS is contemplated is during line-outage situations. In addition, while unplanned transmission line outages cannot be predicted, planned transmission line outages are scheduled in 2006-2007 for periods of time when demand for electricity in the Central D.C. area (and hence emissions from the Plant) is at its lowest. The 2006 amended judicial consent decree, after it is implemented, will provide limitations on NO_x emissions from the Plant.

NEPA Process and this SEA

Major Federal actions significantly affecting the human environment generally call for DOE to prepare an EIS before taking the action to analyze impacts in compliance with NEPA. However, in emergency situations, pursuant to 40 CFR 1506.11, the CEQ's NEPA regulations provide that agencies consult with CEQ to determine what alternative arrangements the agency will take in lieu of preparing an EIS. Before issuing the Order, DOE consulted with CEQ pursuant to 40 CFR 1506.11. As part of its "alternative arrangements plan," DOE agreed to provide opportunity for public involvement, continue Agency consultation, and identify alternatives for mitigation (DOE 2006). In addition, as an alternative to an EIS, CEQ agreed to preparation of this SEA. This SEA does not include an impact assessment of alternative actions that DOE might have taken instead of issuing its Order on December 20, 2005. DOE will not issue a record of decision (ROD) based on this SEA.

In the January 20, 2006, *Federal Register* notice announcing the alternative arrangements (DOE 2006), DOE requested public comments on issues to be addressed in the SEA. Comments were provided by the following organizations: the Mount Vernon group and the Virginia Chapter of the Sierra Club; the Southern Environmental Law Center on behalf of itself and the American Lung Association of Virginia; the City of Alexandria; and the Institute for Public Representation on behalf of the Potomac Riverkeeper, Inc., the Patuxent Riverkeeper, and the Anacostia Riverkeeper at Earth Conservation Corps. Commentors on the notice expressed particular concern about the following issues that are within the scope of this SEA:

- impacts on health of increased particulate emissions, especially particulate matter smaller than 2.5 microns (PM_{2.5}), and of increased emissions of trace metals and hazardous air pollutants (especially arsenic, beryllium, lead, chromium, cadmium, nickel, and mercury);

- the potential for any increased emissions of SO₂ and NO_x to contribute to acid rain, nutrient loading to aquatic systems, and deposition of heavy metals, and the subsequent impacts on the aquatic resources of the Chesapeake Bay and several of its tributaries, specifically the Potomac, Anacostia, and Patuxent rivers;
- impacts of trona utilization; and
- potential mitigation measures, such as use of existing transmission lines along the railroad rights-of-way of the National Railroad Passenger Corporation (“AMTRAK”) and CSX Corporation and notification of nearby residents about potential NO_x exceedances.

A commentor also expressed concern about possible adverse effects of trona utilization on Plant equipment. This concern is not addressed because it is not considered to be an environmental impact.

The aim of this SEA is to describe the impacts resulting from the Order and from potential future alternative actions DOE may take in this matter. Such potential future alternative actions include allowing the Order to expire; extending the Order until the expected June 2007 in-service date of the two additional 230-kV transmission lines (or until December 2007, to account for unlikely, but possible, delays in installation); or extending the Order in modified form to include measures to mitigate impacts. Because allowing the Order to expire would place the Central D.C. area at risk of a potential blackout, this SEA describes potential impacts associated with a blackout. Potential mitigation alternatives discussed in this SEA include measures to, among other things, reduce demand for electricity in the Central D.C. area, require storage of sufficient trona at the Plant, and expedite the installation of the additional 230-kV transmission lines.

In order to give the reader a contextual way to understand the assessed impacts attributable to the Order and from a potential extension of the Order until the two new 230-kV transmission lines are in service, DOE uses assessed impacts from two different earlier Plant operating modes as a basis for comparison: the “pre-shutdown” mode of operations and the “pre-Order” operating mode. The “pre-shutdown” operating mode is based on operations in the year preceding the August 24, 2005, shutdown. The “pre-Order” mode is based on operation of the Plant during its restart of unit 1 in the 8-8-8 operating mode (approximately September - December 2005).

DOE’s assessment of the effects of Plant operations considered the following resource areas and impact topics:

- Effects of any increased *air emissions*;
- *Health* effects on Plant workers and the public of any increased air pollution;
- Effects on *water quality* due to atmospheric deposition of air pollutants from the Plant and changes in Plant water use and releases;
- *Ecological* effects due to acid deposition, changes in water quality, and changes in water use, including impacts to special status species;
- *Waste management* impacts, particularly impacts of trona utilization;

- *Transportation impacts* from increased shipping of coal and trona to the Plant and of wastes away from the Plant; and
- *Environmental justice impacts.*

It is important to understand the process DOE used to assess impacts from the Order and from a potential additional extension of the Order. Understanding DOE's approach for modeling air quality impacts is particularly important because (1) air quality is the most significant environmental concern associated with the Plant's operation and (2) many other impacts, including impacts to human health, are based on modeled estimates of air impacts. For its air analysis DOE used EPA's AERMOD model to assess modeled concentrations of SO₂ and PM₁₀ as a result of the Order (split into two time periods: before the ACO and after the ACO) and a potential extension of the Order (until July 2007 and December 2007). DOE focused on modeling concentrations of SO₂ and PM₁₀ because the original downwash study that prompted the shutdown of the Plant emphasized SO₂, PM₁₀, and NO_x (and the amended judicial consent decree between EPA and Mirant [EPA 2006g] deals with NO_x.) In modeling concentrations of SO₂ and PM₁₀, DOE used several simplifications and made a number of key assumptions that are essential to understand before interpreting the modeled results:

- *Assumptions in Modeling*
 - DOE's modeling of SO₂ and PM₁₀ assumed weather conditions from 2001 because EPA had shown that 2001 resulted in predictions of more adverse air quality than any of the other years during the period from 2000 through 2004. Therefore, DOE's modeling results likely overestimate impacts.
 - DOE's assessment of impacts to the health of people living near the Plant is based on estimated exposures to PM_{2.5}. DOE used air dispersion modeling for PM₁₀ to estimate exposures to PM_{2.5}. Therefore, to the extent that DOE's modeled air quality results overestimate impacts, the health results also likely overestimate impacts. In addition, DOE did not analyze factors such as health status or activity level that affect the likelihood of actual health impacts to specific individuals. Consequently, the results of DOE's health impact analysis represents an estimate of the impact to the population, rather than the likely impact to any specific individual.
- *Assumptions and Simplifications about Operations*
 - For the period from December 21, 2005, through March 31, 2006, DOE used hourly emissions data provided by Mirant to model SO₂ and PM₁₀ emissions. (For the two days for which data were not provided, DOE assumed operations were identical to the preceding day.) To model the air quality impacts of operations during the period April 1 through May 31, 2006, DOE assumed that Mirant operated the Plant to the maximum level described in the operating plan supplements that Mirant provided to DOE.

- For operations during daily predictive modeling, DOE assumed that the Plant would generate the maximum allowed power by using a combination of increased trona injection and reduced power levels to assure that its operations would not contribute to an exceedance of the 24-hour-average NAAQS limit for SO₂ concentrations in the normal course of business (i.e., no line outage). DOE did not simulate predictive modeling for the 3-hour SO₂ standard because the computational effort required to calculate average concentrations for all possible 3-hour periods for each of the over 1,700 modeled locations near the Plant was judged to be excessively large for the information to be gained. Consequently, the SEA reports modest modeled exceedances of the 3-hour SO₂ standard that are not expected to actually occur. The SEA also reports exceedances of the annual standard because operating close to the 24-hour limit day after day raises the long-term average. However, because the ACO requires Mirant to monitor SO₂ concentrations and adjust operation of the Plant to meet SO₂ standards for all averaging periods, actual exceedances of the annual standard are not expected to occur.

Preliminary data from the six new SO₂ monitoring stations that Mirant installed during the summer of 2006, pursuant to the ACO, provides an initial look at actual impacts from the Plant under the ACO's daily predictive modeling. DOE's modeling results are not directly comparable to the monitored data because DOE's modeling used average emissions and historical weather data rather than current-year data. However, monitored data can be compared with the follow-up modeling that Mirant is conducting under the ACO, using actual concurrent emissions and weather data. For the period June 17, 2006, to September 17, 2006, the maximum monitored daily-average SO₂ concentration for the monitors ranged from 4 to 63 µg/m³, whereas Mirant's follow-up modeling gave maximum daily-average SO₂ concentrations from 25 to 570 µg/m³. Thus, monitored concentrations of SO₂ are much lower than Mirant's follow-up modeled concentrations. EPA will be evaluating the reasons for this large discrepancy between the actual monitored data and follow-up modeling throughout the course of the ACO. Should DOE extend the Order on December 1, 2006, DOE will make monitored data (as submitted by Mirant to EPA under the ACO) available on the website it maintains to provide information about this matter, <http://www.oe.energy.gov/permitting/372.htm>.

Table S.1 summarizes the assessed impacts of the Order, both before and after the initiation of daily predictive modeling. It also includes impacts of the temporary extension of the Order and a potential additional extension of the Order until December 2007, assuming a 6-month delay in the installation of the additional 230-kV lines. Finally, the table presents the assessed impacts associated with the "pre-shutdown" and "pre-Order" modes of operation of the Plant to give the reader a basis for comparison.

Table S.1 Summary of impacts of Plant operations (See text for details.)

Resources and Topics	Pre-shutdown (prior to August 24, 2005)	Pre-Order (Sept. - Dec. 20, 2005)	Order (Dec. 20, 2005 - Oct. 1, 2006)	Temporary extension of Order (until Dec. 1, 2006) and potential extension until Dec. 2007 ¹
<i>AIR QUALITY</i>				
SO ₂	Modeled maximum concentration values for SO ₂ in ambient air exceed NAAQS limits for all averaging periods (i.e., 3-hour, 24-hour, and annual).	Modeling shows no exceedance of NAAQS limit for any averaging period.	For operations before the commencement of daily predictive modeling (i.e., before July 1, 2006), there are no modeled SO ₂ or NO _x exceedances during non-line outage situations. For operations during line outages (21 days in January 2006) modeled maximum concentration values for SO ₂ in ambient air exceed SO ₂ NAAQS limits for all averaging periods.	For operations during non-line outage periods, modeling shows no exceedances of 24-hour average SO ₂ NAAQS limit because of requirements of predictive modeling. Modeling shows exceedances for other averaging periods, but because the ACO requires compliance with SO ₂ NAAQS in non-line outage situations, actual exceedances are not expected. For operations during line outages, modeled maximum concentration values for SO ₂ in ambient air exceed SO ₂ NAAQS limits for all averaging periods.
		For operations after the commencement of daily predictive modeling (i.e., starting July 1, 2006), modeling shows no exceedances of 24-hour average SO ₂ NAAQS limit because of requirements of predictive modeling. Modeling shows exceedances for other averaging periods, but because the ACO requires compliance with SO ₂ NAAQS in non-line outage situations, actual exceedances are not expected.		

Table S.1 (Continued)

Resources and Topics	Pre-shutdown (prior to August 24, 2005)	Pre-Order (Sept. - Dec. 20, 2005)	Order (Dec. 20, 2005 - Oct. 1, 2006)	Temporary extension of Order (until Dec. 1, 2006) and potential extension until Dec. 2007 ¹
PM ₁₀	Modeled maximum concentration values for PM ₁₀ in ambient air meet NAAQS annual standard but exceed limit for 24-hour averaging period. ²	Modeled maximum concentration values for PM ₁₀ in ambient air meet NAAQS standards for both the annual and 24-hour averaging periods. ³		
PM _{2.5}	Background concentrations measured by VDEQ while the Plant was operating at pre-shutdown levels are below the current NAAQS limit for 24-hour averaging period (65 µg/m ³) and are slightly below the current NAAQS annual limit (15 µg/m ³), but exceed the NAAQS limit for the 24-hour averaging period (35 µg/m ³) that will take effect in December 2006. As a result of the background contribution, estimated maximum concentration values in ambient air (including background) for all operating modes exceed the NAAQS annual limit and the December 2006 limit for the 24-hour averaging period, both at ground level and the top of Marina Towers. Adding estimated Plant contributions to background concentrations involves some double counting of Plant effects.			
	Estimated maximum concentration values in ambient air (including background) at ground level and the top of Marina Towers exceed current and future NAAQS limits for both 24-hour and annual averaging periods.	Estimated maximum concentration values in ambient air (including background) at ground level and the top of Marina Towers are lower than for pre-shutdown operations and meet the current NAAQS limit for the 24-hour averaging period, but exceed the annual and 24-hr limits that will take effect in December 2006.	Estimated maximum concentration values in ambient air (including background) at ground level are lower than for pre-shutdown operations but higher than for pre-Order operations and meet the current NAAQS limit for the 24-hour averaging period but exceed the annual and 24-hr limits that will take effect in December 2006. Estimated maximum concentration values at the top of Marina Towers are lower than for pre-shutdown operations, but exceed current and future NAAQS limits for both 24-hour and annual averaging periods.	

Table S.1 (Continued)

Resources and Topics	Pre-shutdown (prior to August 24, 2005)	Pre-Order (Sept. - Dec. 20, 2005)	Order (Dec. 20, 2005 - Oct. 1, 2006)	Temporary extension of Order (until Dec. 1, 2006) and potential extension until Dec. 2007 ¹
PM _{2.5} (continued)	Plant contributions to ground-level PM _{2.5} : 38 µg/m ³ for 24-hr 5.7 µg/m ³ for annual	Plant contributions to ground-level PM _{2.5} : 9.2 µg/m ³ for 24-hr 2.0 µg/m ³ for annual	Plant contributions to ground-level PM _{2.5} : 25 µg/m ³ for 24-hr 2.4 µg/m ³ for annual	Plant contributions to ground-level PM _{2.5} : 23 µg/m ³ for 24-hr 4.0 µg/m ³ for annual
	Plant contributions to PM _{2.5} at the top of Marina Towers: 76 µg/m ³ for 24-hr 7.8 µg/m ³ for annual	Plant contributions to PM _{2.5} at the top of Marina Towers: 4.8 µg/m ³ for 24-hr 1.0 µg/m ³ for annual	Plant contributions to PM _{2.5} at the top of Marina Towers: 41 µg/m ³ for 24-hr 3.9 µg/m ³ for annual	Plant contributions to PM _{2.5} at the top of Marina Towers: 43 µg/m ³ for 24-hr 5.7 µg/m ³ for annual
Contributions to ozone pollution from NO _x	Operations estimated to emit 2,300 tons ³ of NO _x (which contributes to formation of ozone) over 285 days (rate of about 3,000 tons/yr)	Operations estimated to emit 640 tons of NO _x over 285 days (rate of about 820 tons/yr)	Operations estimated to emit 2,000 tons of NO _x over 285 days (rate of about 2,600 tons/yr)	Operations estimated to emit 3,700 tons of NO _x over 15 months (rate of about 3,000 tons/yr)
Mercury emissions	Operations estimated to emit mercury at a rate of 116 lb/yr or 91 lb over 285 days ³	Operations estimated to emit 21 lb mercury over 285 days (rate of about 28 lb/yr)	Operations estimated to emit 79 lb mercury over 285 days (rate of about 101 lb/yr)	Operations estimated to emit mercury at a rate of 116 lb/yr or 146 lb over 15 months
Carbon monoxide and lead	Because ambient concentrations of carbon monoxide and lead are far below NAAQS limits and because coal plants are not important sources of either pollutant, DOE did not model Plant contributions to ambient levels for either pollutant.			
Contributions to global climate change	Operations estimated to release CO ₂ (a greenhouse gas that contributes to global warming) at a rate of 2,000,000 tons/yr from coal use	Operations estimated to release CO ₂ at a rate of 488,800 tons/yr from coal use	Operations estimated to release CO ₂ at a rate of 1,766,500 tons/yr from coal and trona use	Operations estimated to release CO ₂ at a rate of 2,007,500 tons/yr from coal and trona use

Table S.1 (Continued)

Resources and Topics	Pre-shutdown (prior to August 24, 2005)	Pre-Order (Sept. - Dec. 20, 2005)	Order (Dec. 20, 2005 - Oct. 1, 2006)	Temporary extension of Order (until Dec. 1, 2006) and potential extension until Dec. 2007 ¹
HUMAN HEALTH				
Premature mortality due to air pollution exposure	Expected incidence of premature mortality among the 144,000 adults in 36-mi ² area ³ around the Plant of 3.8 per year	Expected incidence of premature mortality among the 144,000 adults in 36-mi ² area around the Plant of 0.77 per year	Expected incidence of premature mortality among the 144,000 adults in 36-mi ² area around the Plant of 1.3 over 285-day duration of the Order (annual rate of 1.7)	Expected incidence of premature mortality among the 144,000 adults in 36-mi ² area around the Plant of 2.9 over 15-month duration of the potential extension (annual rate of 2.3)
WATER QUALITY				
Nitrogen loading to Chesapeake Bay	Operations deliver nitrogen to the Bay at an estimated rate of 170,000 lb/yr	Operations deliver nitrogen to the Bay at an estimated rate of 47,000 lb/yr	Operations deliver nitrogen to the Bay at an estimated rate of 150,000 lb/yr	Operations deliver nitrogen to the Bay at an estimated rate of 170,000 lb/yr
Acid deposition	Plant emissions of SO ₂ and NO _x contribute to regional acid deposition.	SO ₂ and NO _x emissions are 28% of pre-shutdown levels	NO _x emissions are 87% of pre-shutdown levels; SO ₂ emissions are less than 45% of pre-shutdown levels	NO _x emissions are similar to pre-shutdown levels, but SO ₂ emissions are 50% of pre-shutdown levels
Effects of changes in Plant water use and releases				
		Negligible impacts to water quality in nearby watersheds, because these watersheds are well buffered against acid rain.		
		Effects of many years of Plant operations are among the natural and human factors reflected in the existing water quality conditions of the Potomac River	Reduced water and thermal discharge rates, compared with pre-shutdown operations, could contribute to improved water quality in the Potomac River	Impacts intermediate between pre-Order and pre-shutdown operations

Table S.1 (Continued)

Resources and Topics	Pre-shutdown (prior to August 24, 2005)	Pre-Order (Sept. - Dec. 20, 2005)	Order (Dec. 20, 2005 - Oct. 1, 2006)	Temporary extension of Order (until Dec. 1, 2006) and potential extension until Dec. 2007 ¹
ECOLOGICAL RESOURCES				
Acid deposition	Acid deposition resulting from Plant operations has negligible impacts on terrestrial and aquatic biological resources because (1) the soils in the nearby river and stream watersheds where emissions from the Plant are likely to fall are well buffered and (2) vegetation has actively grown near and next to the Plant even at "pre-shutdown" levels.			
Changes in water quality	Ecological changes to the Potomac River and Chesapeake Bay due to changes in nutrient loading induced by the Order or a potential extension of the Order would be minimal.	No effects from trona (assessment assumes no use of trona).	Selenium and arsenic leached from solid wastes produced with trona use could adversely affect biota in Mataponi Creek. Monitoring of collected landfill leachate and stormwater for selenium should identify the potential for problems before discharges occur, but the current discharge permit does not require monitoring for arsenic.	
Changes in water use	Effects of Plant operations under the Order or a potential extension of the Order through December 2007 would not have a major impact on aquatic biota, although the impacts from entrainment and impingement would be greater than for the "pre-Order" mode.			
Special status species	No adverse impacts to any special status species would be expected to result from Plant operations.			

Table S.1 (Continued)

Resources and Topics	Pre-shutdown (prior to August 24, 2005)	Pre-Order (Sept. - Dec. 20, 2005)	Order (Dec. 20, 2005 - Oct. 1, 2006)	Temporary extension of Order (until Dec. 1, 2006) and potential extension until Dec. 2007 ¹
WASTE MANAGEMENT				
Solid waste	With indefinite continuation of Plant operations in pre-shutdown mode, the Mirant Brandywine ash landfill would be able to receive fly ash until mid-2012.	With indefinite continuation of Plant operations in pre-Order mode, the Mirant Brandywine landfill would be able to receive fly ash until mid-2015.		With indefinite continuation of Plant operations at operating levels under the Order, including use of trona, the Mirant Brandywine ash landfill would be able to receive fly ash until early 2010.
	Waste characteristics would be unchanged.	Waste characteristics would be unchanged (assessment assumes no use of trona).		Trona in Plant solid wastes may increase the leaching of selenium and arsenic from the landfill. Current monitoring requirements at the landfill include monitoring for selenium in collected leachate and stormwater before water is discharged to surface water, but do not include monitoring for arsenic. Groundwater monitoring does not include selenium or arsenic.
TRANSPORTATION				
Impacts from road and rail traffic	Neither rail nor truck traffic associated with Plant operations have an important effect on local traffic near the Plant.			
	Transport of Plant fly ash to the Mirant Brandywine ash landfill contributes to existing traffic problems on Maryland Route 381, and increased traffic associated with operations under the Order, including the temporary extension of the Order and any potential extension of the Order increases this effect. The State Highway Administration is requiring that Mirant address problems at certain intersections along Maryland Route 381 that have been rated as having "failing" levels of service, and Maryland-National Capital Park and Planning Commission staff have recommended ways to address traffic impacts on North Keys Road.			

Table S.1 (Continued)

Resources and Topics	Pre-shutdown (prior to August 24, 2005)	Pre-Order (Sept. - Dec. 20, 2005)	Order (Dec. 20, 2005 - Oct. 1, 2006)	Temporary extension of Order (until Dec. 1, 2006) and potential extension until Dec. 2007 ¹
ENVIRONMENTAL JUSTICE				
Impacts to minority and low-income populations	Because of their proximity to the Plant, residents of block groups 1 and 2 (which are neither low-income nor minority populations) experience higher air pollution from Plant emissions than residents of block groups 3 (which is identified as a low-income population) and 4 (which is identified as a minority population). DOE has not identified any different or unique ways that these or other minority and low-income populations in the area could be exposed to Plant air pollutants or otherwise affected by the Order or its potential extension. Consequently, the minority and low-income populations in block groups 3 and 4 do not suffer “disproportionately high and adverse human health or environmental effects” related to air pollutant emissions from the Plant.			

¹ For several resources and topics, emissions and impacts are greater under an extension of the Order than under the Order because during the initial months of the Order the Plant operated at lower levels than result from daily predictive modeling.

² EPA’s October 17, 2006, rule making on NAAQS for particulate matter (EPA 2006j) revoked the annual PM₁₀ standard, effective December 18, 2006.

³ To convert tons to metric tons, multiply by 0.91. To convert lbs to kg, multiply by 0.45. To convert square miles to square km, multiply by 2.60.

[This page intentionally left blank]

Special Environmental Analysis

**For Actions Taken under U.S. Department of Energy
Emergency Orders Regarding Operation of the
Potomac River Generating
Station in Alexandria, Virginia**

DOE/SEA-04

**U.S. Department of Energy
Washington, D.C.**

November 2006

[This page intentionally left blank]

TABLE OF CONTENTS

LIST OF FIGURES	vii
LIST OF TABLES	ix
ACRONYMS AND ABBREVIATIONS	xi
1. PURPOSE AND NEED FOR THE DOE ACTION	1
1.1 Introduction	1
1.2 Purpose and Need for Agency Action	2
1.3 Background	2
1.3.1 Electrical Reliability	2
1.3.2 Environmental and Health Issues	3
1.3.3 Detailed History	3
1.4 National Environmental Policy Act (NEPA) Process	10
1.5 Public Involvement	11
1.6 Scope of the Analysis	12
2. DESCRIPTION OF THE MIRANT POTOMAC RIVER GENERATING STATION	14
2.1 Site Layout	14
2.2 Plant Equipment and General Operation	14
2.3 Resource Requirements	17
2.4 Waste and Effluents	18
2.4.1 Air Emissions	18
2.4.2 Water Effluents	19
2.4.3 Solid Wastes	20
2.5 Changes to the Plant Since the DOE Order	21
3. AFFECTED ENVIRONMENT	23
3.1 Climate and Air Quality	23
3.1.1 Climate	23
3.1.2 Air Quality	24
3.2 Human Health	27
3.3 Water Resources and Water Quality	27
3.3.1 Physical Setting and Hydrology	27
3.3.1.1 Potomac River	28
3.3.1.2 Anacostia River	29
3.3.1.3 Rock Creek	29
3.3.1.4 Patuxent River	30
3.3.1.5 Chesapeake Bay	30
3.3.2 Water Quality	31
3.3.2.1 Potomac River	31
3.3.2.2 Anacostia River	32

3.3.2.3	Rock Creek	33
3.3.2.4	Patuxent River	33
3.3.2.5	Chesapeake Bay	33
3.3.2.6	Acid deposition	35
3.4	Ecological Resources	35
3.4.1	Terrestrial Resources	35
3.4.1.1	Vegetation	35
3.4.1.2	Wildlife	36
3.4.1.3	The Mirant Plant site	37
3.4.2	Aquatic Resources	37
3.4.2.1	Potomac River	37
3.4.2.2	Anacostia River	38
3.4.2.3	Rock Creek	39
3.4.2.4	Patuxent River	39
3.4.2.5	Chesapeake Bay organisms	40
3.4.2.6	Chesapeake Bay stresses	40
3.4.3	Wetlands and Riparian Habitats	41
3.4.4	Special Status Species	41
3.4.4.1	Federally listed species	41
3.4.4.2	State-listed species	43
3.5	Waste Management	43
3.6	Transportation Resources	44
3.6.1	Rail	45
3.6.2	Road	45
3.7	Minority and Low-Income Populations	48
4.	PLANT OPERATIONS, ASSUMPTIONS, AND ENVIRONMENTAL CONSEQUENCES	51
4.1	General Plant Operations as Authorized by the DOE Order	51
4.1.1	Operations as Authorized by the DOE Order until the Administrative Compliance Order (ACO)	51
4.1.2	Operation under the ACO	52
4.1.2.1	Operations during non-line outage situations	52
4.1.2.2	Operations during line outage situations	53
4.2	Assumptions and Data Used in SEA to Model Plant Operations	53
4.2.1	Pre-Shutdown Operations	54
4.2.2	Pre-Order Operations	54
4.2.3	Operations under the Order and Potential Extension	55
4.3	Environmental Consequences	58
4.3.1	Air Quality	58
4.3.1.1	Modeling methods and assumptions	59
4.3.1.2	Uncertainties in modeling	62
4.3.1.3	Modeling results for SO ₂ and PM ₁₀ emissions	64
4.3.1.4	Monitored SO ₂ data	68
4.3.1.5	Other air pollutants	70
4.3.1.6	General conformity requirement	75

4.3.1.7 Global climate change	77
4.3.2 Human Health	79
4.3.2.1 Analytical approach	80
4.3.2.2 Results	81
4.3.3 Water Quality	84
4.3.3.1 Direct impacts to the Potomac River	85
4.3.3.2 Indirect impacts to regional water quality	86
4.3.4 Ecological Resources	89
4.3.4.1 Acid deposition	89
4.3.4.2 Impact of water quality changes	90
4.3.4.3 Impacts of changes in water use	91
4.3.4.4 Special status species	94
4.3.5 Waste Management	95
4.3.5.1 Impacts on landfill capacity	95
4.3.5.2 Effects of trona use on the environmental consequences of waste management	98
4.3.6 Transportation Resources	102
4.3.6.1 Pre-shutdown operations	103
4.3.6.2 Pre-Order operations	104
4.3.6.3 Operations under the DOE Order, temporary extension, and potential additional extensions	104
4.3.7 Environmental Justice	106
5. ALTERNATIVES FOR FUTURE DECISION-MAKING	108
5.1 Allow the Order to Expire	108
5.2 Extend the Order as Currently Written	109
5.3 Extend the Order with Mitigation Measures	109
5.3.1 Improve Plant Operations and Pollution Control Measures	109
5.3.2 Reduce Exposure to Pollution	110
5.3.3 Manage the Demand for Electricity in the Central D.C. Area	112
5.3.4 Use Alternative Sources for Generating Electricity	113
5.3.5 Expedite the Installation of Additional Transmission Lines or Encourage the Use of Other Existing Lines	113
6. REGULATORY CONSULTATION AND COMPLIANCE	115
7. REFERENCES	116
8. LIST OF PREPARERS	128
APPENDIX A DOE Emergency Orders	A-1
APPENDIX B EPA's Administrative Compliance Order for the Mirant Potomac River Generation Station	B-1

APPENDIX C	<i>Federal Register</i> Notice of Emergency Action and Correspondence with the Council on Environmental Quality	C-1
APPENDIX D	Consultation Letters with the U.S. Fish and Wildlife Service and the National Marine Fisheries Service	D-1
APPENDIX E	Organizational Conflict of Interest Statement	E-1
APPENDIX F	Glossary	F-1

LIST OF FIGURES

Figure 2-1. The location of the Plant in relation to the central Washington, D.C. area.	14
Figure 2-2. Aerial photo showing the Plant and surrounding residences.	15
Figure 2.1-1. The site layout of Mirant's Potomac River Generating Station.	16
Figure 2.4-1. The location of and access routes to the Brandywine Fly Ash Facility used for disposal of solid wastes from the Plant.	21
Figure 3.1-1. Wind rose for Ronald Reagan Washington National Airport, 2000-2004 weather data	24
Figure 3.3-1. The Chesapeake Bay watershed includes the Patuxent and Potomac rivers.	28
Figure 3.3-2. The Chesapeake Bay watershed near the Plant includes the Potomac, Patuxent, and Anacostia rivers.	28
Figure 3.3-3. Location of features mentioned in the text.	30
Figure 3.4-1. Location of National Park Service trail that passes the Plant.	36
Figure 3.6-1. Access routes near the Mirant Plant.	45
Figure 3.7-1. Block Groups 1-4 within Census Tract 2018.01.	49
Figure 4.2-1. Monthly average power generation for September 2004 through August 2005.	54
Figure 4.3.1-1. Map of receptor grid points for atmospheric dispersion modeling.	59

[This page intentionally left blank]

LIST OF TABLES

Table 1.3-1. Chronology of major actions and events related to the Plant	7
Table 2.3-1. Ranges of values for trace metal concentrations in as-mined samples of Appalachian coals	17
Table 2.4-1. Water quality of Plant intake water and cooling water effluent	20
Table 3.1-1. National Ambient Air Quality Standards for criteria pollutants	25
Table 3.1-2. Ambient air quality in the vicinity of the Plant, 2004	26
Table 3.3-1. NPDES-permitted discharge limits for the Blue Plains Wastewater Treatment Plant	32
Table 3.6-1. Roads traveled by the ash removal trucks between Henry Street and the Brandywine Fly Ash Facility	46
Table 3.6-2. Traffic impacts projected in Mirant's <i>Application for Special Exception</i> for the road intersections used to access the Brandywine Fly Ash Facility	48
Table 3.7-1. Minority and low-income data for census tract 2018.01 and its block groups . . .	50
Table 4.3.1-1. Modeled maximum ambient SO ₂ and PM ₁₀ concentrations (µg/m ³) for Plant operations among all receptor locations	66
Table 4.3.1-2. Modeled maximum ambient SO ₂ and PM ₁₀ concentrations (µg/m ³) for Plant operations among all receptor locations for a potential extension of the Order	69
Table 4.3.1-3. Annualized carbon dioxide emissions (tons/year) from the Mirant Plant during operational periods under analysis in this report	79
Table 4.3.2-1. Expected incidence of short- and long-term health effects resulting from Mirant Plant operations for the population of the eastern United States	85
Table 4.3.5-1. Impact of Plant operations on remaining operating life of the Brandywine ash landfill	97
Table 4.3.5-2. Concentrations of major constituents and trace elements in samples of Plant fly ash resulting from operations with and without trona injection.	100

[This page intentionally left blank]

ACRONYMS AND ABBREVIATIONS

µg	micrograms (i.e., millionths of a gram)	MES	Model Evaluation Study
µm	micrometers (i.e., millionths of a meter)	mg	milligrams (i.e., thousandths of a gram)
ACO	Administrative Compliance Order	mi	mile
Btu	British thermal unit	mi ²	square mile
C	Celsius	min	minute
CAA	Clean Air Act	MSL	mean sea level
CEQ	Council on Environmental Quality	MW	megawatts
CFR	<i>Code of Federal Regulations</i>	MWh	megawatt-hour
cm	centimeter	NAAQS	National Ambient Air Quality Standards
CO	carbon monoxide	NEPA	National Environmental Policy Act
CO ₂	carbon dioxide	NMFS	National Marine Fisheries Service
CT	census tract	NO ₂	nitrogen dioxide
D.C.	District of Columbia	NO _x	oxides of nitrogen
DCPSC	District of Columbia Public Service Commission	NPDES	National Pollutant Discharge Elimination System
DOE	U.S. Department of Energy	O ₃	ozone
EPA	U.S. Environmental Protection Agency	Pb	lead
ESA	Endangered Species Act	Pepco	Potomac Electric Power Company
F	Fahrenheit	PJM	PJM Interconnection, LLC
FAA	Federal Aviation Administration	Plant	Mirant's Potomac River Generating Station (in Alexandria, Virginia)
FERC	Federal Energy Regulatory Commission	PM	particulate matter
FPA	Federal Power Act	PM _{2.5}	particulate matter with an aerodynamic diameter less than or equal to 2.5 µm
FR	<i>Federal Register</i>	PM ₁₀	particulate matter with an aerodynamic diameter less than or equal to 10 µm
ft	feet	ppb	parts per billion
ft ²	square feet	ppm	parts per million
FWS	U.S. Fish and Wildlife Service	RCRA	Resource Conservation and Recovery Act
gal	gallons	ROD	<i>Record of Decision</i>
ha	hectare	SEA	special environmental analysis
hr	hour	SIP	state implementation plan
kg	kilogram	SO ₂	sulfur dioxide
km	kilometer	TCLP	Toxicity Characteristic Leaching Procedure
km ²	square kilometer	U.S.	United States
kV	kilovolt	U.S.C.	United States Code
L	liter	VDEQ	Virginia Department of Environmental Quality
lb	pound(s)	yd ³	cubic yard
LLC	Limited Liability Company	yr	year
LOS	level-of-service		
m	meter		
m ²	square meter		
m ³	cubic meter		
MBtu	million British thermal units		

EXPONENTIAL NOTATION: Some values in the text and tables of this document are expressed in exponential notation. An exponent is the power to which the expression, or number, is raised. This form of notation is used to conserve space and to focus attention on comparisons of the order of magnitude of the numbers (see examples):

1×10^4	=	10,000
1×10^2	=	100
1×10^0	=	1
1×10^{-2}	=	0.01
1×10^{-3}	=	0.001

Metric Conversions Used in this Document:

Multiply	By	To Obtain
<i>Length</i>		
inch (in.)	2.54	centimeters (cm)
feet (ft)	0.30	meters (m)
yards (yd)	0.91	meters (m)
miles (mi)	1.61	kilometers (km)
<i>Area</i>		
acres (ac)	0.40	hectares (ha)
square feet (ft ²)	0.093	square meters (m ²)
square yards (yd ²)	0.84	square meters (m ²)
square miles (mi ²)	2.60	square kilometers (km ²)
<i>Volume</i>		
gallons (gal)	3.79	liters (L)
cubic feet (ft ³)	0.028	cubic meters (m ³)
cubic yards (yd ³)	0.76	cubic meters (m ³)
<i>Weight</i>		
ounces (oz)	28.4	grams (gm)
pounds (lb)	0.45	kilograms (kg)
short ton (ton)	0.91	metric ton (t)

1. PURPOSE AND NEED FOR THE DOE ACTION

1.1 Introduction

This special environmental analysis (SEA) focuses on the environmental impacts of operations at the coal-fired Potomac River Generating Station (the “Plant”) in Alexandria, Virginia, as a result of a U.S. Department of Energy (DOE or “Department”) emergency order (the “DOE Order” or “Order”) (Appendix A) issued on December 20, 2005, pursuant to Section 202(c) of the Federal Power Act (FPA)¹. The Plant is owned by Mirant Corporation and its wholly owned subsidiary, Mirant Potomac River, LLC (collectively referred to herein as Mirant). (See text box.)

On August 24, 2005, Mirant shut down operation of the Plant to respond to concerns about the Plant’s impacts on air quality. (See Section 1.3.3.) On August 24, 2005, DOE received an Emergency Petition and Complaint from the District of Columbia (D.C. or District) Public Service Commission (DCPSC 2005). That petition requested DOE to direct Mirant to continue operation of the Plant. The basis for the petition was that shutdown of the Plant reduced the reliability of the electrical supply (Section 1.3.1) to much of the central business district of the District of Columbia, many Federal institutions, the Georgetown area in D.C., other portions of Northwest D.C., and the D.C. Water and Sewer Authority's Blue Plains Wastewater Water Treatment Plant (collectively referred to herein as the “Central D.C. area”), placing these electrical customers at risk of a blackout (DCPSC 2005).

After receiving the petition from the D.C. Public Service Commission, DOE undertook an exhaustive review of the facts. (See Section 1.3.3 for a detailed history.) Based on this

Entities involved in delivering power in the Central D.C. area

Mirant owns and operates electrical power generating plants, including the Potomac River Generating Station in Alexandria, Virginia.

Potomac Electric Power Company (Pepco) owns and operates transmission lines and is responsible for supplying electricity to retail customers in D.C. and parts of Maryland.

PJM Interconnection, LLC (PJM) is the transmission organization responsible for coordinating the regional electric power grid and wholesale electricity market in D.C., Maryland, Virginia, Delaware, New Jersey, West Virginia, and parts of Indiana, Illinois, Kentucky, Michigan, Ohio, Pennsylvania, and Tennessee. PJM keeps the electricity supply and demand in balance by telling power producers how much power to generate.

¹ Section 202(c) of the FPA vests in the Secretary of Energy the authority to issue an order when “an emergency exists by reason of a sudden increase in the demand for electric energy, or a shortage of electric energy or of facilities for the generation or transmission of electric energy, or of the fuel or water for generating facilities, or other causes...” [16 U.S.C. Section 824a(c)]

extensive evaluation, the Secretary of the Energy on December 20, 2005, issued Order 202-05-03 (the “DOE Order”) directing Mirant to generate electricity at the coal-fired Plant under certain, limited circumstances.

DOE is issuing this SEA in compliance with the “alternative arrangements” plan agreed upon with the Council on Environmental Quality (CEQ) pursuant to 40 CFR 1506.11. This SEA covers a period of about 24 months beginning with the issuance of the Order. The time period for DOE’s original Order ended at 12:01 am on October 1, 2006; on September 28, 2006, the Secretary of Energy extended the Order for two months, until 12:01 am on December 1, 2006. However, this SEA covers the full 24-month period at the end of which the Potomac Electric Power Company (Pepco) (text box) expects to have completed construction of new transmission lines that will provide additional electrical service to customers in the Central D.C. area.

1.2 Purpose and Need for Agency Action

The purpose and need for DOE’s action was to respond to the emergency reliability situation that had been brought on by shutdown of operations at the Mirant Potomac River Generating Station.

1.3 Background

1.3.1 Electrical Reliability

The Plant has been operating since 1949. It is one of three sources that provide electricity to Central D.C. area customers. The other sources are two 230,000-volt (230-kV) transmission lines that deliver electricity from other regional generating sources. Two additional generating stations exist in close physical proximity to the Central D.C. area, but they are not connected by transmission lines that allow the electricity they produce to be delivered to that area. Thus, if the Plant is not available to generate electricity and one of the two transmission lines serving the Central D.C. area goes out of service, electricity would be supplied to that area by only the one remaining transmission line. Should the remaining line fail for any reason, a potentially extended blackout would occur in the Central D.C. area. If both lines are down and one of them could not be brought back into service immediately, it would take at least 28 hours to bring the Plant into full operation, during which time much of the Central D.C. area would be without electricity. Transmission line outages can be either planned in order to perform periodic maintenance or unexpected. The duration of an outage can be several days or weeks for maintenance or up to several weeks in the event of a major, unexpected equipment failure.

An important consideration in issuing the Order was the facilities and functions that would be adversely affected by an extended blackout. The Central D.C. area includes facilities of

all three branches of the U.S. government that are critically important to the Nation's national security, law enforcement, and regulatory functions. The Central D.C. area also includes hundreds of thousands of residents and workers and many public safety and protection facilities (e.g., hospitals, police and fire stations). Moreover, within 24 hours of a Central D.C. blackout the Blue Plains Wastewater Treatment Plant would begin to discharge untreated sewage into the Potomac River. Thus, an extended blackout would severely impact critical portions of the Nation's government with potentially adverse national effects. It would also result in hardship and potential physical risk to many people from loss of heat or cooling, elevator outages, medical equipment failure, and other causes.

In 2005 Pepco received permission from the D.C. Public Service Commission to construct two additional 230-kV lines that would supply electricity to the Central D.C. area and two new 69-kV lines that would supply electricity to the Blue Plains Wastewater Treatment Plant. The two 69-kV lines have since been constructed. Once the new 230-kV lines are completed, these lines will provide a high level of electricity reliability in the Central D.C. area, even in the absence of production from the Plant. However, it could be mid- to late-2007 before the new lines are installed and operating. Pepco's schedule for completing installation of the new transmission lines has the lines going into service in June 2007.

1.3.2 Environmental and Health Issues

Residents in the area of the Plant have been concerned about the environmental and health impacts of its air emissions for years (SPROL 2005). However, the D.C. Public Service Commission, Pepco, and PJM Interconnection, LLC (PJM) (text box) have contended that there were no actual monitored exceedances of the National Ambient Air Quality Standards (NAAQS) of the Clean Air Act (CAA) during the Plant's operation in the period before Mirant shut it down on August 24, 2005, and that operation of the Plant at full power at any time during that period did not exceed the emissions limits contained in the Plant's operating permit (DOE Order 202-05-03).

1.3.3 Detailed History

This section describes the actions taken by DOE in relation to the DOE Order and to the Plant. Table 1.3-1, at the end of the section, provides a more complete chronology of the major actions and events related to the DOE Order and the Plant.

Mirant and the Virginia Department of Environmental Quality (VDEQ) entered into an Order by Consent on September 23, 2004. Under that order Mirant performed a dispersion modeling analysis to assess the effect of downwash² of air emissions from the Plant and to

² The September 23, 2004, judicial consent decree (EPA 2004) defined downwash as "the effect that occurs (continued...)"

determine whether the Plant could cause or contribute to significant localized exceedances of the NAAQS (ENSR 2005). This study, known as the downwash study, used computer modeling to predict ambient concentrations of pollutants emitted by the Plant under certain weather and atmospheric conditions.

Mirant submitted the results of the downwash study to the VDEQ in August 2005. After reviewing the study, VDEQ sent Mirant a letter dated August 19, 2005, stating that the modeling results showed that under certain atmospheric conditions the Plant's operations could result in, cause, or substantially contribute to modeled violations of the NAAQS for sulfur dioxide (SO₂), oxides of nitrogen (NO_x), and particulate matter with an aerodynamic diameter less than or equal to 10 µm (PM₁₀).

In its August 19, 2005, letter the VDEQ requested “that Mirant *immediately* undertake such action as is necessary to ensure protection of human health and the environment, in the area surrounding the Potomac River Generating Station, including the potential reduction of levels of operation, or potential shutdown of the facility.” (emphasis in original)

In response to the letter from the VDEQ, Mirant chose to shut down all five of the generating units at the Plant on August 24, 2005.

On August 24, 2005, the D.C. Public Service Commission filed an Emergency Petition and Complaint with DOE that requested DOE to issue an emergency order directing Mirant to continue operation of the Plant in order to prevent the risk of a blackout in the Central D.C. area (DCPSC 2005). The Commission also requested that the Federal Energy Regulatory Commission (FERC) issue a similar order under Sections 207 and 309 of the FPA.

Mirant then completed a refined computer modeling study using more realistic scenarios that indicated that the Plant could operate, in a limited fashion, within air quality standards. Thus, on September 21, 2005, Mirant restarted only Unit 1 at the Plant. From that date until the DOE Order was issued, Mirant operated that unit on an 8-8-8 basis – that is, in any given 24-hour period, the unit ran for up to eight hours at its maximum level, ran for eight hours at its minimum level, and did not run for eight hours. Mirant also experimented during this period with using trona (i.e., sodium sesquicarbonate, a naturally occurring substance similar to baking soda) or low-sulfur Colombian coal³, alone or in combination, to control SO₂ emissions in order to determine if such changes would allow simultaneous operation of more than one unit without causing NAAQS exceedances.

² (...continued)

when aerodynamic turbulence induced by nearby structures causes pollutants from an elevated source (such as a smokestack) to be mixed rapidly towards the ground resulting in higher ground-level concentrations of pollutants.”

³ During its experiments with low-sulfur coal from Colombia, Mirant determined that the higher moisture content in this type of coal created multiple operational problems. For example, the Plant was unable to dry the coal sufficiently for the coal pulverizers to maintain adequate throughput rates, and the moisture resulted in reduced efficiency of both the combustion and the heat transfer processes. For these reasons after its initial test of Colombian coal, Mirant decided not to use it any further.

After receiving the Commission's petition, DOE conducted an independent examination of the electricity reliability situation in the Central D.C. area and analyzed the Plant's role in ensuring a reliable supply of electricity to that area (Kirby and Kueck 2005). DOE also consulted with Federal and state officials responsible for environmental compliance (e.g., EPA shared information with DOE regarding NAAQS modeled results and other environmental issues at the Plant) and private entities responsible for electricity transmission. DOE's investigation found that the Plant must be available to run when one of the 230-kV lines is out of service in order to maintain a minimally reliable electric power system, because outage of the remaining line could result in a blackout of the Central D.C. area. DOE's investigation also found that the Plant should be operated in such a way as to minimize the amount of time needed to bring it into full operation to be better able to meet electric reliability needs quickly whenever one of the two 230-kV transmission lines was unexpectedly removed from service.

After DOE's investigation, on December 20, 2005, the Secretary issued the Order stating:

I find that in the circumstances presented here, an emergency exists that justifies the issuance of a section 202(c) order. My determination is not based on any single factor, but on the combination of all relevant facts and circumstances. In particular, I find that an emergency exists because of the reasonable possibility an outage will occur that would cause a blackout, the number and importance of facilities and operations in our Nation's Capital that would be potentially affected by such a blackout, the extended number of hours of any blackout that might in fact occur, and the fact that the current situation violates applicable reliability standards.

DOE's Order directed Mirant to generate electricity at the Plant under certain, limited circumstances and to do so in such a way as to minimize adverse environmental impacts. The Order required Mirant to (1) operate the Plant to produce the amount of power (up to its full capabilities) needed to meet demand in the Central D.C. area during any period in which one or both of the 230-kV lines serving the Central D.C. area were out of service and (2) in situations when both lines are functioning, keep as many generating units in operation and take all other measures to reduce the start-up time of units not in operation, without regard to cost and without causing or significantly contributing to any exceedance of the NAAQS, in order to provide electrical reliability to the Central D.C. area. The Order also required Mirant to submit a plan to DOE within ten days indicating how it would comply with the Order. (See Appendix A for the full text of the Order.)

On December 30, 2005, as required by the DOE Order, Mirant submitted a plan describing how it would comply with the Order. The plan outlined a proposed temporary phase and two options for a proposed intermediate phase: Option A and Option B. All proposals included the use of trona and/or low-sulfur coal to manage air emissions. Mirant stated in its compliance plan that "Option A results in no modeled NAAQS exceedances." Mirant also stated

that “Option B offers dramatically better reliability than Option A, but results in a marginal computer-modeled exceedance of the 24-hour NAAQS for [SO₂], although the 3-hour and annual NAAQS for SO₂ are met. Moreover, that exceedance was modeled to occur infrequently in the course of a year and only on the top floor balconies and the roof of the Marina Towers condominium...” After reviewing Mirant’s compliance plan, DOE instructed Mirant on January 4, 2006, to “immediately take the necessary steps to implement Option A.” Between January and May, the Department continued to weigh other options that were available to Mirant to comply with the DOE Order.

On June 1, 2006, Mirant entered into an Administrative Compliance Order (ACO) with EPA regarding operation of the Plant. (See Appendix B.) On June 2, 2006, DOE concluded that operation of the Plant under Option A did not provide an adequate level of electric reliability to the Central D.C. area and that operation of the Plant pursuant to the ACO was necessary to assure an adequate level of electric reliability to the Central D.C. area. Mirant has since that time operated the Plant in accord with those instructions from DOE. Since June 2, 2006, the operation of the Plant under the Order thus followed the scheme summarized in the following paragraphs. (See Section 4.1 for details.) The ACO will expire one year after it was issued, on June 1, 2007.

During “non-line outage situations” the operation of the Plant must follow the ACO, under which Mirant is to “keep as many units in operation,” and “take all other measures to reduce start-up time of units not in operation, for the purpose of providing electricity reliability so long as such operations are in accordance with paragraph B of Part IV of the ACO.” Among other things, paragraph B authorizes operation in accordance with “daily predictive modeling.” Under daily predictive modeling, the Plant operators acquire the appropriate weather forecast for the next day and use that forecast, along with their planned operating parameters, as inputs to conduct a computer modeling run for the following day’s planned operation. If the modeling results indicate that operating the Plant under those conditions would not cause a modeled NAAQS exceedance for 3-hr and 24-hr average SO₂ and PM₁₀, the operators may run the Plant on that day using those parameters. If the modeling results indicate that operation of the Plant would cause an exceedance of these NAAQS, the operators adjust their planned operating parameters until the modeling results indicate compliance with the NAAQS. The operators may then operate the Plant using those parameters. Thus, under this scenario the Plant can operate on any one day up to the maximum level allowed by the preceding day’s weather forecast.

The ACO requires Mirant to maintain alarms that alert the Plant operators if monitored average concentrations reach 80% of the standards for SO₂, including the annual SO₂ standard. In addition, the ACO requires Mirant to install and operate six new SO₂ ambient monitoring stations in the vicinity where elevated pollutant concentrations have been predicted and to conduct actual monitoring of ambient SO₂ concentrations.

During “line outage situations,” the ACO places environmental requirements on Mirant in addition to the requirements of the DOE Order. It requires Mirant to “take all reasonable steps to limit the emissions of PM₁₀, NO_x and SO₂ from each boiler, including operating only the number of units required to meet PJM’s directive and optimizing its use of trona injection to

minimize SO₂ emissions.” Further, the ACO requires that Mirant achieve “80% reduction of SO₂ emissions unless: 1) Mirant demonstrates ... that 80% reduction is not necessary to achieve compliance with the NAAQS; or 2) Mirant demonstrates that 80% reduction is not logistically feasible because of such factors as the quantity of available trona and the predicted duration of the outage.” If Mirant demonstrates that 80% removal is not logistically feasible, it is required to submit a plan to EPA for optimizing its use of trona.

On September 28, 2006, DOE issued an extension of the Order, including all of its terms and conditions, until 12:01 am on December 1, 2006.

Table 1.3-1. Chronology of major actions and events related to the Plant

Date	Agencies and other companies	Mirant; Potomac River Generating Station
2004		
September 23	Effective date of Order by Consent between VDEQ and Mirant	
2005		
until August 20		Historical operations; <i>Pre-shutdown mode for this SEA</i>
August 19		Mirant submitted emissions modeling study to VDEQ
August 19	VDEQ requested Mirant to immediately undertake actions to protect human health and environment around the Plant	
August 21		Output at Plant reduced to lowest feasible level from all five units
August 24		Operations at the Plant ceased
August 24	D.C. Public Service Commission filed emergency petition and complaint with DOE and FERC	
September 21		Unit 1 (one of the two load-following or cycling units) restarted on an 8-8-8 basis ³
September 21 - November 11		Unit 1 operated on an 8-8-8 basis

³ That is, in any given 24-hour period, the unit ran for up to eight hours at power levels up to its maximum level of 88 MW, ran for eight hours at its minimum level of 35 MW, and did not run for eight hours.

Table 1.3-1. Chronology of major actions and events related to the Plant

Date	Agencies and other companies	Mirant; Potomac River Generating Station
November 11 - November 23		Unit 1 operated on an 8-8-8 basis with trona testing
November 24 - December 14		Unit 1 operated on an 8-8-8 basis with Colombian coal testing, but without trona
December 15 - December 20		Unit 1 operated on an 8-8-8 basis with Colombian coal and trona testing; <i>Pre-Order mode for this SEA</i>
December 20	DOE consulted with CEQ	
December 20	The Secretary of Energy issued emergency order requiring Mirant to operate the Plant to assure a reliable supply of electricity to central Washington, D.C.	
December 21- December 23		Plant operated as during December 15 - December 20 period
December 22	DOE consulted with CEQ	
December 24		No data available on Plant operations
December 25 - December 31		Unit 1 operated without using low sulfur coal or trona
December 30		Mirant submitted its compliance plan (also known as the Operating Plan) to DOE identifying two options, A and B
2006		
January 1		No data available on Plant operations
January 2 -3		Unit 1 operated without using low sulfur coal or trona
January 4	DOE instructed Mirant to implement proposed Option A in compliance plan	Plant began to operate under conditions in Option A in compliance plan; Plant continued to operate under Option A until June 2 except during transmission line outages (indicated below).

Table 1.3-1. Chronology of major actions and events related to the Plant

Date	Agencies and other companies	Mirant; Potomac River Generating Station
January 6	PJM specified that it was necessary for Mirant to operate the Plant to meet entire Central D.C. load during transmission line outages Pepco proposed for January 7 - 19 and 22 - 27 for maintenance.	
January 7 - 19		Plant operated to meet entire Central D.C. load during line maintenance.
January 13	DOE consulted with CEQ	
January 17	DOE consulted with CEQ	
January 20	DOE issued <i>Federal Register</i> notice describing its emergency action and requesting comments on scope of the SEA.	
January 21		A second trona unit became operational
January 21 - 28		Plant operated to meet entire Central D.C. load during line maintenance.
February 21	End of comment period on <i>Federal Register</i> notice	
March 6	Pepco receives permission from the D.C. Public Service Commission to construct two new 230-kV lines into the D.C. area and two new 69-kV lines to serve the Blue Plains Wastewater Treatment Plant	
March 20		Third trona unit became operational
March	U.S. Department of Health's Agency for Toxic Substances and Disease Registry began a review of the existing air quality and other environmental data related to the Plant, as requested by the Director of the Alexandria Health Department.	
May 31		All five trona units operational
June 1	EPA issued an ACO to Mirant	
June 2	DOE instructed Mirant to comply with the ACO with EPA	

Table 1.3-1. Chronology of major actions and events related to the Plant

Date	Agencies and other companies	Mirant; Potomac River Generating Station
June 20		Operation began in accordance with daily predictive modeling
July 15	Pepco places two newly constructed 69-kV lines into service at the Blue Plains Wastewater Treatment Plant	
September 28	The Secretary of Energy extended emergency order for two months	
October 1	DOE Order was scheduled to expire at 12:01 am	
November 27 - December 11	Pepco plans transmission line outage for repairs	Full Plant generation will be required to meet central D.C. predicted load because of Pepco line repairs.
December 1	Extension to DOE Order expires at 12:01 am	
2007		
February 19 - March 5	Pepco plans transmission line outage for upgrades	Full Plant generation will be required to meet Central D.C. predicted load because of Pepco line upgrades.
May 2 - 15	Pepco plans transmission line outage for upgrades	Full Plant generation will be required to meet Central D.C. predicted load because of Pepco line upgrades.
May 21 - June 15	Pepco plans transmission line outage for upgrades	Full Plant generation will be required to meet Central D.C. predicted load because of Pepco line upgrades.
June 1	The ACO expires.	
late June	Pepco plans to have two new 230-kV transmission lines in service	.
Fall		Mirant plans to take units out of service to reconfigure the exhaust stacks.

1.4 National Environmental Policy Act (NEPA) Process

Major Federal actions significantly affecting the human environment generally call for DOE to prepare an environmental impact statement (EIS) before taking the action to analyze

impacts in compliance with NEPA. However, in emergency situations, pursuant to 40 CFR 1506.11, the CEQ's NEPA regulations provide that agencies consult with CEQ to determine what alternative arrangements the agency will take in lieu of preparing an EIS. DOE consulted with CEQ on December 20, 2005, December 22, 2005, January 13, 2006, and January 17, 2006, on a plan for alternative NEPA arrangements. Under this plan (71 FR 3279, January 20, 2006) DOE agreed to:

- Prepare a SEA to examine the potential impacts resulting from issuance of the Order and describe further DOE decision-making regarding reasonable future alternatives;
- Provide opportunities for public involvement;
- Continue to consult with EPA and the VDEQ concerning information on emissions, modeling results, potential mitigation measures, and any changes in the operation of the Plant; and
- Identify in the SEA steps that could be taken to mitigate any impacts from the DOE Order.

Consistent with the consultations with CEQ, DOE has prepared this SEA.

1.5 Public Involvement

As described above, on January 20, 2006, DOE published a *Federal Register* notice (71 FR 3279) (Appendix C) in which DOE described the action it had taken under the Order and reported its discussions with CEQ and its agreement to issue an SEA as part of its alternative arrangements for NEPA compliance.

DOE also used that *Federal Register* notice to request public comments on the information in the notice, as well as on issues to be addressed in the SEA. The comment period closed on February 21, 2006. DOE received comments from the following organizations: the Mount Vernon group and the Virginia Chapter of the Sierra Club; the Southern Environmental Law Center on behalf of itself and the American Lung Association of Virginia ; the City of Alexandria; and the Institute for Public Representation on behalf of the Potomac Riverkeeper, Inc., the Patuxent Riverkeeper, and the Anacostia Riverkeeper at Earth Conservation Corps. These comments are posted on the DOE website described below. Commentors identified many of the same issues that DOE had determined should be covered in the SEA. Section 1.6 describes where these issues are addressed in this document.

DOE maintains a website containing information (under DOE Docket EO-05-01) about the D.C. Public Service Commission Petition, its proceedings, and the DOE Order itself: <http://www.oe.energy.gov/permitting/372.htm>. This website also provides links to correspondence related to the petition and the Order, as well as the *Federal Register* notice and the comments received on that notice.

1.6 Scope of the Analysis

Based on its own evaluation of potential impacts and the concerns expressed by commentors, DOE has analyzed the below effects of Plant operations under the Order in the indicated sections of this SEA. Cumulative effects are discussed as appropriate in each section as described at the beginning of Section 4.3.

- Effects of any increased *air emissions* (Section 4.3.1);
- *Health* effects on Plant workers and the public of any increased air pollution; commentors on the DOE *Federal Register* notice expressed particular concern about impacts of increased particulate emissions, especially particulate matter smaller than 2.5 microns (PM_{2.5}), and of increased emissions of trace metals and hazardous air pollutants (especially arsenic, beryllium, lead, chromium, cadmium, nickel, and mercury) (Section 4.3.2);
- *Water quality* (Section 4.3.3) and *ecological* (Section 4.3.4) effects due to changes in Plant water use and releases or any increased deposition of air pollutants on soil and terrestrial communities, water bodies, and watersheds; commentors on the DOE *Federal Register* notice expressed concern about the potential for any increased emissions of SO₂ and NO_x to contribute to acid rain, nutrient loading to aquatic systems, and deposition of heavy metals, and the subsequent impacts on the aquatic resources of the Chesapeake Bay and several of its tributaries, specifically the Potomac, Anacostia, and Patuxent rivers;
- *Waste management* impacts (Section 4.3.5), particularly impacts of trona utilization, which commentors on the DOE *Federal Register* notice identified as a concern;
- *Transportation impacts* from increased shipping of coal and trona to the Plant and of wastes away from the Plant (Section 4.3.6); and
- *Environmental justice* impacts (Section 4.3.7).

This SEA also describes alternatives for potential future decision-making that include mitigation measures should the Order be further extended. Among these are several measures suggested by commentors on DOE's *Federal Register* notice on the proposal to prepare this SEA and parties commenting on the Order itself.

Because of the limited nature of the action, certain types of impacts that are usually analyzed in NEPA documents are not addressed.

- Because there would be no construction outside the footprint of the existing facility, no impacts to *land use, soil structure, floodplains, or aesthetics* are expected.
- Because only very small amounts of construction and employment are associated with the changed operations at the Plant, no appreciable effects on *social or economic resources* are anticipated.

A commentor expressed concern about possible adverse effects of trona utilization on Plant equipment. This concern is not addressed because it is not considered to be an environmental impact.

2. DESCRIPTION OF THE MIRANT POTOMAC RIVER GENERATING STATION

The Plant, which has been operating since 1949, was acquired by Mirant Potomac, Inc in 2000. It is located in Alexandria, Virginia, on the western bank of the Potomac River near the District of Columbia, about 5 miles (8 km) south-southwest of the U.S. Capitol building. (See Figure 2-1.) It is almost directly across the river from the Blue Plains Wastewater Treatment Plant and near Ronald Reagan Washington National Airport. Two National Park Service sites, the George Washington Memorial Parkway, developed both as a memorial to George Washington and to preserve the natural scenery along the Potomac River (NPS undated), and the Mount Vernon Trail (Figure 3.4-1), run past the Mirant Plant.




Figure 2-1. The location of the Plant in relation to the central Washington, D.C. area.

The site occupies approximately 28 acres (11 ha) and was relatively remote when the power plant was built. Alexandria has, however, grown up around it, and residential areas are now located immediately adjacent to the Plant. (See Figure 2-2.)

2.1 Site Layout

The footprint of the Mirant Plant is typical for a coal-fired electricity generation facility (see Figure 2.1-1), consisting of a large coal pile and a set of five steam generating boilers. The Plant has five stacks, each 161 ft (49 m) high (Mirant 2006a).

2.2 Plant Equipment and General Operation

The Plant consists of five steam boilers and associated generators with a net generating capacity of 482 megawatts (MW) of electricity for delivery to Central D.C. area customers. Units 1 and 2 are designed to be capable of load-following or cycling; that is, they are capable of changing power levels quickly as demand rises or falls. These units each have a generating capacity of 88 MW (with an operating range of 35 MW to 88 MW). Units 3, 4, and 5 are

designed for baseload operation; that is, they are intended to generate power at a steady rate for extended periods, typically 24 hours per day, and have historically been used more than Units 1 and 2 (Mirant 2006a). Units 3, 4, and 5 each have a generating capacity of 102 MW (with an operating range of 35 MW to 102 MW).

The facility uses oil to pre-heat units during startup and then burns coal. The Plant receives coal by rail car delivered by the CSX Railroad. (See Figure 2.1-1.) The rail cars are unloaded at a dedicated rail siding at the Plant. Typical plant operations involve unloading the rail cars and feeding some coal directly into the boiler building; additional coal is stored on-site in an outdoor coal pile with a capacity of 135,000 tons (122,000 metric tons). The coal storage yard occupies 4 acres (2 ha) and has an average coal-pile height of about 30 ft (9 m). Diesel-fueled bulldozers move the coal around the footprint of the coal pile, and a conveyor system transfers coal from the coal pile into the boiler building. The coal is pulverized in the boiler building and sized for injection into the five boilers. Steam is then piped from the boilers into the turbine building where the generators produce electricity.

Flue gases from each of the five boiler units exhaust to the atmosphere through separate, dedicated stacks. (See Figure 2.1-1.) Pollution abatement equipment at the Plant consists of hot- and cold-side electrostatic precipitators for each boiler unit. These precipitators remove solid particulate matter, called fly ash, from the exhaust gas streams. The fly ash collected by the precipitators is stored in a pair of on-site silos prior to being shipped by covered truck for off-site




Figure 2-2. Aerial photo showing the Plant and surrounding residences.

disposal. Bottom ash from the boilers is collected and stored in a silo prior to being shipped off-site for beneficial use. (See Section 2.4.3)

The Plant also has trona injection units for each of the five boiler units. Each trona injection unit consists of 8 or 10 injection nozzles in the outlet duct from the boiler economizer to the hot-side precipitator inlet. Each injection unit is capable of injecting trona at a rate of up to 12,000 lb/hour (5,500 kg/hour), which Mirant's study determined to be sufficient to remove 80% of SO₂ from flue gas (Mirant 2006c). At maximum capacity the trona injection units on all five boilers can utilize a total of 25 tons (23 metric tons) of trona per hour to remove about 80% of SO₂ from flue gases.

Trona is delivered to the site in 100-ton (91-metric ton) railcars shipped directly from the mine in Green River, Wyoming. Trona is fluidized and transferred pneumatically from the railcars to a 35-ton-capacity (32-metric ton-capacity) trona feed trailer adjacent to each boiler. Trona is transferred pneumatically to the boiler unit outlet duct where it is injected.

The Plant has a once-through cooling water system. Raw water is pumped from the Potomac River through a 1,250-ft² (116-m²) rectangular intake area located on the river bottom along the shoreline, about 10 ft (3 m) below the water surface (Personal communications between D. Cramer, Mirant Corporation, and E.D. Smith, Oak Ridge National Laboratory, July 12, 2006, and between A. Wearmouth, Mirant Corporation, and E.D. Smith, Oak Ridge National Laboratory, July 21, 2006). The intake area is made up of 10 intake bays (two for each of the boiler units), each of which is 13.5 ft (4.1 m) long by 9 ft (3 m) wide and equipped with a 30,000-gal/min (about 100 m³/min) pump (Personal communication between A. Wearmouth, Mirant Corporation, and E.D. Smith, Oak Ridge National Laboratory, July 21, 2006). Mirant installed new fine-mesh screens on the intakes in July and August 2005. One screen on an intake for Unit 1 is fitted with "fish buckets" for enhanced fish protection. All screens, with or without the enhanced system of fish recovery, facilitate the return of fish to the river south of the power plant intake. After removing debris and suspended solids, the Plant uses this water to cool condensers and auxiliary equipment associated with steam turbines (Mirant 2006b). Major water




Figure 2.1-1. The site layout of Mirant's Potomac River Generating Station.

treatment equipment includes a clarifier, settling pond, neutralization system, and an oil/water separator.

2.3 Resource Requirements

The Plant primarily uses three resources: coal, trona, and water. Each of these is discussed separately in this section.

In the period prior to August 24, 2005, the Plant typically used an average of about 2,280 tons (2,050 metric tons) of coal per day. Operation at full capacity could require up to 5,150 tons (4,670 metric tons) of coal daily. The Plant normally used central Appalachian coal with a heating value of about 12,000 Btu/lb, an ash content of about 14%, a sulfur content of 0.64% by weight, and a carbon content about 67% by weight.

Analyses of coal burned in 2003 indicates that the average mercury content was between 0.03 and 0.07 ppm (dry). DOE conservatively assumes that the coal consumed by Mirant contains 0.07 ppm mercury on average, or about 1.4 lb (0.6 kg) mercury per 1,000 tons (910 metric tons) of coal.

The coal data that Mirant provided to DOE did not include concentrations of toxic metals other than mercury. Table 2.3-1 presents some published data on concentrations of seven trace metals in other central Appalachian coals. These analyses provide an approximate indication of levels that may be present in the central Appalachian coal burned by the Plant.

Table 2.3-1. Ranges of values for trace metal concentrations in as-mined samples of Appalachian coals

Trace metal	Reported concentrations (mg/kg)
Arsenic	7 – 23
Cadmium	ND – 0.2
Lead	15 – 24
Selenium	ND – 2.9
Beryllium	1 – 2
Chromium	30 – 63
Nickel	18 – 34

ND = below quantitation limit

Source: Palmer et al. 1997.

Trona consumption is determined by the target for SO₂ removal. Theoretical calculations show that if trona reacted completely with SO₂ in the hot-side precipitator inlet gas, 2.354 parts by weight of trona would be required to react with each part by weight of SO₂ (e.g., 2.345 lb trona per lb of SO₂). However, testing by Mirant found that much larger quantities of trona must be used in order to achieve desired SO₂ removal rates. Addition of trona to the exhaust gas stream at five times the theoretically calculated rate was found to remove 80% of the SO₂ (Mirant 2006c). For typical coal burned at the Plant, removal of 80% of SO₂ would require 0.15 lb of trona per lb of coal burned (1 lb trona per 6.7 lb coal). Because Mirant does not operate the Plant to achieve 80% SO₂ removal most of the time, average trona consumption is about 1 lb for every 8.5 lb of coal consumed (Personal communication between D. Cramer, Mirant Corporation, and L.N. McCold, Oak Ridge National Laboratory, July 7, 2006).

Water withdrawals from the Potomac River for cooling water and other in-plant uses are estimated to be about 1% higher than discharges (Personal communication between A. Wearmouth and D. Cramer, Mirant Corporation, and E.D. Smith, Oak Ridge National Laboratory, July 14, 2006). Therefore, based on discharges (Section 2.4.2), withdrawals are estimated to have averaged somewhat less than 350 million gal/day (1.3 million m³/day) under pre-shutdown operating conditions (prior to August 24, 2005).

2.4 Waste and Effluents

2.4.1 Air Emissions

The VDEQ approved a Stationary Source Permit to Operate on September 18, 2000, and a Phase II Acid Rain Permit on February 28, 2003. The Stationary Source Permit limits NO_x (as NO₂) emissions to 0.38 lb/MBtu. The EPA judicial consent decree, as amended (EPA 2004, 2006g), requires Mirant to limit Plant total NO_x emissions during the May 1 to September 30 period each year to 1,600 tons (1,500 metric tons) through 2009, among other things. The Acid Rain Permit allocates annual allowances for air emissions of SO₂ during its effective period of January 1, 2003, through December 31, 2007. SO₂ allowances for individual generating units range from 2308 to 3036 tons/year and total 13,344 tons/year for all units combined; in addition, the permit authorizes Mirant to acquire SO₂ allowances from other sources. The Acid Rain permit also limits emissions of NO_x, but the limitation on NO_x is less restrictive than the limit in the Stationary Source Permit.

The coal burned at the Plant averages about 67% by weight carbon. On a day when the Plant consumed 2,280 tons (2,050 metric tons) of coal, as it typically did in the period prior to August 24, 2005, it released about 11 million lb (5,600 tons) of CO₂.

2.4.2 Water Effluents

Plant effluents, including cooling water, boiler blowdown, runoff from the coal pile and fly ash handling areas, and other storm water runoff, are discharged to the Potomac River under National Pollutant Discharge Elimination System (NPDES) permit DC0022004. This permit was last issued for a 5-year duration in 2000 and expired in 2005. Mirant applied for renewal in 2004 (Wearmouth 2004), and the existing permit remains in force while EPA considers the application for renewal (Capacasa 2005). According to the renewal application (Wearmouth 2004), under historical operating conditions discharge under this permit averaged almost 345 million gal/day (1.3 million m³/day), of which all but about 0.4 million gal/day (1,500 m³/day) was once-through cooling water.

Boiler blowdown and effluent from treatment (i.e., demineralization) of intake water are treated by sedimentation and neutralization. Before being mixed with other wastewaters, they are monitored (in accordance with permit requirements) for flow rate, pH, total suspended solids, and oil and grease to verify that concentration limits in the permit are met. Ash clarifier system wastewater and runoff from the coal pile and fly ash handling areas are treated by rapid mixing, flocculation, and precipitation. They are monitored for the same set of parameters prior to mixing with other wastewaters. Once-through cooling water and storm water runoff from uncontaminated areas are blended with the treated effluents and discharged without additional treatment. No chlorine or other chemicals are added to the cooling water or used in the Plant's other water processes.

The NPDES permit requires monitoring of flow rate and other parameters at several internal monitoring points and at outfalls. Mirant submits monthly reports with the monitoring data to EPA and the Washington, D.C. Department of Health (Mirant 2006b). The Plant's primary wastewater outfall is subject to permit limits on pH, total residual chlorine, thermal output, and temperature rise in the river. Heat discharge in cooling water is limited to 4,286 MBtu/hr. Temperature rise in the river is limited to 2.8°C above ambient temperature and a maximum temperature of 32.2°C beyond a 1,000-ft (300-m) radius of the discharge point when the ambient river temperature is less than 27.8°C and beyond a 1,600-ft (490-m) radius when the river temperature is warmer than 27.8°C. Mirant conducted temperature surveys in the river in 2001 that confirmed that heat discharge from the Plant does not cause exceedance of these temperature limits, so temperature monitoring in the river is not required (Mirant 2002, NPDES permit document, and personal communication between A. Wearmouth, Mirant Corporation, and E.D. Smith, Oak Ridge National Laboratory, July 14, 2006).

Table 2.4-1 lists reported concentrations of selected contaminants in the Plant's cooling water intake and in effluent from the outfall that receives cooling water and treated wastewaters from demineralization, boiler blowdown, coal pile runoff, and fly ash handling. The table includes data for many parameters that are not listed in the Plant's NPDES permit. The near-neutral effluent has higher levels of biochemical oxygen demand, suspended solids, nitrate and nitrite, sulfate, aluminum, iron, manganese, copper, and fecal coliform bacteria than the intake

water, while loadings of chemical oxygen demand, total organic carbon, residual chlorine, phosphorus, and phenols are decreased in the effluent compared with the intake water.

Table 2.4-1. Water quality of Plant intake water and cooling water effluent

Contaminant	Intake Concentration (mg/L)	Effluent Concentration (mg/L, except as indicated)
Biochemical oxygen demand	9.6	14
Chemical oxygen demand	22	21
Total organic carbon	4.7	4.3
Total suspended solids	24	39
Fecal coliform bacteria	27	110
pH (pH units)	—	7.6
Chlorine, total residual	0.15	0.05
Fluoride	0.20	0.12
Nitrate-Nitrite as N	1.1	1.2
Nitrogen, total organic	ND	ND
Phosphorus	0.076	0.060
Sulfate	33	37
Aluminum	0.75	1.4
Iron	0.86	1.5
Manganese	0.11	0.13
Copper	ND	0.013
Zinc	0.023	0.023
Phenols, total	0.015	0.014

ND = Not detected

— = Not reported

Source: Wearmouth 2004; These values are from a single set of measurements and may not be representative.

2.4.3 Solid Wastes

The Plant's principal solid wastes are fly ash collected from exhaust gases and bottom ash from the boilers. (See Section 2.2.) Under pre-shutdown operating conditions prior to August 24, 2005, reported fly ash generation totaled about 14,200 tons/month (12,900 metric tons/month), equivalent to about 20% of coal consumption. Bottom ash generation equals about 25% of the fly ash generation (Personal communications between D. Cramer, Mirant Corporation, and L.N. McCold, Oak Ridge National Laboratory, July 7, 2006; and between D.

Cramer, Mirant Corporation, and E.D. Smith, Oak Ridge National Laboratory, July 12, 2006, and July 14, 2006).

Fly ash is sent by covered truck to the Brandywine Fly Ash Facility, a landfill located in southeastern Prince George's County, Maryland (Figure 2.4-1), that is owned and operated by Mirant Ash Management LLC and used solely for disposal of coal combustion ash. (See Section 3.5.) Plant fly ash is marketed for beneficial use, primarily for structural fill, but historically its utilization has been very limited (Personal communication between D. Cramer, Mirant Corporation, and L.N. McCold, Oak Ridge National Laboratory, July 7, 2006). The fly ash generated by the Plant under historical operating conditions is a pozzolanic material (that is, when mixed with water it “sets,” like cement), but its unburned carbon content is too high to permit its use as a cement substitute (TFHRC undated). Bottom ash from the Plant is used or sold for purposes such as road fill.




Figure 2.4-1. The location of and access routes to the Brandywine Fly Ash Facility used for disposal of solid wastes from the Plant.

Note: Mataponi Creek (not shown on the map) originates near Brandywine and flows east-northeast to the Patuxent River.

2.5 Changes to the Plant Since the DOE Order

Mirant has made several changes inside the existing Plant buildings since the DOE Order. The most important of these is the addition of trona injection units to all five boilers. Mirant has also made provision to withdraw trona from rail cars and transfer it to storage

containers inside the building. Several measures to control fugitive dust (for example, improved ash-loading systems for the two fly ash silos) were implemented during 2005 and 2006 in response to a 2004 EPA judicial consent decree (EPA 2004) that required Mirant to take actions to reduce fugitive particulate emissions. None of these changes included new construction or other disturbances at the Plant site.

Mirant is planning to merge the boiler exhaust gases from Units 1 and 2 and run the combined exhaust through the stack of Unit 1. Similarly Mirant is planning to merge the boiler exhaust gases from Units 3, 4, and 5 and run them through the stack of Unit 4. Mirant's modeling shows that combining the gas flows from the two units into one stack and from the three other units into another stack produces higher exit velocities and increases plume rise for all emissions into the atmosphere and, thus, lessens the potential for downwash impacts (Personal communication between D. Cramer, Mirant Corporation, and L.N. McCold, Oak Ridge National Laboratory, July 7, 2006).

Merging unit exhaust gases requires new common ductwork to be installed connecting the individual unit exhaust fan discharges, and installation of new higher capacity fans. This common ductwork will be connected to the existing stack at the existing location at the base of the stack. This common ductwork will be installed inside the existing plant structure and will not be visible from the ground since it will be located in-between the existing precipitator and stacks. There will be no foundations required for this ductwork.

Mirant plans to implement the exhaust system changes during the fall of 2007 (Personal communication between Richard Killian, EPA Region 3, and L.N. McCold, Oak Ridge National Laboratory, October 16, 2006). Each Plant generating unit is expected to have an outage of 7 to 9 weeks in order to remove the existing equipment and install the new equipment.

3. AFFECTED ENVIRONMENT

This section describes the resources and environmental conditions that could be affected by the DOE action. The areal extent of this “affected environment” is not the same for all potentially affected resource areas. Also, because the purpose of this descriptive information is to lay the foundation for evaluating potential environmental impacts of the action, not all resources and geographic areas are described at the same level of detail.

For air quality the extent of the affected environment is very large because air emissions from the Plant are transported within a large region. However, because the potential effects of greatest interest, including the potential for exceedances of ambient air quality standards, are concentrated in a local area very near the Plant, the description and assessment in this document focus primarily on a 36-mi² (93-km²) area within about 3 mi (5 km) of the Plant. Similarly, the area of primary interest for human health and environmental justice is this same 36-mi² (93-km²) area.

For water resources and ecosystems the affected environment consists primarily of the resources directly affected by Plant operations, including the Potomac River, the Plant site, and neighboring lands. However, because atmospheric deposition of contaminants emitted from the Plant to the air contributes to cumulative impacts to water quality and ecosystems in a larger region, the Anacostia River, Patuxent River, Chesapeake Bay, and other land and water areas (including Potomac River tributaries and their watersheds) within about 20 miles (32 km) of the Plant are treated as part of the affected environment for water resources and ecosystems.

For waste management and transportation the affected environment includes the Plant site; the landfill used for disposal of Plant fly ash; the local roads and rail facilities used for access to the Plant and landfill; and resources in the immediate vicinity of these facilities that may be affected by their air, water, or noise emissions.

3.1 Climate and Air Quality

3.1.1 Climate

The Plant is in Alexandria, Virginia, which lies at the western edge of the mid-Atlantic Coastal Plain, about 50 mi (80 km) east of the Blue Ridge Mountains and 35 mi (56 km) west of the Chesapeake Bay, adjacent to the Potomac River. Elevations range from a few feet (about a meter) above sea level to about 400 ft (122 m).

Weather observations in the vicinity have been kept continuously since November 1870. Since June 1941, the official observations have been taken at Ronald Reagan Washington National Airport (National Airport), just north of the Plant.

National Airport is located at the center of a large urban complex. As a result, low temperatures there are higher than those in surrounding areas. In winter low temperatures at the airport are often 10-15°F (6-8°C) higher than in suburban locations. There is less difference between airport and suburban high temperatures. The normal summertime high temperatures range from 85-90°F (30-32°C), and the average winter lows range from 26-32°F (-3 to 0°C). Normal precipitation is distributed rather uniformly throughout the year, ranging, approximately, from 2.7 to 3.9 inches (6.9 to 9.9 cm) per month.




Figure 3.1-1. Wind rose for Ronald Reagan Washington National Airport, 2000-2004 weather data

Thunderstorms can occur at any time but are most frequent during the late spring and summer. The storms are often accompanied by downpours and gusty winds, but are not usually severe. Tornadoes, which occur infrequently, have resulted in significant damage. Severe hailstorms have occurred in the spring. Tropical storms can bring heavy rain, high winds, and flooding, but extensive damage from wind and tidal flooding is rare. Wind gusts of nearly 100 mi (160 km) per hour and rainfall over 7 inches (18 cm) have occurred during the passage of tropical storms.

Normal snowfall during the winter season is 15 inches (38 cm). The average date of the last freezing temperature in the spring is April 1, and the average date for the first freezing temperature in the fall is November 10.

Winds are most often from the south or south-southwest and from the north-northwest (Figure 3.1-1).

3.1.2 Air Quality

Criteria pollutants are defined as those for which National Ambient Air Quality Standards (NAAQS) exist (Table 3.1-1). These pollutants are carbon monoxide (CO), lead (Pb), nitrogen dioxide (NO₂), ozone (O₃), particulate matter less than or equal to 10 µm in aerodynamic diameter (designated PM₁₀), particulate matter less than or equal to 2.5 µm in aerodynamic diameter (designated PM_{2.5}), and sulfur dioxide (SO₂).

Table 3.1-1. National Ambient Air Quality Standards for criteria pollutants

Pollutant	Averaging period	Concentration
CO	8-hour ^a	9 ppm (10 mg/m ³)
	1-hour ^a	35 ppm (40 mg/m ³)
Lead	Maximum quarterly average	1.5 µg/m ³
NO ₂	Annual arithmetic mean	0.053 ppm (100 µg/m ³)
O ₃	4 th highest 8-hour daily maximum ^b	0.08 ppm (157 µg/m ³)
PM ₁₀	Annual arithmetic mean ^c	50 µg/m ³
	24-hour ^c	150 µg/m ³
PM _{2.5}	Annual arithmetic mean ^d	15 µg/m ³
	98 th percentile 24-hour ^d	65 µg/m ³
SO ₂	Annual arithmetic mean	80 µg/m ³ (0.03 ppm)
	24-hour ^a	365 µg/m ³ (0.14 ppm)
	3-hour ^a	1,300 µg/m ³ (0.50 ppm)

^a Not to be exceeded more than once per year.

^b The 8-hour standard is met when the 3-year average of the annual 4th highest daily maximum 8-hour O₃ concentration is less than or equal to 0.08 ppm.

^c The annual PM₁₀ standard is attained when the expected annual arithmetic mean concentration is less than or equal to 50 µg/m³ (3-year average); the 24-hour standard is attained when the expected number of days above 150 µg/m³ is less than or equal to 1 per year. EPA's October 17, 2006, rule making on NAAQS for particulate matter (EPA 2006j) revoked the annual PM₁₀ standard, effective December 18, 2006.

^d The annual PM_{2.5} standard is met when the annual average of the quarterly mean PM_{2.5} concentrations is less than or equal to 15 µg/m³, when averaged over 3 years. If spatial averaging is used, the annual averages from all monitors within the area may be averaged in the calculation of the 3-year mean. The 24-hour standard is met when the 98th percentile value, averaged over 3 years, is less than or equal to 65 µg/m³. Under new standards published on October 17, 2006, and effective December 18, 2006 (EPA 2006j), the 24-hour standard will be 35 µg/m³. The state of Virginia has until April 2008 to develop and submit to EPA for approval SIP provisions to implement, maintain, and enforce the new NAAQS for PM_{2.5}.

^e Same as primary standard.

Source: 40 CFR Part 50.

The NAAQS are expressed as concentrations of pollutants in the ambient air; that is, in the outdoor air to which the general public has access [40 CFR 50.1(e)]. Primary NAAQS define levels of air quality that EPA deems necessary, with an adequate margin of safety, to protect human health. Secondary NAAQS are similarly designated to protect human welfare by safeguarding environmental resources (e.g., soils, water, plants, animals) and manufactured materials. States may modify NAAQS to make them more stringent or set standards for additional pollutants. Virginia has adopted the NAAQS as the state standards without modifications.

Attainment status for NAAQS is determined primarily by evaluating data from ambient air quality monitoring stations. The monitoring station nearest to the Plant (AIRS 51-510-0009) is located at the Alexandria Health Department, 517 North Saint Asaph Street, 0.6 mile (0.9 km) south. The station monitors CO, SO₂, NO₂, and O₃. The nearest PM_{2.5} monitoring station (AIRS 51-013-0020) is located at Aurora Hills Visitors Center, 18th and Hays Streets, Arlington County, due west of Ronald Reagan Washington National Airport and 2.7 miles (4.4 km) north-northwest of the Plant. The nearest PM₁₀ monitoring station (AIRS 51-059-0018) is located at Mount Vernon Fire Station, 2675 Sherwood Hall Lane, Mount Vernon, 5.7 miles (9.2 km)

south-southwest of the Plant. Because no lead monitoring stations are employed in Virginia, this section does not discuss lead.

Table 3.1-2 summarizes recent air quality data in the vicinity of the Mirant Plant.⁴ The city of Alexandria and surrounding Arlington, Fairfax, Loudoun, and Prince William Counties are designated as NAAQS nonattainment areas for PM_{2.5} and the 8-hour O₃ standard (VDEQ 2006a, 2006b).

Table 3.1-2. Ambient air quality in the vicinity of the Plant, 2004

Pollutant	Regulated parameter	Monitored concentration ^a	NAAQS limit
CO ^b	Second highest hour	2.9 ppm	35 ppm (40 mg/m ³)
	Second highest 8-hour average	2.0 ppm	9 ppm (10 mg/m ³)
NO ₂ ^b	Annual average	0.024 ppm	0.053 ppm (100 µg/m ³)
O ₃ ^b	4 th highest 8-hour average	0.080 ppm	0.080 ppm (235 µg/m ³)
PM ₁₀ ^c	Annual arithmetic average	21 µg/m ³	50 µg/m ³
	Second highest 24-hour average ^e	44 µg/m ³	150 µg/m ³
PM _{2.5} ^d	Annual average	14.4 µg/m ³	15 µg/m ³
	98 th percentile 24-hour average	35.7 µg/m ³	65 µg/m ³
SO ₂ ^b	Annual average	0.006 ppm	0.03 ppm (80 µg/m ³)
	2 nd highest 24-hour average	0.021 ppm	0.14 ppm (365 µg/m ³)
	2 nd highest 3-hour average	0.054 ppm	0.50 ppm (1,300 µg/m ³)

^a Source: VDEQ 2005a (Just before publication of this document, Virginia released ambient air monitoring data for 2005 [VDEQ 2006c]. The updated background levels vary only slightly from the 2004 values reported and used here.)

^b Measured at Alexandria Health Department (AIRS 51-510-0009).

^c Measured at Mt. Vernon Fire Station (AIRS 51-059-0018).

^d Measured at Aurora Hills Visitors Center (AIRS 51-013-0020).

^e EPA's October 17, 2006, rule making on NAAQS for particulate matter (EPA 2006j) revoked the annual PM₁₀ standard, effective December 18, 2006.

Contaminants other than the criteria pollutants are present in the atmosphere in varying amounts that depend on the magnitude and characteristics of the sources, the distance from each source, and the residence time of each pollutant in the atmosphere. In the ambient air many of these pollutants are present in extremely small concentrations, requiring expensive state-of the art equipment for detection and measurement. Hazardous air pollutants are regulated at emission sources based on the National Emissions Standards for Hazardous Air Pollutants (40 CFR Parts 61 and 63); measurements of existing ambient air concentrations for many such pollutants are, at best, sporadic.

⁴ While additional air quality monitoring stations are located in Maryland and the District of Columbia, the monitoring station for each pollutant nearest the Plant is found in Virginia. (See Metropolitan Washington Council of Governments 2005 and VDEQ 2005a.)

3.2 Human Health

There is a well established association between exposure to outdoor air pollution and a broad variety of health effects, both acute and chronic. These health effects range from simple irritation such as burning eyes to premature death. The principal air pollutants generated by fossil fuel combustion that are associated with these health effects are PM, SO₂, and NO_x (WHO 2000). U.S. ambient air quality standards have been set at levels above background. For example, while the background concentration of SO₂ in the U.S. is about 1 µg/m³, the NAAQS for annual-average SO₂ concentration is 80 µg/m³. However, human health effects have been reported for concentrations below NAAQS levels for both PM and SO₂ (Dockery et al. 1993).

For the purposes of this SEA DOE has analyzed premature adult (age 30 and older) mortality as a useful indicator for health effects associated with air pollution because background mortality rates are readily obtainable, thereby strengthening the estimates, and the association between air pollution and mortality has well documented exposure response functions. The most recently available all-cause, all-age death rate for the area near the Plant is 7.5 deaths per year per 1000 population, as obtained from the Virginia Department of Health (2004). The most recent all-cause adult (age 30 and older) death rate in the region is 13 deaths per year per 1000 population.

3.3 Water Resources and Water Quality

Water resources potentially affected by Plant operations include the Potomac River and the Patuxent River, as well as the Chesapeake Bay, which is the destination for both of those rivers. The Potomac River supplies water to and receives effluent discharges from the Plant, and the watersheds of the Potomac and Patuxent Rivers include the land areas where air pollutants emitted from the Plant are most likely to be deposited. In addition, effluents from the landfill serving the Plant are discharged to Mataponi Creek, which is in the Patuxent River watershed. The Anacostia River and Rock Creek, which are tributaries to the Potomac located near the Plant, are also specifically discussed in this section.

3.3.1 Physical Setting and Hydrology

The Plant is situated in the Atlantic Coastal Plain physiographic province, in the watershed of Chesapeake Bay (Figures 3.3-1 and 3.3-2). Chesapeake Bay and its major tributaries, including the Potomac and Patuxent rivers, are “drowned river valleys.” That is, they are river valleys that were partially inundated by sea water when sea level rose following the end of the last Pleistocene glaciation. The Potomac, Patuxent, and other major streams in the region arise in upland areas and flow as fresh-water streams to the fall line near the edge of the

coastal plain. Below the fall line, the streams are considered to be estuaries, since their flow is modified by the influence of ocean tides. In the estuarine section of a stream, fresh water mixes with salt water in increasing proportions as the stream flows toward the sea. The effects of tides shelter the waters of these estuaries from the full effects of river currents, while river-valley geometry and stream flow shelter them from the full energy of ocean waves. Because they are sheltered from the flushing actions of both stream flow and ocean waves, water remains in these estuaries for a long time. Thus, pollutants discharged into an estuary remain there much longer than they would in an upland stream or in the open ocean. At the same time the sheltered waters of estuaries support exceptionally productive ecosystems. (See Section 3.4.)

3.3.1.1 Potomac River

The Plant is located next to the Potomac River, which flows from the Appalachian mountains to Chesapeake Bay, draining a 14,670-mi² (38,000-km²) watershed in Maryland, Virginia, West Virginia, Pennsylvania, and the District of Columbia




Figure 3.3-1. The Chesapeake Bay watershed includes the Patuxent and Potomac rivers.




Figure 3.3-2. The Chesapeake Bay watershed near the Plant includes the Potomac, Patuxent, and Anacostia rivers.

(EPA 2000; Wilderness Society undated). The river is tidally influenced for about 110 miles (180 km) from the fall line at Little Falls, Maryland (located a short distance upstream from the District of Columbia border, about 11 miles [18 km] upstream from the Plant), to its mouth at Chesapeake Bay (EPA 2000).

While the entire tidally influenced reach of the river is an estuary, it is classified in three distinct hydrographic regimes: tidal river, transition zone, and mesohaline estuary. Adjacent to the Plant the Potomac is a tidal river with fresh water (salinity less than 500 mg/L) and a net seaward flow direction throughout the water column (EPA 2000). The transition zone begins approximately 38 miles (61 km) downstream from the fall line, about 27 miles (43 km) downstream from the Plant. The transition zone is about 22 miles (35 km) long and is characterized by variable salinity (from 500 to 10,000 mg/L) and significant mixing of fresh water with salt water from Chesapeake Bay. The lower 50 miles (80 km) of the river are classified as a mesohaline estuary with salinity varying from 5,000 to 18,000 mg/L (EPA 2000). Near the Plant the river channel has been extensively modified by past dredging and spoil disposal.

Average stream flow in the Potomac River at the fall line (above the zone of tidal influence) over the 50-year period 1931-1981 was 11,406 ft³/sec (7.4 billion gal/day or 28 million m³/day) (EPA 2000). Seasonally, flow is highest in the spring (February through May) and lowest in the late summer (July through September). September is the month with the lowest average flow, 4,126 ft³/sec (2.7 billion gal/day or 10 million m³/day). The long-term mean 7-day, 10-year low flow at the fall line is 628 ft³/sec (406 million gal/day or 1.54 million m³/day). The District of Columbia and some other area jurisdictions obtain public water supplies from the Potomac above the fall line.

3.3.1.2 Anacostia River

The Anacostia River is a tributary to the Potomac River that enters the Potomac approximately 4 miles (6 km) upstream from the Plant. The extensively urbanized Anacostia watershed encompasses 176 mi² (456 km²) in Montgomery and Prince George's County, Maryland, and the District of Columbia. The Anacostia is a tidal river for its lower 8.4 miles (13.5 km). Flow in the tidal reach is described as sluggish; this reach has an average water residence time of 30 to 35 days. Average flow into the tidal reach from free-flowing tributaries and reaches is approximately 138 ft³/sec (89 million gal/day or 338,000 m³/day) (Anacostia Watershed Network 2006).

3.3.1.3 Rock Creek

Rock Creek (Figure 3.3-3) is a tributary to the Potomac River that enters the river several miles upstream from the Plant. Approximately 80% of its watershed is in Montgomery County, Maryland, with the remainder in Washington, D.C. (MDOE 2006). The nontidal portions of the

creek occur mainly within Maryland and cover about 60 mi² (155 km²); the tidal portion is mainly within D.C.

3.3.1.4 Patuxent River

The Patuxent River watershed is immediately east of the Potomac River watershed in the Maryland counties of Anne Arundel, Calvert, Charles, Howard, Montgomery, Prince George's, and St. Mary's (Maryland DNR undated-a). The drainage divide between the Potomac and Patuxent watersheds is about 10 miles (16 km) east of the Plant. Only about 40% of the 849-mi² (220-km²) Patuxent River watershed contributes to the river's flow above the fall line; the remainder of the watershed drains directly to the river's estuary, which has a water surface area of about 49 mi² (127 km²) (Hagy and Kemp 2002).

Total stream flow to the Patuxent estuary averages about 728 ft³/sec (470 million gal/day or 1.78 million m³/day) (Boynton and Swaney 1998). Fresh water residence time in the estuary typically varies between 50 and 80 days (Hagy and Kemp 2002).

Mataponi Creek, the Patuxent River tributary that receives discharges from the Mirant landfill (Section 3.5), originates in the upland near Brandywine, Maryland (Figure 2.4.1) and flows east-northeast toward the Patuxent River, entering the fresh water tidal reach of the river at a location about 9 miles (14 km) northeast of Brandywine. No stream flow or water quality data have been located for Mataponi Creek.

3.3.1.5 Chesapeake Bay

The Chesapeake Bay is the largest estuary in the United States, about 200 miles (320 km) in length, with a surface area of about 4,400 mi² (11,000 km²) (including the estuarine reaches of its major tributaries) and a watershed of about 63,000 mi² (164,000 km²), including the District




Figure 3.3-3. Location of features mentioned in the text.

of Columbia and parts of the states of Delaware, Maryland, New York, Pennsylvania, Virginia, and West Virginia (Figure 3.3-1). The Chesapeake Bay is the destination of all waters in the region. The Potomac and Patuxent rivers contribute about 15% and 1% of the stream flow into the Bay, respectively (Boynton and Swaney 1998). Average water depth in the Bay is about 22 ft (7 m).

3.3.2 Water Quality

Important water quality concerns for all potentially affected surface waters include the potential for excessive sedimentation and depletion of dissolved oxygen. Dissolved-oxygen depletion is attributable to excessive loadings of organic materials and nutrients. The long water residence times and poor flushing that are typical of estuaries increase the susceptibility of estuaries to pollution problems. Effects on aquatic ecosystems are the principal focus of concern regarding water quality in these waters, as discussed further in Section 3.4. Public water supplies are obtained from rivers and reservoirs above the fall line; tidal waters generally do not supply water for human consumption. Information about water quality conditions in specific surface water bodies is presented below.

3.3.2.1 Potomac River

Water quality in the tidally influenced sections of the Potomac River is controlled primarily by the mixing of fresh water from upland streams and salt water from Chesapeake Bay, resulting in variable salinity. In the vicinity of the Plant fresh water predominates over salt water, and total dissolved solids are less than 500 mg/L. Table 2.4-1 includes additional data on the quality of river water at the Plant's water intake.

Due to their volume, effluent discharges from the Plant and the Blue Plains Wastewater Treatment Plant have the potential to be important influences on Potomac River water quality near the Plant. Data on the quality of effluents from the Plant are provided in Table 2.4-1.

The Blue Plains Wastewater Treatment Plant, owned and operated by the District of Columbia Water and Sewer Authority, is directly across the Potomac River from the Plant. (See Figure 2-1.) This facility provides wastewater treatment services for the District of Columbia and portions of Montgomery and Prince George's Counties, Maryland, and Fairfax and Loudoun Counties, Virginia, with a combined population near 2.2 million. The Blue Plains treatment plant has a rated treatment capacity of 370 million gal/day (1.4 million m³/day) and a peak wet-weather capacity of 1.076 billion gal/day (4.1 million m³/day). Operation at the rated capacity delivers a water volume to the river equivalent to 5% of the average flow and more than 90% of the 7-day, 10-year low flow at the fall line. The Blue Plains facility is considered an advanced wastewater treatment facility, providing primary and secondary treatment followed by nitrification-denitrification, effluent filtration, chlorination-dechlorination, and post-treatment aeration (DC WASA 2006). Historically, wastewater effluents discharged at this site caused

severe water quality degradation in the Potomac estuary, including high bacteria levels and low levels of dissolved oxygen. Downstream water quality improved dramatically, however, following implementation of secondary and advanced treatment in the Blue Plains treatment plant (EPA 2000). The NPDES permit for the Blue Plains facility specifies stringent water quality limits for discharges, as indicated in Table 3.3-1.

Table 3.3-1. NPDES-permitted discharge limits for the Blue Plains Wastewater Treatment Plant

Contaminant		Maximum Concentration (mg/L, except as indicated)
Carbonaceous Biochemical Oxygen Demand		5.0
Total Suspended Solids		7.0
Phosphorus, total		0.18
Ammonia Nitrogen (NH ₃ -N)	May-October	1.0
	November-April	6.5
Dissolved Oxygen		5.0
Chlorine, total residual		0.02
pH (range of values, pH units)		6.0 to 8.5

Source: DC WASA 2006.

Principal water quality concerns for Potomac River tributary streams draining northern Virginia watersheds near the Plant include the effects of urbanization on aquatic habitats, high fecal coliform bacteria counts in some streams, and the need to protect the watersheds of water-supply reservoirs (Northern Virginia Regional Commission undated; Fairfax County Stormwater Planning Division 2001).

3.3.2.2 Anacostia River

Water quality conditions in the free-flowing tributaries of the Anacostia range from excellent to poor, but the tidal reach of the Anacostia River has very poor water quality. Principal water quality issues for the Anacostia watershed include sediment, trash and debris, toxic chemicals, combined sewer and stormwater overflows that discharge directly into the river, and other nonpoint-source pollution (Anacostia Watershed Network 2006). According to EPA (1997), urbanization has altered the Anacostia River and its tributary streams to the point that floods are ten times more frequent, summer flows are much lower, and stream water temperatures are 5 to 10° C higher than under natural conditions. Due to the long water residence time in the tidal reach of the river, this reach has been described as “a very efficient pollutant trap” (Galli et al. 2001). The tidal reach has chronically low dissolved oxygen levels that

threaten aquatic life and high bacterial levels that make it unsafe for swimming and other water contact activities.

Through a series of agreements, beginning in 1984, local, state, and Federal government agencies have committed to cooperative efforts aimed at restoring the river (Metropolitan Washington Council of Governments 1999). The parties have made progress in implementing measures that should improve water quality, including improving stormwater management, reducing combined sewer overflows and trash, changing land use management to protect sensitive headwater tributaries, and increasing riparian forest buffers; the current agreement calls for continued efforts (Anacostia Watershed Restoration Committee 2001).

3.3.2.3 Rock Creek

Because Rock Creek Park surrounds the entire length of Rock Creek in D.C. and Maryland parks surround most of its length upstream from the District, Rock Creek experiences fewer adverse water quality impacts from urbanization than does the Anacostia River. However, creek water quality is affected by sedimentation and other contaminants associated with urban stormwater runoff (EPA 1997).

3.3.2.4 Patuxent River

Upland streams in the Patuxent River watershed are well oxygenated (only 1% are reported to have dissolved oxygen levels below 5 mg/L), but stream bank instability and erosion reduce biotic habitat quality and contribute contamination to downstream areas (Maryland DNR undated-a). In the tidally influenced area of the main channel, salinity increases in the downstream direction, ranging from fresh to moderately saline. Nutrient loading is a water quality concern throughout the watershed, contributing to eutrophication and oxygen depletion in the lower estuary (Maryland DNR undated-c).

3.3.2.5 Chesapeake Bay

A principal focus of concern for Chesapeake Bay water quality is ecosystem health, which is threatened by excessive loading of nutrients (Section 3.4.2). The historic *Chesapeake Bay Agreement of 1983* established the Chesapeake Bay Program with the goal of restoring the Bay (CBP undated). Through this Agreement, which has been updated and revised several times, Pennsylvania, Maryland, Virginia, the District of Columbia, EPA, and the Chesapeake Bay Commission have committed to a coordinated set of goals and targets for restoration of the Bay ecosystem, including its water quality.

Excessive loading of nitrogen, a nutrient, has been identified as one major contributor to various ecological problems in Chesapeake Bay. (See Section 3.4.2.) Nitrogen occurs naturally in soil, animal waste, plant material, and the atmosphere. In addition to these natural sources,

sewage treatment plants, industries, vehicle exhaust, acid rain, and runoff from agricultural, residential, and urban areas contribute nitrogen to the Chesapeake Bay and its rivers. One of the specific goals set by the Chesapeake Bay Program to achieve the overall objectives of the Chesapeake Bay Agreement is to reduce annual nitrogen input to the Bay to no more than 175 million lb (79 million kg) by 2010. This value is 162 million lb (74 million kg) less than the estimated 1985 input of 337 million lb (153 million kg). Between 1985 and 2004 estimated total nitrogen input to the Bay was reduced by 67 million lb/yr (30 million kg/yr) (41% of the goal), with the biggest improvement coming from reductions in point-source loadings, such as from sewage treatment plants (CBP 2005). The majority of the future reductions in nitrogen loading to the Bay are expected to come from land-based measures such as reducing farm runoff into streams.

Another important source of nitrogen in the Bay is atmospheric deposition (both on land in the watershed and directly on water). Atmospheric sources are estimated to contribute about 91 million lb (41 million kg) of nitrogen to the Bay annually. In 1985 this represented 27% of the nitrogen entering the Bay; by 2000 the estimated fractional contribution from atmospheric deposition had increased to 32% due to reductions in inputs from other sources. About three-quarters of the atmospheric nitrogen that reaches the Bay is estimated to have been emitted in the form of NO_x (Blankenship 1997). In the seven-state region (i.e., Maryland, Virginia, Pennsylvania, New York, West Virginia, New Jersey, and Ohio) estimated to produce most of the air emissions that contribute nitrogen to the Bay, utilities are estimated to be responsible for 38% of the NO_x emissions, cars and trucks 35%, industries 6%, and other sources 21% (CBP 2000).

Much of the atmospheric nitrogen that is deposited on land within the Bay watershed is utilized in biological processes and retained in the ecosystem, so that it is not delivered to the Bay (CBP STAC 1996). Thus, delivery of atmospheric nitrogen to the Bay is estimated based on landscape characteristics, data from acid-deposition monitoring, and other data. Maps of estimated per-hectare delivery of nitrogen to the Bay from all parts of the watershed (Brakebill and Preston 2004) indicate that the total delivery of atmospheric nitrogen to the Bay (in all chemical forms) is about one-tenth to one-third of the atmospheric nitrogen estimated to be deposited to the land surface as NO_x.

Plans for achieving the 2010 nitrogen goal assume that input from atmospheric deposition will be reduced by 8 million lb/yr (3.6 million kg/yr) between 1985 and 2010 as a result of the implementation of new or proposed regulations aimed at achieving Clean Air Act mandates to reduce acid rain and ozone and to limit NO_x emissions from automobiles (Blankenship 1997, 2004). The Chesapeake Bay Program has not established any location-specific targets for reducing atmospheric nitrogen input, which can originate from sources outside the watershed as well as sources within the watershed.

3.3.2.6 Acid deposition

Acid deposition (often called acid rain), due to the dry or wet deposition of oxides of nitrogen and sulfur in the air, is a concern for water quality and ecosystems in the Appalachian mountains and northeastern United States. Acids derived from air emissions have the potential to dissolve, and thus mobilize, aluminum and other metals in soils and sediments, introducing toxic metals into surface waters.

Streams and lakes most susceptible to the impacts of acid deposition are those in watersheds where soils lack carbonate minerals and other alkaline constituents that can neutralize acids deposited from the atmosphere. Such watersheds are considered to be “poorly buffered.” In the state of Maryland approximately 96% of the 636 mi² (1,650 km²) portion of the Potomac River watershed surrounding the District of Columbia (including Maryland portions of the Anacostia watershed) and 98% of the Patuxent River watershed are classified as “well buffered” against acid rain (Maryland DNR undated-a and undated-b). Thus, in the watersheds most likely to receive atmospheric deposition of Plant emissions, surface waters are not particularly susceptible to adverse effects from acid deposition.

3.4 Ecological Resources

The Plant is located on the western bank of the Potomac River, in the Chesapeake Bay watershed (Figures 3.3-1 and 3.3-2). The region around it is a highly urbanized ecosystem that includes the District of Columbia. Development has transformed the ecological resources of the region, and they are greatly changed from early historical conditions (EPA 1997). The ecological condition has, however, improved from the highly degraded situation that was prevalent in the late 1950s and early 1960s, and the region continues to support terrestrial, aquatic, and wetland resources.

3.4.1 Terrestrial Resources

3.4.1.1 Vegetation

Since the turn of the 20th century, approximately 75% of the forest cover in the District of Columbia has been eliminated by human activities (EPA 1997). Regionally, tree cover declined more than 30% from 1972 to 1997 (American Forests 2002). In many places intentional plantings or invasions of exotic trees and other plants have displaced and substantially altered the native vegetation (EPA 1997). Agricultural and forest land cover are, however, still predominant in some parts of the region.

Daingerfield Island, which is administered by the National Park Service as part of the George Washington Memorial Parkway, lies about a quarter mile (less than a half kilometer) north of the Plant (Figure 3.4-1). No longer geographically an island, this flat 107-acre (43-ha), mostly wooded peninsula includes a large patch of forest on the eastern portion of the island with common suburban trees and understory plants (NPS 2002).

The National Park Service administers the land between the Potomac River and the Plant. This expanse includes a bike path that runs south from Daingerfield Island past the Plant and a small wooded area near the Plant at the edge of the Potomac River. (See Figure 2-2.) The vegetation in the small wooded area is similar to that on Daingerfield Island, common suburban tree and understory plant species.

3.4.1.2 Wildlife

Many of the animal species originally present in the D.C. region disappeared long ago (EPA 1997). Wildlife in the region is now dominated by opportunistic species characteristic of urbanized areas. Animals tolerant of human activities (e.g., opossums, raccoons, squirrels, black and Norway rats, house mice, stray cats and dogs) have increased in abundance due to the absence of larger predators and the abundant food offered by garbage. Bird species reflect a change from predominantly forest interior species to species representative of mixed land uses.

Wildlife on Daingerfield Island includes common urban species such as small mammals and birds (NPS 2002). Larger animals could possibly use the forest there for habitat. However, because the forest patch is separated from other forested areas by roadways, fields, and water bodies, the movement of large animals into the peninsular forest may be limited. The wooded




Figure 3.4-1. Location of National Park Service trail that passes the Plant.

area near the Plant is also too small and too isolated by roadways, fields, and water bodies to provide habitat that could be easily used by larger animals.

3.4.1.3 The Mirant Plant site

The 28-acre (11-ha) Plant site is almost entirely covered by facilities related to coal storage and electric power generation. However, it also includes a 1,500 ft² (140 m²) wildflower garden planted with woody and herbaceous vegetation for insects and pollinators.

Animals on the site include common urban wildlife species such as small mammals and birds. Artificial nesting structures for purple martins, eastern bluebirds, bats, and peregrine falcons are located within the small scattered areas of wildlife habitat.

3.4.2 Aquatic Resources

Aquatic ecosystems with the most potential to be affected by the Order include those in the Chesapeake Bay and some of its tributaries, particularly the Potomac, Anacostia, and Patuxent rivers and Rock Creek. (See Figures 3.3-2 and 3.3-3 and Section 3.3.) Coal-fired power plants can impact aquatic resources directly by the cooling water withdrawals and discharge of aqueous effluents and indirectly by the deposition of air pollutants (e.g., acid rain) into watersheds. The Plant withdraws cooling water from and discharges back to the Potomac River. The other rivers and the Chesapeake Bay are potentially affected indirectly by atmospheric deposition.

3.4.2.1 Potomac River

The estuarine portion of the Potomac River adjacent to the Plant supports aquatic communities that are recovering from past stresses. Historically the Potomac River supported dense stands of bay grasses along its entire length, but much of it was lost by the late 1930s (EPA 1997). A dense and wide patch of bay grasses has regrown and currently stretches from the Virginia Potomac shoreline at National Airport to the middle of the Potomac, extending past the southern tip and along the northern and eastern edges of Daingerfield Island that lies north of the Plant (NPS 2002). (See Figure 3.4-1.)

A large, tidally influenced river, the Potomac once possessed an exceptionally diverse and productive fish community, but species abundance and diversity are low compared to historic levels (EPA 1997). The Potomac River watershed supported large numbers of both resident, freshwater fish and anadromous fish (i.e., species that spend their adult lives in saltwater and spawn in freshwater), such as shad and river herring (*Alosa* sp.).

Even though the river has been degraded by the effects of human activities, a wide variety of fish species still occur in it. Many of these are exotic species (e.g., largemouth [*Micropterus salmoides*] and smallmouth bass [*Micropterus dolomieu*], walleye [*Sander*

vitreus]). Some native and exotic species present in the river (e.g., catfish [*Ictalurus punctatus*], crappie [*Pomoxis* sp.], sunfish [*Lepomis* sp.], largemouth and smallmouth bass, walleye) are important recreational species. The northern snakehead (*Channa argus*), a fish from Asia that has attracted public interest because it preys on other fish and can survive several days out of water, is believed to be established in the Potomac River and its tributaries (Fuller 2006). The estimated total fish abundance in the Potomac-Washington Metro Basin, which includes the Anacostia and Potomac rivers and a number of creeks, is 4.9 million fish (Maryland DNR undated-b).

An indication of the particular fish species that are affected by the Plant's cooling water withdrawals can be obtained from entrainment and impingement studies. Studies of aquatic organisms impinged (trapped) on the intake screens at the Plant during 2003-2004 provided information on the species that occur in that stretch of the Potomac (Personal communications between A. Wearmouth, Mirant Corporation, and M.S. Salk, Oak Ridge National Laboratory, July 24, and August 18, 2006). The main fish species found were white perch (*Morone americana*), gizzard shad (*Dorosoma cepedianum*), blueback herring (*Alosa aestivalis*), and channel catfish. Striped bass (*Morone saxatilis*) and American shad (*Alosa sapidissima*), commercially important fishes, were found in low numbers. Earlier impingement studies also observed gizzard shad and white perch, many of which were juveniles, stunted, or already diseased prior to impingement (Pepco 1982).

The benthic macroinvertebrate community in the tidally influenced river near the Plant includes a mix of freshwater organisms that are tolerant of exposure to low salinity and estuarine organisms that are tolerant of fresh water (<http://www.dnr.state.md.us>). Benthic organisms are affected by oxygen depletion that occurs in the bottom waters during summer months. The freshwater tidal Potomac does not support shellfish of commercial value, but it does include large populations of Asiatic clams (*Corbicula fluminea*), an undesirable invasive species (EPA 1997).

3.4.2.2 Anacostia River

The Anacostia River estuary has some of the poorest water quality in the Chesapeake Bay system and is, thus, in a degraded ecological condition (EPA 1995). Many miles of stream habitats have been severely degraded by urbanization, which has profoundly altered the flow, shape, water quality, and ecology of streams in the watershed. Stressors of concern in the river are described in Section 3.3.2.2.

Urbanization has caused the loss of nearly 50 percent of the forest cover in the basin, including much of the stream-side or riparian vegetation and other wetlands. (See Section 3.4.3.)

As a large, tidally influenced freshwater river like the Potomac, the Anacostia also has the capacity to support many diadromous as well as resident fish species. Even though the river has been degraded by the effects of human activities, a wide variety of fish species still occurs in it. Numerous man-made fish barriers, however, block migration of fish.

The tidal reach of the river has chronically low dissolved oxygen levels that threaten aquatic life. (See Section 3.3.2.2.) The periodic lack of dissolved oxygen is the likely reason that substantial clam populations are absent from the river (EPA 1997). The macroinvertebrate communities in the river are severely degraded compared to those in the Potomac.

Implementation of the Anacostia Watershed Restoration Agreement (Section 3.3.2.2) has resulted in some improvement in aquatic habitat conditions (EPA 1997, Anacostia Watershed Restoration Committee 2004).

3.4.2.3 Rock Creek

As the largest stream in D.C., Rock Creek has historically supported substantial populations of recreationally important fish species and, through its direct connection to the Potomac River, large numbers of anadromous species (EPA 1995). The present anadromous fish populations and resident fish communities reflect the harmful effects of polluted runoff, barriers to fish movement, and over fishing. Nonnative fish species (e.g., largemouth bass, bluegill [*Lepomis macrochirus*], carp [*Cyprinus carpio carpio*]) now constitute a significant part of the fish community. Some species that were historically present in Rock Creek have apparently been extirpated from the watershed (e.g., white perch, trout-perch [*Percopsis omiscomaycus*]). In contrast, populations of anadromous alewife (*Alosa pseudoharengus*) and blueback herring appear to be healthy. Even though instream impediments to fish movement probably affect these species and prevent them from passing far upstream, schools of hundreds of individuals occur at several locations.

In contrast to the mainstem, fish communities in tributaries of Rock Creek are small or absent (EPA 1995). Episodic water quality problems (e.g., low flows, flooding, scouring during storm events) and polluted runoff are likely contributing factors.

Overall, the condition of the benthic macroinvertebrate communities in Rock Creek is poor. However, the creek contains several spring-dependent species of isopods, ostracods, and amphipods (EPA 1995), including one amphipod that is listed as an endangered species (Section 3.4.4.1).

3.4.2.4 Patuxent River

Stream quality for fish communities in the Patuxent River is poor in over 50% of the stream miles; only 18% are considered to be in good condition for fish (Maryland DNR undated-a). The Patuxent River watershed includes an estimated 1.1 million fish of 44 species in its wadeable streams. Four species in the basin are at risk of local extinction: American brook lamprey (*Lampetra appendix*), glassy darter (*Etheostoma vitreum*), stripeback darter (*Percina notogramma*), and warmouth (*Lepomis gulosus*). The wadeable tributary streams of the watershed serve as a nursery for the five gamefish species that are found there (i.e., largemouth

bass, smallmouth bass, chain pickerel [*Esox niger*], brown trout [*Salmo trutta trutta*], and rainbow trout [*Oncorhynchus mykiss*]), as most individuals are not of harvestable size.

3.4.2.5 Chesapeake Bay organisms

The sheltered waters of Chesapeake Bay, the largest estuary in the U.S., are exceptionally productive. The Bay is a complex ecosystem that provides homes, protection, and food for many species, including fish, shellfish, and turtles (CBP undated, Alliance for the Chesapeake Bay undated).

Bay grasses, a form of naturally submerged aquatic vegetation, are important to the Chesapeake Bay ecosystem (CBP undated). Bay grasses produce oxygen, supply food for many species (especially waterfowl), offer shelter and nursery habitat for fish and shellfish, reduce wave action and shoreline erosion, absorb excess nutrients (e.g, nitrogen, phosphorus), and trap sediments.

More than 300 species of fish, including 32 year-round species, live in the Bay and its tributaries or use its waters as they migrate along the Atlantic Coast (Alliance for the Chesapeake Bay undated). Migrating fish can, however, no longer reach many stream habitats due to the presence of dams, inadequate culverts, and other barriers to their passage (EPA 1997).

The Bay acts as a nursery for crabs, oysters, and many other species of shellfish (Alliance for the Chesapeake Bay undated). While many of these species, particularly blue crabs (*Callinectes sapidus*), are still commercially important, oyster (*Crassostrea virginica*) populations have declined to about one percent of historical levels.

3.4.2.6 Chesapeake Bay stresses

Hydrological changes, sedimentation, and pollutant loading have degraded aquatic habitats throughout Chesapeake Bay. The cooperative efforts and guidance of the Chesapeake Bay Program have led to improvements, including reduced levels of nutrients and sediments in the Bay and increased availability of dissolved oxygen for the Bay's aquatic biota, but they have not fully restored the health of the Bay (CBP undated). The biggest problems currently facing the Bay's ecosystem and making restoration difficult are excess nutrients, chemical contaminants, air pollution, and landscape changes. (See Section 3.3.2.5.)

Nutrient loading contributes to excessive algal growth, which in turn depletes dissolved oxygen and reduces water clarity. Harmful blooms of *Microcystis* and other cyanobacteria (blue-green algae) that are toxic to humans and other mammals can occur in the fresh-water and low-salinity portions of the Bay and in tributary estuaries (e.g., the Potomac River). In addition, suspended sediment loading and the presence of toxic substances in Bay sediments stress Bay biota.

3.4.3. Wetlands and Riparian Habitats

Wetlands act as water-storage basins and provide vital habitats for a rich diversity of wildlife, including threatened and endangered species (EPA 2006d). They also reduce flooding and storm damage, minimize erosion of uplands, improve water quality by filtering pollutants, and support tourism and the hunting and fishing industries.

Many of the wetlands in the region have been degraded and are of poor quality, but some continue to provide habitat for waterfowl, wildlife, fish, and shellfish (EPA 1995).

Much of the area (e.g., the District of Columbia) was initially built by filling in extensive areas of marshes and swamps along the Potomac and Anacostia rivers (EPA 1997). Such wetlands originally comprised about half the area within the boundaries of the city, totaling more than 9,600 acres (3,900 ha) in 1790. In the early 1990's only 845 acres (342 ha) of wetlands remained in the District, a decrease in area of more than 90% in 200 years.

Riparian, or stream side, vegetation is especially important to the integrity of the District of Columbia ecosystem because it buffers aquatic resources from developed areas and provides habitat for terrestrial species near water (EPA 1997). Contiguous riparian habitats also provide migration corridors for wildlife, a critical factor in urbanized environments. Because Rock Creek Park surrounds the entire length of Rock Creek in the District and Maryland parks surround most of its length beyond the District, the area along Rock Creek is the most important terrestrial and riparian resource in the city.

Within the Anacostia River watershed nearly 75 percent of the freshwater wetlands have been destroyed. Of the original 2,600 acres (1,100 ha) of emergent tidal wetlands in the watershed, less than 100 acres (40 ha) remained in the early 1990s (EPA 1995); by 2003 ongoing restoration efforts had increased the area of tidal wetlands to 123 acres (50 ha) (Anacostia Watershed Restoration Committee 2004). Parklands along the Anacostia River do not provide benefits similar to those along Rock Creek because they are not protected natural areas, but rather are reclaimed wetlands in the form of sparsely wooded lawns. They have the potential, however, to provide such benefits, especially if riparian restoration is coordinated with ongoing restoration of wetlands.

The Federal government maintains 80% of the property bordering the Potomac River, Anacostia River, and Rock Creek drainage basins in the District of Columbia, thus providing some protection to their riparian areas (EPA 1997).

3.4.4. Special Status Species

3.4.4.1 Federally listed species

The Plant's NPDES permit names three species listed as threatened or endangered under the Federal Endangered Species Act (ESA) that could occur at locations in or near the District of Columbia, including the Potomac River drainage. These are the endangered Hay's Spring

amphipod (*Stygobromus hayi*) and shortnose sturgeon (*Acipenser brevirostrum*) and the threatened bald eagle (*Haliaeetus leucocephalus*).

The Hay's Spring amphipod is restricted to a small area in Rock Creek in D.C., a very specialized habitat, and the species is not found elsewhere (Personal communication between A. Moser, U.S. Fish and Wildlife Service, and M.S. Salk, Oak Ridge National Laboratory, June 19, 2006).

The shortnose sturgeon exists as 19 distinct populations that occupy and spawn in rivers and bays from Canada to Florida (Keeney 2002). The Potomac River is one of several tributaries in the Chesapeake Bay drainage that appear to have suitable habitat for it. The Shortnose Sturgeon Recovery Plan (NMFS 1998) reports that one shortnose sturgeon was captured in 1996 at the mouth of a small creek off the Potomac River about 50 miles (80 km) downstream from the Plant. Between 1996 and 2002 six sturgeon were captured many miles downstream from the Plant in the lower and middle tidal Potomac River (Keeney 2002). Two mature, egg-bearing females were captured in the river in September 2005 and March 2006, suggesting that a spawning population continues to exist in the river system (Appendix D). The female caught in September 2005 overwintered in a creek approximately 24 miles (39 km) downstream of the Plant. Population dynamics in the Potomac River have not been documented, but it is likely that they migrate past the Plant in the spring (March - June) while moving to and from the presumed spawning grounds near Little Falls, Maryland (about 11 miles [18 km] upstream from the Plant). It is unknown if the sturgeon occur in this region of the river during other times of the year. However, if appropriate forage items are present, they could live in the area in the summer and fall. The shortnose sturgeon has not been reported among the species impinged by the Plant (Personal communication between D. Knight, Mirant, and M.S. Salk, Oak Ridge National Laboratory, July 24, 2006).

While a pair of bald eagles lived for several years about two miles (3 km) south of the Plant near the Woodrow Wilson Bridge (WWBP 2006a) until the recent death of the female (WWBP 2006b), bald eagles are only rarely seen near the Plant (Personal communication between D. Knight, Mirant, and M.S. Salk, Oak Ridge National Laboratory, July 24, 2006). (See Figure 3.3-3.)

The Virginia Natural Heritage Resources information database indicates that no Federally listed threatened or endangered species occur in the city of Alexandria, but it names two Federal species of concern⁵ that could occur there: the Northern Virginia well amphipod (*Stygobromus phreaticus*) and Torrey's mountain-mint (*Pycnanthemum torrei*) (VNHR 2006). The amphipod is found only in caves (NatureServe 2006). In Virginia Torrey's mountain-mint occurs in dry, rocky, upland, deciduous woods; along roadsides; and in thickets near streams (NatureServe 2006). There is no suitable habitat for either species on the Plant site.

⁵ "Species of concern" means a species that might be in need of conservation action (FWS 2006). Such species receive no legal protection, and use of the term does not necessarily imply that a species will eventually be proposed for listing.

3.4.4.2 State-listed species

The Virginia Natural Heritage Resources information database indicates that the only state protected species that occurs in the city of Alexandria is the threatened wood turtle (*Glyptemys insculpta*) (VNHR 2006). Wood turtles live along permanent streams during much of each year, but in summer they may roam widely overland and can be found in a variety of terrestrial habitats adjacent to streams, often associated with the margins of woods (NatureServe 2006). There is no suitable habitat for the species on the Plant site.

3.5 Waste Management

Except for small quantities of fly ash that are used beneficially (Section 2.4.3), fly ash from the Plant is disposed of in the Brandywine Fly Ash Facility, a landfill owned and operated by Mirant Ash Management LLC and used solely for disposal of coal combustion ash. The landfill, located in southeastern Prince George's County, Maryland (east of the community of Brandywine) (Figure 2.4.1), is also used for disposal of fly ash from Mirant's Chalk Point Generating Plant on the Patuxent River estuary in southeastern Prince George's County.

The 178-acre (72-ha) site currently used for waste disposal is part of a larger area that was formerly surface-mined for gravel and that has been used for coal combustion ash disposal since 1971. Surrounding land uses include an active sand and gravel mining operation, agricultural fields, forest, a high-voltage electric transmission line, and other landfills. The landfill site has a low-permeability base of compacted native soil (Personal communication between D. Cramer, Mirant Corporation, and L.N. McCold, Oak Ridge National Laboratory, July 7, 2006) and is equipped with a leachate collection system. Ash is delivered to the landfill by dual-axle dump trucks and is placed and compacted in the landfill in 2-ft (0.6-m) layers. On weekdays during peak power-generation periods the landfill receives approximately 60 truckloads of ash from the two generating stations; average daily ash receipts are approximately 70% of peak daily receipts.

Stormwater runoff and leachate from the landfill drain to collection ponds where a sprinkler pump provides aeration, water quality is monitored, pH is adjusted, and solids settle out before the water is discharged to the upper reaches of Mataponi Creek (a tributary to the fresh water tidal river reach of the Patuxent River) and an unnamed tributary to the creek (Baxter 2006). Dust is controlled by periodically watering haul roads and the active disposal area, using water recycled from the collection ponds (Personal communication between D. Cramer, Mirant Corporation, and L.N. McCold, Oak Ridge National Laboratory, July 7, 2006).

Landfill site plans limit the final height of the fill to a elevation of 260 ft (79 m) above mean sea level (MSL), or about 70 ft (21 m) above the original land surface grade (Personal communication between A. Wearmouth, Mirant Corporation, and E.D. Smith, Oak Ridge National Laboratory, July 21, 2006). Areas of the landfill that have reached their maximum

design height are capped with a 3-ft (1-meter) thickness of soil and seeded to establish a vegetative cover. In January 2005 the landfill was calculated to have a remaining capacity of 2.07 million yd³ (1.58 million m³), providing sufficient capacity for disposal of the two power plants' projected ash generation for about 7 years, or approximately through the middle of 2012 (GB&B Inc. 2005).

Disposal facilities for coal combustion ash are not subject to state solid waste regulation in Maryland (Personal communication between R. Daniel, Maryland Department of Environment Customer Service Center, and E.D. Smith, Oak Ridge National Laboratory, June 6, 2006), but local zoning requirements and state wastewater regulations apply. The Brandywine facility operates under a series of special exceptions from Prince George's County zoning restrictions. The most recent special exception for 12 years of continued operation was approved by Maryland-National Capital Park & Planning Commission, Prince George's County Planning Department in 1991 (Baxter 2006). In 2005 Mirant filed an application for a 15-year extension to this special exception (Baxter 2006); the application is currently pending.


Discharge of wastewater from the site, including storm water runoff, collected leachate, and truck wash water, is permitted under MDE Discharge Permit 02-DP-1389 (NPDES Permit MD0054836), issued by the Maryland Department of the Environment. The current 5-year discharge permit is effective September 1, 2005, to August 31, 2010. The permit limits discharge to a pH range of 6 to 9 pH units, total suspended solids of no more than 35 mg/L as a monthly average and 70 mg/L as a daily maximum, and total iron of no more than 3.5 mg/L as a monthly average and 7.0 mg/L as a daily maximum. Discharge monitoring requirements under the permit include monthly flow and monthly measurements for pH, total suspended solids, hardness, iron, copper, lead, selenium, and zinc. Six groundwater monitoring wells in the vicinity of the landfill are monitored quarterly for pH; total dissolved solids; chloride; sulfate; and dissolved aluminum, cadmium, manganese, copper, iron, lead, silver, and nickel. No surface or groundwater problems are currently identified at the site (Baxter 2006). There have been no regulatory violations since 1996 when a discharge from one of the wastewater ponds exceeded the permit limit for total suspended solids (Personal communication between D. Cramer, Mirant Corporation, and L.N. McCold, Oak Ridge National Laboratory, July 7, 2006).

3.6 Transportation Resources

The primary transportation activities associated with Plant operations are (1) trains traveling to and from the Plant to deliver coal and trona and (2) trucks traveling to and from the plant to remove ash. The following sections discuss the affected local environment for these rail and road operations.

3.6.1 Rail

Trains enter and exit the Plant to deliver coal and trona via a short rail spur from the CSX, Inc., main rail line located west of North Henry Street (Figure 3.6-1). The City of Alexandria allows the Plant to conduct rail operations during two daytime periods (11 a.m. to 12 p.m. and 1 p.m. to 3 p.m.) and one nighttime period (7 p.m. to 11 p.m.) from Monday through Saturday. (The Plant does not receive rail deliveries on Sundays.) Daytime rail operations involve removing empty rail cars from the Plant during each of the two daytime periods to avoid blocking vehicular traffic on the George Washington Parkway (Figure 3.6-1). Nighttime rail operations involve deliveries of coal and trona (Personal communication between D. Cramer, Mirant Corporation, and L.N. McCold, Oak Ridge National Laboratory, July 7, 2006).



ORNL 2006-G00959r/g

Figure 3.6-1. Access routes near the Mirant Plant.

3.6.2 Road

Trucks enter and exit the Plant to remove ash via a gated entrance located on North Royal Street (Figure 3.6-1). The trucks haul ash from the Plant to the Brandywine Fly Ash Facility in Prince George's County, Maryland (Figure 2.4-1).

From the Plant the trucks travel south on North Royal Street, then west on Montgomery Street (Figure 3.6-1). Neither the Virginia Department of Transportation nor the City of Alexandria maintains data on annual average daily traffic⁶ or level-of-service (LOS)⁷ for North Royal Street, but it is a local street with relatively little traffic and an existing level-of-service (LOS) at or near "A" (Personal communication between B. Garbacz, Transportation Engineer,

⁶ The annual average daily traffic is "an estimate of typical daily traffic on a road segment for all days of the week, Sunday through Saturday, over the period of one year" (VDOT 2004).

⁷ Level-of-service (LOS) is "a standard measurement used by transportation officials which reflects the relative ease of traffic flow on a scale of A to F, with free-flow being rated LOS-A and congested conditions rated as LOS-F" (FHWA 2006).

City of Alexandria, Virginia, and J.W. Saulsbury, Oak Ridge National Laboratory, May 26, 2006). On Montgomery Street annual average daily traffic is 3,800 vehicles (VDOT 2004).

Once the trucks reach the intersection of Montgomery Street and Henry Street (State Route 1) (Figure 3.6-1), they travel south on Henry Street to access Interstate 495 (I-495 or the Capital Beltway) (Figure 2.4-1). The trucks then travel east on I-495 North, crossing the Potomac River on the Woodrow Wilson Memorial Bridge, which serves as a major connector between Virginia and Maryland (Figure 3.3-3). On entering Maryland, trucks exit onto Maryland Route 5 and travel south. The trucks continue to travel south on Maryland Route 381 (Brandywine Road) to North Keys Road, on which the Brandywine facility is located. Table 3.6-1 lists the existing traffic volumes on each of these roads between Henry Street in Alexandria and the Brandywine facility in Maryland.

Table 3.6-1. Roads traveled by the ash removal trucks between Henry Street and the Brandywine Fly Ash Facility

Road	Segment	Annual Average Daily Traffic
Henry Street (Route 1)	Southbound to I-495 North (Capital Beltway)	22,000 to 25,000
I-495 North	Eastbound into Maryland via the Woodrow Wilson Memorial Bridge	154,000
I-495 North	Eastbound in Maryland to Maryland Route 5	142,925 to 174,800
Maryland Route 5	Southbound to Maryland Route 381	62,450 to 112,050
Maryland Route 381 (Brandywine Road)	Southbound to North Keys Road	4,850 to 12,150
North Keys Road	Southbound to the Brandywine Fly Ash Facility	No data available

Sources: VDOT 2004; MDOT 2005

The road network used to transport ash to the landfill is affected by ongoing construction activities associated with the Woodrow Wilson Bridge Project (WWBP 2006a). This project, which is scheduled for completion in December 2012, involves a series of roadway and interchange improvements along a 7.5-mile-long (12-km-long) segment of I-495 that extends from the Telegraph Road interchange in Virginia to the Route 210 interchange in Maryland. The project's centerpiece, widening and improving the Woodrow Wilson Memorial Bridge, is scheduled for completion in December 2008.

Access to the Brandywine Fly Ash Facility from North Keys Road is via a private road that is shared by an adjoining sand and gravel mining and wet processing facility. During peak winter and summer months total hauling operations at the Brandywine Fly Ash Facility consist of approximately 60 truckloads per day. This total includes trucks from the Plant and from Mirant's Chalk Point Power Plant in Prince George's County, Maryland. Typical weekday

haulage activity at the Brandywine facility is approximately 70 percent of the seasonal peaks (Baxter 2006).

There are some existing traffic problems on Maryland Route 381, which is used to access the Brandywine facility. Although the State of Maryland's accident records indicate that this road operates without any significant safety deficiencies, certain intersections along Maryland Route 381 function inadequately and have a low LOS based on existing traffic volumes (Baxter 2006).

In April 2005 Mirant filed with the Maryland-National Capital Park and Planning Commission an Application for Special Exception for a Sanitary Landfill (Fly Ash) (Baxter 2006). That application includes information about transporting ash to the Brandywine facility. Mirant's Application was reviewed by the Maryland Department of Transportation State Highway Administration and the Prince George's County Department of Public Works and Transportation. The Department of Public Works and Transportation conducted a traffic study for Mirant's Application in which it assumed that there would be "an increase in through traffic percent along key roadways in the study area." The traffic study examined impacts for seven intersections under three scenarios:

- existing traffic conditions,
- the addition of 13 background developments whose impact would affect some or all of the study intersections, and
- traffic volumes representing total background conditions combined with projected facility site trip generation (the 20-year build-out projection).

Analysis of this third scenario (which includes Mirant's Application, as well as 13 other "background" developments over a 20-year period) indicated impacts on the seven intersections as listed in Table 3.6-2. Ash hauling associated with pre-shutdown operations at the Plant was a minor contributor to these existing traffic problems.

The Department of Public Works and Transportation traffic study notes that the State Highway Administration has required Mirant to address the failing levels of service at these intersections along Maryland Route 381. In particular, the study notes that the intersection of Maryland Route 381 and U.S. Highway 301 "operates inadequately based on existing traffic volumes (LOS-E in the morning) and will worsen significantly with the inclusion of approved background developments." The study adds that pursuant to State Highway Administration's comments, Mirant "has offered no improvements that would ameliorate the inadequacies at that intersection" (Baxter 2006).

Table 3.6-2. Traffic impacts projected in Mirant's *Application for Special Exception* for the road intersections used to access the Brandywine Fly Ash Facility

Intersection	Level-of-Service during after-midnight and morning hours	Level-of-Service during afternoon and evening hours
North Keys Road/Gibbons Church Road (unsignalized)	B	A
Maryland 381/North Keys Road (unsignalized)	<i>F</i>	C
Maryland 381/U.S. 301 (signalized)	<i>F</i>	<i>F</i>
Maryland 381/Baden Westwood Road (unsignalized)	<i>F</i>	B
Maryland 381/Croom Road (unsignalized)	<i>F</i>	<i>F</i>
Link—Maryland 381 (U.S. 301–North Keys Road)	E	D
Link—Maryland 381 (Croom Road–North Keys Road)	C	C

Figures in ***boldface italics*** represent failing levels of service.

Source: Baxter 2006

3.7 Minority and Low-Income Populations

Executive Order 12898, *Federal Actions to Address Environmental Justice in Minority Populations and Low-Income Populations*, directs each Federal agency to identify and address the “disproportionately high and adverse human health or environmental effects of its programs, policies, and activities on minority and low-income populations.” The Council on Environmental Quality (CEQ) guidance on environmental justice (CEQ 1997) states that a “minority population” should be identified where either: “(a) the minority population of the affected area exceeds 50 percent or (b) the minority population percentage in the affected area is meaningfully greater than the minority population percentage in the general population or appropriate unit of geographical analysis.” The CEQ guidance defines “low-income” using statistical poverty thresholds from the Bureau of Census Current Population Reports, Series P-60 on Income and Poverty.

For this analysis DOE examined the 2000 U.S. Census data to identify any minority or low-income populations in census tract⁸ (CT) 2018.01, in which the Plant is located (Figure 3.7-1), and the four block groups⁹ within CT 2018.01. DOE focused on CT 2018.01 because its boundaries encompass the geographical distribution of the greatest air quality impacts from the

⁸ The U.S. Census Bureau defines census tracts as small, relatively permanent statistical subdivisions of a county. Census tracts average about 4,000 inhabitants and are designed to be relatively homogeneous units with respect to population characteristics, economic status, and living conditions. Census Tract 2018.01 has a total population of 4,727.

⁹ The U.S. Census Bureau defines block groups as subdivisions of a census tract. Block groups are the smallest geographic unit for which the Census Bureau tabulates sample data.

Plant. To identify minority and low-income populations within CT 2018.01 and its block groups, DOE defined a “meaningfully greater” population as one that had a minority or low-income percentage at least 10 percentage points higher than the percentages for the city of Alexandria, the state of Virginia, or the United States (whichever is lower).¹⁰ Thus, based on the data in Table 3.7-1, DOE identified minority populations as those that have a minority percentage of at least 39.8% (10 percentage points higher than the state of Virginia) and low-income populations as those that have a low-income percentage of at least 18.9% (10 percentage points higher than the city of Alexandria).

As indicated in Table 3.7-1, the percentages of the total population in CT 2018.01 (population 4,727) that are classified as minority (27.2%) and low-income (11.1%) do not exceed DOE’s threshold for identifying either minority or low-income populations. However, block group 3, which is located south of the Plant (Figure 3.7-1) and has a total population of 1,368, exceeds DOE’s low-income threshold. Similarly, block group 4, which is located southwest of the Plant (Figure 3.7-1) and has a total population of 620, exceeds DOE’s minority threshold. Therefore, block groups 3 and 4 of CT 2018.01 contain minority and low-income populations that meet the DOE thresholds, while block groups 1 and 2 (populations of 1,650 and 1,085, respectively) do not.




Figure 3.7-1. Block Groups 1-4 within Census Tract 2018.01.

¹⁰ The “10 percentage point” criterion is used here because it is large enough to indicate the presence of a minority or low-income population when compared to a large geographic area (i.e., the state or the nation), yet small enough to indicate minor differences in percentages among several census tracts or block groups in a small geographic area. Note that the use of a more conservative criterion, such as 5 percentage points, would not change which block groups are identified as minority or low-income populations.

Table 3.7-1. Minority and low-income data for census tract 2018.01 and its block groups (See Figure 3.7-1)

Location	Percent minority ^a	Percent low-income ^b
United States	30.9	12.4
State of Virginia	29.8	9.6
City of Alexandria	46.3 [‡]	8.9
Census tract 2018.01	27.2	11.1
Block group 1	18.9	5.0
Block group 2	6.3	9.5
Block group 3	37.8	23.3 [‡]
Block group 4	60.0 [‡]	3.4

^a Includes all persons who identified themselves as not “white alone,” plus those who identified themselves as both “white alone” and “Hispanic or Latino.”

^b Represents individuals below the poverty level as defined by the U.S. Census Bureau.

[‡] Minority or low-income population based on the DOE thresholds for percent minority or low-income.

Source: U.S. Census Bureau 2006.

4. PLANT OPERATIONS, ASSUMPTIONS, AND ENVIRONMENTAL CONSEQUENCES

This chapter begins by describing general Plant operations as authorized by the DOE Order. Next, this chapter describes the information and assumptions that DOE used to assess the impacts of the Plant under the DOE Order and a potential extension of the Order until the new 230-kV transmission lines are in service. Finally, this chapter assesses the impacts to air, human health, water, ecological resources, waste management, transportation resources, and minority and low-income populations as a result of the Order and a potential extension of the Order until the new 230-kV transmission lines are in service.

4.1 General Plant Operations as Authorized by the DOE Order

The DOE Order consists of 285 days, from December 20, 2005, to October 1, 2006. Just before the Secretary issued the Order, Mirant operated Unit 1 on an 8-8-8 basis (that is, in any given 24-hour period, it ran for eight hours at up to its maximum level of 88 MW, ran for up to eight hours at its minimum level of 35 MW, and did not run for at least eight hours), and began using trona and low sulfur Colombian coal, alone or in combination.

4.1.1 Operations as Authorized by the DOE Order until the Administrative Compliance Order (ACO)

At the time the Order was issued, Mirant had one operational trona injection unit that serviced only the Unit 1 boiler. A second trona unit became operational on January 22, 2006, and a third on March 20, 2006. Except during transmission line outages (Table 1.3-1), Mirant operated only boilers that had trona units. By April 28, 2006, Mirant had operational trona injection units installed on all five boiler units.

On January 4, 2006, DOE authorized Mirant to operate each of the two load-following or cycling units at the Plant (i.e., Units 1 and 2) up to 16 hours per day. Each unit was authorized to operate 8 hours at minimum load and up to an additional 8 hours at maximum load. In addition, DOE authorized Mirant to operate any one of the three baseload units continuously without constraint as to load or operating hours. According to Mirant's proposed operating plan, each baseload unit would operate for approximately two weeks before another baseload unit began a two-week operating period.

In January 2006, due to transmission line outages for maintenance, Mirant operated the Plant to meet the entire Central Washington, D.C., load for 21 days. No line outages have occurred since those in January. Between January and May, DOE continued to weigh other options that were available to Mirant to comply with the Order and consulted with EPA on options to increase electricity reliability while ensuring environmental protection.

4.1.2 Operation under the ACO

EPA issued its ACO to Mirant on June 1, 2006. On June 2, 2006, DOE directed Mirant to operate under the ACO during non-line outage situations, for the purpose of providing electricity reliability, and to continue operation in accordance with the DOE Order in line-outage situations.

4.1.2.1 Operations during non-line outage situations

Daily predictive modeling. Upon installation of three SO₂ monitors¹¹ the ACO directs Mirant, in non-line outage situations, to operate under daily predictive modeling. Under daily predictive modeling the Plant operators acquire the National Weather Service forecast for the next day for Ronald Reagan Washington National Airport and use that forecast along with their planned operating parameters as inputs to a computer modeling run for the following day using AERMOD Default¹². If the modeling results indicate that operating the Plant under those conditions would not cause a modeled exceedance of the 3- and 24-hour average SO₂ and PM₁₀ NAAQS limits, operators may run the Plant on that day using those parameters. If the results indicate that operation of the Plant would cause a modeled exceedance for these pollutants, the operators must adjust the planned operating parameters and rerun the model using the same weather forecast. The operators must continue to adjust their planned operating parameters and rerun the model until the results indicate no modeled exceedance of these pollutants. The operators then will operate the Plant the next day using those parameters. Thus, under this scenario the Plant can operate each day up to the maximum level allowed by the weather forecast for that day. The ACO only requires daily predictive modeling for PM₁₀ when Mirant operates four or five units. Mirant is required to assume a PM₁₀ emission rate of 0.055 lb/MBtu and to adjust operations to prevent a modeled exceedance for PM₁₀.

Other requirements of the ACO. In addition to daily predictive modeling, the ACO requires Mirant to install an audible alarm in the Plant's control room that will sound when the ambient concentration of SO₂ at any monitor reaches specified levels. When an alarm sounds, Mirant must make operational changes (e.g., increase use of trona, decrease operating level) and observe the effect of those changes on the level of SO₂ measured at the monitors. The ACO uses this alarm system to monitor the Plant's compliance with the annual SO₂ NAAQS limit. The

¹¹ Until June 20, 2006, when three newly installed SO₂ monitors were functioning, Mirant operated under the constraints detailed in Table 1 in the ACO. (See Appendix B.) These constraints included, for example, restrictions on number of hours of operation and SO₂ emission rate during each calendar day. For example, on days when Units 1 and 3 were operating, each unit was required to achieve a 24-hour average SO₂ emission rate no higher than 0.24 lb/MBtu and a 3-hour rolling rate no higher than 0.51 lb/MBtu, and Unit 1 was required to operate for no more than 8 hours per day above minimum power and spend at least 8 hours per day off.

¹² AERMOD Default means Version 04300 of the AERMOD computer model, currently approved for general use by EPA in accordance with 40 CFR Part 51, Appendix W, to predict NAAQS compliance. See the AERMOD text box in Section 4.3.1.

ACO also directs Mirant to undertake a “Model Evaluation Study” (MES) (text box) “to determine the best performing model for predicting the computer-modeled ambient air quality impacts” from Plant operations. To provide data for the MES and to support the alarms, Mirant installed six SO₂ monitors in locations identified in the ACO. (See Appendix B.) Lastly, the ACO puts a NO_x limitation on the Plant; at all times Mirant may not emit more than 3,700 tons (3,400 metric tons) of NO_x per year.

4.1.2.2 Operations during line outage situations

The ACO directs Mirant, in line-outage situations, to follow the DOE Order, but requires Mirant to “take all reasonable steps to limit the emissions of PM₁₀, NO_x and SO₂ from each boiler, including operating only the number of units required to meet PJM’s directive and optimizing its use of trona injection to minimize SO₂ emissions.” Further, the ACO requires that Mirant achieve “80% reduction of SO₂ emissions unless: 1) Mirant demonstrates ... that 80% reduction is not necessary to achieve compliance with the NAAQS; or 2) Mirant demonstrates that 80% reduction is not logistically feasible because of such factors as the quantity of available trona and the predicted duration of the outage.” If Mirant demonstrates that 80% removal is not logistically feasible, it is required to submit a plan to EPA for optimizing its use of trona. However, as described in Section 4.3.1.1 and Section 5.3.1, DOE assumed 50% removal of SO₂ emissions in assessing impacts under the DOE Order and a potential extension of the Order.

Model Evaluation Study

The objective of the MES is to determine the best performing model for predicting the computer-modeled ambient air quality impacts from Plant operations. The MES proceeds by comparing the air quality impacts predicted by the AERMOD Default and those predicted by AERMOD EBD computer models to actual measured SO₂ concentrations in order to determine the better performing model. AERMOD Default is Version 04300 of AERMOD computer model, currently approved for general use by EPA. AERMOD EBD means the standard AERMOD computer model with modified direction-specific equivalent building dimensions derived from a wind tunnel study. Mirant submitted an MES protocol to EPA in July 2006 and submitted the results of the wind tunnel study to EPA in August 2006. If EPA and the VDEQ approve AERMOD EBD, Mirant must use it in its predictive modeling for the remainder of the MES period.

Mirant is to compare the actual data from the six monitors to the results of the two computer models. At the end of the study EPA and the VDEQ expect to determine which model is *best performing*. The best performing model will then be used to develop permanent emission limits for the Plant.

4.2 Assumptions and Data Used in SEA to Model Plant Operations

To the extent possible, DOE’s assessment of the environmental impacts of Plant operations under the Order is based on actual operating data. However, the Plant has had several different modes of operation under the Order, and data are not available for all parameters.

Therefore, it was necessary to make some assumptions in order to assess the impacts of the Order and of the potential extension of the Order. This section describes operations under the Order and the assumptions that DOE used to estimate the environmental consequences.

4.2.1 Pre-Shutdown Operations

Before it shut down on August 25, 2005, the Plant operated its five units without SO₂ emissions controls. The Plant generated electricity at an annual average rate of 210 MW and burned about 837,000 tons (755,000 metric tons) of coal per year. Generation varied seasonally, with the highest generation occurring in the summer months when demand for air conditioning is high (Figure 4.2-1).

DOE used hourly, unit-by-unit electricity generation data, provided by Mirant, to model operations of the Plant. DOE used SO₂ emission factors it developed by analyzing detailed operation and emission data for the period December 20, 2005, through March 31, 2006. DOE assumed that the Plant emitted SO₂ at a rate of 1.05 lb/MBtu and that it emitted NO₂ at a rate of 0.35 lb/MBtu for Units 1 and 2 and 0.26 lb/MBtu for Units 3, 4, and 5.




Figure 4.2-1. Monthly average power generation for September 2004 through August 2005.

4.2.2 Pre-Order Operations

Before the Secretary of Energy issued the Order, Mirant was operating Unit 1 in an 8-8-8 mode (in any given 24-hour period, the unit ran for up to eight hours at power levels up to its maximum level of 88 MW, ran for eight hours at its minimum level of 35 MW, and did not run for eight hours) and had begun using trona injection and low-sulfur coal in varying quantities. If the Order had not been issued, it is likely that Mirant would have continued to restart additional units at the Plant with the further installation of trona injection units. However, because it is impossible to know exactly what would have happened if the Order had not been issued, DOE is providing this “pre-Order” mode of operations as a basis for comparing impacts under the Order.¹³

¹³ Because Mirant did not provide DOE with operations data for periods before December 20, 2005, and
(continued...)

During the pre-Order mode, the Plant's Unit 1 operated for 16 hours per day with intermittent use of Colombian coal and/or trona injection. A typical day started at about 4 am with the unit being brought up to operating temperature by burning oil for about two hours. At about 6 am the unit was switched to coal and began generating electricity. The unit would reach a level close to its 88 MW capacity in about five hours, around 11 am. The unit would continue at that high power level through the afternoon and evening before making the transition to shut down status by about 10 pm. This is the 8-8-8 mode of operation.

During the pre-Order period Unit 1 consumed about 540 tons (490 metric tons) each day of coal with an average heat content of 12,000 Btu/lb and a heat rate of 12.9 million Btu per MWh (MBtu/MWh). On average, the unit emitted about 10,300 lb (4,700 kg) of SO₂ and about 4,300 lb (1,900 kg) of NO_x per day. SO₂ emission rates varied within the period due to trona injection and burning of coal with different sulfur contents. At this rate of coal consumption, one train containing 40 rail cars with 100 tons (91 metric tons) of coal per rail car could provide a week's worth of coal to the Plant. On a day when the Plant consumed 540 tons (490 metric tons) of coal that was on average 67% by weight carbon, it released about 1,300 tons (1,200 metric tons) of CO₂.

According to discharge monitoring reports that Mirant prepared for submission to EPA (Personal communication between A. Wearmouth, Mirant Corporation, and E.D. Smith, Oak Ridge National Laboratory, July 21, 2006), during December 2005 discharges to the Potomac River of cooling water and treated in-plant effluents averaged 94 million gal (356,000 m³) per day. The reported maximum thermal discharge to the river was 969 MBtu per hour.

4.2.3 Operations under the Order and Potential Extension

Mirant provided DOE with hourly records of power plant operations for the period December 20, 2005, through March 31, 2006. These records include power production, stack gas parameters (e.g., flow rate, temperature, percent CO₂, opacity), pounds of NO₂ released per million Btu, pounds per hour of NO₂ released, pounds of SO₂ released per million Btu, and pounds per hour of SO₂ released. Table 4.2-1 is a summary of plant operations through March 31, 2006.

Mirant also supplied data on wastewater discharges for all months through June 2006 and data on total coal consumption and fly ash generation during the 3-month period March through May 2006.

The operating records described above allowed DOE to estimate plant operational parameters for each unit. DOE used those parameters to model plant operations during the Order and during a potential extension of the Order.

¹³ (...continued)

because Mirant continued its pre-Order (8-8-8 mode) operations through December 23, DOE used December 20 through 23 to represent pre-Order operations.

Table 4.2-1. Plant operation from December 21, 2005, through March 31, 2006

Dates	Operating mode
December 20- 23, 2005	Unit 1 operated with Colombian coal and trona testing
December 24, 2005	No data available
December 25 - 31, 2005	Unit 1 operated without using low sulfur coal or trona
January 1, 2006	No data available
January 2 - 6	Unit 1 operated without using low sulfur coal or trona
January 7 - 19	All five units operated as directed by PJM for a transmission line outage; only Unit 4 had trona injection
January 20	Only Unit 4 operated
January 21 - 28	All five units operated as directed by PJM for a transmission line outage; trona injection on Units 3 and 4
January 29 - February 15	Units 1 and 4 operated with trona injection
February 16 - 17	Only Unit 4 operated
February 18 - 21	Unit 3 and Unit 4 operated
February 22 - 25	Unit 1 and Unit 3 operated
February 26 - 27	Only Unit 3 operated
February 28 - March 8	Unit 2 and Unit 3 operated
March 9	Only Unit 4 operated
March 10 - 21	Unit 4 and Unit 5 operated
March 22	Only Unit 4 operated
March 23 - 31	Unit 3 and Unit 4 operated

Note: After January 28, only units employing trona injection were operated. Because Mirant found the Colombian coal unsuitable for use at the Plant, after the initial supply was consumed, Mirant used only trona injection to control SO₂ emissions.

For the purpose of evaluating impacts for which actual emissions data are not available, DOE assumed that impacts could be scaled to power production and coal use based on pre-August 2005 data (Section 4.2.1). During the year before shutting down in August 2005, the Plant generated power at an average rate of approximately 210 MW and consumed about 832,000 tons (755,000 metric tons) of coal.

Assumptions for operations from December 20, 2005, through June 30, 2006. For the period through March 31, DOE used hourly emissions data provided by Mirant to model air emissions. For the two days for which data were not provided, DOE assumed operations were identical to the preceding day. For this period DOE used historical weather data for the specific days of operation acquired from the National Weather Service.

Beginning with April, DOE made assumptions on operating modes based on information provided by Mirant. In operating plan supplements that Mirant supplied to DOE on January 13, 17, and 24 and February 6 and 16, 2006, Mirant described combinations of SO₂ emission rates and limits on hours of operation for all combinations of two units that its modeling determined would not cause any NAAQS exceedance. To model the air quality impacts of operations during the period April 1 through May 31, 2006, DOE assumed that Mirant operated the Plant to the maximum level described in those supplements.

Assumptions for operations from July 1 through September 30. On June 2, 2006, DOE directed Mirant to operate the Plant in compliance with the ACO. The ACO directed Mirant to operate the Plant within a set of constraints on operation hours and SO₂ emission rates enumerated in the ACO until Mirant met the requirements to operate in accordance with daily predictive modeling. For the purposes of this SEA DOE assumed that the Plant operated June 1 through June 30, 2006, in a manner that produced the maximum electrical power while being in compliance with the table of operational limits in the ACO.¹⁴

DOE assumed that after June 30 Mirant operated at the maximum level of power generation allowed under daily predictive modeling, as described in Section 4.1.2.1, and that, except during line-outage periods, this mode of operation continued through the duration of the Order and during a potential extension of the Order through 2007. The Plant generates electric power in response to demand, at levels requested by PJM. In order to estimate how much power might be generated during non-line outage situations when operating under daily predictive modeling, DOE used the record of the last year of historical operation (i.e., the year prior to August 24, 2005; Figure 4.2-1) to produce a scenario that represents levels of operations that might reasonably be expected if it were not for environmental constraints.

Assumptions for a potential extension of the Order.¹⁵ DOE assumed that during non-line outage periods, the Plant would produce as much power as during the year before shutting down in August 2005, while complying with the ACO. Pepco has plans for several transmission line outages that would occur during a potential extension of DOE's Order before the two new 230-kV transmission lines are put into service. Outages are planned from November 27 through December 11, 2006; and February 19 through March 5, May 2 through 15, and May 21 through June 15, 2007. During outage periods DOE assumed that the Plant generated an amount

¹⁴ Table 1 of the ACO specifies maximum operations levels and SO₂ emission rates for individual units and for combinations of two or three units. For operations under the ACO before daily predictive modeling commenced, DOE assumed that the Plant operated two units at all times.

¹⁵ On September 28, 2006 Secretary Bodman issued a temporary extension of the Order until 12:01 a.m., December 1, 2006 to allow time to complete the SEA and consider public comments.

of power equal to the Central D.C. load during the corresponding dates in the year ending on August 31, 2005.¹⁶

Mirant is planning to take units out of service beginning in the fall of 2007 to reconfigure the exhaust stacks. DOE has not modeled these planned unit outages because they are not confirmed.

4.3 Environmental Consequences

Assessment of the environmental consequences of the Order is organized by environmental resource. Consideration of cumulative environmental impacts is incorporated into the individual resource-specific discussions, both implicitly (by considering impacts of the Order in the context of environmental conditions that exist because of past and ongoing actions) and explicitly (by considering the potential impacts of any additional ongoing and reasonably foreseeable future actions identified as having the potential to affect the resource).

4.3.1 Air Quality

Impacts to air quality would occur as the result of pollutants being emitted from the Plant's stacks during operations, as well as from activities at the Plant involving vehicle emissions and fugitive dust associated with the coal pile and the handling of ash. The pollutants of primary concern are SO₂ and particulate matter. Modeled concentrations of SO₂ and PM₁₀ are discussed in Section 4.3.1.3. All other NAAQS pollutants, including PM_{2.5}, and hazardous air pollutants are discussed in Section 4.3.1.5. The emissions from the Plant were modeled for four periods: (1) Pre-shutdown operations, that is, the period before the Plant shutdown in August 2005; (2) Pre-Order operations (Section 4.2.2); (3) the period of the Order, including before

AERMOD

AERMOD is one of the approved models included in EPA's Guideline on Air Quality Models (40 CFR Part 51, Appendix W). It is composed of three parts: AERMAP, AERMET, and AERMOD. AERMOD is a steady-state plume air dispersion model that computes the air concentration of released pollutants at selected receptor points. During each hour modeled AERMOD considers the source characteristics (e.g., amount, temperature, stack exit velocity), atmospheric parameters (e.g., wind speed and direction, atmospheric stability), the relative locations of the source and receptor, and the effects of nearby buildings. The computed hourly concentrations are combined to produce the averaging periods (e.g., 24-hour averages) as requested by the user. AERMAP produces the required input data relative to the receptor grid, including elevation. AERMET processes surface and upper-air atmospheric data and produces the input files required by AERMOD.

¹⁶ Because the Plant was not operating at normal historical levels in the period from August 21-31, 2005, DOE used operational levels for the first 11 days of August 2005 to represent the level that the Plant would likely have operated at if it had been generating power at historical levels during the last 11 days of the month.

the ACO allowed daily predictive modeling (December 20, 2005 through June 30, 2006) and after daily predictive modeling began (July 1 through September 30, 2006); and (4) the period beyond the Order (including the period of the temporary extension of the Order to December 1, 2006) until such time as the new transmission lines are placed into operation (October 1, 2006, through June 30, 2007, or, possibly, December 31, 2007).

4.3.1.1 Modeling methods and assumptions

DOE modeled hourly- and annual-average air concentrations of SO₂ and PM₁₀ using the AERMOD system (EPA 2002). (See text box.) AERMOD was used to calculate concentrations for each of the more than 1,700 receptor locations provided by EPA, as shown in Figure 4.3.1-1. The modeled receptor locations include 50-meter intervals along the Plant's fence line. Beyond the fence line, the receptor grid forms a rectangular pattern with the innermost receptors spaced at 100-meter intervals out to a distance of 1,000 meters from the Plant (i.e., the innermost




Figure 4.3.1-1. Map of receptor grid points for atmospheric dispersion modeling.

receptor grid forms a square 2,000 meters long on each side). A second set of receptors is located on the rectangular coordinates at 250-meter spacing for the distances between 1,000 and 3,000 meters of the Plant. Beyond 3,000 meters from the Plant, the receptor grid spacing is increased to 500-meter intervals. The receptor farthest from the Plant in an east-west direction (or in a north-south direction) is located 5,000 meters from the Plant. In addition to the grid of receptor locations, DOE modeled pollutant concentrations at several tall buildings in the vicinity of the Plant. DOE modeled 336 points around Marina Towers at the north end of the Plant, as well as points at multiple heights for six other nearby, tall buildings. The 336 points around Marina Towers are from 24 locations around the perimeter of the building and each of 24 floors of the building. Similarly, the multiple heights at the six other nearby buildings are the heights of each floor of the building.

AERMOD input data. For the period December 20, 2005, through March 31, 2006, DOE used actual unit-by-unit emissions (as provided by Mirant) and actual weather data obtained for Ronald Reagan Washington National Airport. These actual emissions and weather data were used in AERMOD to calculate local air pollution contributions of the Plant. For all other time periods DOE used estimated emissions and weather data from 2001 (as provided by EPA). Previous analyses by EPA had shown that 2001 resulted in predictions of more adverse air quality than the other years in the period 2000 through 2004.

For the period April 1 through May 31, 2006, DOE assumed that the Plant operated a different pair of units each week. Mirant reported to DOE that it had identified 10 two-unit operating modes (i.e., combinations of units that could operate for specified numbers of hours per day at specified SO₂ emission rates) that modeling by Mirant's contractor had demonstrated would not lead to exceedances of the 24-hour average SO₂ concentration at any location. For modeling purposes DOE assumed that the Plant practiced a ten-week rotation during which two of the five units were in operation during any given week. DOE assumed the following rotation of units: 1 and 2, 1 and 3, 1 and 4, 1 and 5, 2 and 3, 2 and 4, 2 and 5, 3 and 4, 3 and 5, and 4 and 5.

For the period April 1 through May 31, 2006, DOE assumed that the Plant operated a different pair of units each week. Mirant reported to DOE that it had identified 10 two-unit operating modes (i.e., combinations of units that could operate for specified numbers of hours per day at specified SO₂ emission rates) that modeling by Mirant's contractor had demonstrated would not lead to exceedances of the 24-hour average SO₂ concentration at any location. For modeling purposes DOE assumed that the Plant practiced a ten-week rotation during which two of the five units were in operation during any given week. DOE assumed the following rotation of units: 1 and 2, 1 and 3, 1 and 4, 1 and 5, 2 and 3, 2 and 4, 2 and 5, 3 and 4, 3 and 5, and 4 and 5.

For the month of June DOE assumed that two units at a time operated according to the schedule of allowed operations given in the ACO (Section 4.1.2). DOE assumed that the Plant used each of the 10 combinations of two units and operated each for three days.

DOE assumed that daily predictive modeling, as authorized by the ACO, was implemented beginning July 1, 2006. For operations under daily predictive modeling DOE assumed that, except during outages, each Plant unit generated power at the same level as it had during the year before Mirant terminated operations in August 2005¹⁷ and that at all times Mirant injected enough trona to achieve 50% SO₂ removal (i.e., controlled to 0.525 lb/MBtu). DOE estimated 50% SO₂ removal to be an average or typical removal rate. At low power generation times and/or favorable wind conditions, very little SO₂ removal is needed to meet air quality standards. During high generation times and/or unfavorable wind conditions, higher rates of trona use (to remove up to 80% of SO₂) are necessary to meet air quality standards. DOE selected the assumption of 50% removal as a mid-range value.

During the transmission line outages planned by Pepco (Table 1.3-1), DOE assumed that all five units operated as necessary to meet the full load of Central D.C. as determined from past data.¹⁸ DOE assumed that after a planned transmission outage the Plant resumed generating power at the level it had the year before operations were terminated on August 24, 2005.

The greatest modeled exceedances of the NAAQS SO₂ limits occur during line outage periods. Although removal of 80% of SO₂ from stack gases, which is technically feasible, would considerably reduce (but not eliminate) modeled exceedances, DOE's modeling of line outage periods assumes that the Plant removes 50% of SO₂ from stack gases. DOE has not modeled 80% removal because Mirant does not stockpile sufficient trona to maintain 80% SO₂ removal for an extended (typically, two-week) line outage.

Sulfur Dioxide. The SO₂ modeling proceeded by using AERMOD to calculate concentrations for each receptor grid point. To simulate the daily predictive modeling process of adjusting planned operations until modeled NAAQS compliance is achieved, DOE examined the 24-hour average concentration for each receptor grid point and for each day. For each day the predicted pollution concentration of each point in the receptor grid was reduced by the percentage that just brought the point with the highest concentration into compliance with the 24-hour SO₂ NAAQS limit.¹⁹ DOE performed this procedure for every modeled day (except

¹⁷ Mirant provided unit-by-unit, hour-by-hour generation data for the period September 1, 2004, through August 31, 2005. DOE used this hourly power generation data to represent what the Plant would do if there were no environmental constraints. Plant operations were terminated on August 24, 2005. Because the data suggest that the Plant started reducing operations on August 21, generation data after August 20 were not considered representative of normal operation.

¹⁸ During outages, DOE assumed that all five units operate at all times, each generating at least 30 MW (minimum capacity), for a total of at least 150 MW. When the load exceeded 150 MW but did not exceed 366 MW, DOE assumed that the two load-following or cycling units (Units 1 and 2) operated at minimum load (for a total of 60 MW) and the three baseload units (Units 3, 4, and 5) each operated at the same level to meet the remaining load. When the load exceeded 366 MW, DOE assumed that the baseload units each operated at capacity (102 MW), for a total of 306 MW, and the load-following or cycling units each operated at the same level to produce enough additional power to meet the demand until the load exceeded the capacity of the Plant (482 MW).

¹⁹ Compliance with the 24-hour SO₂ limit was based on a concentration of 314 µg/m³ (the NAAQS standard
(continued...))

during outages) before calculating 3-hour, 24-hour, and long-term average concentrations. Although the ACO also requires modifying planned operations if daily predictive modeling forecasts an exceedance of 3-hour average SO₂ limits, DOE did not simulate predictive modeling for the 3-hour standard because the computational effort required to calculate average concentrations for all possible 3-hour periods for each of the 1,747 modeled locations was judged to be excessively large for the information to be gained.

Particulate Matter. DOE's modeling considered both stack emissions and fugitive emissions from the Plant as sources of airborne particulate matter.

Based on particulate emissions testing by TRC Environmental Corporation (2006), DOE used a stack emission rate of 0.019 lb PM₁₀ per MBtu when trona injection was employed and 0.035 lb/MBtu PM₁₀ when it was not in use. For operations before the Order and during the January 2006 transmission line outage, DOE assumed the 0.035 lb/MBtu PM₁₀ emission rate. For all other periods after the Order, DOE assumed the 0.019 lb/MBtu emission rate. DOE modeled stack emitted PM₁₀ emissions using the same operational schedule as used for SO₂ modeling. However, DOE did not simulate the effects of daily predictive modeling on PM₁₀ emissions because DOE found that with the 0.019 lb/MBtu emission rate, stack emissions never lead to exceedances of the NAAQS limit for PM₁₀.

DOE modeled fugitive PM₁₀ emissions using fugitive dust parameters supplied to EPA by Mirant. Some fugitive emissions are related to wind; for example, wind blows dust off the coal pile. Most of the emissions are related to the handling of coal and ash, which are operations that increase as plant operations increase. Fugitive dust modeling parameters were not, however, increased or decreased as generating levels increased or decreased. The parameters are based on the assumption that four of the five units operate full time, but they do not account for the extra dust generated by disposal of trona waste.

4.3.1.2 Uncertainties in modeling

The modeling results need to be interpreted cautiously because of many uncertainties related to assumptions and modeling approaches. Overall, DOE's approach was conservative in that it tends to overestimate impacts. Specific sources of uncertainty include the following:

1. DOE chose to use 2001 weather data because, based on EPA experience using 2000 through 2004 weather data, the 2001 data were more likely than other years to yield modeled exceedances.
2. For periods after June 30, 2006, DOE assumed that Mirant used trona injection to reduce SO₂ emissions by 50%. The Plant may operate with less than 50% SO₂ removal when

¹⁹ (...continued)
of 365 less the assumed background concentration of 51 µg/m³).

modeling (based on predicted weather conditions) does not indicate an exceedance would result. Conversely, the Plant may remove more than 50% of SO₂ or reduce power generation rates when modeling indicates this is necessary to avoid exceedances of the NAAQS. The assumption of 50% SO₂ removal is likely to mean that DOE's modeling underestimates the period-average concentrations of SO₂. However, because of the way DOE has modeled daily predictive modeling, this should introduce little error in estimates of maximum short-term SO₂ concentrations.

3. DOE did not model all of the operational possibilities available to Mirant. When modeling indicates an exceedance, DOE's modeling assumes that Mirant reduces emissions to a level just below what would cause a modeled exceedance. (This is equivalent to assuming that the power generation from each boiler is reduced by the necessary percentage, or that additional trona is injected at each boiler to reduce SO₂ emissions by that percentage.) While it is mathematically possible to exactly meet the 314-µg/m³ 24-hour limit, DOE expects Mirant to keep SO₂ emissions somewhat below the levels that are computed to just meet the limit. Therefore, this DOE modeling approach tends to overestimate actual 24-hour averages.²⁰
4. The ACO requires Mirant to achieve 80% SO₂ removal during line outage situations unless predictive modeling demonstrates that this level of SO₂ removal is not necessary or Mirant demonstrates that 80% removal is not "logistically feasible." Because Mirant does not have the capacity to stockpile sufficient trona for an extended line outage, DOE assumed 50% SO₂ removal during line outage situations.
5. DOE has used an estimate of fugitive PM₁₀ emissions that is based on the assumption that four of the five boiler units are operating at all times. While some fugitive emissions are caused by wind-blown erosion (e.g., of the coal pile), most fugitive emissions result from coal and ash handling. Because the amount of coal and ash handling is related to the level of power generation, fugitive emissions are probably overestimated for periods when the Plant is producing relatively little power. On the other hand, because the fugitive emissions rates do not account for increased emissions due to trona waste generated by operations, the fugitive emissions may be underestimated during high power generation periods.
6. DOE's modeling of operations under daily predictive modeling does not account for the use of monitoring and alarms to prevent exceedances of SO₂ NAAQS. The ACO requires

²⁰ Although not required, Mirant is known to be targeting 200 µg/m³ for a margin of predictive modeling to provide a margin of safety. (D. Lohman, EPA Region 3, personal communication with Seema Kakade, DOE, October 26, 2006.)

Mirant to monitor SO₂ at two locations on the top of Marina Towers and four other locations near the Plant. The ACO requires Mirant to maintain alarms that alert the Plant operators if monitored average concentrations reach 80% of the standards for SO₂. If one of the alarms sound, Mirant is required to modify operations to prevent an exceedance. (See Appendix B, Section IV, B, 5.) Because DOE's modeling does not account for use of monitoring to constrain operations, it overestimates the actual concentrations that will be observed during operations after this section of the ACO takes effect.

7. The highest modeled SO₂ concentrations occur at the rooftop at Marina Towers. Initial monitoring data collected by SO₂ monitors installed by Mirant for the MES do not show concentrations as high as calculated by Mirant's follow-up modeling, which is based on actual weather data. Because DOE believes it used the same AERMOD input parameters that Mirant used, these data suggest that the DOE application of AERMOD may overestimate maximum concentrations at Marina Towers. These data and the questions they raise are described in more detail in Section 4.3.1.4.

Despite the limitations, the results presented here are the best estimates available at this writing.

4.3.1.3 Modeling results for SO₂ and PM₁₀ emissions

The EPA has established air quality standards for different averaging periods. An area is considered to be in attainment when the standards are not exceeded at any location in the area. For most pollutants compliance is determined by the second highest value or some other statistical characteristic per year.

The tables in this section present concentrations for three time averaging periods: 3-hour, 24-hour, and specific indicated time periods ranging from 21 to 387 days in length, which are presented as surrogates for the annual average. Although the standards typically determine compliance by the second highest value or another statistical characteristic, for simplicity DOE presents only the highest value for the specified averaging period. This maximum value is likely to be higher than the value used to determine compliance with the standard.

In all cases the value presented in the table is the modeled value for the receptor location that had the highest modeled value among the 1,747 modeled receptor locations. The 3-hour average refers to the highest average concentration for any three consecutive hours for any location. The 24-hour average is the highest average concentration for any calendar day (in the period) at any location. The maximum 3- and 24-hour averages represent relatively unusual occurrences. The annual or period average is more indicative of the usual air quality. Because most of the modeled periods are shorter than one year, the modeled period averages in the tables are not directly comparable to the annual air quality standards, but they do indicate how the period contributes to the annual average. For example, operations during a period with an average that exceeds the annual standard could contribute toward an exceedance of the annual

standard, while operations during a period with an average below the standard could contribute toward meeting the annual standard. Note that, because pollutants are not evenly distributed across the area, all values in the tables considerably overstate the expected concentration at all but a few of the 1,747 modeled locations.

Table 4.3.1-1 shows modeled SO₂ and PM₁₀ concentrations for pre-shutdown operations, pre-Order operations, and operations under the Order through September 30, 2006. The first row of the table presents maximum background concentrations. These are the maximum values observed at nearby ambient air quality monitoring stations for the specified averaging periods (Table 3.1-2). The ACO specifies that these “background concentrations” must be added to modeled concentrations resulting from Plant operations in determining whether a “modeled exceedance” occurs. Other rows in the table present modeled concentrations resulting from Plant operations and summed values in which modeled concentrations are added to the maximum background concentrations. The summation approach specified in the ACO is conservative because it is very unlikely that maximum Plant-induced concentrations would occur at the same time as maximum background concentrations. The modeling results presented in the table are discussed in more detail in the following paragraphs.

Pre-shutdown operations. Until August 2005 the Plant operated in the historical manner; essentially, it produced power as economics would dictate. The Plant operated without controls on SO₂ emissions. Table 4.3.1-1 shows that modeling of pre-shutdown operations predicts significant exceedances of the NAAQS for SO₂ concentrations. The table also shows exceedance for the maximum 24-hour PM₁₀ concentration. The maximum PM₁₀ values reported here are dominated by fugitive dust emissions. Maximum modeled concentrations of PM₁₀ from stack emissions are generally less than half of concentrations due to fugitive emissions.

Pre-Order operations. During the fall of 2005, the Plant operated in an 8-8-8 mode: 8 hours off, 8 hours at minimum power, and 8 hours at up to maximum power each day (Section 4.2.2). During this period the Plant was experimenting with trona injection and use of Colombian coal. However, Mirant had performed modeling that showed that no exceedance of the NAAQS SO₂ limit would occur under 8-8-8 operation even if no SO₂ control were employed. Consequently, during this period Mirant did not control SO₂ emissions to any set level. Table 4.3.1-1 shows the results of modeling pre-Order operations for an assumed full year. The table shows that pre-Order operations allow the Plant to meet SO₂ limits.

During 2005 and 2006, Mirant implemented several fugitive dust control measures (Section 2.5). Modeling of PM₁₀ concentrations resulting from pre-Order operations used emissions factors that assume that some of these measures were in place. Table 4.3.1-1 shows that modeled PM₁₀ concentrations for pre-Order operations are substantially lower than for pre-shutdown operations and meet the PM₁₀ limits.

**Table 4.3.1-1. Modeled maximum ambient SO₂ and PM₁₀ concentrations (µg/m³)
for Plant operations among all receptor locations.**

Operating Scenario and Period	SO ₂			PM ₁₀	
	Maximum 3-hour average	Maximum 24-hour average	Maximum period average (for the specified period or 1 year)	Maximum 24-hour average	Maximum period average (for the specified period or 1 year)
Maximum Background Concentration	238 ^a	51 ^a	16 ^a	45 ^a	21 ^a
Modeled Maximum Concentrations					
Pre-shutdown operations (Sep. 1, 2004 through Aug. 20, 2005)	5,156	2,967	299	150	25
Pre-Order operations (annual)	767	277	24	61	13
Dec. 20, 2005 through June 30, 2006					
Non-outage periods (172 days)	479	246	32	36	9
Outage periods (21 days)	3,484	1,888	389	43	13
July 1 through September 30, 2006	1,445	314	136	58	10
Modeled Maximum Concentrations with Maximum Background Concentrations Added					
Pre-shutdown operations (Sep. 1, 2004 through Aug. 20, 2005)	5,394	3,018	315	195	46
Pre-Order operations (annual)	1,005	328	40	106	34
Dec. 20, 2005 through June 30, 2006					
Non-outage periods (172 days)	717	295	48	81	30
Outage periods (21 days)	3,772	1,939	405	88	34
July 1 through September 30, 2006	1,683	365	152	103	31
NAAQS limit^b	1,300	365	80	150	50

Note: Modeled values are the highest criteria pollutant concentration among all receptor locations. Pre-shutdown and pre-Order operations do not include higher levels of operations for line outages. Actual or planned line outage conditions are included in the operational periods of the Order. Annual values for modeled concentrations for periods less than one year are time-weighted averages. Whereas many NAAQS limits are specified as the second highest or other value, the modeled values presented in this table are the highest values.

^a These are the highest values observed at nearby monitoring stations for the specified averaging periods. At most times ambient concentrations are lower than these values. Annual SO₂ concentration is the annual arithmetic mean for years 2001, 2002, and 2003 measured at 517 N. Saint Asaph Street, Alexandria City (ENSR Corporation 2005). Annual PM₁₀ concentration is the 2004 arithmetic mean reported in VDEQ 2005, page 49, monitoring site L-46-B3. (Just before publication of this document, Virginia released ambient air monitoring data for 2005 [VDEQ 2006c]. The updated background levels vary only slightly from the 2004 values reported and used here.)

^b NAAQS values from 40 CFR Part 50. See Section 3.1.2 and Table 3.1-1 for an explanation of NAAQS and the averaging periods that apply to each. EPA's October 17, 2006, rule making on NAAQS for particulate matter (EPA 2006j) revoked the annual PM₁₀ standard, effective December 18, 2006.

Operations under the Order. Operations under the Order were addressed in two periods, December 20, 2005, through June 30, 2006, and July 1 through September 30, 2006. Operations under the Order were divided in this manner because DOE assumed that operations changed significantly when Mirant began operations under daily predictive modeling as permitted by the ACO. The following paragraphs discuss the effects of SO₂ and PM₁₀ emissions for these two time periods.

December 20, 2005, through June 30, 2006. For the December through June period, maximum modeled SO₂ concentrations (Table 4.3.1-1) show exceedances of the SO₂ limits during the January line outages, when the highest modeled 3- and 24-hour SO₂ concentrations occurred. For most of the outage trona injection was available on only one unit; Mirant injected trona in two units simultaneously during the last week of the outage. For non-line outage periods through June 30, there were no modeled exceedances of the 3- or 24-hour limits, in part because the Plant operated at a relatively low average power. Table 4.3.1-1 shows no modeled exceedances of limits for PM₁₀ during either line outage or non-line outage periods. The fugitive dust parameters used in modeling PM₁₀ concentrations for this time period reflect the progressive implementation of fugitive dust control measures at the Plant.

July 1 through September 30, 2006. The commencement of *daily predictive modeling* on July 1, 2006, approximately coincided with the beginning of the season of highest power demand (Figure 4.2-1). Beginning July 1, 2006, modeled plant generation increased and modeled SO₂ exceedances occur for all averaging periods except the 24-hour average during non-outage periods. The ACO requires modifying planned operations if daily predictive modeling forecasts an exceedance of either 3- or 24-hour average SO₂ limits. DOE's modeling assumed that the Plant would scale back operations to meet the 24-hour SO₂ standard as required by the ACO (Section 4.1.2). However, as described in Section 4.3.1.1, DOE's model did not assume that the Plant would scale back operation to meet the 3-hour standard, even though it is required by the ACO, because it would have been excessively complex to model. In actuality, it is expected that the modeled maximum 3-hour average exceedances indicated by Table 4.3.1-1 for the July through September period would be prevented by daily predictive modeling. However, the model's prediction of exceedances when the 3-hour limit is not applied suggests that controlling operations for 24-hour averages is not enough to assure compliance with the 3-hour average SO₂ limit.

The modeled exceedance of the longer-period average SO₂ limit (Table 4.3.1-1) is a logical consequence of operations under daily predictive modeling, because daily predictive modeling allows the Plant to operate at the highest levels that do not cause exceedances of 24-hour SO₂ limit. Operating close to the 24-hour limit (314 g/m³) day after day inevitably raises the long-term average to a higher level than for a plant that does not consistently operate close to the limit.

The exceedances indicated in the table are modeled exceedances, not actual exceedances. The ACO has provisions for preventing actual exceedances during non-outage periods. In particular, the ACO requires Mirant to monitor SO₂ concentrations near the top of Marina Towers (where the maximum modeled exceedances occur) for close approaches to NAAQS SO₂ limits. If a monitored concentration exceeds 80% of the limit for one of the averaging periods, an audible alarm will sound in the control room (Section 4.1.2.1) and the ACO requires Mirant to take corrective action, such as reducing power generation. Consequently, DOE anticipates that actual exceedances of the SO₂ limits will not occur during non-line outage periods.

As shown by Table 4.3.1-1, Plant operations under the ACO do not result in modeled exceedances of any of the NAAQS limits for PM₁₀.

Operations during a potential extension of the Order until new transmission lines are installed. Table 4.3.1-2 presents modeled maximum concentrations of SO₂ and PM₁₀ due to Plant operations during a potential 9- or 15-month extension of the Order beyond September 30, 2006. This includes the period of the temporary 2-month extension of the Order from October 1 to December 1, 2006. Pepco's current schedule has the new transmission lines being installed and operational by the end of June 2007. Because there is a possibility that the transmission lines may not become operational on schedule, DOE has also examined a scenario for extension of the Order through December 2007.

As shown by Table 4.3.1-2, compliance with the ACO leads to meeting the NAAQS limits for 24-hour average SO₂ concentrations during non-line outage periods. As with operations under the initial term of the Order, DOE's model did not assume that the Plant would scale back operation to meet the 3-hour standard as required by the ACO. In actuality, it is expected that the modeled maximum 3-hour average exceedances indicated by Table 4.3.1-2 would be prevented by daily predictive modeling. The modeled exceedances of the NAAQS SO₂ limits for the annual average during non-line outage situations shown in Table 4.3.1-2 result from the assumption that the Plant operates close to the 24-hour limit on a continuing basis. Under the ACO Mirant would be required to modify Plant operations to avoid predicted exceedances of all SO₂ NAAQS averaging periods. Consequently, DOE anticipates that actual exceedances of the SO₂ limits would not occur during non-line outage periods.

As shown by Table 4.3.1-2, Plant operations under an extension of the Order would not result in modeled exceedances of any of the NAAQS limits for PM₁₀.

EPA has provided DOE with preliminary data on monitored air quality measurements taken by Mirant pursuant to the ACO. Mirant sent this information to EPA as part of its monthly reporting requirements under the ACO. EPA is currently reviewing and interpreting the data; however, as discussed in Section 4.3.1.4, the data suggest that actual air quality impacts from operation of the Plant under daily predictive modeling are lower than impacts predicted through DOE's modeling efforts.

4.3.1.4 Monitored SO₂ data

Pursuant to the requirements for performing the MES (Appendix B, Section VI), Mirant has installed six SO₂ monitoring stations near the Plant. Two are located on the roof of Marina Towers--one at the center of the building and one on the southeast wing. One station is located east of stack 5 on the west bank of the Potomac River. Another monitor is located southeast of the Plant along the fence line near the River. One monitor is located at Daingerfield Island about 800 m north of Marina Towers. One monitor is located on the roof of Harbor Terrace (Holiday Inn) southwest of the Plant. These monitoring sites were selected based on discussions among Mirant, DOE and EPA modeling and meteorological experts.

Initial results from the monitors show that actual monitored daily average (approximately the same as 24-hour average) values are much lower than shown by Mirant's follow-up modeling using actual hourly emissions and exhaust parameters and observed weather

Table 4.3.1-2. Modeled maximum ambient SO₂ and PM₁₀ concentrations (µg/m³) for Plant operations among all receptor locations for a potential extension of the Order.

Operating Scenario and Period	SO ₂			PM ₁₀	
	Maximum 3-hour average	Maximum 24-hour average	Maximum period average (for the specified period or 1 year)	Maximum 24-hour average	Maximum period average (for the specified period or 1 year)
Maximum Background Concentration	238 ^a	51 ^a	16 ^a	45 ^a	21 ^a
Modeled Maximum Concentrations					
Potential extension of the Order Oct. 1, 2006 – Jun. 30, 2007					
Non-outage periods (203 days)	1,236	314	101	61	12
Outage periods (70 days)	2,193	1,152	171	66	13
Potential extension of the Order Oct. 1, 2006 – Dec. 31, 2007					
Non-outage periods (387 days)	1,449	314	115	67	12
Outage periods (70 days)	2,193	1,152	171	66	13
Modeled Maximum Concentrations with Maximum Background Concentrations Added					
Potential extension of the Order Oct. 1, 2006 – Jun. 30, 2007					
Non-outage periods (203 days)	1,474	365	117	106	33
Outage periods (70 days)	2,431	1,203	187	111	34
Potential extension of the Order Oct. 1, 2006 – Dec. 31, 2007					
Non-outage periods (387 days)	1,687	365	131	112	33
Outage periods (70 days)	2,431	1,203	187	111	34
NAAQS limit^b	1,300	365	80	150	50

Note: All periods include the period of the two-month temporary extension of the Order from October 1 to December 1, 2006. Modeled values are the highest criteria pollutant concentration among all receptor locations. Planned transmission line outages in preparation for the 230-kV lines are included in the periods. Annual values for modeled concentrations for periods other than one year are time-weighted averages. While, many NAAQS limits are specified as the second highest or other value, the values presented in this table are the highest values.

^a These are the highest values observed at nearby monitoring stations for the specified averaging periods. At most times, ambient concentrations are lower than these values. Annual SO₂ concentration is the annual arithmetic mean for years 2001, 2002, and 2003 measured at 517 N. Saint Asaph Street, Alexandria City (ENSR Corporation 2005). Annual PM₁₀ concentration is the 2004 arithmetic mean reported in VDEQ 2005, page 49, monitoring site L-46-B3. (Just before publication of this document, Virginia released ambient air monitoring data for 2005 [VDEQ 2006c]. The updated background levels vary only slightly from the 2004 values reported and used here.)

^b NAAQS values from 40 CFR Part 50. See Section 3.1.2 and Table 3.1-1 for an explanation of NAAQS and the averaging periods that apply to each. EPA's October 17, 2006, rule making on NAAQS for particulate matter (EPA 2006j) revoked the annual PM₁₀ standard, effective December 18, 2006.

conditions, matched hour for hour. Specifically, for the period June 17 through September 17, 2006, the maximum monitored daily-average concentration for the monitors ranged from 4 to 63 µg/m³. For the same time period Mirant's follow-up modeling of actual operations using weather data recorded at Ronald Reagan Washington National Airport gave maximum daily-average concentrations that ranged from 25 to 570 µg/m³. Aside from the specific operations and weather data, follow-up modeling used the same parameters to characterize the Plant as used for the analysis in the SEA and the 2005 downwash study (ENSR Corporation 2005).

The reasons for the discrepancy between monitored and maximum concentrations from follow-up modeling are not apparent. Mirant's technical consultant reports that when modeling uses effective building dimensions derived from a wind tunnel study, the resulting modeled maximum SO₂ concentrations are closer to the monitored concentrations (Personal communication between D. Shea, ENSR Corporation, Welsford, MA, and L.N. McCold, Oak Ridge National Laboratory, Oak Ridge, TN, October 3, 2006), but this modeling approach does not fully account for the discrepancy. An explanation suggested by Mirant's consultant is that AERMOD underestimates the buoyancy of multiple stack plumes when the wind is blowing parallel to the line of stacks. Another possible explanation is that the weather data from National Airport does not precisely match the weather at the Plant. Mirant's consultant reports that wind directions reported at National Airport are often slightly different from those detected at the Plant. Particularly near the Plant, small differences in wind direction can cause large differences in pollutant concentration at any specific point.

The discrepancy between monitoring data and modeled concentrations raises the possibility that the modeled maximum concentrations reported in Tables 4.3.1-1 and 4.3.1-2 of this SEA are unrealistically high for receptor points that are very close to the Plant. However, because DOE used forecasts rather than actual emissions and weather data, the results presented in this SEA are not directly comparable to either the monitoring data or to Mirant's follow-up modeling.

Because the MES may require as much as a year of monitoring data, EPA is not expected to reach a conclusion about the accuracy of the modeled concentrations before late 2007. In the meanwhile, the ACO requires that the Plant be operated to avoid predicted modeled exceedances.

4.3.1.5 Other air pollutants

Contributions to PM_{2.5} pollution. For PM_{2.5} the NAAQS specify a maximum annual average concentration of 15 µg/m³ and a 98th-percentile 24-hour average concentration of 65 µg/m³. Regulation of PM_{2.5} is still developing. On October 17, 2006, EPA published new ambient air quality standards for PM_{2.5} in the *Federal Register* (EPA 2006j). The new standards, which take effect December 18, 2006, retain the level of 15 µg/m³ for the annual average and institute a 35 µg/m³ 24-hour average. State implementation plans (SIPs) for PM_{2.5} are not due to EPA until 2008.

The PM_{2.5} monitor nearest to the Plant is at Aurora Hills Visitor Center (Table 3.1-2), a short distance west of Ronald Reagan Washington National Airport. The 2004 annual average PM_{2.5} concentration measured at Aurora Hills was 14.4 µg/m³; the 98th-percentile 24-hour average concentration was 35.7 µg/m³.²¹ As noted in Section 3.1.2, the region in which the Plant exists is in nonattainment with the PM_{2.5} standard.

²¹ Just before publication of this document, Virginia released ambient air monitoring data for 2005 (VDEQ 2006c). The updated background levels vary only slightly from the 2004 values reported and used here.

There are two important sources of particulate matter associated with the Plant: stack emissions and fugitive dust. Because fugitive dust from the Plant is emitted near ground level, for locations near the Plant fugitive dust is the principal source of ground level PM_{2.5} attributable to Plant operations. Because stack emissions are located far off the ground, they are the most important Plant-related source of particulate matter at nearby elevated receptor locations, specifically near the top of Marina Towers. Because both ground level and elevated concentrations are important, maximum values for each are presented here.²²

DOE used estimates of PM₁₀ concentrations (Section 4.3.1.3) as a basis for estimating PM_{2.5} concentrations. EPA's AP-42 emission factor guidelines (Personal communication between D. Lohman, U.S. EPA, Region III, and L.N. McCold, Oak Ridge National Laboratory, August 28, 2006) applied to wind blown dust indicate that PM_{2.5} is 15% of the PM₁₀. Based on this guidance, DOE assumed that 15% of fugitive PM₁₀ was PM_{2.5}. The AP-42 factors for the PM_{2.5} fraction of PM₁₀ from electric generating units controlled by electrostatic precipitators range between 44% for dry bottom boilers and 76% for over-fire stokers (Personal communication between D. Lohman, U.S. EPA, Region III, and L.N. McCold, Oak Ridge National Laboratory, August 28, 2006). Based on this guidance, DOE conservatively assumed 76% of PM₁₀ emitted from the Plant stacks was PM_{2.5}.

DOE's analysis considers only directly emitted particulate matter. In addition to PM_{2.5} that is emitted directly as particulate matter, certain chemicals, especially SO₂ and NO_x, are emitted as gases, but form particulate matter after they are released. This source of PM_{2.5} is not included in the air quality analysis because AERMOD does not incorporate a photochemical model that can account for nonlinear chemical reactions. In addition, such a model would require much more extensive atmospheric data than are readily available. However, because the background concentrations used in developing DOE's PM_{2.5} estimates were measured while the Plant was operating at pre-shutdown levels, some, unknown but probably small, fraction of the background is due to Plant operations. Consequently, adding estimated Plant contributions to background concentrations involves some double counting of Plant effects. The discussion below presents estimates of PM_{2.5} contributions first with and then without background concentrations.

Pre-shutdown operations. Pre-shutdown operations (one year) are estimated to have resulted in maximum 24-hour average concentrations of 74 µg/m³ (38 µg/m³ due to Plant operations alone; that is, without background) at ground level and 112 µg/m³ (76 µg/m³ due to Plant operations) at the top of Marina Towers. The annual average ground level PM_{2.5} concentration was estimated to be 20 µg/m³ (5.7 µg/m³ due to Plant operations), and the average annual PM_{2.5} concentration at the top of Marina Towers was estimated to be 22 µg/m³ (7.8 µg/m³ due to Plant operations).

Pre-Order operations. If pre-Order operations had continued for one year, the maximum estimated ground-level 24-hour-average PM_{2.5} would have been 45 µg/m³ (9.2 µg/m³ due to

²² Both stack and fugitive sources were included in estimating PM_{2.5} concentrations for both ground-level and elevated receptors.

Plant operations), and the comparable concentration at the top of Marina Towers would have been $40 \mu\text{g}/\text{m}^3$ ($4.8 \mu\text{g}/\text{m}^3$ due to Plant operations). The maximum estimated ground-level annual average $\text{PM}_{2.5}$ concentration would have been $16 \mu\text{g}/\text{m}^3$ ($2.0 \mu\text{g}/\text{m}^3$ due to Plant operations), and the maximum annual average concentration at the top of Marina Towers would have been $15 \mu\text{g}/\text{m}^3$ ($1.0 \mu\text{g}/\text{m}^3$ due to Plant operations).

Operations under the Order. For the duration of the Order, the estimated maximum 24-hour-average ground-level $\text{PM}_{2.5}$ concentration is $61 \mu\text{g}/\text{m}^3$ ($25 \mu\text{g}/\text{m}^3$ due to Plant operations), and the maximum estimated ground-level 285-day-period-average $\text{PM}_{2.5}$ concentration is $38 \mu\text{g}/\text{m}^3$ ($2.4 \mu\text{g}/\text{m}^3$ due to Plant operations). Because an important fugitive dust suppression measure was implemented in March 2006, the period before April contributed more to the 285-day-period average $\text{PM}_{2.5}$ concentration than operations after April, and the maximum estimated 24-hour-average $\text{PM}_{2.5}$ concentration occurred before April.

For the duration of the Order, the maximum 24-hour-average concentration at the top of Marina Towers is $76 \mu\text{g}/\text{m}^3$ ($41 \mu\text{g}/\text{m}^3$ due to Plant operations), and the maximum 285-day-period-average concentration at the top of Marina Towers is $18 \mu\text{g}/\text{m}^3$ ($3.9 \mu\text{g}/\text{m}^3$ due to Plant operations). Because of increased generation after the start of operations under daily predictive modeling, operations after June contributed more to the 285-day-period-average $\text{PM}_{2.5}$ concentrations than operations before July, and the maximum estimated 24-hour-average concentration occurred after June.

Potential extension of the Order. For a potential extension of the Order through December 2007 (including the period of the temporary extension until December 1, 2006), the estimated maximum 24-hour average ground-level concentration would be $58 \mu\text{g}/\text{m}^3$ ($23 \mu\text{g}/\text{m}^3$ due to Plant operations), and the maximum estimated concentration on the top of Marina Towers would be $79 \mu\text{g}/\text{m}^3$ ($43 \mu\text{g}/\text{m}^3$ due to Plant operations). The estimated maximum 24-hour average occurs during non-outage periods. The estimated maximum annual average ground-level $\text{PM}_{2.5}$ concentration would be $18 \mu\text{g}/\text{m}^3$ ($4.0 \mu\text{g}/\text{m}^3$ due to Plant operations), and the estimated maximum concentration at the top of Marina Towers would be $20 \mu\text{g}/\text{m}^3$ ($5.7 \mu\text{g}/\text{m}^3$ due to Plant operations).

Nitrogen oxide contributions to ozone (O_3) pollution. Alexandria and the surrounding area are in nonattainment for O_3 . Ozone is formed in the atmosphere when sunlight interacts with NO_x and volatile hydrocarbons. In the eastern United States, natural volatile hydrocarbon molecules are abundant in the atmosphere. Consequently, the most effective method for limiting the formation of O_3 is limiting the abundance of NO_x in the atmosphere. NO_x is readily formed in high temperature combustion processes such as power plants and internal combustion engines.

The following data were used to estimate NO_x emissions. Hourly operations data for December 20, 2005, through March 31, 2006, indicate that average NO_x emission rate for Units 1 and 2 is about 0.35 lb/MBtu and the emission rate for Units 3, 4, and 5 averages 0.26 lb/MBtu. Assuming that each unit consumes the same average amount of coal, the average emission rate would be 0.296 lb per MBtu of coal consumed. At 12,000 Btu/lb of coal, Units 1 and 2 have NO_x

emission rates of 8.4 lb per ton of coal. When all units operate (using equal quantities of coal), the average NO_x emission rate is about 7.1 lb per ton of coal.

As a point of reference, the ACO requires that the Plant emit no more than 3,700 tons (3,400 metric tons) of NO_x per year.

Pre-shutdown operations consumed about 832,000 tons (755,000 metric tons) of coal per year and emitted 3,000 tons (2,700 metric tons) of NO_x per year. For comparison purposes, if pre-shutdown operations had continued for the 285-day duration of the Order, the Plant would have consumed about 650,000 tons (590,000 metric tons) of coal and emitted about 2,300 tons (2,100 metric tons) of NO_x. If pre-shutdown operations were to continue for a 15-month extension of the Order through December 2007 (including the period of the temporary extension until December 1, 2006), the Plant would consume about 1,040,000 tons (943,000 metric tons) of coal and emit about 3,700 tons (3,400 metric tons) of NO_x.

Pre-Order operations. For comparison purposes, if pre-Order operations (when only Unit 1 operated) had continued for the duration of the Order, the Plant would have consumed about 153,000 tons (140,000 metric tons) of coal and emitted about 640 tons (580 metric tons) of NO_x, a rate of about 820 tons (750 metric tons) per year. If pre-Order operations were to continue for an extension of the Order through December 2007 (including the period of the temporary extension until December 1, 2006), the Plant would emit about 1,030 tons (940 metric tons) of NO_x over the 15-month period.

For the 285-day term of *the Order*, the Plant is estimated to burn about 566,000 tons (504,000 metric tons) of coal and emit about 2,600 tons (2,300 metric tons) of NO_x, a rate of 2,600 tons (2,300 metric tons) per year.

For *potential extension of the Order* from October 1, 2006 through December 2007 (including the period of the two-month temporary extension until December 1, 2006), the Plant would consume about 1,040,000 tons (940,000 metric tons) of coal and emit about 3,700 tons (3,400 metric tons) of NO_x, a rate of about 3,000 tons (2,700 metric tons) per year.

Contributions to carbon monoxide (CO) and lead pollution. As shown by Table 3.1.2, monitored levels of CO are well below the standard. Because CO levels are so low and because coal-fired power plants are not significant sources of CO, DOE did not model contributions to ambient CO levels due to Plant operations. Because ambient lead concentrations have declined to such low levels since the elimination of leaded gasoline that lead concentrations are no longer monitored in Virginia, DOE did not model potential contributions due to Plant operations.

Contributions to hazardous air pollutants. *Mercury* emissions by coal fired power plants are believed to be a major contributor to atmospheric mercury contamination. In its elemental form mercury is easily vaporized. Mercury forms nonvolatile compounds with sulfur and chlorine that can be captured in precipitators and incorporated in fly ash, but DOE assumed that all mercury in the coal burned by the Plant is emitted to the atmosphere through the stacks. This assumption is not likely to lead to an overestimate of mercury emissions because chemical analyses of Plant fly ash did not detect mercury (Section 4.3.5).

Data provided by Mirant indicates that the mercury content of coal supplied to the Plant ranges from 0.03 to 0.07 ppm (0.06 to 0.14 lb mercury per thousand tons of coal). DOE's analysis conservatively uses the high end of this range, that is 0.14 lb per thousand tons of coal.

Pre-shutdown operations consumed about 832,000 tons (755,000 metric tons) of coal per year. At 0.14 lb of mercury per thousand tons of coal, pre-shutdown operations can be estimated to emit 116 lb/year (53 kg/year) of mercury. For the 285-day period of the Order, it would emit about 91 lb of mercury. For extension of pre-shutdown operations through a 15-month extension of the Order, operations would emit about 145 lb of mercury.

For *pre-Order operations*, the Plant would burn about 540 tons (490 metric tons) of coal per day. Pre-Order operations for the period of the Order would lead to consumption of about 153,000 tons (140,000 metric tons) of coal. At 0.14 lb mercury per thousand tons of coal, pre-Order operations would have caused emission of about 21 lb (10 kg) of mercury for the period of the Order. Pre-Order operations for a 15 month extension of the Order would involve consumption of about 245,000 tons (220,000 metric tons) of coal and emission of about 34 lb (16 kg) of mercury.

For the 285 days of *the Order*, DOE estimates Plant coal consumption at 566,000 tons (510,000 metric tons), resulting in emissions of about 79 lb (36 kg) of mercury. Thus, the Order is estimated to increase mercury emissions of the Plant by 58 lb (26 kg) over the 285-day term of the Order. By comparison, if *pre-shutdown operations* had continued for the same 285 days, the Plant would have consumed about 650,000 tons (590,000 metric tons) of coal and emitted about 91 lb (41 kg) of mercury.

For *potential extension of the Order* from October 2006 through December 2007 (including the period of the two-month temporary extension until December 1, 2006), the Plant would consume about 1,040,000 tons (943,000 metric tons) of coal and emit approximately 146 lb (66 kg) of mercury. By comparison, pre-Order operations of the Plant for the same period would involve burning about 245,000 tons (220,000 metric tons) of coal with emission of about 34 lb (16 kg) of mercury. Thus, extension of the Order for 15 months would result in an increase in mercury emissions, over pre-Order operations, of about 111 lb (50 kg) mercury.

Other metals typically present as trace constituents of coal are less volatile than mercury, so they are primarily incorporated into solid wastes (bottom ash and fly ash), with only small fractions emitted to the atmosphere. The coal data that Mirant provided to DOE did not include concentrations of toxic metals other than mercury. Table 2.3-1 summarizes some published data on concentrations of seven trace metals in Appalachian coals. These data provide an indication of levels that may be present in the central Appalachian coal burned by the Plant. DOE performed a mass balance analysis for five of these metals using data on fly ash from Table 4.3.5-2. The results suggest that much of the arsenic and cadmium in the original coal, and some of the lead, selenium, and chromium are captured in fly ash. Capture of selenium in fly ash increases greatly when trona is used in the Plant (Section 4.3.5). DOE does not have data on the composition of the Plant's bottom ash, which would be expected to contain the majority of some metals, particularly the least volatile, such as beryllium, chromium, and nickel. Metals not

captured in a solid phase are released to the atmosphere. DOE has not estimated the quantities of these metals released to the atmosphere.

4.3.1.6 General conformity requirement

Background. General conformity arises out of Section 176(c)(1) of the Clean Air Act (CAA) which provides that no Federal agency shall “engage in, support in any way or provide financial assistance for, license or permit, or approve, any activity which does not conform to [an approved State implementation plan (SIP)].” Under the CAA conformity to an implementation plan means that such activities will not (1) cause or contribute to any new violation of any standard in any area, (2) increase the frequency or severity of any existing violation of any standard in any area, or (3) delay timely attainment of any standard or any required interim emission reductions or other milestones in any area [CAA §176(c)(1)(B)].

Before DOE issued its Order, VDEQ raised several concerns related to general conformity in its filing to FERC (VDEQ 2005b).²³ VDEQ claimed that resumption of Plant operations at the previous levels would “not be in conformity with the Virginia SIP’s purpose of eliminating or reducing the severity and number of exceedances of the NAAQS.” VDEQ’s filing to FERC also claimed that resumption of Plant operations “at the previous levels, or any other level that would not be protective of human health or the environment, would clearly conflict with Mirant’s regulatory obligation to comply with the [VDEQ] Director’s request under 9 VAC 5-20-180(I), and therefore would not be in conformity with the SIP.”

The Federal general conformity regulations implementing Section 176(c)(1) of the CAA are codified at 40 CFR Part 51, Subpart W, and 40 CFR Part 93, Subpart B. Pursuant to 40 CFR 51.851, Virginia has an EPA approved general conformity rule that complies with the CAA. Therefore, Virginia’s general conformity rule applies here.

Under the general conformity rules, if the conformity rule applies to a Federal action, then the agency must determine whether the action “conforms” to a SIP. The conformity rule applies for each pollutant where the total of direct and indirect emissions in a nonattainment or maintenance area caused by the action would equal or exceed de minimis thresholds and where the action does not fit an exception (9 VAC 5-160-30). If the conformity rule applies, a Federal action is deemed to “conform” to a SIP if it is in compliance with all relevant requirements and milestones in the SIP and meets one of several requirements enumerated in the regulations, such as the emissions are specifically identified and accounted for in the SIP (40 CFR 93.158, 9 VAC 5-160-160).

The city of Alexandria and surrounding Arlington, Fairfax, Loudoun, and Prince William counties are in nonattainment for PM_{2.5} and 8-hour ozone (the precursors for ozone are NO_x and volatile hydrocarbons) (EPA 2006f). Because the general conformity regulations only apply to

²³ As stated in DOE’s Order (footnote 2), DOE considered all legal arguments made in FERC filings in its decision-making process.

Federal actions that exceed de minimis thresholds in designated “nonattainment” or “maintenance” areas, these are the only pollutants that are relevant here.

The Order conforms to the Virginia SIP. Because the Order does not cause or contribute to new emissions not already accounted for in the SIP or interfere with limits in the SIP, the Order conforms to the Virginia SIP. The Order does not allow the Plant to resume operations at levels it had been operating at under the Virginia SIP before the August 24, 2005, shutdown. Instead, the Order only allows the Plant to operate at pre-shutdown levels in limited transmission line outage circumstances, or when permitted by daily predictive modeling. In addition, for PM_{2.5} the Order cannot interfere with PM_{2.5} emissions not already accounted for in the SIP because Virginia does not currently have a SIP for PM_{2.5}.²⁴ Similarly, because the original study regarding the Plant’s NO_x emissions (prompting the shutdown of the Plant on August 24, 2005), related to downwash rather than to NO_x as a precursor to ozone, the Order would not appear to affect Virginia’s SIP for ozone (EPA 2006g).²⁵

Furthermore, the Order alleviates the concerns related to conformity to the SIP raised by VDEQ in its filing to FERC. To the extent that the SIP accounts for full operation of the Plant without the use of trona and low-sulfur coal, the Order actually decreases emissions already accounted for in the SIP. Therefore, the Order helps Virginia achieve its “purpose of eliminating or reducing the severity and number of exceedances of the NAAQS” (VDEQ 2005b). The Order also does not present a conflict between resumption of Plant operations under the Order and Mirant’s regulatory obligation to comply with the VDEQ Director’s August 19, 2005, request. Indeed, the VDEQ Director’s August 19, 2005, letter to Mirant suggested the “potential reduction of levels of operation” as a potential method of complying with the Director’s request under 9 VAC 5-20-180(I) to “immediately undertake such action as is necessary to ensure protection of human health and the environment” (Personal communication between R.G. Burnley, VDEQ, and L.D. Johnson, Mirant Potomac River, LLC., August 19, 2005). Moreover, the DOE Order does not impinge upon VDEQ’s ability to enforce concerns over pollutants emitted from the Plant. For example, during the period of the Order, VDEQ continued to work with EPA and Mirant on a long-standing settlement over NO_x that began in 2003 and resulted in an amended settlement on May 8, 2006 (EPA 2006g).

The function of the general conformity requirement is to ensure that Federal actions do not interfere with SIPs for meeting CAA standards and requirements. The integration of Federal actions and state air quality planning is intended to “protect the integrity of the SIP by helping ensure that SIP growth projections are not exceeded, emissions reduction progress targets are achieved, and air quality attainment and maintenance efforts are not undermined” (58 FR 63214,

²⁴ Although EPA has had a PM_{2.5} NAAQS since 1997 (revised on October 17, 2006), PM_{2.5} SIP’s are not due for states with designated nonattainment areas for PM_{2.5} until April 2008 (EPA 2006h, 2006i).

²⁵ Concerns over alleged violations of the 2003 Ozone Season NO_x emission limitations specified in Mirant’s Stationary Source Permit have been resolved through a judicial consent decree between EPA, VDEQ, the State of Maryland, and Mirant (EPA 2004, 2006g).

63215; Nov. 30, 1993). In this case the Order not only conforms to the Virginia SIP by definition, but also achieves the overarching purpose of the general conformity principle.

The Order is exempt under the General Conformity regulations. Even if the Order does not conform to the Virginia SIP, the emissions generated from the Order fall within the “emergency” exceptions enumerated in the Virginia conformity regulations (9 VAC 5-160-30). A conformity determination is not required for “actions in response to emergencies or natural disasters such as hurricanes, earthquakes, etc., which are commenced on the order of hours or days after the emergency or disaster . . .” (40 CFR 93.153(d)2). “Emergency” is further defined in the Federal conformity regulations as:

A situation where extremely quick action on the part of the Federal agencies involved is needed and where the timing of such Federal activities makes it impractical to meet the requirements of this subpart, such as natural disasters like hurricanes or earthquakes, civil disturbances such as terrorist acts and military mobilizations. (40 CFR 93.152)

An emergency clearly existed on December 20, 2005. In fact, the very nature of DOE’s ability to issue the Order in the first place comes from the Department’s *emergency* authority under Section 202(c) of the Federal Power Act. It took DOE three months to understand the reliability situation at hand and determine the potential environment, health, and safety risks associated with the Plant’s shutdown. However, as soon as a line outage occurred (December 16, 2005) and the very real threat of a blackout in the Central D.C. area became apparent, DOE took quick action by issuing its Order. Therefore, DOE’s action qualifies as an emergency exception to the general conformity regulations.

4.3.1.7 Global climate change

A major worldwide environmental issue is the likelihood of major changes in the global climate (e.g., global warming) as a consequence of increasing atmospheric concentrations of “greenhouse” gases (IPCC 2001). The atmosphere allows a large percentage of incoming solar radiation to pass through to the earth’s surface and be converted to heat energy (infrared radiation) that does not pass back through the atmosphere as easily as the solar radiation passes in. The result is that heat energy is “trapped” near the earth’s surface.

Greenhouse gases include water vapor, CO₂, methane, nitrous oxide, O₃, and several chlorofluorocarbons. The greenhouse gases constitute a small percentage of the earth’s atmosphere; however, their collective effect is to keep the temperature of the earth’s surface about 60°F (33°C) warmer, on average, than it would be if no atmosphere existed. Water vapor, a natural component of the atmosphere, is the most abundant greenhouse gas. The second-most abundant greenhouse gas is CO₂, which has increased about 30% in concentration over the last century. Fossil fuel burning is the primary contributor to increasing concentrations of CO₂ (IPCC 2001). The increasing CO₂ concentrations likely have contributed to a corresponding increase in

globally averaged temperature in the lower atmosphere, which has increased by about 1–1.4°F (0.5–0.8°C) in the last hundred years (IPCC 2001).

Because CO₂ is relatively stable in the atmosphere and essentially uniformly mixed throughout the troposphere and stratosphere, the climatic impact of CO₂ emissions does not depend upon their source location on the earth. Instead, an increase in CO₂ emissions from a specific source is effective in contributing to global increases in CO₂ concentrations.

Carbon dioxide emissions from the Plant involve two components: CO₂ produced by the combustion of the carbon contained in the coal and CO₂ produced by chemical reactions as the trona removes SO₂ from the exhaust gases. These two components of Plant emissions are shown in Table 4.3.1-3 and are discussed in detail in the following paragraphs. Coal combustion is discussed first.

During four days in December 2005, when the Plant was running in pre-Order mode, the Plant burned 2,150 tons (1,950 metric tons) of coal. This coal produced 5,300 tons (4,800 metric tons) of CO₂. Operation of the Plant for a full year at the pre-Order level operations would be expected to produce about 480,000 tons (440,000 metric tons) of CO₂.

For the 285-day term of the Order (December 20, 2005, through September 30, 2006), the total amount of coal used by the Plant is estimated to be 566,000 tons (513,000 metric tons). This quantity of coal, when burned, would produce approximately 1.38 million tons (1.25 million metric tons) of CO₂. On an annualized basis operation of the Plant under the Order would be expected to produce at an annual rate of 1.76 million tons (1.60 million metric tons) of CO₂ per year.

During the one-year period immediately preceding the shutdown of the Plant in August 2005, the Plant generated power at an average rate of 210 MW, using an estimated 832,000 tons (755,000 metric tons) of coal. The combustion of this amount of coal produced approximately 2 million tons (1.8 million metric tons) of CO₂. These data can be used to represent the anticipated operation of the Plant during the two-month temporary extension until December 1, 2006, and through the duration of any additional extension of the Order (i.e., October 1, 2006, through December 31, 2007).

For all three cases above, the use of trona is assumed to result in 50% removal of SO₂ from the Plant's stack gases. To achieve this removal rate, trona needs to be fed at a 2.5 times higher than the rate theoretically calculated to be sufficient to react with all of the SO₂ in the stack gases. With the addition of heat CO₂ is released from trona in a calcining reaction. This results in approximately 0.009 lb of CO₂ being released from trona for each pound of coal burned. The resulting quantities of the CO₂ released from trona, as shown in Table 4.3.1-3, are a very small fraction of the CO₂ released by coal combustion.

To put the above numbers into perspective, global fossil combustion in the year 2003 resulted in emissions of approximately 28 billion tons (26 billion metric tons) of CO₂ (Marland et al. 2006).

Table 4.3.1-3. Annualized carbon dioxide emissions (tons/year) from the Mirant Plant during operational periods under analysis in this report

	Coal combustion	Trona utilization	Total from Plant
Pre-shutdown operations	2,000,000	0	2,000,000
Pre-Order operations	480,000	1,800	488,800
The Order (Dec. 20, 2005 – Sep. 30, 2006)	1,760,000	6,500	1,766,500
Potential extension of the Order (Oct. 1, 2006 – Dec. 19, 2007) ^a	2,000,000	7,500	2,007,500

Note: “Annualized” values were obtained by prorating the emissions during the actual period over a hypothetical 365-day period.

^aIncludes the period of the temporary extension of the Order until December 1, 2006.

4.3.2 Human Health

This section discusses the human health impacts of emissions from the Plant during two principal time periods: (1) the period of operations under the Order and (2) the duration of a potential extension of the Order. As a comparison, the health effects of the pre-Order mode of operation as well as the pre-shutdown operation of the Plant are also presented. The analysis in this section uses mathematical factors that relate a person’s exposure to concentrations of airborne pollutants to premature mortality and other health effects.

Potential human health effects resulting from the Order are a serious concern to DOE. A wide range of human health effects are associated with ambient concentrations of particulate matter and SO₂ as well as other NAAQS primary and secondary pollutants. Numerous epidemiological studies have demonstrated that increases in pollution levels are associated with increases in illness rates, use of health services, and earlier death among exposed persons.²⁶

Particle pollution, especially fine particle pollution (i.e., PM_{2.5}), contains microscopic solids or liquid droplets that are so small that they can get deep into the lungs and cause serious health problems. Numerous scientific studies have linked particle pollution exposure to a variety of problems, including:

- increased respiratory symptoms, such as irritation of the airways, coughing, or difficulty breathing,
- decreased lung function,
- aggravated asthma,
- development of chronic bronchitis,
- irregular heartbeat,

²⁶ Some recent information about air pollution health effects may be found in the Criteria Documents prepared to support EPA periodic reviews of the NAAQS; <http://www.epa.gov/ttn/naaqs/>.

- nonfatal heart attacks, and
- premature death in people with heart or lung disease.

People with heart or lung diseases, children, and older adults are most likely to be affected by particle pollution exposure. However, even healthy people may experience temporary symptoms from exposure to elevated levels of particle pollution.

Peak levels of SO₂ in the air can cause temporary breathing difficulty for people with asthma who are active outdoors. Longer-term exposures to high levels of SO₂ gas and particles cause respiratory illness and aggravate existing heart disease. SO₂ reacts with other chemicals in the air to form tiny sulfate particles. When these are breathed, they gather in the lungs and are associated with increased respiratory symptoms and disease, difficulty in breathing, and premature death.

4.3.2.1 Analytical approach

For the purposes of this SEA, DOE has used two techniques to estimate premature mortality due to Plant operations and has used one technique to estimate the incidence of other health effects. DOE analyzed all-cause mortality as a useful indicator of health effects because background mortality rates are readily obtainable and the association between air pollution and premature mortality²⁷ has well-documented response functions. DOE used a concentration-response function for premature mortality from Pope et al. (2002) to estimate the expected fatalities and to estimate the risk of premature mortality to a hypothetical maximally exposed individual in the community near the Plant. DOE used an EPA scaling technique (EPA 2005) to estimate premature mortality and other health effects to a much broader population.

For the assessment of health effects to persons in the local area, DOE used estimated PM_{2.5} and modeled SO₂ concentrations for a 36-mi² (93-km²) receptor grid comprised of 1,747 receptor locations with the Plant near its center (Figure 4.3.1-1). This area contains approximately 240,581 people.²⁸

In order to provide estimates of the adverse effects of various operating scenarios in this SEA, DOE has chosen all-cause mortality as the most useful single indicator of adverse health effects. Mortality is the most severe outcome in personal terms and also represents 90% or more of the associated cost in economic terms.

²⁷ The studies on which this environmental analysis is based analyzed all-cause mortality for cohort studies, which capture both short-term and long-term effects. *All-cause mortality* means fatalities that occur for any reason. Scientists studying the effects of air pollution use all-cause mortality rather than fatalities that are clearly tied to air pollution because accurately determining the cause of death is often impossible in epidemiological studies.

²⁸ The population estimates are based on individual, rectangular cells with a dimension of 15 seconds of one degree on each side. The populations within all such cells within the grid are interpolated to the U.S. Census Bureau's 2005 estimates (Personal communication between P. Coleman, Oak Ridge National Laboratory, and A.L. Sjoeren, Oak Ridge National Laboratory, June 5, 2006).

DOE used the adult (age 30 and older) PM_{2.5} concentration-response function (relative rate: 1.06 per 10 µg/m³, 95% confidence interval: 1.02–1.11) from Pope et al. (2002).²⁹ The Pope et al. (2002) study finds one of the strongest associations between PM_{2.5} exposure and premature mortality. Because SO₂ represents a significant proportion of the Plant's pollutant output, and SO₂ is known to convert to sulfate particles in ambient air, it is considered here as an addition to the estimated PM_{2.5} concentrations.³⁰ DOE assumed that SO₂ converts to sulfate particles as an addition to the PM_{2.5} loading at the rate of 7% per 24-hour period (Azad and Kitada 1998).

All cause premature mortality is calculated by multiplying the modeled pollutant concentration by the age specific population, the age specific all-cause death rate, and the concentration-response function to obtain the expected number of deaths. Sixty percent of the population in Virginia is aged 30 or older (Virginia Department of Health 2004). For the receptor grid DOE studied this yields an estimate of 144,000 persons 30 or older. For this age group, the annual, all-cause death rate is 13 per 1,000 (Virginia Department of Health 2004).

To estimate several other health effects from particulate matter resulting from plant operations, DOE used a scaling technique developed by EPA based on extensive air quality modeling (EPA 2005). The method involves interpolation among cases that were modeled in detail by EPA. DOE used parameters provided by EPA to estimate health effects incidence based on total emissions of SO₂, NO_x, and PM_{2.5} from the Plant (Personal communication between B. Hubbell, EPA, and L.N. McCold, Oak Ridge National Laboratory, October 11, 2006). The potentially affected population on which these estimates are based is roughly the population of the eastern United States. While the risks to persons who live near the Plant are largest, the expected incidence includes the sum of very small risks to millions of people.

4.3.2.2 Results

DOE estimated the expected incidence of premature mortality among the 144,000 adult population (age 30 or older) in a 36-mi² (93-km²) area centered on the Plant (Figure 4.3.1-1). The results of the analysis of health effects to the adult population are described by the following bullets:

- As a result of exposure to the combined effects of SO₂ and PM₁₀, the expected incidence of premature mortality among the 144,000 adults (30 and older) in a 36-mi² (93-km²) area around the Plant from *pre-shutdown operations* is about 3.8 (confidence interval: 1.2 to 6.8) per year.

²⁹ EPA employs the Pope et al. PM_{2.5}-related mortality estimates as one component in cost/benefit analyses of various air pollution reduction strategies (EPA 2005). Information on EPA's studies and the methodology can be found in the Regulatory Impact Analysis for the Final Clean Air Interstate Rule (EPA-452/R-05-002, March 2005), which may be found at <http://www.epa.gov/air/interstateairquality/pdfs/finaltech08.pdf>.

³⁰ NO_x is also known to convert to PM_{2.5} in the atmosphere. DOE did not include NO_x in the analysis of nearby health effects because NO_x is a relatively smaller part of Plant pollution emissions and converts to PM_{2.5} less efficiently than SO₂.

- For *pre-Order operations*, the expected incidence of premature mortality among the exposed population of 144,000 adults (30 and older) would be 0.77 (confidence interval: 0.26 to 1.4) per year.
- For *operations under the Order* the expected incidence of premature mortality among the adult population of 144,000 is 1.3 (confidence interval: 0.44 to 2.4). The annual rate for operations under the Order is 1.7 (confidence interval: 0.58 to 3.1).
- For *potential extension of the Order* through June 2007 the expected incidence of premature mortality among the adult population of 144,000 would be 1.5 (confidence interval: 0.51 to 2.7). Extending it through December 2007 would raise the expected fatalities to 2.9 (confidence interval: 0.97 to 5.1). The annual rate for extension of the Order is 2.3 (confidence interval 0.78 to 4.1).

The reader should understand that the estimates of expected fatalities above do not indicate the risk faced by any particular individual. Pollutants do not affect all sectors of the population to the same extent. The very young, the elderly, and those with preexisting health conditions tend to experience adverse health effects at pollutant levels that have little or no effect on the remainder of the population. Activity levels also affect the nature of the health effects; the more active the person, the more likely that PM or SO₂ will induce health effects. For instance,

jogging while pollution levels are high is more likely to cause health effects in healthy people than would resting on a picnic bench or walking slowly. The reader should also bear in mind that among the modeled population of 144,000 adults, about 1,800 would die each year due to various causes.

Statistical Terminology

The results of the health effects analysis are expressed in statistical terms.

Some results are expressed as the **expected incidence** of a specified health effect occurring in the exposed population. For instance, if pepper were thrown into the faces of 1,000 people in 100 groups of 10 people and 340 of the people sneezed, for the next randomly selected group of 10 people, the expected incidence of sneezing would be 3.4 people. In each group of 10, the number of people sneezing would be a whole number. Sometimes it would be three people, sometimes it would be four, and it could as small as zero or as high as 10, but for this hypothetical example the long-term average would be 3.4. Expected incidence, in this case 3.4, is not a statement about what will occur, but a statement of what is likely to occur.

Other results are expressed as the **probability** that an individual who is exposed would experience the specified health effect. For the example above, the probability that any one random individual would sneeze would be 0.34 (=340/1000).

Another example shows how probability statements can be interpreted for groups and individuals. In 2003 approximately 25 per 100,000 (0.00025 or 0.025%) Americans 50 years of age or older, were diagnosed with stomach cancer. This can be reported as an expected incidence of 25 stomach cancers per 100,000 Americans age 50 or older. For an average American 50 or older, the probability per year of being diagnosed with stomach cancer is 0.00025.

Another useful indicator of the potential health effects of the Order is the risk to the “maximally exposed individual.” The maximally exposed individual is a hypothetical person who spends all his time outdoors at the receptor point that has the highest average modeled concentration. Nobody stays at the same place all the time, so the maximally exposed individual establishes the upper limit on the health risk that anyone could experience. However, the response factor used to generate these estimates is for the average adult (30 or older). Persons who are more susceptible to air pollutants would have a higher risk and healthy people would have a smaller risk.

- For *pre-shutdown operations* the hypothetical maximally exposed individual has a risk of premature mortality of 0.22% (confidence interval: 0.074 to 0.39%) for a year of operation.
- For *pre-Order operations* if they had continued for one year, the risk of premature fatality to the hypothetical maximally exposed individual would be 0.028% (confidence interval: 0.0094 to 0.050%)
- For *operations under the Order* the risk of premature mortality from SO₂ concentrations to the maximally exposed individual is 0.072% (confidence interval: 0.024 to 0.13%).
- For a *potential extension of the Order* through June 2007, the risk of premature mortality to a hypothetical maximally exposed individual would be 0.067% (confidence interval: 0.022% to 0.12%). If the Order were extended through December 2007, the hypothetical maximally exposed individual risk of premature mortality would be 0.13% (confidence interval: 0.045 to 0.24%).

Confidence Intervals

A confidence interval is one expression of the uncertainty associated with a statistical estimate. To be clearly defined, the confidence interval needs to specify the confidence level associated with the interval. The confidence intervals reported in this SEA are for a 95% confidence level. For example, if the estimate of the probability of a health effect is 0.30, it means that the best estimate of the probability is 0.30. If the associated 95% confidence interval is 0.17 to 0.48, it means that while the estimate is not certain, we are 95% confident that the true probability of the health effect is no lower than 0.17 and no higher than 0.48.

A confidence interval is helpful in informing us of how much confidence we can have in a statistical estimate. For example, if the confidence interval above were 0.29 to 0.31, we would know that we could be very confident in the estimate of 0.30. Conversely, if the confidence interval were 0.01 to 0.99, we would know to have much less confidence that 0.30 was close to the true value.

There are important uncertainties that are relevant to both the maximally exposed individual and population analyses. First, there are uncertainties associated with the response factors as indicated by the 95% confidence intervals. (See text box.)

Another uncertainty is the health status of the affected persons. If the persons exposed to the highest concentrations are more healthy than average, the risks are lower. Conversely, if the people exposed to the highest concentrations are relatively unhealthy, the estimated premature fatality probability may be an underestimate. Further, there is uncertainty associated with the location of affected persons, e.g., people who may not be at home all day or workers who may be

outside much of the day, so their actual exposures may be lower or higher than assumed for this analysis. To reduce these uncertainties would require very detailed information about the health status and daily movements of a large number of people. Such detailed information is not available.

Another important uncertainty has to do with the air dispersion modeling. As discussed in Section 4.3.1, many assumptions and approximations were used in the air dispersion analysis. Where there was uncertainty, DOE selected assumptions that avoid underestimating the impacts of Plant operations. The net result of all these assumptions is most likely to overestimate maximum pollutant concentrations. In addition, Mirant has stated that the standard building dimensions used in AERMOD lead to overestimating the modeled downwash effect, with the result that modeled concentrations at Marina Towers are unrealistically high. EPA authorized Mirant to initiate the MES to help resolve this concern. Initial monitoring results for SO₂ monitors near the Plant tend to support Mirant's statement, but EPA has yet to reach a conclusion.

If the estimate of the downwash effect is too high, it would mean that the maximum exposures to stack emissions are overestimated and the risk to the hypothetical maximally exposed individual may be too high. However, overestimate of the risk to the hypothetical maximally exposed individual may not appreciably affect the risk to the population. The population health effect is the sum of the individual risks for the modeled population of 144,000 adults. Relatively few people live in the top floors of Marina Towers. Even if modeling with improved input parameters showed that pollutant concentrations at Marina Towers are lower than current estimates, the concentrations at points that are farther away and the exposures for most of the population would be little affected. Thus, the population risk is not expected to be much affected by more accurate modeled building dimensions.

EPA Scaling Technique. The EPA scaling technique is a simple method of making estimates of a variety of health effects. The health effects reported in Table 4.3.2-1 are those examined by EPA in its recent regulatory impact assessments for emission standards. The estimates of population health effects are higher than those that would result from the method above because the potentially affected population is much larger. The EPA scaling technique does not provide estimates of uncertainty or confidence intervals. However, the estimates of premature mortalities are based on Pope et al. (2002) cited above. Consequently, at least for the premature mortalities, it is reasonable to estimate that a 95% confidence interval would span at least 70% below to 80% above the expected incidences reported in Table 4.3.2-1 based on Pope's reported confidence intervals.

4.3.3 Water Quality

Two types of water quality impacts could result from Plant operations as a result of the Order. Plant operations could cause direct impacts to Potomac River water quality by changing the volume or characteristics of the effluent discharged from the Plant. Indirect impacts to regional water quality could result from changes in the emissions of air pollutants that are

Table 4.3.2-1. Expected incidence of short- and long-term health effects resulting from Mirant Plant operations for the population of the eastern United States

Health effect	Pre-shutdown (one year)	Pre-Order (285 days)	Order (285 days)	Order extension Oct. '06 – Jun. '07	Order extension Oct. '06 – Dec. '07
Premature mortality (adults, 30 and over)	37	5	14	12	23
Infant mortality (infants less than one year)	0.08	0.01	0.03	0.03	0.05
Chronic bronchitis (adults, 26 and over)	20	3	7	6	13
Non-fatal myocardial infarctions (adults, 18 and older)	50	7	18	16	31
Hospital admissions – Respiratory (adults, 20 and older)	13	2	5	4	8
Hospital admissions – Cardiovascular (adults, 20 and older)	11	2	4	3	7
Emergency room visits for asthma (18 and younger)	30	4	11	9	19
Acute bronchitis (children, 8-12)	46	7	17	14	29
Asthma exacerbations (asthmatic children, 6-18)	698	101	258	218	440
Lower respiratory symptoms (children, 7-14)	553	80	205	173	349
Upper respiratory symptoms (asthmatic children, 9-11)	423	61	157	132	267
Work loss days (adults, 18-65)	3,942	568	1,459	1,234	2,488
Minor restricted activity days (adults, age 18-65)	23,490	3,387	8,693	7,350	14,823

Source: DOE analysis of SO₂, NO_x, and PM_{2.5} emissions from the Mirant Potomac River Generating Station, using EPA scaling technique (Personal communication between B. Hubbell, Health and Environmental Impacts Division, EPA, Research Triangle Park, North Carolina, and L.N. McCold, Oak Ridge National Laboratory, October 11, 2006).

subsequently deposited in surface waters or that are washed into surface waters after being deposited on the ground surface.

4.3.3.1 Direct impacts to the Potomac River

The operating changes associated with the pre-Order period or operations under the Order do not change the water quality characteristics of Plant intake water and effluents. Thus, the effect of the Plant on the pollutant load in the Potomac River (including suspended sediments, coliform bacteria, and metals) under different operating conditions can be assumed to be proportional to the volume of water used and discharged by the Plant. No chlorine was used in the Plant during pre-Order operations or under the Order; thus, Plant operations do not affect chlorine levels in the Potomac River.

Pre-shutdown operations. Under pre-shutdown operating conditions the Plant used Potomac River water and discharged effluents to the river as described in Section 2. The effects of many years of Plant operations are among the natural and human factors reflected in the existing water quality and ecological conditions in the river, as described in Sections 3.3.2.1 and

3.4.2.1. Table 2.4-1 presents data on the water quality of intake water and effluents associated with pre-shutdown operations.

Pre-Order operations. The Plant's water discharges to the Potomac River in December 2005 (assumed to be typical of pre-Order conditions) averaged 94 million gal/day (360,000 m³/day), approximately 27% (on average) of the average pre-shutdown discharge volume (Section 2.4.2). Assuming that withdrawals from the river during any period are about 1% higher than monitored discharges (Section 2.3), withdrawals during this pre-Order period are estimated at less than 95 million gal/day (360,000 m³/day). The reported maximum thermal discharge to the river in December 2005 was 969 Mbtu/hr. The much lower water and thermal discharge rates associated with pre-Order operations could contribute to improved river water quality relative to pre-shutdown operations, which could improve conditions for aquatic organisms (Section 4.3.4.2).

Operations under the Order and potential extensions of the Order. The Plant's water and thermal discharges to the river varied during the 285-day period of the Order. Operations during the line outage in January 2006 contributed to an average water discharge for the entire month of 266 million gal/day (1.0 million m³/day), nearly three times the discharge recorded in the pre-Order period. Reported maximum thermal discharge to the river was 3,355 MBtu/hr, more than three times the December maximum. Operations in the period February through May 2006, a period of relatively low power demand (Figure 4.2-1) during which there were no line outages, resulted in an average discharge of 170 million gal/day (640,000 m³/day), about 80% higher than pre-Order operations but only about half of the average for the pre-shutdown period. Maximum thermal discharges in this period ranged from 1,157 to 1,620 MBtu/hr. Average water discharge in June 2006 was 250 million gal/day (950,000 m³/day). This value is 165% higher than discharge under pre-Order conditions, but is still 27% less than the average discharge under pre-shutdown operations before August 2005. Maximum thermal discharge in June 2006 was 2,406 MBtu/hr, which also is intermediate between pre-shutdown and pre-Order levels. The somewhat lower water and thermal discharge rates resulting from operations under the Order through June 2006 could contribute to improved river water quality relative to pre-shutdown operations, which could improve conditions for aquatic organisms (Section 4.3.4.2).

For operations under the Order following the commencement of daily predictive modeling in July 2006 (including the temporary extension of the Order to December 1, 2006, and any extension beyond that date), water and thermal discharges are assumed to be similar to those during pre-shutdown operations. Impacts are estimated to be the same as for pre-shutdown operations.

4.3.3.2 Indirect impacts to regional water quality

DOE identified and assessed two potential sources of indirect impact to regional water quality from deposition of Plant air pollutants: (1) nitrogen loading and (2) acid deposition.

Nitrogen loading. Deposition of nitrogen compounds emitted from the Plant contributes to nitrogen input to Chesapeake Bay and other waters in the region, thus contributing to the nutrient loading that degrades water quality (Section 3.3.2) and can impact aquatic organisms (Section 4.3.4).

Targets for reducing atmospheric nitrogen inputs have been set for the Chesapeake Bay as a whole (Section 3.3.2.5), but not for component watersheds. Therefore, DOE's assessment of the potential impacts of Plant operations on nitrogen loading to area surface waters focuses on Chesapeake Bay. Because nitrogen inputs due to pre-shutdown operations of the Plant are implicitly included in current Bay nutrient budgets, the reduced levels of operations associated with pre-Order conditions and the Order contribute toward the Chesapeake Bay Program's 8-million-lb (3.6-million-kg) target for reduction in atmospheric inputs of nitrogen (Section 3.3.2.5). In all cases the estimated reductions in nitrogen loading are small when compared with the total nitrogen input to the Bay.

Assumptions. DOE estimates (Section 4.3.1.5) that the Plant emitted 2,800 tons (2,500 metric tons) of NO_x per year under pre-shutdown operating conditions. In estimating the impacts of nitrogen emissions from the Plant on Chesapeake Bay water quality, DOE assumes that NO_x has the same nitrogen content as an equivalent mass of NO₂; the pre-shutdown NO_x emission is the equivalent of about 1.7 million lb/yr (770,000 kg/yr) of nitrogen.

To estimate the impact of the Plant on Chesapeake Bay nitrogen loading, DOE assumed that 10% of the nitrogen released from the Plant reaches the Bay, primarily due to being deposited directly on water or on impervious urban surfaces, while all other nitrogen emitted from the Plant is either consumed in terrestrial or aquatic ecosystems or deposited outside the Bay watershed (e.g., on the open Atlantic Ocean). (See Section 3.3.2.5.)

The above assumption is believed to be realistic, based on the following reasoning. Assuming that electric power plants such as the Plant are responsible for 38% of the atmospheric contribution of nitrogen to the Bay (consistent with their contribution to regional NO_x emissions, as discussed in Section 3.3.2.5), the total estimated electric-utility contribution to the Bay is about 35 million lb/yr (16 million kg/yr). The 170,000 lb/yr (77,000 kg/yr) of nitrogen estimated to reach the Bay as a result of Plant air emissions (10% of the total nitrogen emissions) are approximately 0.5% of this total electric-utility contribution. This 0.5% value is consistent with power-plant NO_x emissions inventories reported by EPA (2006b), which indicate that during several months in early 2005 the Plant accounted for about 0.5% of electric utility NO_x emissions in the seven-state region (i.e., Maryland, Virginia, Pennsylvania, New York, West Virginia, New Jersey, and Ohio) estimated to produce most of the air emissions that contribute nitrogen to the Bay.

Pre-shutdown operations. Based on the above assumptions and the Plant's estimated NO_x emissions under pre-shutdown operating conditions, pre-shutdown Plant operations contributed about 170,000 lb (77,000 kg) of nitrogen to the Bay annually, or about 0.2% of the total annual nitrogen input to the Bay that is attributed to atmospheric sources (Section 3.3.2.5).

Pre-Order operations. Based on the estimate of NO_x emissions presented in Section 4.3.1.5, pre-Order operations are estimated to emit nitrogen at an annual rate of about 470,000

lb/yr (220,000 kg/yr). For the 285-day duration of the Order (through October 1, 2006) operations at pre-Order levels would emit about 370,000 lb (170,000 kg) of nitrogen.

Assuming that 10% of the nitrogen from the Plant reaches the Bay, pre-Order operations, if extended for a full year, would contribute about 47,000 lb (22,000 kg) of nitrogen to the Bay annually. Compared with pre-shutdown operations, pre-Order operations would avoid an estimated 123,000 lb (55,000 kg) of annual nitrogen delivery to the Bay, thus potentially achieving about 1.5% of the Chesapeake Bay Program's targeted 8-million-lb (3.6-million-kg) reduction in atmospheric nitrogen input.

Operations under the Order. Based on the estimate of NO_x emissions presented in Section 4.3.1.5, operations under the Order emit nitrogen at a rate of about 1.5 million lb/yr (670,000 kg/yr). For the 285-day duration of the Order (through October 1, 2006) operations under the Order emit 1.2 million lb (530,000 kg) of nitrogen, delivering nitrogen to the Bay at an estimated rate of 150,000 lb (67,000 kg) per year. If sustained for a full year this level of operations would avoid about 20,000 lb (10,000 kg) of pre-shutdown nitrogen delivery to the Bay annually and would achieve about 0.2% of the Chesapeake Bay Program's goal for annual atmospheric nitrogen reductions.

Potential extension of the Order. DOE's analysis assumes that Plant operations after October 1, 2006, including operations during the temporary extension of the Order through December 1, 2006, and any subsequent extension of the Order, would utilize coal and emit NO_x at approximately the same rate as pre-shutdown operations, so there would be no reduction from pre-shutdown nitrogen delivery to the Bay and no contribution toward meeting the Chesapeake Bay Program's nitrogen-reduction goals.

Acid deposition. The Plant's air emissions of SO₂ and NO_x (Section 4.3.1) contribute to regional acid deposition. However, under all operating conditions acid-deposition impacts to water quality of streams in nearby watersheds, including the Anacostia, Patuxent, and nearby portions of the Potomac watershed, would be negligible because these watersheds are well buffered against acid rain (Section 3.3.2.6).

Pre-Order operations. Air emissions of SO₂ and NO_x under pre-Order conditions were about 28% of pre-shutdown emissions of these pollutants, proportionately reducing the Plant's contribution to regional acid deposition, relative to pre-shutdown operations.

Operations under the Order. Compared to pre-Order operations, operations under the Order increase the Plant's contribution to regional emissions of these air pollutants that produce acid deposition, but the Plant's contribution is smaller than under pre-shutdown operations. Over the 285-day duration of the Order, the Plant produced about 87% of the NO_x emissions that would have occurred for the same duration of pre-shutdown operations, but roughly three times the emissions estimated for pre-Order operations. SO₂ emissions also increased relative to pre-Order operations, but the use of trona caused emission of less than 45% of the SO₂ that would have been emitted from pre-shutdown operations.

Potential extension of the Order. Operations under the Order after October 1, 2006, including during the temporary extension of the Order to December 1, 2006, and any extension

beyond that date, are conservatively estimated to emit NO_x at the same annual rate as pre-shutdown operations, but use of trona is assumed to reduce SO₂ emissions by 50% compared with pre-shutdown operations. Thus, the Plant's overall contribution to regional acid deposition is smaller than under pre-shutdown operations.

4.3.4 Ecological Resources

Operation of coal-fired power plants can impact ecological resources through air, water, or solid waste releases that can result in acid deposition, nutrient enrichment (see section 4.3.3.2), or changes in water quality or quantity of the receiving bodies (Dvorak et al. 1978, EPA 2006c).

4.3.4.1 Acid deposition

Acid deposition can affect plant and animal species, both directly and indirectly (Schreiber 1995, Roth et al. 2005, EPA 2006a), but Plant emissions (discussed in Sections 3.3.2.6 and 4.3.3.2) are expected to have minimal impacts as described below.

Aquatic impacts. The ecological effects of acid rain are most clearly seen in aquatic environments (e.g., streams, lakes, marshes) located in watersheds where the soils have a limited buffering capacity (EPA 2006a). (See Section 3.3.2.6.) In areas where buffering capacity is low, acid rain can release aluminum, which is highly toxic to many species of aquatic organisms, from soil into lakes and streams. In general, lowering the pH of a water body can impair the ability of certain fish and other aquatic organisms to grow, reproduce, and survive.

Soils in the river and stream basins in the region where air emissions from the Plant are most likely to fall (e.g., Potomac, Anacostia, and Patuxent rivers; Rock Creek) are generally well buffered (CBWP-MANTA 2001, Roth et al. 2005, Shanks 2005; also see Sections 3.3.2.6 and 4.3.3.2). Mobilization of aluminum is, thus, unlikely to occur, and acid deposition will not greatly change the pH level of the streams. Therefore, acid deposition resulting from the DOE Order, including the temporary extension of the Order to December 1, 2006, and any extension beyond that date, would have minimal impacts on biological resources in regional waterways.

Terrestrial impacts. Increases in soil acidity can impair the ability of some species of trees to grow and resist disease, while dry deposition of acidic gases and particles can directly impact some terrestrial vegetation.

The effects of over 50 years of Plant operations are among the natural and human factors reflected in the existing ecological conditions near the Plant, as described in Section 3.4.1. Vegetation still actively grows nearby on Daingerfield Island and in the small wooded area next to the Plant (Figure 2-2). While the Order results in higher emissions of the air pollutants responsible for acid deposition than occurred during the pre-Order period (Sections 4.3.1 and 4.3.3.2), combined total estimates of emissions of these pollutants under the Order and any

extension of the Order, including the temporary extension, are still lower than during pre-shutdown operations, when vegetation was growing well near the Plant. Thus, the Order is unlikely to have negative impacts from acid deposition on vegetation or the wildlife that depends on it.

4.3.4.2 Impact of water quality changes

Nutrients. One of the main causes of aquatic habitat loss in the Chesapeake Bay watershed as a whole (CBP undated) is elevated loading of two nutrients: nitrogen and phosphorus. (See Section 3.3.) To the extent that the DOE Order changes loading of these two nutrients to surface waters compared to the pre-Order or pre-shutdown operating periods, there could be effects on habitats in the river for fish and submerged aquatic vegetation (Section 3.4.2.6), but the Plant's impact on nutrient loading would be small relative to the total.

As discussed in Section 4.3.3.2, nitrogen compounds are emitted from the Plant and augment the nitrogen input to Chesapeake Bay and other waters in the region, thus, contributing to the nutrient loading that impacts aquatic organisms and their habitat. During the first six months of operations under the DOE Order, the Plant's contribution to the nitrogen in the Bay increased over the pre-Order value, but was still lower than under pre-shutdown operating conditions. Operations under daily predictive modeling are estimated to contribute a similar amount of nitrogen as pre-shutdown operations. In all cases changes in the Plant's contribution of atmospheric nitrogen to the Bay are small (as discussed in Section 4.3.3.2), when compared with the total nitrogen input to the Bay.

Reported phosphorus levels in Plant water effluent (Table 2.4-1) were lower than those in the intake water, suggesting that Plant water use may reduce the phosphorus load and, thus, benefit aquatic systems. If the Plant reduces phosphorus concentration in effluent by 0.016 mg/L (Table 2.4-1), effluent discharge at the pre-shutdown rate of almost 345 million gal/day (1.3 million m³/day) would remove about 48 kg/day of phosphorus. Reduced operating levels during pre-Order operations and the first six months of the DOE Order would have diminished the Plant's beneficial impact by removing proportionately less phosphorus than pre-shutdown operations or operations under daily predictive modeling. At any level of operations, however, any beneficial impact on phosphorus load resulting from Plant operations is small relative to the total daily input (from all sources) of phosphorus to the Potomac River, which has been estimated to be about 8,000 kg/day (Boynton and Swaney 1998), or the contribution of the nearby Blue Plains Wastewater Treatment Plant, which delivers 720 kg/day of phosphorus to the river when operating at its rated capacity of 370 million gal/day (1.4 million m³/day) and discharging effluent with the phosphorus concentration of 0.18 mg/L allowed by its NPDES permit (Table 3.3-1).

Other contaminants. As discussed in Section 4.3.3.1, changes under the Order in the amount of water used and discharged by the Plant could cause proportional, but small, changes

in concentrations of other pollutants removed from or returned to the Potomac River that are unlikely to result in impacts to organisms or their habitats in the Potomac River.

Trona use. Use of trona may change the landfill effluent discharged to Mataponi Creek by increasing pH and concentrations of sodium sulfate, sodium chloride, selenium, arsenic, and dissolved metals. (See Section 4.3.5.) Modest increases in pH that result from carbonate leaching could be beneficial to aquatic life in the creek due to buffering of acidity. Sulfate compounds are neither toxins nor nutrients; thus, increased concentrations of sodium sulfate would not be expected to impact the creek's aquatic life. Any increase in sodium chloride would likely be indistinguishable from background.

Release of arsenic and selenium could, however, have adverse impacts on aquatic biota and other wildlife that consume these organisms, depending upon the levels at which they occur in the effluent. As noted in Section 4.3.5, monitoring of collected landfill leachate and stormwater, as required under the existing discharge permit, should identify the potential for any problems from selenium before discharges occur. Arsenic levels are not, however, currently monitored prior to water discharge, so there is a potential for arsenic to be released to the creek at concentrations that could be harmful to aquatic life.

Selenium can enter the food web from both sediments and surface water (EPA 2006e). In the food web it undergoes bioconcentration, bioaccumulation, and biomagnification as organisms that first take it in are eaten by others. Elevated levels cause growth reduction in green algae. In other aquatic organisms a number of adverse effects have been observed including loss of equilibrium and other neurological disorders, liver damage, reproductive failure, reduced growth, reduced movement rate, chromosomal aberrations, reduced hemoglobin and increased white blood cell count, and necrosis of the ovaries.

Arsenic can cause cancer and genetic mutations in aquatic organisms, with those effects including behavioral impairments, growth reduction, appetite loss, and metabolic failure (EPA 2006e). Aquatic bottom feeders are more susceptible to arsenic than other organisms.

4.3.4.3 Impacts of changes in water use

Once-through cooling water systems such as used by the Plant can impact aquatic species by impingement (when aquatic organisms become trapped on the intake screens), entrainment (when aquatic organisms are taken in and pass through the cooling water intake system), or thermal changes (Jensen 1981). Impingement and entrainment are often roughly proportional to the volume of water withdrawn, as well as the numbers and species of aquatic organisms in the water body. At the Plant the numbers and species of fish, crabs, and other aquatic organisms that are susceptible to impingement or entrainment at any one time depends on the season of the year, annual fluctuations in relative abundance, and the impact of restoration activities in the Chesapeake Bay watershed. Overall, the effect on species or their habitats of water use and changes in water use by the Plant in different operation modes is expected to be small. The

Plant's thermal discharge is permitted and has been shown to not form a barrier to movement or cause lethality of aquatic organisms.

Impingement. Mirant studied impingement at the Plant during 1981-1982 and 2003-2004 (Pepco 1982; Personal communications between A. Wearmouth, Mirant Corporation, and M.S. Salk, Oak Ridge National Laboratory, July 24, and August 18, 2006). Rates of cooling water withdrawal at the Plant were similar for both study periods (i.e., pre-shutdown conditions). For 1981-1982 the estimated impingement was 206,379 finfish³¹ and 56,600 blue crabs; for 2003-2004 the annual estimates were 19,392 finfish and no blue crabs. In the 1981-1982 study over 90% of the fish were impinged in the winter and spring. The main fish species impinged in both studies were species that were either not used commercially (e.g., gizzard shad) or were too small to be of commercial value (e.g., white perch). Some fish exhibited disease conditions or appeared stunted, indicating that they were in poor health.

Although the 2003-2004 study is likely more representative of the fish community that is currently susceptible to impingement by the Plant, the large differences in the results of the two studies illustrate the potential magnitude of annual variation in potential impacts, so results of both studies were used as a basis for assessing impacts of the Order.

Impingement is assumed to be proportional to water intake for the Plant. At pre-Order operating levels the Plant withdraws about 27% of the amount of water it used during the pre-shutdown period. (See Section 4.3.3.1.) Thus, impingement under pre-Order conditions is estimated to amount to about 5,200–55,000 fish per year, based on the levels observed during the two studies at the Plant.

Under the Order before the commencement of daily predictive modeling (i.e., between January and June 2006), monthly Plant water use ranged from 42 to 77% of monthly use in the pre-shutdown period, averaging about twice the use during the pre-Order period. Assuming that 90% of annual impingement occurs during the winter and spring months of January through June, impingement during this time period is estimated at approximately 9,400–99,000 fish. At the high end of the range the number of fish impinged under the Order on an annual basis is equivalent to about 3% of the estimated 4.9 million fish in the Potomac-Washington Metro Basin (Maryland DNR undated-b).

Following the commencement of daily predictive modeling in July 2006, the Plant is assumed to withdraw water at pre-shutdown levels, resulting in annual impingement rates within the range indicated by the two studies (i.e., about 19,000–206,000 fish per year). However, because the 1981-1982 study indicated that less than 10% of annual impingement occurs during the summer months, operations under the Order during the period July through September 2006 are estimated to have impinged fewer than 1,900–21,000 fish. The temporary extension of the Order to December 1, 2006, and any extension beyond that date would result in cooling water

³¹ The number of fish impinged is for the 56-week duration of the study. Thus, the annual rates would be slightly less.

withdrawal rates and annual impingement rates similar to pre-shutdown conditions (i.e., about 19,000–206,000 fish per year).

Not all impinged fish are killed; new intake screens, particularly the one with the fish buckets (Section 2.2), should lower impingement mortality. Fish or other organisms impinged on the water intake screens are washed off the screens and returned to the river on the south side of the cove area next to the Plant, south of the water intake area. (See Figure 2.1-1.)

Little impact is expected to the blue crab population as studies have indicated that initial and latent mortality from impingement is less than 10% (Pepco 1982). Also, blue crabs are found near the Plant only in years when the river is particularly salty (Personal communication between A. Wearmouth, Mirant Corporation, and M.S. Salk, Oak Ridge National Laboratory, August 17, 2006). A difference in the salt level in the river between the two impingement studies is the likely explanation for the difference in the observed number of impinged crabs.

Entrainment. Mirant studied entrainment of fish eggs and larvae at the Plant in 1981 and 2005. Preliminary results from the 2005 study are similar to those from the 1981 study reported below (Pepco 1983; Personal communication between A. Wearmouth, Mirant Corporation, and M.S. Salk, Oak Ridge National Laboratory, August 25, 2006).

Only organisms small enough to pass through the screens on the water intakes are drawn into the Plant where they are subjected to heat, fluid, and mechanical stresses (Cada et al. 1981). Entrainment of fish eggs and larvae is mainly an issue in the period during and soon after fish spawning, from early spring through mid-summer.

During the 1981 study, eggs and larvae of anadromous species (i.e., white perch and herring) were 99% of the total number entrained. Freshwater species (e.g., minnows [fish in the Cyprinidae family], tessellated darter [*Etheostoma olmstedi*]) were entrained in very low numbers, less than 1% of the total.

The major spawning area for both white perch and herring is about 9 miles (14 km) above the Plant at Little Falls. As they mature, the larvae float downriver, past the Plant, mostly in a dredged channel well offshore. The Plant draws cooling water primarily from shallow water near shore, which results in relatively low entrainment rates. Significant spawning of white perch and herrings also occurs in other portions of the Potomac River and its tributaries. Thus, while some fish spawn in the Washington, D.C. portion of the Potomac River, spawning there represents a small portion of the spawning of the Potomac River population. The best estimate of the percent entrainment varied from 1.6% for white perch yolk-sac larvae (an early larval stage) to 8.7% for herring larvae after yolk absorption (Pepco 1983).

Pre-Order operations. There would have been no entrainment of fish eggs and larvae during pre-Order conditions in December 2005 because of the absence of these organisms from the Potomac River at that time. On an annual basis, assuming that entrainment is proportional to water intake, pre-Order conditions would result in entrainment at about 27% of pre-shutdown rates.

Operations under the Order. Under the Order before the commencement of daily predictive modeling (i.e., during January through June 2006) entrainment is estimated to have

occurred at approximately twice the calculated pre-Order rates, but substantially less than pre-shutdown levels (about 55% of pre-shutdown rates). Following commencement of daily predictive modeling in July 2006, entrainment is estimated to have been similar to pre-shutdown conditions for the summer season (owing to similar cooling water withdrawal rates). The temporary extension of the Order to December 1, 2006, and any extension beyond that date would be expected to result in entrainment rates similar to those that occurred during the pre-shutdown time period.

Since entrainment was not a major issue when the Plant was operating at the pre-shutdown level before August 2005, entrainment resulting from operations under the Order or any extension of the Order would not have a major impact on fish populations.

Temperature changes. The Plant's NPDES permit (Section 2.4.2) limits temperature rise in the Potomac River from water discharge to 2.8°C above ambient temperature beyond a 1,000-ft (300-m) radius in order to prevent formation of a barrier to movement of aquatic life or lethality to passing organisms. Based on a 2001 study (Mirant 2002), the thermal plume from the Plant does not form a barrier to movements of aquatic life or cause lethality to passing organisms. The main path for movement of aquatic organisms is the river channel, which is unaffected by the warm water plume from the Plant (Mirant 2002). Thus, no blockage to aquatic life movement is expected from the thermal plume under any assessed operating conditions.

If pre-Order operating conditions continued throughout the year, slightly lower summer water temperatures would result. This could slightly reduce the potential for nuisance algal blooms (Section 3.4.2). Similar, but smaller, benefits could be expected in 2006 because Plant operations under the Order before the commencement of daily predictive modeling resulted in thermal input levels intermediate between pre-Order and pre-shutdown operations (Section 4.3.3.1). Following commencement of daily predictive modeling in July 2006 and throughout any extensions of the Order, however, thermal input to the river is assumed to be similar to pre-shutdown conditions.

If there were a sudden shutdown of the Plant during the winter under any operating conditions, fish that were acclimated to the warm discharge might suffer cold shock when they lose the warm water habitat.

4.3.4.4 Special status species

The NPDES permit stated that the Fish and Wildlife Service (FWS) and the National Marine Fisheries Service (NMFS), the agencies responsible for implementing the Federal Endangered Species Act (ESA), had indicated that the Plant's wastewater discharges were not adversely affecting the three Federally listed species mentioned in the permit. (See Section 3.4.2.)

During consultation with Mirant before the start of sampling for an entrainment study, FWS concluded that taking of eggs of the shortnose sturgeon, an endangered species, in the sampling process was not an issue as there was no possibility of finding them (Personal

communication between A. Wearmouth, Mirant Corporation, and E.D. Smith, Oak Ridge National Laboratory, July 14, 2006).

While bald eagles are occasionally seen near the Plant, the site provides no suitable nesting habitat for them (Personal communications between A. Wearmouth and D. Knight, Mirant Corporation, and M.S. Salk, Oak Ridge National Laboratory, July 24, and 25, 2006, respectively).

The Plant site does not provide any suitable habitat for any of the other special status species (i.e., the Hay's Spring amphipod, the Federal species of concern, and the Virginia state-listed species) discussed in Section 3.4.2. There have been no reported adverse impacts to any of these species due to the Plant while operating at the pre-shutdown level before August 24, 2005. Since Plant operating levels under the DOE Order are no higher than they were under pre-shutdown conditions, adverse impacts to any of the special status species would not be expected.

In order to comply with Section 7 of the ESA, DOE sent letters to FWS and NMFS as part of informal consultation. (See Chapter 6 and Appendix D.) The NMFS by letter dated October 3, 2006, concurred with DOE's determination that continued operation of the Plant under the Orders is not likely to adversely affect any listed species. The FWS by letter dated November 20, 2006, stated that only occasional transient individuals of Federally listed endangered or threatened species are known to exist within the project impact area. Both agencies concluded that no further consultation under Section 7 of the ESA is required.

4.3.5 Waste Management

Potential waste management impacts from the Order include (1) impacts to landfill capacity resulting from changes in the quantity of waste generated and (2) changes in environmental impacts of waste management resulting from changes in solid waste characteristics. Impacts related to solid waste transportation are discussed in Section 4.3.6.

4.3.5.1 Impacts on landfill capacity

Assumptions. In estimating the impacts of operations under the Order on remaining waste capacity in the Mirant Brandywine ash landfill used for disposal of fly ash from the Plant (Section 3.5), DOE made the following assumptions, derived from GB&B Inc. (2005):

- remaining disposal capacity at the beginning of 2005 was 2.07 million yd³ (1.58 million m³);
- ash placed in the landfill has an in-place density of 1.1 ton per yd³ (760 kg per m³); and
- throughout the period of analysis the Chalk Point Generating Plant would generate 206,000 tons (187,000 metric tons) of ash per year, of which 15% would be recycled and 85% would be placed in the Brandywine landfill.

Data and assumptions for pre-shutdown operations. Mirant's records indicate that the Plant sent 113,865 tons (103,297 metric tons) of ash to the landfill during the period January

through August 2005, prior to the events and actions addressed in this SEA (Personal communication between D. Cramer, Mirant Corporation, and L.N. McCold, Oak Ridge National Laboratory, July 7, 2006). This corresponds to an annual ash generation rate of 170,000 tons (150,000 metric tons) per year, which is somewhat higher than the rate (136,000 tons [124,000 metric tons] per year) used in the GB&B Inc. (2005) analysis.

Assumptions for pre-Order operations. Making the conservative assumption that, on average, pre-Order operations of the Plant during the last three months of 2005 generated fly ash at 20% of the rate recorded for the first eight months of the year, DOE estimated that under pre-Order operating conditions the plant would generate fly ash at a rate of 34,000 tons (31,000 metric tons) per year. (To simplify the assessment of waste management impacts, DOE assumed that under pre-Order operating conditions trona use did not affect the rate of ash generation. This assumption is conservative, in that it minimizes the estimated impacts of pre-Order operations, thus increasing the contrast between the impacts of pre-Order operations and operations under the Order.)

Data and assumptions for operations under the Order. Mirant's records indicate that the Plant sent 28,399 tons (25,763 metric tons) of ash to the Brandywine landfill during the 3-month period March through May 2006 (Personal communication between D. Cramer, Mirant Corporation, and L.N. McCold, Oak Ridge National Laboratory, July 7, 2006). In estimating the impacts of operations under the Order on landfill capacity, DOE assumed that fly ash was generated at the same average rate from February 2006 until the beginning of June, when the Plant began operating under the ACO. From that time forward the analysis conservatively assumes that under the Order the Plant operates, on average, at pre-shutdown levels, including the temporary extension of the Order to December 1, 2006, and any extension beyond that date.

Impacts. Using the data and assumptions summarized above, DOE estimated total Brandywine landfill waste disposal (from both power plants) during 2005 (prior to the Order) at 269,000 yd³ (206,000 m³), which is somewhat less than the historical annual disposal rate of 278,000 yd³ (213,000 m³) used in the GB&B Inc. (2005) analysis. This value then became the starting point for analysis of the effect of several different Plant operating modes on the remaining capacity and operating life of the landfill, summarized in Table 4.3.5-1.

Pre-shutdown operations. The 2005 analysis by GB&B Inc. projected that with continued operations at then-current (i.e., pre-shutdown) operating levels, the Brandywine ash landfill would be able to continue receiving ash from the Plant and Mirant's Chalk Point Generating Plant until the middle of 2012.

Pre-Order operations. Table 4.3.5-1 indicates that under pre-Order operating conditions, beginning with the date of the Order and continuing indefinitely, the landfill would be able to receive waste from both power plants for approximately the next 9 years, through the middle of 2015.

Operations under the Order and any extension. To indicate the potential range of impacts from operations under the Order and any extension (including the temporary extension through December 1, 2006), Table 4.3.5-1 presents estimates of disposed waste volume and remaining

Table 4.3.5-1. Impact of Plant operations on remaining operating life of the Brandywine ash landfill

Plant operating mode ^a	Disposal rate for Plant fly ash (yd ³ /year) ^b	Estimated full-capacity date for landfill
Pre-shutdown operations ^c	119,000	mid-2012
Plant operates at pre-Order level ^d	31,000	mid-2015
Plant operates in accordance with the Order, without trona injection ^e	varies ^e	late 2011
Plant operates in accordance with the Order (as above), with trona injection ^f	310,000 ^f	early 2010

^a Mirant's Chalk Point Generating Plant is assumed to operate under all scenarios, generating 159,000 yd³ of in-place waste annually. If Chalk Point Generating Plant operated and the Mirant Potomac Plant did not, the estimated full-capacity date for the landfill would be the end of 2017 (GB&B 2005).

^b To obtain the approximate equivalent numerical value in tons/year, multiply by 1.1.

^c These values are from GB&B Inc. (2005).

^d Pre-Order level of operations is conservatively estimated to be equivalent to approximately 20% of pre-shutdown operations.

^e Due to line outage conditions in January 2006, operations in accordance with the Order during that month are assumed to have resulted in waste disposal at the pre-shutdown rate. Operations during February through May are assumed to have resulted in waste disposal at the annual rate of 103,000 yd³/year recorded during March through May (Personal communication between D. Cramer, Mirant Corporation, and L.N. McCold, Oak Ridge National Laboratory, July 7, 2006). Beginning in June 2006, the Plant is assumed to operate at the pre-August 2005 level, without trona injection, resulting in waste disposal at annual rate of 155,000 yd³/year.

^f Beginning in June 2006, trona injection is assumed to double the quantity of waste requiring disposal.

landfill life for two different assumptions: (1) the Plant operates at pre-shutdown levels, but with no use of trona, after the beginning of June 2006 (since trona is used in operations under the Order, this assumption results in a lower-bound estimate of potential impacts from the Order) and (2) the Plant operates at pre-shutdown levels beginning in June 2006 and trona is injected at a rate which doubles the pre-shutdown rate of solids generation. Trona injection in the Plant can substantially increase ash production; at injection rates necessary to achieve maximum SO₂ removal, trona injection could double or triple the quantity of fly ash waste generated by the Plant (Mirant 2006c). Because trona injection is done only part of the time that the Plant operates and Mirant records of fly ash generation during the period March through May 2006 (Personal communication between D. Cramer, Mirant Corporation, and L.N. McCold, Oak Ridge National Laboratory, July 7, 2006) indicate that trona use during that period increased fly ash production by approximately 50% over the quantity expected based on coal utilization during the same period, the assumption that trona use doubles the rate of fly ash generation is expected to provide an upper bound on the potential impacts of trona use on landfill capacity. DOE's estimates of the potential impact of the Order on landfill operating life (Table 4.3.5-1) assume that operations

continue indefinitely at pre-shutdown levels, instead of ending when the Order or any extension to the Order expires.

The table indicates that with the level of Plant operations estimated under the Order, but without trona use after June 2006, the landfill's operating life would be about one-half year shorter than projected by GB&B (2005) for pre-shutdown conditions, but about 3.5 years shorter than under pre-Order operations. (Note that this analysis assumes that the ash-generation rate reported in the first 8 months of 2005 would continue, rather than the lower rate assumed by GB&B.) Use of trona would cut almost two additional years off the Brandywine landfill's life expectancy, causing it to reach capacity in a little more than three years.

The assumptions of this analysis are conservative, but the limited landfill life that is estimated to remain if trona injection continues at a high rate may not provide sufficient lead time for siting a new ash landfill. If the Brandywine landfill were to reach capacity before a new ash landfill were sited, Mirant could ship fly ash to a commercial sanitary landfill until a new landfill became available.

Because commercial landfill capacity in the region is very limited (Metropolitan Washington Council of Governments 2001, VDEQ 2002, Harrison 2004, MDOE 2005), ash might need to be transported long distances if it is required to be sent to a commercial landfill licensed for municipal solid waste. Several large privately owned Virginia landfills receive municipal solid waste from outside the local area (Metropolitan Washington Council of Governments 2001). The nearest of these landfills is in King George County, about 60 miles (100 km) by road from the Plant; others are in the Richmond area, more than 100 miles (160 km) from the Plant. If the state regulatory agency allows coal combustion ash disposal in landfills permitted for disposal of construction and demolition debris (in Maryland, these are called "rubble landfills" or "rubblefills"), there are private landfills closer to the Plant (in Lorton, Virginia, and in Prince George's and Baltimore counties in Maryland) that possibly could be used. It has been estimated that the Lorton landfill will reach capacity before 2011 (Harrison 2004), but the state of Maryland has received applications to site several additional commercial rubble landfills (MDOE 2005), giving some assurance that the region will continue to have disposal capacity for construction and demolition waste.

4.3.5.2 Effects of trona use on the environmental consequences of waste management

In addition to increasing the volume of solid waste requiring management, operation of the Plant with trona injection alters the chemistry and physical properties of the fly ash waste, potentially changing the environmental consequences of its management. (Quantities and characteristics of the Plant's bottom ash are not affected by the use of trona.)

Chemical characteristics of Plant fly ash. Reaction of trona (sodium sesquicarbonate; $\text{Na}_2\text{CO}_3 \cdot \text{NaHCO}_3 \cdot 2\text{H}_2\text{O}$) with SO_2 in the exhaust gas results in the formation of solid sodium sulfate compounds (assumed to be Na_2SO_4), along with the release of gaseous CO_2 . The resulting

sodium sulfate is incorporated into the fly ash captured in the Plant's precipitators, together with mineral ash derived from coal combustion and unreacted trona (which is assumed to be dehydrated in the exhaust gas stream, forming sodium carbonate). Because the trona feed rate is typically several times larger than the feed rate calculated to be necessary to react chemically with SO_2 in the air emissions, the fly ash captured in the precipitators contains several times more sodium carbonate than trona reaction products. Although trona use enhances particulate capture in precipitators (Mirant 2006c), thus adding to the volume of fly ash, the increase in Plant fly ash volume that results from trona injection is due almost entirely to incorporation of trona residue into the fly ash. The trona-ash waste stream also can be assumed to include minor amounts of (1) any trace elements found in the raw trona and (2) compounds formed when other gases in Plant emissions react with trona.

Table 4.3.5-2 presents results of chemical analyses of four samples of ash produced in October and November 2005, including two samples produced during Plant operations without trona injection and two samples produced during trona injection. Comparison of the two pairs of analyses illustrates that trona use converts the Plant's fly ash from a largely insoluble mineral ash (oxide percentages of silica and alumina total 84-86% in the pair of samples produced during operations without trona injection) into a mixture of mineral ash and water-soluble carbonates and salts (the high values for sodium and alkalinity in the second pair of samples in Table 4.3.5-2 identify the sodium carbonate component of the ashes produced during trona injection). Trona use increases ash pH (which already is high, indicating an alkaline material) but also greatly increases alkalinity, which is a quantitative measure of the amount of material available to react with acid. Sulfate, which is a very minor component of ash produced without trona injection (first pair of analyses), is a significant fraction of the ash produced with trona (second pair of analyses). With trona use measurements of loss on ignition (a test used to indicate the level of unburned carbon in a sample) increased from 5% and 12% to values of 20% and higher. Trona addition should not affect the amount of unburned carbon in fly ash, so the increased measured values of loss on ignition probably are attributable to volatilization of trona-related constituents. Chloride was not measured, but it is likely that some sodium chloride is included in the ash due to chemical reaction of trona with the small amounts of chlorine present in Plant emissions.

Selenium concentrations are increased approximately 10-fold in the ash produced when trona is used (second pair of selenium in Table 4.3.5-2) compared with ash produced by Plant operations without trona use (first pair of selenium results in Table 4.3.5-2). The source of the increased selenium in the trona ash has not been determined, but it is likely that selenium (a trace constituent in coal that can volatilize during coal combustion) in Plant exhaust gas reacts with sodium carbonate or trona and is incorporated into the fly ash as solid sodium selenate, Na_2SeO_3 . This chemical reaction is used industrially when sodium carbonate (often referred to as "soda ash") is used in the commercial production of selenium metal to isolate selenium from various other compounds and convert it to the sodium selenate form (WebElements 2006). Although selenium might also be present as an impurity in the natural trona used in the Plant, it is not mentioned in published reports about this material (Dyni 1991, 1996).

Table 4.3.5-2. Concentrations of major constituents and trace elements in samples of Plant fly ash resulting from operations with and without trona injection.

Parameter (units)	Ashes produced without trona injection		Ashes produced during high-rate trona injection	
	Load following	Baseline	Low load	Full load
Silica (%)	56.4	59.3	33.2	38.6
Alumina (%)	27.4	26.6	15.4	17.5
Titania (%)	1.4	1.3	0.7	0.9
Iron (as % FeO)	5.6	5.3	3.1	3.4
Calcium (as % CaO)	1.4	1.3	0.8	1.1
Magnesium (as % MgO)	1.4	1.3	0.8	1.1
Potassium (as % KO)	3	2.5	1.3	1.7
Sodium (as % Na ₂ O)	0.34	0.32	39.2	28.3
Sulfate (as % SO ₃)	0.22	0.17	3.4	5.7
pH (pH units)	10.2	10.2	11.1	11.0
Alkalinity (% CaCO ₃ equivalent)	0.55	0.55	39.21	32.4
Lead (mg/kg)	15	15	8.7	10
Arsenic (mg/kg)	47	39	31	26
Barium (mg/kg)	680	660	310	360
Cadmium (mg/kg)	0.29	0.39	0.2	0.28
Chromium (mg/kg)	13	19	7.7	13
Selenium (mg/kg)	1.1	ND ^a	15	11

^a ND = Not detectable

Source: Mirant (Personal communication between A. Wearmouth, Mirant Corporation, and E.D. Smith, Oak Ridge National Laboratory, July 21, 2006)

Measured concentrations of lead, arsenic, barium, and chromium are lower in ash produced during trona operations, probably indicating a dilution effect from the addition of trona components to the mineral ash. Cadmium concentrations are similar in both types of ash. Mercury and silver concentrations are not presented in Table 4.3.5-2 because these metals were below detection limits in all samples.

The ash samples were tested for leachability using the Toxicity Characteristic Leaching Procedure (TCLP) (Personal communication between A. Wearmouth, Mirant Corporation, and E.D. Smith, Oak Ridge National Laboratory, July 21, 2006). The TCLP simulates leaching in the acidic environment of a municipal solid waste landfill and is one of the tests specified under the Resource Conservation and Recovery Act (RCRA) for determining whether a solid waste is a hazardous waste. TCLP extracts were analyzed for lead, silver, arsenic, barium, cadmium,

chromium, selenium, and mercury. These test results do not affect the regulatory status of Plant ash because ash from the combustion of coal, including flue gas emission control waste (such as the trona component of Plant fly ash), is exempt from RCRA regulation as a hazardous waste (40 CFR 261.4).

Barium was the only metal detected in TCLP leachates from the two ash samples produced without trona injection, with concentrations of 0.28 and 0.43 mg/L. Leachates from the two ash samples obtained during trona use had somewhat higher concentrations of barium (0.63 and 0.93 mg/L), but all barium concentrations were below the primary drinking water standard of 1 mg/L, as well as the 100 mg/L threshold for identifying a waste material as a RCRA hazardous waste.

TCLP leachates from both of the ash samples produced during trona injection also contained detectable levels of arsenic and selenium. The measured arsenic concentrations of 1.4 and 1.1 mg/L exceed the primary drinking water standard of 0.05 mg/L, but not the 5 mg/L threshold for identifying a waste material as a hazardous waste. Measured selenium concentrations of 1.1 and 0.77 mg/L also exceed the primary drinking water standard, which is 0.01 mg/L, and the higher measurement exceeds the 1 mg/L threshold for identifying a waste material as a hazardous waste. (As discussed above, however, Plant ash is exempt from RCRA regulation as a hazardous waste.) Sodium selenate (the form in which selenium is likely to be present) is soluble in water, and the presence of sulfate is likely to increase the solubility of both arsenic and selenium.

Implications for waste management operations. Although ash produced during trona injection has reduced pozzolanic activity (Section 2.4.3), it still has significant pozzolanic properties that facilitate its management. Mirant personnel report that trona use does not adversely affect ash workability or its physical stability after placement in the Brandywine ash landfill (Personal communication between D. Cramer, Mirant Corporation, and E.D. Smith, Oak Ridge National Laboratory, July 12, 2006). Thus, there should be no adverse consequences for the emission of windblown dust or for successful stabilization and closure of completed portions of the landfill. Ash produced during trona injection has, however, been observed to be more corrosive than other ash wastes handled at the Brandywine ash landfill (presumably due to the sulfate component), increasing the need for equipment maintenance and possibly accelerating the need for equipment replacement (Personal communication between A. Wearmouth and D. Cramer, Mirant Corporation, and E.D. Smith, Oak Ridge National Laboratory, July 14, 2006).

Fly ash generated during trona use has pozzolanic activity that is too low for most structural uses (TFHRC undated) and contains substantial amounts of sulfate and other soluble constituents that would reduce its suitability for construction use. Therefore, it is unlikely that any Plant fly ash generated during trona use can be beneficially used as a construction material. However, Mirant might be able to find other beneficial uses for this material. For example, due to its high alkalinity, the ash generated during trona production might be a suitable fill material in settings where alkaline material is needed to neutralize acids, such as in waste-site restoration or coal mine reclamation.

Implications for impacts of the Brandywine ash landfill. Leaching of the fly ash produced during trona injection would increase the release of dissolved solids into the landfill leachate that eventually is discharged to Mataponi Creek.

Sodium sulfate, sodium carbonate, and sodium chloride, which are major chemical constituents of the ash produced during trona injection (see discussion above), are all soluble and could be readily released into the leachate. Leachate pH is likely to be higher due to the presence of large amounts of carbonate.

The TCLP test results indicate a potential for the waste produced during trona injection to release the trace constituents selenium and arsenic. The presence of soluble sulfate and carbonate in leachate might increase the solubility and mobility of these or other trace constituents in the fly ash. Because the TCLP test protocol uses acidic leaching conditions, the TCLP test results may not be good predictors of the potential for selenium and arsenic to leach in the alkaline conditions found in the fly ash landfill. Leach testing using “synthetic precipitation” or “synthetic groundwater” would be more reliable than the TCLP for predicting contaminant mobility in the environment of a fly ash landfill.

Modest increases in effluent pH could be beneficial due to buffering of acidity, but there is a possibility of generating a leachate with a pH higher than permitted for discharge. Release of arsenic and selenium to Mataponi Creek could result in adverse impacts to aquatic biota and other wildlife that consume these organisms (Section 4.3.4).

Increases in release of other dissolved solids are not expected to adversely affect creek water quality. Increased concentrations of sodium sulfate would not be expected to affect the creek’s suitability for aquatic life, since sulfate compounds are neither toxins nor nutrients. Any increase in sodium chloride would likely be indistinguishable from background.

If landfill leachate or storm water had unacceptably high levels of pH, selenium, lead, iron, copper, or zinc, the monitoring required under the existing discharge permit for the landfill (Section 3.5) should identify the presence of these contaminants before the water was discharged, thus providing an opportunity to make arrangements to treat the water before discharges occur. Current discharge monitoring does not, however, provide for detection of arsenic, so surface water releases of arsenic could go undetected.

Similarly, the current groundwater monitoring program (Section 3.5) should provide for detection of unacceptably high levels of pH, chloride, sulfate, and several dissolved metals before any substantial migration occurred. However, groundwater is not monitored for either arsenic or selenium, so groundwater releases of these substances could go undetected. Because shallow groundwater in hydrologic settings similar to the landfill site flows primarily to nearby streams, any adverse impacts from undetected groundwater releases of selenium or arsenic would be experienced in Mataponi Creek and its tributaries.

4.3.6 Transportation Resources

The primary impacts to transportation associated with Plant operations are increases in rail and road traffic due to trains and trucks traveling to and from the Plant.

Impacts from traffic increases due to Plant operations are considered in the context of existing traffic conditions. Other ongoing and future actions in the area that generate traffic or affect the capacity of transportation facilities also contribute to cumulative transportation impacts, including increased traffic and noise. Actions that could combine with Plant operations to create cumulative impacts include the 13 background developments that have been identified (Baxter 2006) as increasing automobile and truck traffic in the vicinity of the Brandywine landfill facility and contributing to the exacerbation of existing road traffic problems, especially on Maryland Route 381. (See Section 3.6.2.) The Woodrow Wilson Bridge Project (Section 3.6.2) is the only highway construction and maintenance project in the Virginia or Maryland Department of Transportation databases (VDOT 2006, MDOT 2006) that is likely to contribute to the cumulative impacts of Plant operations. Truck traffic from the Plant that crosses the bridge going to and from the Brandywine facility would combine with the increased traffic, delays, and noise generated by the Woodrow Wilson Bridge Project to contribute to cumulative impacts on transportation.

The following sections discuss transportation impacts for each of the Plant operating scenarios.

4.3.6.1 Pre-shutdown operations

Rail. Under pre-shutdown operations the Plant used about 2,280 tons (2,052 metric tons) of coal per day. Assuming the use of 100-ton (91-metric ton) rail cars, the Plant required about 23 rail car loads of coal per day. This demand could be met with five coal deliveries to the Plant each week using a 40-car train. Because the Plant has its own rail spur and train yard, five 40-car trains per week did not have major impacts on rail traffic or service on the CSX, Inc. main line.

Also, pre-shutdown operations did not have a major impact in terms of wait times for vehicular traffic at the on-grade rail crossing on the George Washington Parkway. Typical daytime rail operations (20-car trains) stopped traffic on the Parkway for ten periods of about 2 minutes each week, while typical nighttime operations (40-car trains) stopped traffic on the Parkway for five periods of about 4 minutes each week (Personal communication between D. Cramer, Mirant Corporation, and L.N. McCold, Oak Ridge National Laboratory, July 7, 2006).

Road. Under pre-shutdown operations the Plant generated about 470 tons (430 metric tons) of ash per day. Assuming the use of 24-ton (22-metric ton) dump trucks, ash removal required about 28 round trips each weekday from the Plant to the Brandywine facility. These trips had a minor impact in terms of traffic on the local streets used to access the Plant, as the streets have relatively little traffic and operate at a level-of-service at or near “A” (Personal communication between B. Garbacz, Transportation Engineer, City of Alexandria, Virginia, and J.W. Saulsbury, Oak Ridge National Laboratory, May 26, 2006). Similarly, the 28 truck trips attributable to pre-shutdown Plant operations were not a major part of the traffic volume on the major roads between Henry Street and Maryland Route 381 (Table 3.6-1). However,

pre-shutdown operations did contribute to the existing traffic problems on Maryland Route 381 (see Section 3.6.2).

4.3.6.2 Pre-Order operations

Rail. Under pre-Order operations the Plant used about 540 tons (490 metric tons) of coal per day. Assuming the use of 100-ton (91-metric ton) rail cars, the Plant required about 5.5 rail car loads of coal per day. This total demand could be met with one coal delivery to the Plant each week using a 40-car train. Because the Plant has its own rail spur and train yard, one 40-car train per week did not have major impacts on rail traffic or service on the CSX, Inc. main line.

Also, pre-Order operations did not have a major impact in terms of wait times for vehicular traffic at the on-grade rail crossing on the George Washington Parkway. Typical daytime rail operations (20-car trains) stopped traffic on the Parkway for two periods of about 2 minutes each week, while typical nighttime operations (40-car trains) stopped traffic on the Parkway for one period of about 4 minutes each week (Personal communication between D. Cramer, Mirant Corporation, and L.N. McCold, Oak Ridge National Laboratory, July 7, 2006).

Road. Under pre-Order operations, the Plant is estimated to have generated about 95 tons (86 metric tons) of ash per day. Assuming the use of 24-ton (22-metric ton) dump trucks, ash removal required about five or six round trips each weekday from the Plant to the Brandywine facility. These trips had a negligible impact in terms of traffic on the local streets used to access the Plant, since the streets have relatively little traffic and operate at an level-of-service at or near “A” (Personal communication between B. Garbacz, Transportation Engineer, City of Alexandria, Virginia, and J.W. Saulsbury, Oak Ridge National Laboratory, May 26, 2006). Similarly, the addition of five or six truck trips to the existing traffic volume on the major roads between Henry Street and Maryland Route 381 (Table 3.6-1) represented only a small impact. However, pre-Order operations did contribute to a small extent to the existing traffic problems on Maryland Route 381. (See Section 3.6.2.)

4.3.6.3 Operations under the DOE Order, temporary extension, and potential additional extensions

Rail. Under the Order before the commencement of daily predictive modeling (between December 20, 2005, and June 30, 2006), the Plant is assumed to have used an average of about 1,990 tons (1810 metric tons) of coal per day. Assuming the use of 100-ton (91-metric ton) rail cars, the Plant required about 20 rail car loads of coal per day. In addition, the use of trona required delivery by two rail cars per day. This total demand (about 22 rail cars per day) could be met with four coal/trona deliveries to the Plant each week using a 40-car train. Because the Plant has its own rail spur and train yard, two 40-car trains per week did not have major impacts on rail traffic or service on the CSX, Inc. main line.

Also, operations between December 20, 2005, and June 30, 2006, did not have a major impact in terms of wait times for vehicular traffic at the on-grade rail crossing on the George Washington Parkway. Typical daytime rail operations (20-car trains) stopped traffic on the Parkway for eight periods of about 2 minutes each day, while typical nighttime operations (40-car trains) stopped traffic on the Parkway for four periods of about 4 minutes each night (Personal communication between D. Cramer, Mirant Corporation, and L.N. McCold, Oak Ridge National Laboratory, July 7, 2006).

Following commencement of daily predictive modeling (on July 1, 2006), including the temporary extension of the Order to December 1, 2006, and any extension beyond that date, the Plant is assumed to operate at a level similar to pre-shutdown operations, but with the addition of trona. Thus, the Plant uses an average of about 2,280 tons (2,050 metric tons) of coal per day. Assuming the use of 100-ton (91-metric ton) rail cars, the Plant requires about 23 rail car loads of coal per day. In addition, the use of trona requires delivery by two rail cars per day. This total demand (about 25 rail cars per day) could be met with five coal/trona deliveries to the Plant each week using a 40-car train. Because the Plant has its own rail spur and train yard, five 40-car trains per week do not have major impacts on rail traffic or service on the CSX, Inc. main line.

Also, following commencement of daily predictive modeling, the Plant is assumed to not have a major impact in terms of wait times for vehicular traffic at the on-grade rail crossing on the George Washington Parkway. Typical daytime rail operations (20-car trains) stop traffic on the Parkway for ten periods of about 2 minutes each week, while typical nighttime operations (40-car trains) stop traffic on the Parkway for five periods of about 4 minutes each week (Personal communication between D. Cramer, Mirant Corporation, and L.N. McCold, Oak Ridge National Laboratory, July 7, 2006).

Road. Under the Order before the commencement of daily predictive modeling (between December 20, 2005, and June 30, 2006), the Plant is estimated to have generated about 16 to 28 round trips each weekday (using 24-ton trucks) transporting ash from the Plant to the Brandywine facility. These trips had a negligible impact in terms of traffic on the local streets used to access the Plant, as the streets have relatively little traffic and operate at a level-of-service at or near “A” (Personal communication between B. Garbacz, Transportation Engineer, City of Alexandria, Virginia, and J.W. Saulsbury, Oak Ridge National Laboratory, May 26, 2006). Similarly, the addition of 16 to 28 truck trips to the existing traffic volume on the major roads between Henry Street and Maryland Route 381 (Table 3.6-1) represented only a small impact. However, the increase in traffic associated with operations between December 20, 2005, and June 30, 2006, contributed to the existing traffic problems on Maryland Route 381. (See the discussion in Section 3.6.2.)

Following commencement of daily predictive modeling (on July 1, 2006), including the temporary extension of the Order to December 1, 2006, and any extension beyond that date, the Plant is assumed to operate at a level similar to pre-shutdown operations, but with the addition of trona. Because the use of trona can approximately double the amount of ash produced, the Plant generates up to twice as much coal fly ash per day as under pre-shutdown operations (Section

4.3.6.1), requiring up to 56 round trips each weekday from the Plant to the Brandywine facility. Mirant is currently approved to deliver a total of 100 truckloads of ash to the Brandywine facility each weekday from the Potomac River Generating Plant and the Chalk Point Generating Plant combined (Baxter 2006).

Although the estimated level of truck traffic each weekday after July 1, 2006 (56 round trips), exceeds truck traffic under pre-shutdown operations (28 round trips), pre-Order operations (6 round trips), and operations between December 20, 2005, and June 30, 2006 (14 to 16 round trips), it does not appear to have a major impact in terms of traffic on the local streets used to access the Plant, since the streets have relatively little traffic and operate at a level of service at or near “A” (Personal communication between B. Garbacz, Transportation Engineer, City of Alexandria, Virginia, and J.W. Saulsbury, Oak Ridge National Laboratory, May 26, 2006). Similarly, the addition of about 56 truck trips to the existing traffic volume on the major roads between Henry Street and Maryland Route 381 (Table 3.6 1) represents a relatively minor impact in terms of traffic. The increase in traffic associated with operations after commencement of daily predictive modeling is, however, estimated to make a relatively large contribution to the existing traffic problems on Maryland Route 381. (See the discussion in Section 3.6.2.)

4.3.7 Environmental Justice

As discussed in Section 4.3.1, the elevated levels of air pollution from Plant operation that occur under certain conditions are highest very close to the Plant. Because of their proximity to the Plant, under all operating conditions residents of block groups 1 and 2 (Figure 3.7-1) experience higher exposures to air pollution from Plant emissions than residents of block groups 3 and 4. All of the gridded locations where maximum modeled ambient air concentrations occur (as reported in Tables 4.3.1-1 and 4.3.1-2) are located within block groups 1 and 2.

Thus, the populations with the highest exposure to impacts from the Plant are the non-minority and non-low-income populations in block groups 1 and 2. Consequently, the minority and low-income populations in block groups 3 and 4 (Section 3.7) do not experience “disproportionately high and adverse human health or environmental effects” related to air pollutant emissions from the Plant. In addition, DOE has not identified any different or unique ways that these or other minority and low-income populations in the area could be exposed to Plant air pollutants or otherwise affected by the Order or its potential extension. Thus, neither the Order nor any extension to the Order have “disproportionately high and adverse human health or environmental effects ... on minority and low-income populations” as discussed in Executive Order 12898, *Federal Actions to Address Environmental Justice in Minority Populations and Low-Income Populations*.

As discussed in Section 4.3.1, the elevated levels of air pollution from Plant operation that occur under certain conditions are highest close to the Plant. Thus, because of their proximity to the Plant, under all operating conditions residents of block groups 1 and 2 experience higher air pollution from Plant emissions than residents of block groups 3 and 4. Consequently, the minority and low-income populations in block groups 3 and 4 do not

experience “disproportionately high and adverse human health or environmental effects” related to air pollutant emissions from the Plant. In addition, these populations do not have different or unique ways of being affected by the Order or its potential extension.

5. ALTERNATIVES FOR FUTURE DECISION-MAKING

The DOE Order, as extended, expires on December 1, 2006. Before December 1, 2006, DOE will decide whether to allow the Order to expire, extend the Order, or take some other action, such as extending the Order with mitigation measures.

5.1 Allow the Order to Expire

As stated in the Order, Pepco's new 230-kV transmission lines are expected to provide a high level of electric reliability to the Central D.C. area even in the absence of production from the Plant. However, these new lines are not expected to be complete until the summer of 2007. DOE cannot speculate how Mirant would operate if DOE did not extend the Order; however, allowing the Order to expire would likely place the Central D.C. area in risk of a potential blackout.

It is difficult to specify the risk of death or health injury associated with blackouts because of the lack of statistical studies on such risk. However, blackouts can cause, and historically have caused, significant health and environmental impacts.

Blackouts create multiple public health problems that can lead to new or exacerbated injury or death. During hot weather blackouts can result in increased deaths, due to loss of air-conditioning or cooling ventilation. For example, 232 deaths were reported in the Midwest in the summer of 1999 during an extreme heat wave that also included a series of power disturbances; the majority of the deaths were attributable to elderly individuals without access to air-conditioning (Palecki and Changnon 1999). Blackouts can also cause significant problems for people with existing illnesses. During the Midwest/Northeast blackout of August 2003 paramedics from Passaic Beth Israel hospital had to respond to four times the usual number of calls, many involving respiratory ailments for patients whose batteries on home respirators had expired and for electronic breathing aids that went dead (WNBC 2003a).

Blackouts can also cause impacts to drinking water supplies and water bodies. The Midwest/Northeast blackout of August 2003 cut water service to 1.5 million people in Cleveland and caused officials in Detroit to warn residents to boil their water until the supply could be tested for potential bacteria (Water Quality and Health Council 2004). Because electricity powers pumps that push water through a city's water system, blackouts can cause the pressure in water pipes to drop, leaving the system open to bacteria entering the water supply. In addition, the discharge of sewage from treatment plants that run on electricity can cause environmental damage to water bodies. As recently as May 19, 2006, a 3-hr power failure at the Blue Plains Wastewater Treatment Plant in Washington, D.C. resulted in 17 million gallons (64,000 m³) of raw untreated sewage being spilled into the Potomac River (Cohn 2006).

Blackouts also cause injury and death from fires (e.g. due to burning of candles), use of unvented portable emergency generators, accidents, and criminal activity. In the July 1977

blackout in New York City fires killed three, and one store owner shot and killed an armed looter (TIME 1977). Hundreds were also injured during widespread looting and other criminal activity in the July 1977 blackout. In a July 2006 blackout in Missouri that affected 150,000 people, a utility worker died after touching downed power lines, and another man died from burns while he tried to fix a generator he was using in his home (Associated Press 2006). In addition, during the Midwest/Northeast blackout of 2003 two people succumbed to carbon monoxide fumes from a gas generator aboard the boat they had been sleeping in overnight (WNBC 2003b).

5.2 Extend the Order as Currently Written

Impacts associated with extending the Order until either June 30, 2007, or December 31, 2007 (assuming a delay in installation of the new transmission lines), are assessed in Chapter 4. Extension of the Order until either date would result in increased impacts as compared to the Plant's "pre-Order" operating mode, but not the Plant's "pre-shutdown" operating mode. As presented in Chapter 4, impacts resulting from SO₂ emissions would be lower than under the pre-shutdown mode, while impacts resulting from trona use would be higher than under the pre-shutdown mode, and levels of other impacts would be similar to those from pre-shutdown operations.

5.3 Extend the Order with Mitigation Measures

Impacts of Plant operation under an extension of the Order could be mitigated by various alternatives including: (1) requiring Mirant to improve Plant operations and pollution control measures, (2) requiring Mirant to reduce exposure to pollutants to workers and nearby residents, (3) managing the demand for electricity in the Central D.C. area, (4) using alternative sources for generating electricity, and (5) expediting the installation of additional transmission lines.

5.3.1 Improve Plant Operations and Pollution Control Measures

- Require Mirant to store enough trona at or near the Plant to achieve 80% removal of SO₂ emissions for the full duration of any planned line outages. Mirant's experiments with trona indicate that this level of sulfur removal can be achieved. While Mirant has installed trona units on all five boilers, Mirant does not maintain sufficient trona on site or nearby to reduce emissions by 80% under high power operations for the duration of planned line outages.
 - Requiring Mirant to store sufficient trona at the Plant could help to ensure the logistical feasibility of achieving 80% removal of SO₂ emissions during a planned line outage, pursuant to the ACO. This could result in decreased modeled emissions

and any associated health effects. The quantity of trona available to Mirant may be limited, however, or it may take more time to increase current storage space at or near the Plant than required to install the two new transmission lines. DOE can consider working with EPA to monitor the ability of Mirant to gain and store enough trona for the Plant to achieve 80% SO₂ removal.

- Require that during non-outage situations Mirant operate the Plant at the minimum level of power generation that would maintain all units in a state in which they would be available to produce full power within a few hours of a line outage. Based on information provided by Mirant, minimum operation would require each baseload unit to operate 20 hours per day at minimum power (about 30 MW) and 4 hours at maximum power (about 105 MW). Similarly, the load-following or cycling units would need to operate 8 hours per day at minimum power (30 MW) and 4 hours at maximum power (88 MW).
 - This would reduce overall operation of the Plant and, therefore, reduce emissions and any associated health effects. DOE considered this operating mode before issuing the Order, but determined that it is not feasible because the baseload units at the Plant are designed for operation at high power levels and cannot sustain low levels of operation for a long period of time without damage.
- Require Mirant to increase the height of the Plant's exhaust stacks in order to create conditions conducive to better dispersion of emitted pollutants.
 - Taller stacks would reduce modeled air quality impacts of plant operations. The taller stacks would be visible at a greater distance and may also result in adverse visual impacts for neighbors of the Plant. Issues related to stack height increase are under the jurisdiction of the Federal Aviation Administration (FAA), which has granted Mirant permission to raise the stacks by 50 ft (15 m).

5.3.2 Reduce Exposure to Pollution

- Require Mirant to notify nearby residents when they would be potentially affected by a modeled NAAQS exceedance.
 - DOE is not able to estimate what people would do with such information and whether any decrease in health effects would occur. However, DOE can consider requiring Mirant to post daily when residents would be potentially affected by a modeled NAAQS exceedance during a line outage.

- DOE will post Mirant's monthly reports to EPA (as required by the ACO), as they become available to DOE, on DOE's website containing information related to the Plant. Such monthly reports would notify nearby residents of the results of monitored data, thereby allowing nearby residents to assess the likelihood of future exposure to an actual NAAQS exceedance.
- Pepco is filing monthly progress reports on the status of Pepco's new transmission lines and corresponding planned outages with FERC (FERC docket number EL05-145-000). Nearby residents can access Pepco's monthly reports through FERC's elibrary system at <http://www.ferc.gov/docs-filing/elibrary.asp> (search for FERC docket number EL-05-145-*).

In addition, pursuant to the December 20, 2005, Order, Pepco is required to give advance notice of any planned outage and the estimated duration of any such outage to DOE. DOE will post any advance notice received from Pepco on DOE's website containing information related to the Plant (<http://www.oe.energy.gov/permitting/372.htm>).

Therefore, nearby residents should be aware of planned line outage situations when the Plant is directed to produce power (up to full capacity) as directed by PJM.

- Require Mirant to provide the people who live in areas that would be affected by modeled exceedances of NAAQS during planned line outage situations the reasonable cost of moving to alternate locations until the threat of an exceedance is over if such people so choose.
 - Implementing this would involve several practical difficulties, such as determining the number of people who would be affected by a modeled exceedance, and whether relocation would be an appropriate response.
 - DOE believes that this may not be an appropriate use of its authority under Section 202(c) of the Federal Power Act (FPA) under these circumstances.
- Require Mirant to monitor outdoor levels of PM on the Plant site and provide suitable breathing protection for those working in high PM areas.
 - DOE can consider consulting with EPA about the need for PM monitoring. Determining the need for or type of suitable breathing protection is too speculative at this time.

5.3.3 Manage the Demand for Electricity in the Central D.C. Area

- Require the D.C. Public Service Commission (DCPSC) to develop a plan for reducing electrical demand in the Central D.C. area.
 - Reducing electrical demand in the Central D.C. area would reduce the need for operation of the Plant. However, the DCPSC and Pepco do not currently have a formal plan to reduce electrical demand in this area. Developing a plan would require rulemaking procedures, and implementing the plan would require infrastructure changes that may well take more time than required to install the new transmission lines. However, DOE has had several discussions with DCPSC encouraging DCPSC's efforts to reduce electrical demand in the Central D.C. area. DCPSC has informed DOE that:
 - DCPSC has given approval to Pepco to install "smart meters" in 2,250 homes as part of an effort to investigate how demand can be reduced in peak and other critical times.
 - DCPSC is currently in discussions with fellow state public service commissions in the Mid-Atlantic area and with PJM on how to improve demand response and related distributed energy resources.
 - A DCPSC commissioner is currently chairing the Mid-Atlantic Distributed Resources Initiative (<http://www.energetics.com/madri/>). DOE is currently providing technical advisory services and funding for facilitation efforts for this Initiative.
 - DOE can continue to encourage DCPSC to pursue demand-response initiatives in the Central D.C. area as in previous Orders.
- Order the development of specific, emergency load reduction programs to compensate for an unexpected loss of electricity generation or transmission capacity. For example, DOE could require emergency load shedding or load cycling for Federal and/or D.C. government buildings and/or other facilities during electrical emergencies.
 - Emergency load shedding or load cycling would reduce the need for operation of the Plant. DOE's Federal Energy Management Program is pursuing opportunities for energy management within the Federal government, both within and outside of emergency situations. Most recently, DOE and the General Services Administration held a workshop on April 26, 2006, on potential demand-response opportunities that

was attended by the majority of Federal electricity customers. The workshop educated Federal electricity customers on the reliability problems in the Central D.C. area and offered DOE technical assistance for demand-response initiatives.

5.3.4 Use Alternative Sources for Generating Electricity

- Require installation of temporary or back-up electricity generating equipment at specific facilities or government agencies to eliminate the need for the Mirant Plant.
 - Installation of temporary or back-up electricity generating equipment would not likely generate enough power to eliminate the need for the Plant. Alternative sources of electricity sufficient to eliminate the need for one or more units at the Plant could not be brought on line before the additional 230-kV power lines have been brought into service.
- Encourage Federal agencies in the Central D.C. area to operate on alternative sources of electricity, to reduce their peak electricity demand, or to develop a generating capability. For example, heating plants operated by the General Service Administration could be modified to cogenerate both heat and electricity, and essential government facilities could become capable of independently generating their own electricity in emergencies.
 - Alternative sources of electricity could reduce the need for the Plant and were discussed at DOE's April 2006 workshop described above. However, alternative sources of electricity sufficient to replace the Plant or eliminate the need for one or more units at the Plant could not be brought on line before the additional 230-kV power lines have been brought into service.

5.3.5 Expedite the Installation of Additional Transmission Lines or Encourage the Use of Other Existing Lines

- Expedite the installation of the two 230-kV transmission lines that Pepco is currently working on.
 - DOE has evaluated Pepco's construction schedule to make sure it is as efficient as possible. DOE can continue to monitor the construction and outage schedule to ensure, as much as possible, that the construction process remains on schedule and that any planned outages are essential. Pepco notified DOE on September 7, 2006, that the expected installation date of the new 230-kV lines is now June 21, 2007, instead of July 1, 2007.

- DOE can provide assistance to Pepco in expediting the installation of the new 230-kV lines that is requested by Pepco and that is practical and feasible. For example, at Pepco's request DOE met with Pepco representatives in March 2006 to discuss ways that DOE could help with the NEPA process for Pepco's proposed route for the new 69-kV lines to the Blue Plains Wastewater Treatment Plant (which partially fall on National Park Service land). The new 69-kV lines became operational on July 15, 2006.
- Encourage Pepco to construct additional new transmission lines, for example, from other plants in close proximity to the Central D.C. area, namely the Benning Road or Buzzard Point plants, to supply the power currently provided by the Plant.
 - Pepco already uses the power from these sources for other customers. Obtaining additional rights-of-way to construct new transmission lines would not be feasible in the time period required to solve the immediate reliability issues in the Central D.C. area.
- Encourage the use of additional transmission lines along existing corridors. Existing transmission lines enter the D.C. area from the north and south along, for example, railroad rights-of-way of the National Railroad Passenger Corporation ("AMTRAK") and CSX Corporation.
 - As described in Pepco's April 13, 2006, filing to DOE, although use of the existing transmission lines on the AMTRAK and CSX rights-of-way would reduce the need for the Plant in the Central D.C. area, the lines are already being used by Pepco. Adding additional lines along the same corridor would take more time than required to install the new 230-kV transmission lines already planned and under development.
- Encourage the use of currently existing, but inactive, transmission lines, such as the 69-kV circuits between Buzzard Point and the Plant.
 - As described in Pepco's April 13, 2006, filing to DOE, Pepco refurbished three 69-kV circuits between Buzzard Point and the Plant in 2004 to provide emergency back-up service, which would be used to restart the Plant and help the restoration process for any blackout of the Central D.C. area. These circuits cannot be energized under normal operating conditions because they are of small capacity and would overload quickly upon the failure of one of the existing 230-kV transmission circuits or the Plant; thus, their use would not provide an increase in reliability.

6. REGULATORY CONSULTATION AND COMPLIANCE

Under Section 7 of the Endangered Species Act (ESA) Federal agencies must consult with the Fish and Wildlife Service (FWS) or the National Marine Fisheries Service (NMFS) regarding actions that they may undertake that could adversely affect species and habitats protected under the Act. In order to comply with this requirement, DOE sent letters to FWS and NMFS as part of informal consultation describing the species that were likely to occur near the Plant and requesting concurrence from FWS and NMFS that the operation of the Mirant Potomac River Generating Station under the terms of the DOE Orders would not adversely impact Federally listed or proposed threatened or endangered species or designated or proposed critical habit. (See Appendix D.)

The responses from FWS and NMFS, also included in Appendix D, are discussed in Section 4.3.4.4.

7. REFERENCES³²

- Alliance for the Chesapeake Bay. Undated. <http://www.alliancechesbay.org/index.cfm>
<http://www.acb-online.org/about.cfm> (Accessed June 1, 2006)
- American Forests. 2002. Urban Ecosystem Analysis for the Washington D.C. Metropolitan Area. An Assessment of Existing Conditions and a Resource for Local Action. February.
http://americanforests.org/downloads/rea/AF_WashingtonDC2.pdf (Accessed May 29, 2006)
- Anacostia Watershed Network. 2006. <http://www.anacostia.net/> (Accessed June 5, 2006)
- Anacostia Watershed Restoration Committee. 2001. Aiming High, Setting Targets for a Restored Anacostia Watershed. 2001 Anacostia Watershed Restoration Agreement. December 3.
http://www.anacostia.net/download/2001_Agreement_Color.pdf
- Anacostia Watershed Restoration Committee. 2004. Working Together to Restore the Anacostia Watershed. Annual Report 2003. Washington, D.C..
http://www.anacostia.net/download/2003_annual_report_final.pdf (Accessed September 25, 2006)
- Associated Press. 2006. "California Heat Wave Blamed in up to 90 Deaths." July 27.
<http://msnbc.msn.com/id/14003245/?GT1=8307> (Accessed September 25, 2006)
- Azad, A.D., and T. Kitada. 1998. Characteristics of the air pollution in the city of Dhaka, Bangladesh in winter. *Atmospheric Environment* 32, No. 11, p. 1991-2005.
- Baxter, Reggie. 2006. Technical Staff Report, Special Exception Application No. 4520, Extension of Time for the Operation of a Sanitary Landfill (Fly Ash). The Maryland-National Capital Park and Planning Commission, Prince George's County Planning Department, Upper Marlboro, MD. SE-4250. March 1.
<http://www.mncppc.org/pgco/planning/pdf/03-16-6/SE-4520.pdf>

³² Internet addresses (URLs) are provided for all items that are only available on the Internet as electronic documents, as well as for many items that are available as both electronic documents and conventional paper publications. Access dates are provided in all cases where the Internet content cited is potentially subject to revision but is not marked with a revision date.

- Blankenship, Karl. 1997. Water Managers Urged to Add Their Concerns to Air Rules Debate. Chesapeake Bay Journal. April. <http://bayjournal.com/article.cfm?article=1740> (Accessed April 7, 2006)
- Blankenship, Karl. 2004. How Allocations Were Made. Chesapeake Bay Journal. March. <http://www.bayjournal.com/article.cfm?article=1212> (Accessed April 7, 2006)
- Boynton, W.R., and D. P. Swaney. 1998. N and P budget for the Chesapeake Bay. <http://data.ecology.su.se/mnode/North%20America/chesapeake/chbbud.htm> (Accessed June 7, 2006)
- Brakebill, John W., and Steven D. Preston. 2004. "Digital Data Used to Relate Nutrient Inputs to Water Quality in the Chesapeake Bay Watershed, Version 3.0," U.S. Geological Survey, Baltimore, Maryland. Open-File Report 2004-1433.
- Cada, Glenn F., J. Samuel Suffern, K. Deva Kumar, and Jean A. Solomon. 1981. Investigations of entrainment mortality among larval and juvenile fishes using a power plant simulator. Pp. 111-122. IN: *Issues Associated with Impact Assessment*. Edited by Loren D. Jensen. Proceedings of the Firth National Workshop on Entrainment and Impingement. San Francisco, CA, 5-7 May 1980.
- Capacasa, Jon M. 2005. NPDES Permit No. DC0022004, Potomac River Generating Station, Administrative Extension of Current Permit. Letter to Hula C. Edmonds, Mirant Potomac River, LL. EPA, Philadelphia, PA. March 15.
- CBP (Chesapeake Bay Program). Undated. <http://www.chesapeakebay.net/index.cfm> (and information linked from this page) (Accessed May 30 and June 20, 2006)
- CBP. 2000. Air Pollutants and the Chesapeake Bay (slide presentation). <http://www.chesapeakebay.net/pubs/airlink.ppt>
- CBP. 2005. Simulated Nutrient and Sediment Load Reductions (1985-2004). http://www.chesapeakebay.net/status/status_print.cfm and spreadsheet "npsedload.xls", updated November 1, 2005. (Accessed April 10, 2006)
- CBP STAC (Chesapeake Bay Program Scientific and Technical Advisory Committee). 1996. "Ascertaining Sources of Nitrogen Entry to the Chesapeake Bay with Emphasis on Atmospheric Inputs," October. http://www.chesapeake.org/stac/Pubs/stac02_Nentry.pdf (Accessed April 7, 2006)

- CBWP-MANTA (Chesapeake Bay and Watershed Programs. Monitoring and Non-tidal Assessment). 2001. Habitat Quality and Biological Integrity Assessment for the Northeast and Northwest Branches of the Anacostia River. CBWP-MANTA-EA-01-3. March. http://www.dnr.state.md.us/streams/pubs/ea01-3_anacostia.pdf (Accessed June 6, 2006)
- CEQ (Council on Environmental Quality). 1997. Environmental Justice Guidance under the National Environmental Policy Act. Washington, D.C.. December 10.
- 10 CFR (Code of Federal Regulations) Part 1021. *National Environmental Policy Act Implementing Procedures*.
- 40 CFR 261.4. *Identification and Listing of Hazardous Waste; Exclusions*.
- 40 CFR Part 50. *National Ambient Air Quality Standards*.
- 40 CFR Part 61. *National Emission Standards for Hazardous Air Pollutants*.
- 40 CFR Part 62. *Approval and Promulgation of State Plans for Designated Facilities and Pollutants*.
- 40 CFR Part 63. *National Emission Standards for Hazardous Air Pollutants for Source Categories*.
- 40 CFR Parts 1500-1508. *Regulations for Implementing the Procedural Provisions of the National Environmental Policy Act*.
- Cohn, D'Vera. 2006. "Power Outage Unleashes Raw Sewage," *The Washington Post*, page B10. Washington, D.C., May 20.
- DC WASA (District of Columbia Water and Sewer Authority). 2006. District of Columbia Water and Sewer Authority. <http://www.dcwasa.com/> (Accessed June 2, 2006)
- DCPSC (District of Columbia Public Service Commission). 2005. *Emergency Petition and Complaint of the District of Columbia Public Service Commission*, Docket No. EL05-145-000, as filed with the Department of Energy and the Federal Energy Regulatory Commission, August 24.

- Dockery, D.W., C.A. Pope, X. Xu, J.D. Spengler, J.H. Ware, M.E. Fay, B.G. Ferris, and F.E. Speizer. 1993. "An Association Between Air Pollution and Mortality in Six U.S. Cities," *New England J. Med.* 329: 1753-1759.
- DOE (U.S. Department of Energy). 2005. Order 202-05-03. [District of Columbia Public Service Commission Docket EO-05-01], Samuel W. Bodman, Secretary of Energy, Washington, D.C., December 20.
- DOE. 2006. "Emergency Order to Resume Limited Operation at the Potomac River Generating Station, Alexandria, VA, in Response to Electricity Reliability Concerns in Washington, D.C." Notice of Emergency Action, 71 *Federal Register* 3279-3281. January 20.
- Dvorak, A. J., B. G. Lewis, et al. 1978. Impacts of Coal-Fired Power Plants on Fish, Wildlife, and their Habitats. FWS/OBS-78/29. March.
- Dyni, John R. 1991. Descriptive Model of Sodium Carbonate in Bedded Lacustrine Evaporites; Deposit Subtype: Green River (Model 35b.1). In: Some Industrial Mineral Deposit Models: Descriptive Deposit Models (G.J. Orris and J.D. Bliss, eds.), Open-File Report 91-11A, U.S. Geological Survey, Tucson, AZ.
- Dyni, John R. 1996. Sodium Carbonate Resources of the Green River Formation. Open-File Report 96-279, U.S. Geological Survey, Denver, CO.
- ENSR Corporation. 2005. *A Dispersion Modeling Analysis of Downwash from Mirant's Potomac River Power Plant*. Document No. 10350-002-410. August.
- EPA (Environmental Protection Agency). 1995. Ecological Restoration. EPA 841-F-95-007. November. <http://www.epa.gov/owow/nps/Ecology/> (Accessed June 6, 2006)
- EPA. 1997. *An Environmental Characterization of the District of Columbia: A Scientific Foundation for Setting an Environmental Agenda* EPA-903-R-97-027. http://www.epa.gov/maia/html/dc_report.html (Accessed May 29, 2006)
- EPA. 2000. "Potomac Estuary Case Study." Chapter 8 in *Progress in Water Quality: An Evaluation of the National Investment in Municipal Wastewater Treatment*. Office of Water. Washington, D.C.. EPA-832-R-00-008. June.
- EPA. 2002. "User's Guide for the AMS/EPA Regulatory Model – AERMOD, draft," August.

- EPA. 2004. "United States of American and the State of Maryland, Plaintiffs, and Robert G. Burnley, Director, Commonwealth of Virginia, Department of Environmental Quality, Plaintiff-Intervenor v. Mirant Potomac River, LLC and Mirant, Mid-Atlantic, LLC, Defendants; Consent Decree," September 27.
<http://www.epa.gov/compliance/resources/decrees/civil/caa/mirantcd.pdf> (accessed August 18, 2006)
- EPA. 2005. Methods for Projection Health Benefits for EPA's Multi-Pollutant Analyses of 2005. Office of Air and Radiation, October.
http://www.epa.gov/airmarkets/mp/bmresults/health_benefits_method.pdf
- EPA. 2006a. Acid Rain. <http://www.epa.gov/acidrain/index.html> (and information linked from this page) (Accessed June 8, 2006)
- EPA. 2006b. "NO_x SIP Call (NO_x Budget Trading Program) Preliminary Summary Emission Reports," <http://www.epa.gov/airmarkets/emissions/prelimsip/> March 22.
- EPA. 2006c. Electricity from coal. <http://www.epa.gov/cleanrgy/coal.htm> (Accessed July 24, 2006)
- EPA. 2006d. Ecological Resources Fact Sheet. <http://www.epa.gov/maia/html/er-fact.html> (Accessed May 29, 2006)
- EPA. 2006e. Information on the Toxic Effects of Various Chemicals and Groups of Chemicals <http://www.epa.gov/R5Super/ecology/html/toxprofiles.htm> (Accessed August 19, 2006)
- EPA. 2006f. *Currently Designated Nonattainment Areas for All Criteria Pollutants*, as of March 2, 2006. <http://www.epa.gov/air/oaqps/greenbk/ancl.html#VIRGINIA> (Accessed September 21, 2006)
- EPA. 2006g. "United States of America and the State of Maryland, Plaintiffs, and David K. Paylor, Director, Commonwealth of Virginia, Department of Environmental Quality, Plaintiff-Intervenor v. Mirant Potomac River, LLC and Mirant Mid-Atlantic, LLC, Defendants, Amended Consent Decree." Civil Action No: 1:04CV1136, lodged May 8, 2006.
<http://www.epa.gov/compliance/resources/cases/civil/caa/mirant0406.html> (Accessed September 20, 2006)

- EPA. 2006h. "Fact Sheet: Implementation of New or Revised National Ambient Air Quality Standards for Particle Pollution," <http://www.epa.gov/air/particlepollution/fs20060203.html> (Accessed September 20, 2006)
- EPA. 2006i. "Fine Particle (PM_{2.5}) Designations Frequent Questions; Why haven't PM_{2.5} nonattainment areas already been designated?" <http://www.epa.gov/pmdesignations/faq.htm#7> (Accessed September 20, 2006)
- EPA. 2006j. "National Ambient Air Quality Standards for Particulate Matter, Final Rule," 40 CFR Part 50. 71 *Federal Register* 61144-61233. October 17.
- Fairfax County Stormwater Planning Division. 2001. Fairfax County Stream Protection Strategy Baseline Study. Department of Public Works and Environmental Services. Fairfax, VA. January. http://www.fairfaxcounty.gov/dpwes/environmental/sps_pdf.htm (Accessed June 7, 2006)
- FHWA (Federal Highway Administration). 2006. U.S. Department of Transportation, Federal Highway Administration. Transportation Conformity Reference Guide, Glossary. Revised March 2006. http://www.fhwa.dot.gov/environment/conformity/ref_guid/glossary.htm (Accessed October 16, 2006)
- Fuller, Pam. 2006. *Channa argus*. U.S. Geological Survey Nonindigenous Aquatic Species Database, Gainesville, FL. <http://nas.er.usgs.gov/queries/FactSheet.asp?speciesID=2265> Revised April 11.
- FWS (Fish and Wildlife Service). 2006. Endangered Species Glossary. <http://www.fws.gov/endangered/glossary.pdf> (Accessed July 21, 2006)
- Galli, John, Edward Graham, Timothy Murphy, Phong Trieu, Peter Guillozet, and Dave Shepp. 2001. Anacostia Watershed Restoration Indicators and Targets for the Period 2001-2010. Metropolitan Washington Council of Governments, Department of Environmental Programs. Washington, D.C. August. http://www.anacostia.net/download/indicators_and_targets.pdf
- GB&B Inc. (Gershman, Brickner & Bratton, Inc.). 2005. Rubblefill Needs Assessment -- Ashfill of Mirant MD Ash Management LLC. May.
- Hagy, James D., and Michael Kemp. 2002. Patuxent River, Maryland, USA. http://data.ecology.su.se/mnode/North%20America/chesapeake/Patuxent/patuxent_riverbudget.htm (Accessed June 7, 2006)

- Harrison, David. 2004. "Fairfax Landfills Filling Up." Connection Newspapers. May 13.
- IPCC (Intergovernmental Panel on Climate Change). 2001. "Climate Change 2001: Synthesis Report, Summary for Policymakers." <http://www.ipcc.ch/> (Accessed August 8, 2006)
- Jensen, Loren D., editor. 1981. Issues associated with impact assessment. Proceedings of the Fifth National Workshop on Entrainment and Impingement. San Francisco, CA, May 5-7, 1980.
- Keeney, Timothy R. E. 2002. Testimony on the effect of Washington aqueduct discharges on the endangered shortnose sturgeon before the Committee on Resources, U. S. House of Representatives. June 19.
- Kirby, Brendan, and John Kueck. 2005. "Washington D.C. Reliability Requirements and the Need to Operate Mirant's Potomac River [Generating] Station to Support Local Area Reliability," Oak Ridge National Laboratory, Oak Ridge, Tennessee, December. Redacted version at: http://www.oe.energy.gov/DocumentsandMedia/mirant_122905.pdf (Accessed July 13, 2006)
- Marland, G., T.A. Boden, and R. J. Andres. 2006. *Global, Regional, and National CO2 Emissions*. In *Trends: A Compendium of Data on Global Change*. Carbon Dioxide Information Analysis Center, Oak Ridge National Laboratory, Oak Ridge, TN. http://cdiac.esd.ornl.gov/trends/emis/tre_glob.htm (Accessed August 8, 2006)
- Maryland DNR (Department of Natural Resources). Undated-a. Patuxent River Basin. <http://www.dnr.state.md.us/streams/pubs/patuxent.pdf> (Accessed September 25, 2006)
- Maryland DNR. Undated-b. Potomac-Washington Metro Basin. <http://www.dnr.state.md.us/streams/pubs/potomacwashingtonmetro.pdf> (Accessed September 25, 2006)
- Maryland DNR. Undated-c. Tributary Strategies: Patuxent River Commission. <http://www.dnr.state.md.us/bay/tribstrat/patuxent/patuxent.html> and http://www.dnr.state.md.us/bay/tribstrat/patuxent/pr_status_trends.html (Accessed June 21, 2006)
- MDOE (Maryland Department of Environment). 2005. Solid Waste Managed in Maryland, Calendar Year 2004. Annual Report to the Legislature. Baltimore, MD. September 1.

- MDOE. 2006. Prioritizing Sites for Wetland Restoration, Mitigation, and Preservation in Maryland. Montgomery County. May 18.
<http://www.mde.state.md.us/assets/document/wetlandswaterways/MO.pdf> (accessed August 19, 2006)
- MDOT (Maryland Department of Transportation) 2005. Maryland's Traffic Volume Maps by County: Prince George's County Traffic Volume Map 2005. Maintained by the State Highway Administration.
<http://www.sha.state.md.us/shaservices/mapsbrochures/maps/oppe/trafficvolumemaps/2005/princegeorges.pdf> (Accessed May 30, 2006)
- MDOT. 2006. Projects. Maintained by the State Highway Administration.
<http://www.sha.state.md.us/businesswithsha/projects.asp?id=WD51+B170> (Accessed May 30, 2006)
- Metropolitan Washington Council of Governments. 1999. Anacostia Restoration Agreement.
<http://www.anacostia.net/agreement.htm> May 10.
- Metropolitan Washington Council of Governments. 2001. "Waste Management Trends in the Washington Metropolitan Region 2001." Washington, D.C. November.
<http://www.mwcog.org/uploads/pub-documents/DI5f20030624150406.pdf> (Accessed September 11, 2006)
- Metropolitan Washington Council of Governments. 2005. "Air Quality Trends, Metropolitan Washington, D.C. Region, 1993-2004." Department of Environmental Programs, Washington, D.C., August.
- Mirant. 2002. Potomac River Generating Station Thermal Plume Study in 2001.
- Mirant. 2006a. Potomac River Generating Plant. <http://potomac.mirant.com/index.html> (Accessed June 16, 2006)
- Mirant. 2006b. Potomac River Generating Plant Water Quality.
<http://potomac.mirant.com/environment/waterquality.htm> (Accessed June 16, 2006)
- Mirant. 2006c. Trona Injection Tests, Mirant Potomac River Station Unit 1, November 12 to December 23, 2005. 21 pages. January 16.
http://mirant.com/our_business/where_we_work/potomac.htm (Accessed November 7, 2006)

- NatureServe. 2006. NatureServe Explorer: An online encyclopedia of life [web application]. Version 5.0. NatureServe, Arlington, Virginia. Available at <http://www.natureserve.org/explorer> (Accessed July 21, 2006)
- NMFS (National Marine Fisheries Service). 1998. Final Recovery Plan for the Shortnose Sturgeon *Acipenser brevirostrum*. December. http://www.nmfs.noaa.gov/pr/pdfs/recovery/sturgeon_shortnose.pdf (Accessed June 19, 2006)
- Northern Virginia Regional Commission. Undated. Occoquan Basin Nonpoint Pollution Management Program. <http://www.novaregion.org/occoquan.htm> (Accessed June 6, 2006.)
- NPS (National Park Service). Undated. George Washington Memorial Parkway. <http://www.nps.gov/gwmp/index.htm> (Accessed May 29, 2006)
- NPS. 2002. Study for the National Park Service: Facility & Site Analysis for a Boathouse on the Potomac River in Arlington County and Vicinity. August. <http://www.nps.gov/gwmp/boathouse/chapters.htm> (Accessed May 26, 2006)
- Palecki, Michael A., and Stanley A. Changnon. 1999. The Nature and Impacts of the July 1999 Heat Wave in the Midwest. Midwestern Climate Center, Illinois State Water Survey. Champaign, IL. August 23. http://mcc.sws.uiuc.edu/climate_midwest/historical/hw99/hw99.html (Accessed September 25, 2006)
- Palmer, Curtis A., Allan Kolker, Robert B. Finkelman, Kathleen C. Kolb, Stanley J. Mroczkowski, Sharon S. Crowley, Harvey E. Belkin, John H. Bullock, Jr., and Jerry M. Motooka. 1997. Trace Elements in Coal - Modes of Occurrence Analysis. DE-AI22-95PC95156. U.S. Geological Survey, Reston, VA. July 24.
- Pepco. 1982. Impingement at the Potomac River Generating Station. 35 pages. August.
- Pepco. 1983. Potomac River Generating Station Entrainment Study. 60 pages.
- Pope, C.A., III, R.T. Burnett, M.J. Thun, E.E. Calle, D. Krewski, K. Ito, and G.D. Thurston. 2002. "Lung Cancer, Cardiopulmonary Mortality, and Long-term Exposure to Fine Particulate Air Pollution." *Journal of the American Medical Association*. 287: 1132.

- Roth, Nancy E., Mark T. Southerland, Ginny M. Rogers, and Jon H. Vølstad. 2005. Maryland Biological Stream Survey 2000-2004. Volume IV: Ecological Assessment of Watersheds Sampled in 2003. Maryland Department of Natural Resources (DNR) Publication # DNR-12-0105-0038. January. <http://www.dnr.state.md.us/streams/pubs/ea05-1data03.pdf>
- Schreiber, R. K. 1995. Acidic Deposition (“Acid Rain”), pp. 418-420; In LaRoe, E.T., G. S. Farris, C. E. Puckett, P. D. Doran, and M. J. Mac. *Our Living Resources. A report to the Nation on the distribution, abundance, and health of U.S. plants, animals and ecosystems*. U.S. Dept. Interior, National Biological Service, Washington, D.C. 530 pp. <http://biology.usgs.gov/s+t/frame/u204.htm> (Accessed June 1, 2006)
- Shanks, Kenneth (Primary Author and Editor). 2005. Characterization of the Anacostia River Watershed in Prince George’s County, Maryland. Maryland Department of Natural Resources (DNR) Publication No. DNR-14-1209-0021. March. http://dnrweb.dnr.state.md.us/download/bays/ar_char_text_appa.pdf (Accessed June 9, 2006)
- SPROL. 2005. Mirant Flips off Power Plant. August 28. <http://www.sprol.com/?p=241> (Accessed May 29, 2006)
- TFHRC (Turner-Fairbank Highway Research Center). Undated. User Guidelines for Waste and Byproduct Material in Pavement Construction. United States Department of Transportation Federal Highway Administration. <http://www.tfhrc.gov/hnr20/recycle/waste/begin.htm> (Accessed July 28, 2006)
- TIME. 1977. “Night of Terror,” *TIME Magazine*, July 25, pp. 12-22.
- TRC Environmental Corporation. 2006. “Final Report; Particulate Emissions Testing, Unit 1, Potomac Generating Station, Alexandria, Virginia.” (prepared for Mirant Potomac River, LLC.) Lowell, Massachusetts, January.
- 16 U.S.C. (United States Code) § 824 *et seq.* “Regulation of Electric Utility Companies Engaged in Interstate Commerce” under the *Federal Power Act*.
- U.S. Census Bureau. 2006. American FactFinder. <http://www.factfinder.census.gov>
- VDEQ (Virginia Department of Environmental Quality). 2002. Active Solid Waste Facilities in Virginia’s DEQ Northern Regional Office. April 23. <http://www.deq.state.va.us/waste/pdf/anvro.pdf> (Accessed September 11, 2006)

- VDEQ. 2005a. *Virginia Ambient Air Monitoring 2004 Data Report*. August.
<http://www.deq.virginia.gov/airmon/pdf/AnnualRpt04.pdf> (Accessed September 11, 2006)
- VDEQ. 2005b. "Motion of Robert G. Burnley, Director of the Commonwealth of Virginia Department of Environmental Quality to Deny the District of Columbia Public Service Commission's Petition on the Grounds that the Commission May Not Lawfully Grant the Requested Relief; or, in the Alternative, to Defer Action Pending Further Analysis of Environmental Impacts of Requested Relief," October 11, Before the Federal Energy Regulatory Commission, Docket No. EL05-145-000.
http://www.oe.energy.gov/DocumentsandMedia/mirant_101205.pdf (Accessed September 20, 2006)
- VDEQ. 2006a. 8-hour Ozone Nonattainment & Early Action Areas.
<http://www.deq.virginia.gov/air/status.html> (Accessed July 28, 2006)
- VDEQ. 2006b. PM_{2.5} Nonattainment Area. <http://www.deq.virginia.gov/air/status2.html>
(Accessed July 28, 2006)
- VDEQ. 2006c. *Virginia Ambient Air Monitoring 2005 Data Report*. August.
http://www.deq.virginia.gov/airmon/documents/AnnualReport05_002.pdf (Accessed November 15, 2006)
- VDOT (Virginia Department of Transportation). 2004. 2004 Virginia Department of Transportation Daily Traffic Volume Estimates, Including Vehicle Classification Estimates Where Available: Special Locality Report 100, City of Alexandria.
http://www.virginiadot.org/comtravel/resources/AADT_100_Alexandria_2004.pdf
(Accessed May 26, 2006)
- VDOT. 2006. Virginia Department of Transportation Projects By Region: Northern Virginia Projects. <http://www.virginiadot.org/projects/district-projects.asp?ID=9> (Accessed May 26, 2006)
- Virginia Department of Health. 2004. Health Statistics. <http://www.vdh.virginia.gov/healthstats/>
(Accessed August 28, 2006, and October 17, 2006)
- VNHR (Virginia Natural Heritage Resources). 2006. Search for VA Natural Heritage Resources Information. http://192.206.31.52/cfprog/dnh/naturalheritage/display_counties.cfm
(Accessed July 21, 2006)

- Water Quality and Health Council. 2004. "Water in the Balance- A Boiling Crisis for the Nation's Water Supply," *Drinking Water & Health Quarterly* 10(1).
http://www.waterandhealth.org/newsletter/new/winter_2004/water_balance.html (Accessed September 25, 2006)
- Wearmouth, Ann. 2004. NPDES Renewal for Mirant Potomac River, Potomac River Generating Station - DC002204 (submittal to EPA Region III, Philadelphia, PA). Mirant Mid-Atlantic, LLC, Upper Marlboro, MD. October 19.
- WebElements. 2006. Chemistry: WebElements Periodic Table: Professional Edition: Selenium: Key Information. The University of Sheffield and WebElements Ltd, UK
<http://www.webelements.com/webelements/elements/text/Se/key.html> (Accessed August 4, 2006)
- WHO (World Health Organization). 2000. "Air Quality Guidelines for Europe, Second Edition," World Health Organization Regional Publications, European Series No. 91.
- Wilderness Society. Undated. Potomac River Watershed Facts.
<http://www.wilderness.org/Library/Documents/upload/Potomac-River-Watershed-Facts.pdf>
- WNBC. 2003a. "Respiratory Patients Flood N.J. Hospitals During Blackouts," August 17-18.
<http://www.wnbc.com/health/2410840/detail.html> (Accessed September 25, 2006)
- WNBC. 2003b. "No Power Woes Yet, But Will Lights Stay On?," August 18.
<http://www.wnbc.com/news/2411302/detail.html> (Accessed September 25, 2006)
- WWBP (Woodrow Wilson Bridge Project). 2006a. The Woodrow Wilson Bridge Project.
<http://www.wilsonbridge.com/> (Accessed May 30, 2006)
- WWBP. 2006b. "Eagle Martha Put Down after Severe Injury," October 3.
<http://www.wilsonbridge.com/pdfs/pressReleases/pr2006-1002.pdf> (Accessed October 16, 2006)

8. LIST OF PREPARERS

Department of Energy

Anthony J. Como, Office of Electricity Delivery and Energy Reliability. NEPA Document Manager

Oak Ridge National Laboratory

Lance N. McCold, Research Staff, Environmental Sciences Division

Technical Responsibilities: Team Leader, Meteorology, Air Quality

Education: B.S., 1973, Physics, Oregon State University

M.S., 1976, Mechanical Engineering, Oregon State University

Years of Experience: 27

Total Publications: 40

Kenneth W. Childs, Research Staff, Computational Sciences & Engineering Division

Technical Responsibilities: Air quality modeling

Education: B.S., 1971, Mechanical Engineering, University of Tennessee

M.S., 1974, Mechanical Engineering, University of Tennessee

Years of Experience: 35

Total Publications: 80+

John T. Jankovic, Industrial Hygiene Specialist, Safety Services Division

Technical Responsibilities: Human Health

Education: B.S., 1972, Environmental Health Science, Ferris State University

M.S.P.H., 1979, Industrial Hygiene and Safety Engineering, University of North Carolina

Years of Experience: 33

Total Publications: 15

Martha S. Salk, Research Staff, Environmental Sciences Division
Technical Responsibilities: Ecological Resources, Document Integration
Education: B.A., 1967, Biology, Albion College
 M.S., 1969, Botany, University of Iowa
 Ph.D., 1975, Plant ecology, University of Louisville
Years of Experience: 32
Total Publications: 40

James W. Saulsbury, Research Staff, Environmental Sciences Division
Technical Responsibilities: Transportation, Environmental Justice
Education: B.A., 1986, History, University of Tennessee
 M.S., 1989, Planning, University of Tennessee
Years of Experience: 19
Total Publications: 30

Ellen D. Smith, Research Staff, Environmental Sciences Division
Technical Responsibilities: Water Resources, Waste Management
Education: B.A., 1974, Geology, Carleton College
 M.S., 1979, Water Resources Management, University of Wisconsin-Madison
Years of Experience: 27
Total Publications: 27

Gregory P. Zimmerman, Research Staff, Environmental Sciences Division
Technical Responsibilities: Figures/Drawings/Graphic Arts; Document Review, Editing, and
 Composition
Education: B.S., Mechanical Engineering, 1975, University of Tennessee
 M.S., Mechanical Engineering, 1977, University of Tennessee
Years of Experience: 29
Total Publications: 80+

[This page intentionally left blank]

APPENDIX A

DOE Emergency Orders

[This page intentionally left blank]

United States of America
Department of Energy

District of Columbia Public Service Commission)

Docket No. EO-05-01

Order No. 202-05-3

I. Summary

Pursuant to the authority vested in the Secretary of Energy by section 202(c) of the Federal Power Act (FPA), 16 U.S.C. § 824a(c), and section 301(b) of the Department of Energy Organization Act, 42 U.S.C. § 7151(b), and for the reasons set forth below, I hereby determine that an emergency exists due to a shortage of electric energy, a shortage of facilities for the generation of electric energy, a shortage of facilities for the transmission of electric energy and other causes, and that issuance of this order will meet the emergency and serve the public interest. Therefore, Mirant Corporation and its wholly owned subsidiary, Mirant Potomac River, LLC (collectively referred to herein as Mirant), are hereby ordered to generate electricity at their Potomac River Generating Station (the “Plant”) pursuant to the terms of this order.

II. Procedural History

On August 19, 2005, Mirant submitted to the Virginia Department of Environmental Quality (DEQ) a computerized emissions modeling study Mirant had conducted of its Plant that indicated that emissions from the Plant caused or contributed to significant localized exceedances of the National Ambient Air Quality Standards (NAAQS).¹ Also on August 19, 2005, DEQ issued a letter to Mirant which requested “that Mirant *immediately* undertake such action as is necessary to ensure protection of human health and the environment, in the area surrounding the Potomac River Generating Station, including the potential reduction of levels of operation, or potential shut down of the facility.” (emphasis in original). The letter asked Mirant to provide DEQ with a summary of the actions taken and the progress toward eliminating NAAQS exceedances by August 24, 2005. At midnight on August 21, 2005, Mirant reduced production of all units at the Plant to their minimum load, and at midnight on August 24, 2005, Mirant shut down all five of the generating units at the Plant.

On August 24, 2005, the District of Columbia Public Service Commission (DCPSC) filed an *Emergency Petition and Complaint* with both the United States Department of Energy (DOE or Department) and the Federal Energy Regulatory Commission (FERC or Commission) pursuant to the FPA. The DCPSC requested the Secretary of Energy to find that an emergency exists under section 202(c) of the FPA and to issue an order directing Mirant to continue

¹ The Clean Air Act, 42 U.S.C. § 7401 *et seq.*, authorizes the United States Environmental Protection Agency (EPA) to establish NAAQS, 42 U.S.C. §§ 7408-7409, and states that it is the responsibility of the states and local governments for assuring that they are attained, 42 U.S.C. §§ 7401(a)(3) and 7416.

operation of the Plant. The basis for the petition was that the shutdown of the Plant “...will have a drastic and potentially immediate effect on the electric reliability in the greater Washington, D.C., area and could expose hundreds of thousands of consumers, agencies of the Federal Government and critical federal infrastructure to curtailments of electric service, load shedding and, potentially, blackouts.” The DCPSC requested that the Commission issue a similar order under sections 207 and 309 of the FPA. Numerous parties filed interventions and comments in response to DCPSC’s emergency petition, as well as subsequent comments and responses.² Further, both FERC and DOE issued information requests to Mirant, the Potomac Electric Power Company (PEPCO), the company responsible for supplying electricity to retail customers in the District of Columbia, and PJM Interconnection, LLC (PJM), the grid operator responsible for the administration of the bulk power grid and electricity market in the region.³ In addition to the DCPSC petition proceedings, DOE has hosted and participated in numerous conference calls and meetings to gather information on the shutdown of the Plant and its effect on the reliability of D.C.’s electricity system.⁴

III. Background

The coal-fired Mirant Plant, which began operation in 1949, is located in Alexandria, Virginia, and is capable of producing 482 megawatts of electricity primarily for delivery to Washington, D.C. The Plant consists of five generating units, two of which are cycling units that range in output from 35 MW to 88 MW, and three of which are baseload units that range in output from 35 MW to 102 MW. It is one of only three sources of electricity that serve the central business district of the District of Columbia, many federal institutions, the Georgetown area in D.C., as well as other portions of Northwest, D.C., and the District of Columbia Water and Sewer Authority’s Blue Plains Advanced Water Treatment Plant, the largest wastewater

² Several of these filings were only made in the FERC docket and not in DOE’s docket. Even though a number of filers did not submit their comments in the DOE docket, the Department has, in the interest of rendering an appropriate and fully informed determination, reviewed all the filings in the FERC docket for any pertinent facts that will assist the Department in making its decision. Also, to the extent the filings contained analysis or legal arguments pertaining to the Department’s 202(c) authority, they have been considered in the Department’s decision making process.

³ The data submitted contained Critical Energy Infrastructure Information and was submitted in both confidential and redacted versions, as defined in FERC’s rules at 18 C.F.R. § 388.13. All information contained in this order is from public filings in the DOE and FERC dockets.

⁴ The Administrative Procedure Act’s prohibitions on ex parte communications in an adjudicatory proceeding, 5 U.S.C. § 557(d)(1), do not apply to DOE’s 202(c) proceedings, because section 202(c) explicitly authorizes the Department to issue a 202(c) order “either upon its own motion or upon complaint, with or without notice, hearing, or report. . .” 16 U.S.C. § 824a(c).

treatment plant in the world.⁵ The other two sources are two 230 kV lines that deliver electricity from other generating sources in the regional electric grid operated by PJM. Although there are other generating units in close physical proximity to the Central D.C. area, (e.g., the Benning Road and Buzzard Point generating facilities, which are dual-fueled oil and natural gas generating power plants, owned by PEPCO) there are no transmission lines that would allow delivery of power from these other units to reach the Central D.C. area. With regard to the sources of power that serve the Central D.C. area, PEPCO owns and operates the transmission lines, and PJM determines electricity demand.

Although Mirant shut down all of the Plant's generating units on August 24, 2005, it has since restarted unit number one which, the Department understands, is currently operating. Mirant is operating the unit on an 8/8/8 basis --- that is, in any given twenty-four hour period, the unit runs for eight hours at its maximum level of 88 MW, eight hours at its minimum level of 35 MW, and has eight hours when it does not run. DOE has been informed that both EPA and DEQ acknowledge that the operation of this unit in this manner does not result in any NAAQS exceedances. In addition, DOE understands that Mirant is taking other steps to increase production at the Plant in a manner which will be acceptable to DEQ and EPA.

PEPCO has applied to the DCPSC to construct two new 230 kV lines that would supply electricity to the Central D.C. area. In the same application, PEPCO has proposed building two new 69kV lines to supply the Blue Plains wastewater treatment plant. PEPCO proposes having the two 69 kV lines installed by the summer 2006 peak season, and the two 230 kV lines installed in 18 to 24 months. The two existing 230 kV lines that supply the Central D.C. area would need to be temporarily taken out of service sequentially in order to connect the new lines to the Central D.C. area. Once completed, these lines apparently would provide a high level of electric reliability in the Central D.C. area, even in the absence of production from the Plant.

IV. Discussion

A. Reliability Issues

The Department has conducted an independent analysis of the electricity reliability situation in the Central D.C. area and has analyzed the Plant's role in ensuring a sufficiently reliable supply of electricity to that area. DOE's analysis was conducted by the Department's Oak Ridge National Laboratory. Under North American Electric Reliability Council standards, at a minimum, the power system must carry at least enough contingency reserves of electricity to cover the most severe single contingency. The standards require that an area's system always be operated with sufficient reserves to compensate for the sudden failure of the area's most important single generator or transmission line.

⁵ For purposes of this order, the area supplied with electricity by these three sources will be referred to as the "Central D.C. area," and the retail customers in this area will be referred to as the "Central D.C. area customers."

Based on the fact that the Central D.C. area has only three sources of supply, the Plant and the two 230 kV transmission lines, the Department's analysis concludes that in order to maintain a minimally reliable electric power system, the Plant must be available to run when one of the 230 kV lines is out of service, because if the remaining line failed there would be no other source of electricity to serve the Central D.C. area load. In addition, the analysis concludes that if one of the 230 kV lines failed unexpectedly, enough generation must be started as rapidly as possible so as to be able to serve all of the Central D.C. area load as a contingency reserve in the event the other line were to fail. The analysis also indicates that the Plant should be operated in such a way as to minimize the amount of time needed to bring it into production.

PEPCO has asserted that:

Absent the generating capacity of the Plant, if the two 230 kV transmission circuits into the [Central D.C. area] fail, there will be a blackout in much of the District of Columbia until the circuits are repaired or the Plant's generators are restarted and can operate at a level that matches load. All electric customers in Georgetown, Foggy Bottom and major portions of downtown Washington will be affected. The affected customers will also include Blue Plains wastewater treatment plant. It is PEPCO's understanding that within 24 hours of the loss of electric supply, Blue Plains will have no option but to release untreated sewage directly into the Potomac River, which would result in a significant adverse impact to human health, aquatic wildlife and other environmental resources. Affected customers will also include numerous hospitals, schools, universities, commercial buildings, and residential customers. Importantly, numerous federal facilities will lose power, including those critical to the security, safety, and welfare of the whole country, such as the FBI, the Justice Department, the State Department, the Federal Emergency Management Agency, the Department of the Interior, and the Department of Energy to name but a few.⁶

No commenter has disputed these statements by PEPCO, and they have been generally corroborated by DOE's own independent analysis; therefore, DOE will accept them as correct statements of fact. Further, the 230 kV lines do go out of service on occasion; since 2000, there have been 34 one-line outages for maintenance, and seven occasions where one of the lines has tripped unexpectedly. DOE has been informed that, prior to 2000, there were two occasions when both of the lines failed simultaneously.

B. Environmental Issues

Some commenters have asserted that the renewed operation of the Plant would result in NAAQS exceedances and a violation of the Clean Air Act, and that DOE could not issue a 202(c) order which would contravene the Clean Air Act (42 U.S.C. §§ 7401-7626). In response to this assertion, DCPSC, PEPCO and PJM contend that there were no actual monitored

⁶ See Potomac Electric Power Company's Leave to Answer and Answer to Comments, FERC Docket No. EL05-145-000 at pages 2 & 3 (September 9, 2005).

exceedances of the NAAQS at the Plant during operation, and that operation of the plant at full power does not exceed the emissions limits contained in the Plant's operating permit and therefore the operation of the Plant pursuant to a DOE order would not violate the Clean Air Act. EPA has shared information with DOE regarding NAAQS modeled results and other environmental issues at the Plant. In response to the environmental concerns raised, this order seeks to minimize, to the extent reasonable, any adverse environmental impacts. Should EPA issue a compliance order directed to operation of the Plant, DOE will consider whether and how this order should conformed to such order.

Another assertion raised is that DOE cannot issue an order without complying with the National Environmental Policy Act (NEPA), 42 U.S.C. § 4321 *et seq.* Responders to that assertion stated that NEPA review requirements do not apply because any order would merely require the Plant to operate in the manner and at the level it has historically operated, and thus is not a "major federal action" triggering NEPA. In addition, responders assert that "...the emergency nature of the relief sought in this case permits the [the Secretary] to act without conducting a NEPA analysis, even if it were required."⁷ DOE has determined that the emergency circumstances here make it necessary to take action without performing a NEPA analysis. Indeed, in order for an order under FPA section 202(c) to be issued at all, the Secretary of Energy must determine that an emergency exists, and I have made that determination here. DOE has consulted with CEQ about alternative arrangements pursuant to 40 C.F.R. § 1506.11.

C. Other Issues

Commenters opposed to the issuance of a FPA section 202(c) order cited *Richmond Power & Light v. FERC*, 574 F. 2d 610 (D.C. Cir. 1978) as imposing a limit on the Secretary's authority to make an emergency finding under section 202(c). In *Richmond*, the New England Power Pool (NEPOOL) petitioned the Federal Power Commission (the Secretary's predecessor in exercising section 202(c) authority) for an order pursuant to FPA section 202(c) to have utilities east of the Mississippi River with excess electric generating capacity supply NEPOOL with that excess capacity. The request was based on fears of an oil shortage due to the 1973 Arab oil embargo. The Commission responded by holding a conference and a series of meetings which resulted in an agreement among the purchasing, transmitting and supplying utilities and participating state regulatory commissions. As a result of the agreement, NEPOOL moved to withdraw its petition, which the Commission allowed. Richmond Power & Light Company challenged the decision to allow the withdrawal and the court found that the Commission did not abuse its discretion in declining to issue an order under section 202(c), but rather settling on the temporary-voluntary agreement program reached by the interested parties. Instead of limiting its

⁷ District of Columbia Public Service Commission Answer to Motion of the Virginia Department of Environmental Quality at page 24 (October 26, 2005), FERC Docket No. EL05-145-000. *See also* Answer of Potomac Electric Power Company and PJM Interconnection, LLC at page 18, (October 13, 2005), FERC Docket No. EL01-145-000.

reach, *Richmond* underscores the discretionary nature of the Secretary's authority under section 202(c).⁸

Another case asserted to limit the Secretary's authority to issue an order under section 202(c) was *National Fuel Gas Supply v. FERC*, 909 F2d 1519 (D.C. Cir. 1990). In that case, National Fuel applied under section 7 of the Natural Gas Act (NGA), 15 U.S.C. § 717 *et seq.*, for a certificate of public convenience and necessity to allow it to make interruptible sales of natural gas. The Commission imposed a condition that National Fuel accept a blanket transportation certificate to provide open access transportation. The court ruled that the Commission was improperly using a NGA section 7 certificate condition in place of an individual or generic proceeding under section 5 of the NGA. The Department does not see the relevance of *National Fuel* here. I am using section 202(c) of the FPA for precisely the type of situation contemplated by section 202(c) of the FPA.

V. Decision

Section 202(c) of the FPA vests in the Secretary of Energy the authority to issue an order when "an emergency exists by reason of a sudden increase in the demand for electric energy, or a shortage of electric energy or of facilities for the generation or transmission of electric energy, or of the fuel or water for generating facilities, or other causes...." 16 U.S.C. § 824a(c). DOE's regulations acknowledge that "[e]xtended periods of insufficient power supply as a result of inadequate planning or the failure to construct necessary facilities can result in an emergency as contemplated by these regulations." 10 C.F.R. § 205.371.

I find that in the circumstances presented here, an emergency exists that justifies the issuance of a section 202(c) order. My determination is not based on any single factor, but on the combination of all relevant facts and circumstances. In particular, I find that an emergency exists because of the reasonable possibility an outage will occur that would cause a blackout, the number and importance of facilities and operations in our Nation's Capital that would be potentially affected by such a blackout, the extended number of hours of any blackout that might in fact occur, and the fact that the current situation violates applicable reliability standards.

⁸ The facts in *Richmond* and in the current situation are very different. *Richmond* dealt with a wide regional or even national energy shortage situation, while we are considering electricity reliability in a discrete geographic area. The facts here more closely resemble those considered by the Federal Power Commission in *City of Cleveland, Ohio v. Cleveland Electric Illuminating Company*, 47 FPC 747 (1972). In that case, the City of Cleveland petitioned the Commission pursuant to section 202(c) to order an interconnection with Cleveland Electric Illuminating Company to provide services during shortages caused by outages of the City of Cleveland's generating facilities, or delays getting generation on line. The Commission found that the City of Cleveland had an emergency due to periodic shortages of generating facilities caused by outages and ordered the establishment of a 69kV temporary emergency interconnection between the electric systems of the City and Cleveland Electric Illuminating. Similarly, here DOE is ordering the Plant to provide electricity in certain limited situations.

More specifically, if the Mirant plant is not available to generate electricity and one of the two transmission lines serving the Central D.C. area goes out of service, the Central D.C. area would be served by only one transmission line. Should that remaining line fail for any reason, a blackout would occur in the Central D.C. area, potentially for an extended period of time. In fact, if one or both of the transmission lines could not be brought back into service immediately and the only source of energy for the Central D.C. area was the Mirant Plant, in the absence of today's order it would take several hours at a minimum to bring the Plant into full operation.

The outage of one of these two lines is not merely a theoretical possibility. On Friday, December 16, 2005, PJM informed DOE that on the previous night, "one of the two circuits critical to providing service to the District tripped. Continued [electric] service to certain load within the District was at that time entirely dependent on the remaining circuit." As a result, PJM requested dispatch of a second generating unit at the Plant, but Mirant refused to do so. PJM informed DOE that "service was not interrupted because load was low and the remaining circuit performed without incident." Fortunately, full service to the line that had tripped was restored by the morning of December 16. Nonetheless, there can be no assurance that the Central D.C. area will be so lucky next time, either with respect to the timing of the event, the operation of the second transmission line, or the ability to bring the first transmission line back into service.

Furthermore, it is periodically necessary for an outage to occur on one of the transmission lines because of the need to perform maintenance. In fact, maintenance is scheduled on one of the lines in the next few weeks. Thus, as occurred on the night of December 15, 2005 and as will certainly occur again in the future, if the Mirant Plant is not made operational Central D.C. will find itself relying solely on one transmission line. The duration of an outage can range from up to several days (for maintenance) or even longer (up to weeks) if the outage of a line is due to a major equipment failure. Throughout such a period, if the Plant is not fully operational a blackout in Central D.C. is only one step away, i.e., if an event should occur that causes the second line to fail. Such a blackout could last for hours or days.

I recognize that, if past experience is any guide, the simultaneous failure or outage of both transmission lines serving the Central D.C. area is not a high probability. While this event has occurred in the past, it has not happened often. Moreover, the recent tripping of one circuit does not in itself dictate the existence of an emergency justifying issuance of a 202(c) order.

The facilities and functions that would be adversely affected by an extended blackout in this instance, however, is an important consideration. The Central D.C. area includes offices, facilities and operations involved in all three branches of government, and that are critically important to the Nation's national security, law enforcement and regulatory functions. The Central D.C. area also includes hundreds of thousands of residents and workers, and all manner of public safety and protection facilities, including hospitals, police, and fire facilities. Moreover, DOE has been informed that within 24 hours of a blackout in the Central D.C. area, untreated sewage from the Blue Plains Wastewater Treatment plant would be discharged into the Potomac River.

Finally, it is noteworthy that a blackout in the Central D.C. area not only would affect critically important facilities and operations, it could last for an extended period. Depending on the reason for the outage of the transmission lines, the lack of service on those lines accompanied by the lack of generation by the Plant could result in a large portion of the District of Columbia being without electricity for a period that could last hours or days. At the very least, if the two transmission lines were made unavailable with no advance notice and the only source of electricity for the Central D.C. area was the Mirant plant, in the absence of today's order DOE understands it would take at least 28 hours, and likely longer, to bring the Plant into full operation, during which time all or a substantial part of the Central D.C. area would be without electric power. The results would be hardship and physical risk to hundreds of thousands of persons from loss of heat, elevator outages, medical equipment failure and numerous other causes. In addition, critical portions of the nation's government would also be severely impacted, with resulting adverse effects on a national scale.

Of course, the fact that the Department did not act immediately on the DCPSC petition does not argue against my finding that an emergency currently exists. After the petition was filed, DOE took several weeks to gather the relevant information, consider the facts, talk with environmental regulatory authorities, and develop an order that balanced the appropriate considerations. As explained in the text of this order, the current facts fully justify my finding that an emergency exists and that this order will meet that emergency. There certainly is nothing in the Federal Power Act that requires me to wait until a blackout actually has occurred, lives are put in jeopardy, and a significant disruption of National government functions already has happened before exercising my section 202(c) authority.

Accordingly, and based on all of the facts and circumstances, I find that an emergency exists justifying the issuance of this order under Federal Power Act section 202(c).

After finding the existence of an emergency, DOE has the authority, "either upon its own motion or upon complaint, with or without notice, hearing, or report, to order such temporary connections of facilities and such generation, delivery, interchange, or transmission of electric energy as in its judgment will best meet the emergency and serve the public interest." 16 U.S.C. § 824a(c). The statute gives the Secretary of Energy broad discretion to fashion the terms of an order that will, in the Secretary's judgment, "best meet the emergency and serve the public interest." Based on the circumstances described above in this order, I hereby direct Mirant to generate electricity at the Plant pursuant to the terms of this order.

While I am issuing this order to help ensure a reliable supply of electric energy to the Central D.C. area, I am cognizant of the concerns that have been expressed concerning the potential adverse environmental consequences of operating the Plant, and of the national interest in attainment of the NAAQS that have been established under the Clean Air Act. Ordering action that may result in even local exceedances of the NAAQS is not a step to be taken lightly. However, it would not be reasonable for the Department of Energy to stand by and take no positive action on the DCPSC petition, even though the Central D.C. area is in danger of an extended blackout and the Department and private parties have available to them the legal and operational tools to prevent such a blackout from occurring. In this order, I have sought to harmonize those interests to the extent reasonable and feasible by ordering Mirant to operate in a

manner that provides reasonable electric reliability, but that also minimizes any adverse environmental consequences from operation of the Plant.

DOE expects that the DCPSC, having sought an emergency order, will take such actions as are within its authority to provide adequate and reliable electric service for the Central D.C. area including, for example, expediting approval of PEPCO transmission system upgrades and instituting demand response programs.⁹ Indeed, DOE views this order not as a permanent solution to the Central D.C. area's reliability issues, but rather as a bridge between the current untenable situation and a more permanent solution that must be crafted by appropriate parties, including the DCPCS, FERC, environmental regulatory authorities, and relevant private sector parties. This permanent solution may include the installation of the new transmission lines discussed above, the installation of new pollution control equipment at the Mirant Plant, or other means.

As explained above, in the event that one of the two transmission lines that serve the Central D.C. area is out of service (due either to a necessary planned outage or to unforeseen events) and sufficient electricity from the Mirant power plant were not available, then the Central D.C. area would experience an immediate blackout should the one remaining source of electricity fail. This situation must be avoided, and ordering paragraph A of this order ensures that this situation will be avoided. When an outage is planned, Mirant is to be given advance notice and is required to supply necessary generation throughout the period of the outage.¹⁰ In the event of an unexpected outage, Mirant must provide such generation as soon as possible. In the very unlikely eventuality of both transmission lines failing at the same time, Mirant is required to provide sufficient generation to supply the electrical demands of the affected area as soon as possible.

It is essential to determine the level of operation and other steps that will enable Mirant to rapidly respond to an unplanned transmission line outage. Some commenters have urged the Department to order the Plant to run continuously, even if doing so causes ongoing exceedances of the NAAQS. This would assure a high level of reliability of the electricity supply, but of course would not be tailored to particular circumstances in which operation of the Plant would be most necessary to provide needed reliability for the Central D.C. area and might also cause local air quality concerns. Other commenters have urged the Department to do nothing.

⁹ Demand response programs prompt electricity customers to reduce demand, especially during periods of short supply.

¹⁰ In making certain portions of this order effective only upon notice to Mirant by PEPCO of a planned or unplanned outage of one or both of the 230 kV lines, it is similar to the FPA section 202(c) orders issued during the 2000/2001 California energy crisis. In those, DOE ordered certain entities to generate, deliver, interchange and transmit electricity to the California Independent System Operator (California ISO), but the entities were not required to deliver energy or services unless the California ISO had filed with DOE a certificate that it had been unable to acquire adequate supplies of electricity in the market. See Order pursuant to Section 202(c) of the Federal Power Act (December 14, 2000); Order Pursuant to Section 202(c) of the Federal Power Act (January 11, 2001).

The Department is not prepared to order actions that could cause more localized NAAQS exceedances than are necessary in order to assure adequate electric reliability for the Central D.C. area. At the same time, the Department should address the risks that delays in responding to an unplanned transmission line outage would present if measures are available to mitigate that risk. In my judgment, the appropriate balance is struck by (1) requiring Mirant to keep as many units in operation, and take all other measures to reduce the start-up time of units not in operation, for the purpose of providing electrical reliability, as feasible (as further defined in the ordering paragraphs below). Thus, Mirant must take actions to reduce the time it takes to respond to an unplanned outage. This will serve to reduce the risk of a blackout but not at the price of unnecessary exceedances of health-based NAAQS. As Mirant improves its environmental performance, in cooperation with environmental regulators, its ability to react to an unforeseen outage also will improve. Environmental regulators and Mirant can work together, with the Department, to reduce, and perhaps eliminate, any conflict between environmental goals and electric reliability.

This order is effective immediately and will terminate at 12:01 a.m. October 1, 2006. This order may be modified or extended at any time upon order of the Secretary of Energy.

VI. Ordering Paragraphs

For the reasons set forth above, pursuant to section 202(c) of the Federal Power Act, it is hereby ordered that:

A. During any period in which one or both of the 230kV lines serving the Central D.C. area is out of service, whether planned or unplanned, Mirant will operate the Potomac River Generating Plant to produce the amount of power (up to its full capacity) needed to meet demand in the Central D.C. area as specified by PJM for the duration of the outage.

In the event of a planned outage, Potomac River units will generate that amount of electricity specified by PJM to meet demand.

In the event of an unplanned 230 kV line outage, Potomac River units will generate that amount of electricity specified by PJM to meet demand as soon as possible.

When producing electricity pursuant to this paragraph, Mirant shall utilize pollution control equipment and measures to the maximum extent possible to minimize the magnitude and duration of any exceedance of the NAAQS.

B. Mirant shall keep as many units in operation, and shall take all other measures to reduce the start-up time of units not in operation, for the purpose of providing electricity reliability, as “feasible.” For purposes of this paragraph, “feasible” means as determined by the Department of Energy, after consideration of the plan submitted by Mirant pursuant to paragraph D of this order and after consultation with the Environmental Protection Agency, without regard to cost and without causing or significantly contributing to any exceedance of the NAAQS.

C. Notice

In instances of scheduled outages of one of the 230kV lines, PEPCO will give advance notice of the planned outage and the estimated duration of such outage to Mirant, PJM, DOE, FERC, EPA, and DEQ. The notice must be sufficiently in advance of the outage to allow Mirant to bring the required amount of generation needed for reliability purposes on line by the time the outage is scheduled. PEPCO will ensure that only those planned outages needed to maintain or enhance the reliability of the 230 kV lines (or to install new lines) are scheduled and that such outages are scheduled to minimize the environmental effects of the operation of the Plant.

PEPCO will notify DOE, PJM, FERC, EPA, and DEQ of any unplanned outage of one or both of the 230 kV lines as soon as possible, but in no event later than two hours after informing Mirant.

In the event of either a planned or unplanned outage, PJM will specify the amount of electricity that Mirant must provide in order to meet demand.

D. Mirant shall submit a plan to DOE, within 10 days of the date of this order, detailing the steps it will take to ensure compliance with this order. This compliance plan shall include, at minimum, information regarding adequate staffing, materials, and supplies; emissions controls; and length of time necessary to start-up the Plant's generating units in the event of an unplanned or planned outage. DOE will review the compliance plan and order additional requirements if necessary.

E. Pursuant to the terms of FPA section 202(c) and DOE regulations at 10 C.F.R. § 205.376, Mirant and its customers should agree to mutually satisfactory terms for any costs incurred by Mirant under this order. If no agreement can be reached, just and reasonable terms shall be established by a supplemental order.

F. DOE expects that the DCPSC will take all reasonable actions to augment electrical reliability and to reduce electricity demand in the Central D.C. area.

G. DOE will periodically reexamine the need for this order with particular emphasis on: (1) Mirant's progress, working with environmental regulators, in reducing emissions and/or the impact of emissions; and (2) whether the DCPSC is taking all reasonable actions available to it to support electricity reliability in the Central D.C. area.

H. Pursuant to section 313 of the Federal Power Act (16 U.S.C. § 8251), any person, State, municipality, or State commission that is a party to this proceeding and is aggrieved by this order may apply for a rehearing within thirty days. Requests for rehearing may be submitted by mail, facsimile, or electronic mail to the following: (1) mail should be directed to Lawrence Mansueti of the Permitting, Siting, and Analysis Division of the Office of Electricity Delivery and Energy Reliability at the United States Department of Energy, Routing Symbol OE-20, 1000

Independence Avenue, S.W., Washington, D.C. 20585; (2) facsimiles may be submitted to 202-586-5860; (3) e-mail may be submitted to Lawrence.Mansueti@hq.doe.gov.

Issued in Washington, D.C. at _____ this 20th day of December, 2005.

Samuel W. Bodman
Secretary of Energy



Department of Energy

Washington, DC 20585

District of Columbia Public Service Commission

Docket No. EO-05-01

Order No. 202-06-2

On December 20, 2005, in Order No. 202-05-3, I determined that an emergency existed in the Central District of Columbia area due to a shortage of electric energy, a shortage of facilities for the generation of electric energy, a shortage of facilities for the transmission of electric energy and other causes, and that issuance of the order would serve to alleviate the emergency and serve the public interest. Therefore, pursuant to the authority vested in the Secretary of Energy by section 202(c) of the Federal Power Act (FPA), 16 U.S.C. 824a(c), and section 301(b) of the Department of Energy (DOE) Organization Act, 42 U.S.C. 7151(b), and for the reasons set forth in Order No. 202-05-3, I ordered Mirant Corporation and its wholly owned subsidiary, Mirant Potomac River, LLC, to generate electricity at its Potomac River Generating Station (the Plant) pursuant to the terms of the order.

In Order No. 202-05-3, I noted that the Plant is one of only three sources of electricity that serve the central business district of Washington, D.C., many federal institutions, and the Georgetown area, as well as other portions of Northwest D.C., and the District of Columbia Water and Sewer Authority's Blue Plains Advanced Wastewater Treatment Plant. The order further noted that:

PEPCO has applied to the [District of Columbia Public Service Commission] to construct two new 230 kV lines that would supply electricity to the Central D.C. area. In the same application, PEPCO has proposed building two new 69kV lines to supply the Blue Plains wastewater treatment plant. PEPCO proposes having the two 69 kV lines installed by the summer 2006 peak season, and the two 230 kV lines installed in 18 to 24 months. The two existing 230 kV lines that supply the Central D.C. area would need to be temporarily taken out of service sequentially in order to connect the new lines to the Central D.C. area. Once completed, these lines apparently would provide a high level of electric reliability in the Central D.C. area, even in the absence of production from the Plant.

The two 69 kV lines to the Blue Plains wastewater treatment plant have been completed. The two new 230 kV lines have been approved by the relevant regulatory authorities and are scheduled to be completed and in operation by mid-summer 2007.



On January 18, 2006, DOE issued a notice of the emergency order (published in the Federal Register on January 20, 2006, 71 FR 3279) in which DOE stated that it would prepare a Special Environmental Analysis (SEA) pursuant to the Council on Environmental Quality's Regulations Implementing the Procedural Requirements of the National Environmental Policy Act. The SEA would examine the potential impacts of the operation of the Plant pursuant to Order No. 202-05-3. DOE said it would make the SEA publicly available and would consider information contained in the SEA, and public comments on the SEA, in any future decision making regarding the operation of the Plant. The SEA has not yet been issued, but DOE expects it to be completed shortly.

Because the reliability problems identified in Order No. 202-05-3 continue in the absence of the completion of the two new 230 kV lines, but the SEA has not been completed, I am issuing a short-term extension of the emergency order pending completion and consideration of the SEA and DOE's review of comments thereon.

The Department reiterates its expectation that the DC Public Service Commission pursue demand response initiatives and actively promote conservation as additional means of enhancing reliability in the central D.C. area.

On February 17, 2006, I issued Order No. 202-06-1, which granted certain requests for rehearing of Order No. 202-05-3 for the limited purpose of further consideration. The rehearing requests continue under consideration and no action is being taken on those requests by the issuance of this order.

Based on the above, I find that the circumstances which led to my previous determination that an emergency existed still continue, and therefore I hereby extend Order No. 202-05-3 and all the terms and conditions thereof until 12:01 a.m., December 1, 2006.

Issued in Washington D.C. at 6:00 PM this 28 day of September, 2006.


Samuel W. Bodman
Secretary of Energy

APPENDIX B

EPA's Administrative Compliance Order for the Mirant Potomac River Generation Station

[This page intentionally left blank]

**UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION III
1650 Arch Street
Philadelphia, Pennsylvania 19103-2029**

In the Matter of:

Mirant Potomac River LLC
Potomac River Generating Station
Alexandria, Virginia

Docket No. CAA-03-2006-0163DA

**ADMINISTRATIVE COMPLIANCE ORDER
BY CONSENT**

I. STATUTORY AUTHORITY

This Order is issued pursuant to Section 113(a)(1) of the Clean Air Act (the "Act"), 42 U.S.C. § 7413(a)(1). Under Section 113(a)(1) of the Act, the Administrator of the United States Environmental Protection Agency ("EPA" or "the Agency") has the authority to issue Orders requiring persons to comply with the requirements of an applicable State Implementation Plan ("SIP") or permit issued by a state. The Administrator has delegated his authority to issue such Orders within the geographical jurisdiction of EPA Region III to the Regional Administrator of EPA Region III, who has re-delegated this authority to the Director of the Air Protection Division of Region III. The geographical jurisdiction of EPA Region III includes the Commonwealth of Virginia.

This Order is issued to Mirant Potomac River, LLC ("Mirant") for its Potomac River Generating Station in Alexandria, Virginia.

II. FINDINGS OF FACT

1. Mirant owns and operates an electricity generating station known as the Potomac River Generating Station ("PRGS") in Alexandria, Virginia.
2. Mirant is a Limited Liability Company organized in the State of Delaware on August 2, 2000.
3. Pursuant to the Order By Consent entered into by Mirant and the Virginia Department of Environmental Quality ("VaDEQ"), effective September 23, 2004, Mirant performed a

Dispersion Modeling Analysis to assess the effect of Downwash (the "downwash study") of emissions from the PRGS. The downwash study used computer modeling to predict ambient concentrations of pollutants emitted by the PRGS under certain weather and atmospheric conditions.

4. Mirant provided the results of the downwash study to VaDEQ in August 2005. By letter dated August 19, 2005, VaDEQ informed Mirant that the downwash study demonstrated that emissions from the PRGS result in, cause or substantially contribute to, modeled violations of the primary National Ambient Air Quality Standards ("NAAQS") for sulfur dioxide ("SO₂"), nitrogen dioxide ("NO₂"), and PM₁₀ under certain atmospheric conditions.
5. VaDEQ's August 19th letter also requested that Mirant immediately undertake "such action as is necessary to ensure protection of human health and the environment, in the area surrounding the Potomac River Generating Station." VaDEQ cited 9 VAC 5-20-180(I) as the authority for this action.
6. The provision of the Virginia State Implementation Plan ("SIP") cited by VaDEQ, 9 VAC 5-20-180(I), has been approved and incorporated into the Virginia SIP at 40 C.F.R. § 52.2420(c), and is therefore federally-enforceable.
7. Mirant shut down all five Units of the PRGS at midnight on August 24, 2005.
8. On August 24, 2005, the District of Columbia Public Service Commission ("DCPSC") filed an "Emergency Petition and Complaint" with the United States Department of Energy ("DOE") and the Federal Energy Regulatory Commission ("FERC"), respectively, pursuant to the Federal Power Act ("FPA"), 16 U.S.C. § 824a(c), 824f and 825h, and Section 301(b) of the DOE Organization Act, 42 U.S.C. § 7151(b). The Emergency Petition requested that DOE find that an emergency exists under Section 202(c) of the FPA and issue an order requiring Mirant to continue operation of the PRGS.
9. Following additional modeling and assessment of the downwash study, Mirant re-started Unit 1 of the PRGS on September 21, 2005. Additional modeling conducted by Mirant indicated that operation of only Unit 1 would not cause any modeled NAAQS exceedances.
10. On December 20th, 2005, the Secretary of Energy issued Order No. 202-05-3 ("DOE Order") finding that an emergency did exist and ordering Mirant to, among other things, submit a plan to DOE detailing the steps to be taken to ensure Mirant's compliance with the DOE Order.
11. On December 30, 2005, Mirant submitted to DOE the Operating Plan setting forth the steps that Mirant would take to ensure compliance with the DOE Order.

12. By letter dated January 4, 2006, DOE required that Mirant "immediately take the necessary steps to implement Option A of the intermediate phase proposed in the [Operating Plan]." The DOE letter also noted that implementation of Option A was an interim measure.
13. In accordance with DOE's directive to maximize electric generation while not causing or contributing to a NAAQS violation, Mirant supplemented the original Operating Plan with additional operating configurations and modeling. The supplements contemplated that Mirant would use trona injection and a blend of low sulfur coal to manage SO₂ emissions. Mirant stated that these supplemental operating scenarios result in no modeled NAAQS exceedances.
14. By letter dated December 22, 2005, EPA issued a Notice to Mirant and the VaDEQ, alleging that Mirant did not immediately undertake the necessary action to protect human health and the environment required by VaDEQ's August 19, 2005 letter, and that Mirant was therefore in violation of 9 VAC 5-20-180(I) and the federally-enforceable Virginia SIP for the period of time in which it failed to immediately shut down all the PRGS Units.
15. Following issuance of the Notice, EPA met with Mirant on several occasions to discuss settlement of EPA's possible enforcement action for the violation alleged in the Notice under Section 113 of the CAA. These discussions, along with discussions with DOE and VaDEQ, have resulted in this Order.
16. In its evaluation of potential PRGS operating scenarios, DOE has determined that the levels of PRGS operation allowed under the terms and conditions of Part IV of this Order are necessary to assure an acceptable level of electric reliability to the District of Columbia under the circumstances.
17. EPA will require use of the AERMOD model with a 24 hour background SO₂ concentration of 51 micrograms per cubic meter ("ug/m³") when evaluating the PRGS's effects on the SO₂ NAAQS. In Mirant's December 30, 2005 Operating Plan and subsequent submissions to DOE and EPA, Mirant has used varying background concentrations for SO₂ in determining the maximum predicted impact of various operating scenarios at the PRGS. EPA has determined that Mirant's use of these varying background concentrations was technically defensible but that additional conservatism will be required in this Order. In an effort to build additional conservatism into Mirant's operating scenarios to ensure protection of the NAAQS, EPA has instructed Mirant to use a background concentration of 51 ug/m³ to add to the AERMOD 24 hour SO₂ modeled pollutant concentrations to determine the maximum predicted impacts for all operational scenarios considered during and incorporated into this Order.
18. EPA has determined through modeling and analysis that there is a strong correlation between the days, hours, and locations of predicted highest 24-hour concentrations of

SO₂ and predicted highest 24-hour concentrations of PM₁₀; that the predicted highest concentrations of SO₂ are higher, relative to the SO₂ NAAQS, than the predicted highest concentrations of PM₁₀ relative to the PM₁₀ NAAQS; and that measures taken to reduce SO₂ emissions from the PRGS facility, such as reduced levels of operation and/or increased levels of trona usage, will also reduce emissions of PM₁₀.

III. CONCLUSIONS OF LAW

19. Mirant is a "person" within the meaning of Section 302(e) of the CAA, 42 U.S.C. § 7602(e), and within the meaning of Section 113(a) of the CAA, 42 U.S.C. § 7413(a), because it is a corporation.
20. EPA concludes that Mirant violated 9 VAC 5-20-180(I) by failing to immediately shut down the boilers at the PRGS upon receipt of the letter from VaDEQ, and that such failure is also a violation of Section 113(a) of the CAA, 42 U.S.C. § 7413(a).
21. Mirant has had an opportunity to confer with the Administrator or his designee regarding this alleged violation and the terms of this Order. Mirant denies that any violation occurred, but agrees to the entry of this Order.
22. EPA has determined that the following schedule and plan for compliance is reasonable, taking into account the seriousness of the modeled NAAQS exceedances and the concerns of DOE regarding electric reliability in the Central D.C. area, and that this schedule is expeditious given the length of time it will take Mirant to take more permanent measures as well as the time it will take for additional electric transmission lines to be put into service to alleviate the emergency as determined by DOE.

IV. ORDER

Based upon the forgoing, under Section 113(a)(4) of the Act, 42 U.S.C. § 7413(a)(4), IT IS DETERMINED AND ORDERED that:

A. Definitions - For the purpose of this Order, the following terms shall have the meanings defined below:

3-Hour Rolling SO₂ and 24-Hour Calendar Day SO₂ Emission Rate.

For the purpose of calculating the specified rate in Table 1 for a specified time period, the actual SO₂ emission rate is determined by dividing the sum of the total pounds of actual SO₂ emissions from the boiler stack of that unit, as determined by hourly CEMS data, as certified by 40 CFR Part 75, by the sum of the total heat input in million Btus from that coal-fired boiler unit.

For any 3 hour rolling period when there are fewer than 2 hours of actual emissions from a coal-fired boiler unit, an emission rate for that 3 hour period that would have to comply with the Table 1 emission rates does not need to be calculated for that unit.

For any calendar day when there are fewer than 3 hours of actual emissions from a coal-fired boiler unit, a 24 hour emission rate to comply with Table 1 need not be calculated for that unit.

On any day when a unit runs between 3 and 18 hours, the complying 24 hour emissions rate for Table 1 shall be calculated as follows:

If a unit operates between 3 hours and 10 hours, the SO₂ limit for that unit equals the 3 hour rate in Table 1 minus 1/3 of the difference between the 3 hr and 24 hr rate for that unit configuration;

If a unit operates 10 hours or more up to 18 hours, the SO₂ limit for that unit equals the 3 hour rate in Table 1 minus 2/3 of the difference between the 3 hr and 24 hr rate for that unit configuration.

If a unit operates 18 hours or more, the 24 hour rate in Table 1 shall apply.

Nothing in this paragraph is intended to allow greater operation of a unit than what is specified in Table 1 where this Order requires operation in accordance with Table 1. In addition, where this Order requires operation in accordance with Table 1 and that configuration calls for unit(s) to operate between 3 and 18 hours, then the Table 1 emission rates shall apply without the above adjustments.

AERMOD Default means Version 04300 of the AERMOD computer model, currently approved for general use by EPA.

AERMOD EBD means the AERMOD computer model with modified direction-specific building dimensions derived from the Wind Tunnel Study.

Alternative Operating Scenario means a method of operating the Potomac River Generating Station during the Model Evaluation Study, which has been approved by EPA and reviewed by VaDEQ.

DOE means the United States Department of Energy

DOE Order means Order No. 202-05-3, issued by the Department of Energy on December 20, 2005 in Docket No. EO-05-01 in response to an Emergency Petition and Complaint filed by the District of Columbia Public Service Commission.

EPA means the United States Environmental Protection Agency, Region III.

Line Outage Situation means that one or both 230 kV transmission lines, serving the Central D.C. area are out of service due to a planned or unplanned outage.

Mirant means Mirant Potomac River, LLC.

Modeled NAAQS Exceedance means a modeled 3-hour average sulfur dioxide concentration which, when a background concentration of 238.4 micrograms per cubic meter is added, exceeds 1,300 micrograms per cubic meter; or a modeled 24-hour average sulfur dioxide concentration which, when a background concentration of 51 micrograms per cubic meter is added, exceeds 365 micrograms per cubic meter; or, a modeled 24 hour PM10 concentration which, when a background concentration of 45 micrograms per cubic meter is added, exceeds 150 micrograms per cubic meter.

Model Evaluation Study or MES means a study proposed by Mirant and approved by EPA and reviewed by VaDEQ to compare multiple computer model predicted ambient air impacts to actual measured ambient air concentrations for the purpose of determining the best performing computer model in evaluating the effects of the emissions resulting from the operation of the PRGS.

Monitoring Plan means a plan proposed by Mirant and approved by EPA and reviewed by VaDEQ as part of the MES for the installation and use of ambient air monitors in the vicinity of the PRGS to monitor ambient air quality impacts of the PRGS.

Monitors means the ambient air monitors installed in accordance with the Monitoring Plan.

NAAQS means the National Ambient Air Quality Standards.

Non-Line Outage Situation means all periods of time that do not qualify as a Line Outage Situation.

Operating Parameters means the hourly average MW load of each unit for each hour of that day at the PRGS, the hourly average SO2 emission rate expressed in lb/MMBtu for each unit for each hour of that day, and the emission rate of PM10 expressed in lb/MMBtu.

Operating Plan means the December 30, 2005 Operating Plan submitted to DOE by Mirant to respond to the requirement for a compliance plan under the DOE Order.

Predictive Modeling means the daily use of an approved AERMOD computer model run in accordance with 40 C.F.R. Part 51, Appendix W, with forecasted weather conditions and planned Operating Parameters for the following day to predict modeled NAAQS compliance on a day-ahead basis.

PJM means the regional transmission organization for the region where the PRGS is located.

PRGS means the coal-fired electric generating station owned by Mirant and located in Alexandria, VA, comprised of three baseload generating units (Units 3, 4, 5) of approximately 102 MW each and two cycling units (Units 1 and 2) of approximately 88 MW each.

VaDEQ means the Virginia Department of Environmental Quality.

Wind Tunnel Study means a study proposed by Mirant using a physical model, as outlined in CPP Wind's Wind Tunnel Model Evaluation protocol, dated January 17, 2006, reviewed by EPA and VaDEQ, and conducted in accordance with EPA Guidance, to evaluate the accuracy of AERMOD Default's assumptions with respect to the direction-specific effective building dimensions when applied to the PRGS.

B. Operation During Non-Line Outage Situations

1. Mirant shall implement and comply with all of the single-unit, two-unit, and three-unit configuration constraints listed in Table 1 below until such time as Mirant is authorized by EPA and DOE to begin an alternative operating scenario as described below. Mirant shall operate each unit within the applicable hours-of-operation and SO₂ emission rate restrictions listed in the table each calendar day. Generally, unit transitions and unit startups will occur within (+/-) four hours of midnight. The following procedures will be followed when there is a transition between operating scenarios:

a. When transitioning between two units, the unit that is coming offline will cease burning coal before the starting unit begins burning coal. Number 2 oil will be burned during the warm-up phase of the starting unit and during the shutdown phase of the unit coming offline. The number of boilers burning coal will not exceed at any time the constraints applicable to the Unit Configurations listed in Table 1.

b. When a change in operating Unit Configuration occurs, Mirant shall, for the balance of the calendar day, meet the more stringent of the 3-hour SO₂ and/or 24-hour SO₂ rate caps and hours of operation applicable to:

- (i.) the Unit Configuration being ceased, and
- (ii.) the Unit Configuration being commenced.

TABLE 1

Unit Configuration	24 Hr Calendar Day SO₂ Rate - lb/MBtu	3-Hr Rolling SO₂ Rate - lb/MBtu	Operating Constraints
Unit 1	1.20	1.20	8 hrs max / 8 min / 8 off, 14,800 lb/day
Unit 1	0.84	1.14	None
Unit 2	0.41	0.73	None
Unit 3	0.31	0.66	None
Unit 4	0.36	0.70	None
Unit 5	0.61	0.90	None
Units 1 & 2	0.29	0.50	Both Units: 100% Load 24 hrs/day
Units 1 & 3	0.24	0.51	#1 @ 8 max / 8 min / 8 off, none on #3
Units 2 & 3	0.23	0.40	#2 @ 8 max / 8 min / 8 off, none on #3
Units 1 & 4	0.30	0.54	#1 @ 8 max / 8 min / 8 off, none on #4
Units 2 & 4	0.25	0.44	#2 @ 8 max / 8 min / 8 off, none on #4
Units 1 & 5	0.43	0.60	#1 @ 8 max / 8 min / 8 off, none on #5
Units 2 & 5	0.35	0.55	#2 @ 8 max / 8 min / 8 off, none on #5
Units 3 & 4	0.23	0.43	#3 @ 6 max / 18 min; #4 @ 7 max / 17 min
Units 3 & 5	0.24	0.43	Both units @ 12 hr max / 12 hr min
Units 4 & 5	0.27	0.51	Both units @ 12 hr max / 12 hr min
Units 1, 2 & 3	0.21	0.36	#1&2 @ 5 max / 4 min / 15 off, none on #3
Units 1, 2, & 4	0.24	0.35	#1&2 @ 6 max / 5 min / 13 off, none on #4
Units 1, 2, & 5	0.27	0.42	#1&2 @ 8 max / 8 min / 8 off, none on #5

2. Schedule for Installation of Trona Injection at All Boiler Units

a. In accordance with the schedule set forth in Mirant's Operating Plan of December 30, 2005, Mirant shall ensure that Trona injection units are installed and operated as follows:

(1). March 20, 2006 - In addition to the two portable, rental Trona units, Mirant shall have a third operational Trona injection unit, whether an engineered unit or a rental unit. Mirant shall operate all three Trona units whenever three or more boilers are operating.

(2). April 28, 2006 - Mirant shall have installed and be operating three engineered Trona injection units, and shall operate each unit whenever the boiler to which it is attached is operating. Mirant shall operate the rental Trona units on boilers not equipped with operating engineered units.

(3). May 31, 2006 - Mirant shall have installed and be operating

all five engineered Trona injection units, and shall operate each unit whenever the boiler to which it is attached is operating.

3. Model Evaluation Study

a. Mirant shall undertake a Model Evaluation Study to determine the best performing model for predicting the computer-modeled ambient air quality impacts from the PRGS's operations. Prior to beginning the MES, Mirant must submit to EPA for approval an MES protocol, and simultaneously send a copy to VaDEQ. Mirant may begin operating the PRGS in a manner that does not cause or contribute to Modeled NAAQS Exceedances by using Predictive Modeling as described in subsection 4 below, after completing the following tasks:

- (1). EPA approval of the MES protocol;
- (2). installation and operation of at least 3 SO₂ monitors in accordance with the approved monitoring plan;
- (3). execution of this Order by EPA; and
- (4). authorization by DOE for Mirant to operate in accordance with this Order.

b. Upon commencement of daily predictive modeling performed in conjunction with the MES, the SO₂ emission rate limitations and other unit operating restrictions set forth in Table 1 shall no longer apply unless otherwise indicated. The Table 1 restrictions apply if Mirant ceases to operate the PRGS in accordance with the MES.

4. Operations in Accordance with Daily Predictive Modeling

a. By 10 AM each morning, Mirant shall collect actual weather predictions from the National Weather Service for the Reagan National Airport and use them along with planned Operating Parameters as inputs to conduct a computer modeling run for the following day using AERMOD Default. If the modeling confirms that Mirant's planned operations for the following day will not cause or contribute to a Modeled NAAQS Exceedance, Mirant may operate on the day modeled in accordance with the modeled Operating Parameters. If the Predictive Modeling indicates that the planned Operating Parameters will result in one or more Modeled NAAQS Exceedances, Mirant shall not run under those operating parameters but shall continue to adjust its planned operations and conduct additional modeling runs using the adjusted Operating Parameters to confirm that the adjusted operations will not cause or contribute to a Modeled NAAQS Exceedance for the day modeled.

b. During Line Outage Situations, Predictive Modeling must continue to be performed but the PRGS shall be operated under the Line Outage Situation provision in accordance with the DOE Order and this Order.

c. If the Predictive Modeling indicates that the predicted weather conditions and planned Operating Parameters do not result in a Modeled NAAQS Exceedance,

Mirant is authorized to operate using the planned Operating Parameters and shall not be in violation of this Order; or 9 VAC 5-20-180(I), as incorporated into the Virginia SIP at 40 C.F.R. 52.2420(c); nor shall such operation be deemed to give a right for a cause of action for any alleged violation of the NAAQS as a result of Mirant causing or contributing to any modeled or monitored exceedance of the NAAQS. This release shall only apply to alleged exceedances or violations occurring during the lifetime of the Order or the duration of the MES if the requirements of this Order have been incorporated into a state operating permit; shall only apply to laws in existence on the effective date of the Order; and shall not prevent Virginia from issuing an order under 9 VAC 5-20-180(I) or EPA from taking action under Section 303 of the Clean Air Act.

5. Operation During Certain Periods of Elevated SO₂ Impacts After MES

Approval

a. As a precaution, after the installation of at least three monitors, Mirant shall institute additional measures that will apply whenever ambient concentrations of SO₂ are elevated, as defined below. Specifically, Mirant shall:

(1). Install a monitor alert system in the Potomac River Control Room that registers an audible alarm if in any one hour the average measured ambient concentration of SO₂ at any monitor is equal to or greater than 80% of the 3 hour SO₂ National Ambient Air Quality Standard, measured as 400 parts per billion (1,040 $\mu\text{g}/\text{m}^3$).

(a). During the hour following the sounding of the alarm, Mirant shall make operational adjustments, which may include increasing Trona injection and/or decreasing operation and shall observe the effect of these adjustments on the average, measured ambient concentration of SO₂.

(b). If, at the end of the second hour, the average measured ambient concentration of SO₂ is not equal to or less than 1,040 $\mu\text{g}/\text{m}^3$, Mirant shall adjust its operations to conform to the scenarios described in Table 1 until the rolling 3 hour average is less than 1,040 $\mu\text{g}/\text{m}^3$.

(2). Mirant shall also configure the audible alarm to sound if, in any 12 hour period, any monitor measures an average, ambient concentration of SO₂ equal to or greater than 80% of the 24 hour SO₂ National Ambient Air Quality Standard, measured as 112 parts per billion (292 $\mu\text{g}/\text{m}^3$).

(a). During the following 6 hours, Mirant shall make operational adjustments, which may include increasing Trona injection and/or decreasing operation and shall observe the effect of these adjustments on the measured ambient concentration of SO₂.

(b). If, at the end of the 6 hour period, the average, measured ambient concentration of SO₂ is not equal to or less than 292 $\mu\text{g}/\text{m}^3$, Mirant shall adjust its operations to conform to the scenarios described in Table 1 for the balance of the calendar day.

(3). Mirant shall also configure the audible alarm to sound if, after the first 6 months of operation, any monitor measures an average, ambient concentration of SO₂ equal to or greater than 80% of the annual average NAAQS, measured as 64 µg/m³.

(a). During the following 3 months, Mirant shall monitor the 7 month, 8 month and 9 month averages.

(b). If, at the end of 9 months, the average, measured ambient concentration of SO₂ is not equal to or less than 64 µg/m³, Mirant shall adjust its operations so that the annual, measured ambient concentration of SO₂ does not exceed 80 µg/m³.

(4). If the audible alarm sounds more than 5 times in a calendar month, Mirant shall, on a one-time basis, adjust the alarm to 75% of the applicable NAAQS.

6. PM10 Predictive Modeling

Whenever Mirant operates 4 or more units, it shall abide by an emission rate of 0.055 lbs/MM Btu and shall first conduct Predictive Modeling using this rate to determine whether operation of the units causes or contributes to a Modeled NAAQS Exceedance. If the Predictive Modeling indicates that the planned Operating Parameters will result in a Modeled NAAQS Exceedance for PM10, Mirant shall adjust its planned operating scenario and re-run the Predictive Modeling with an emission rate of 0.055 lbs/MM Btu until such time as Mirant confirms through Predictive Modeling that the adjusted operations will not cause or contribute to a Modeled NAAQS Exceedance for PM10.

7. AERMOD EBD - Physical Changes Requiring Model Changes

If Mirant elects to refine the AERMOD Default model by performing a Wind Tunnel Study, Mirant will submit a Wind Tunnel Study evaluation protocol for review by EPA and VaDEQ and approval by EPA. The protocol will describe the technical features of the proposed Wind Tunnel Study and the theoretical basis for demonstrating that the data generated should be used to develop a site-specific set of assumptions, including equivalent building dimensions, to be applied to AERMOD Default.

The results of the Wind Tunnel Study shall be submitted to EPA for approval and may result in site-specific equivalent building dimensions to be used in lieu of the assumptions in the AERMOD Default model. The results must be submitted to EPA no later than 90 days following entry of this AO. Upon approval of AERMOD EBD by EPA and VaDEQ, Mirant shall operate for the balance of the MES study period applying AERMOD EBD in its Predictive Modeling.

As the Model Evaluation Study progresses, Mirant may make other changes at the PRGS, including physical changes such as changes to the stacks. In that event, inputs utilized during the Predictive Modeling and in the models evaluated at the conclusion of the Model Evaluation Study (and the model used to develop emission limits for the PRGS) may, after EPA

approval, be adjusted to correspond to these changes. However, the MES study period must be conducted for a minimum of six months following any physical change in order to obtain monitoring data upon which to evaluate the models.

8. Monitoring and Comparison Modeling During the Model Evaluation

Study

In accordance with the MES Protocol, as attached, Mirant shall install and operate a total of six (6) ambient SO₂ monitors in the preferred locations or alternate locations as described below:

a. Preferred locations

(1). Two monitors on the roof of Marina Towers, with one located on the Southeast wing and one at the center of the building;

(2). One monitor east of the PRGS, approximately due east of Stack 5 on the west bank of the Potomac River;

(3). One monitor southeast of the PRGS, along the facility fenceline, near the River;

(4). One monitor approximately 800 meters north of Marina Towers; and

(5). One monitor on the roof of a building in the Harbor Terrace complex three

EPA will work with Mirant to assist in obtaining permission needed to install monitors in these preferred locations.

b. Alternate Locations: If EPA determines that notwithstanding Mirant's good faith and reasonable efforts to obtain permission to install monitors in the preferred locations, it is impractical to install some or all of the monitors in the preferred locations in a timely manner because the owner of the preferred monitor location declines to host the SO₂ monitor(s) or the preferred location is unavailable or impractical for any other reason, EPA will authorize installation of monitors at some or all of the five alternative SO₂ monitor locations set forth in the MES Protocol, as summarized below:

(1) Southwest of the PRGS on the rooftop of Braddock Place;

(2) Approximately 600 meters South-Southeast of the stack locations, at ground level along the Potomac River;

(3) Approximately 300 meters Southwest of the PRGS at ground level;

(4) Approximately 600 meters South-Southwest of the PRGS at ground level; and

(5) Approximately 100 meters SW of the plant at ground level.

c. Deadline for ambient monitor installation: Mirant shall have all six monitors installed and operating within 60 days of the execution of this Order. EPA may, at its own discretion, extend the deadline, and/or change locations, for installation and/or operation of one or all of the monitors and in the event that EPA determines that one of the preferred locations is impractical and authorizes use of an alternate location, Mirant shall have an additional 30 days in which to install that monitor.

d. Operation, Maintenance, and Quality Assurance/Quality Control ("QA/QC") of monitors - It shall be the responsibility of Mirant to ensure that the monitors are operated, maintained, and subject to the appropriate QA/QC provisions set forth at Appendix A to 40 C.F.R. Part 58.

e. Follow-up modeling: The data generated by the monitors shall be used at the end of the study to conduct a model evaluation. Until such time as all the ambient air monitors are installed in accordance with the Monitoring Plan and begin measuring and recording ambient air data, Mirant shall perform "follow up" computer modeling using actual weather conditions and Operating Parameters, and shall report the results to EPA and VaDEQ on a monthly basis, as described below. This "follow-up" modeling will be performed on the Monday following the previous week of operation.

9. Determination of Best Performing Model at Conclusion of Model Evaluation Study

At the conclusion of the MES, the performance of the applicable models will be evaluated in accordance with the document "Protocol for Determining the Best Performing Model." EPA-454/R-92-025, Sept. 1992, Comparing Computer Model-Predicted Air Concentrations to Actual Ambient Air Concentrations Measured by the Monitors. The information yielded by the comparison of model predictions to measured ambient concentrations will result in a determination by EPA and VaDEQ as to which model is best-performing. Thereafter, the best-performing model shall be used to conduct computer modeling to develop permanent emission limits at the PRGS.

10. Reporting

a. Throughout the period of the MES, Mirant shall deliver to EPA and VaDEQ monthly: (1) the modeled input files and results of the daily Predictive Modeling for the preceding month, including the hourly average heat input in MMBtu for each unit and the exit velocity (or exhaust volume) for each unit; (2) verification that the planned Operating Parameters utilized for Predictive Modeling in the preceding month were not exceeded, or if exceeded, documentation describing that exceedance; (3) the inputs and results of "follow-up" modeling for the preceding month (or portion thereof during which all Monitors were not in place), including the hourly average heat input in MMBtu for each unit and the exit velocity (or

exhaust volume) for each unit, but only until commencement of operation of all Monitors, and;
(4) after installation of the Monitors, the data generated by the Monitors.

b. If at any time the "follow-up" modeling demonstrates a modeled exceedance of the NAAQS or the Monitors demonstrate an actual exceedance of the NAAQS, Mirant shall report such modeled or monitored exceedance to EPA and VaDEQ within 3 days of the modeled or monitored exceedance for a determination as to whether corrective action is required.

C. Operation During Line Outage Situations

1. During a Line Outage Situation, Mirant shall operate the PRGS to produce the amount of power needed to meet the load demand in the Central D.C. area, as specified by PJM and in accordance with the DOE Order. During such operations, Mirant shall take all reasonable steps to limit the emissions of PM10, NOX and SO2 from each boiler, including operating only the number of units necessary to meet PJM's directive and optimizing its use of Trona injection to minimize SO2 emissions. During a Line Outage Situation, Mirant shall achieve 80% reduction of SO2 emissions unless: 1) Mirant demonstrates, through predictive modeling or otherwise, that 80% reduction is not necessary to achieve compliance with the NAAQS; or 2) Mirant demonstrates that 80% reduction is not logistically feasible because of factors such as the quantity of available Trona and predicted duration of the outage. In the event that Mirant demonstrates that 80% reduction is not logistically feasible, it shall submit a plan to EPA for optimizing its use of Trona injection so as to maximize SO2 reduction and the plan shall propose control measures and removal efficiencies to be achieved during the Line Outage Situation. If Mirant has 30 days notice in advance of the Line Outage Situation, it shall submit the plan to EPA for approval 15 days before commencement of the Line Outage. If Mirant has less than 30 days advance notice of the Line Outage Situation, Mirant shall submit the plan to EPA for approval as promptly as reasonably possible under the circumstances. It is understood and acknowledged that the plan to be followed for an unscheduled Line Outage Situation will depend upon the specific circumstances at the time of the unscheduled Line Outage Situation. Nothing here shall diminish Mirant's obligation to produce the amount of power needed to meet the load demand in the Central D.C. area, as specified by PJM, and in accordance with DOE's Order.

2. Malfunctions of emission control devices, such as Trona injection, shall not be deemed a failure to limit the emissions during a line outage, provided that Mirant has made reasonable efforts to avoid the malfunction and to promptly correct the malfunction. All emissions during a Line Outage Situation count toward any other permit, statutory, or regulatory limits for the PRGS. Upon Mirant's request, EPA (after consultation with DOE) will provide contemporaneous written confirmation of the existence of a Line Outage Situation. If Mirant operates the PRGS in accordance with dispatch directions from PJM and the relevant terms of this Order during a Line Outage Situation, Mirant shall not be in violation of this Order; or 9 VAC 5-20-180(I), as incorporated into the Virginia SIP at 40 C.F.R. 52.2420(c); nor shall such operation be deemed to give a right for a cause of action for any alleged violation of the

NAAQS as a result of Mirant causing or contributing to any modeled or monitored exceedance of the NAAQS. This release shall only apply to alleged exceedances or violations occurring during the lifetime of the Order or the duration of the MES if the requirements of this Order have been incorporated into a state operating permit; shall only apply to laws in existence on the effective date of the Order; and shall not prevent Virginia from issuing an order under 9 VAC 5-20-180(1) or EPA from taking action under Section 303 of the Clean Air Act.

D. General Provisions

1. At all times, Mirant shall not emit more than 3700 tons of NO_x per year and shall limit the emission rate of PM₁₀ to 0.055 lbs/MMBtu.
2. Mirant's actions shall be consistent with all provisions of federal and state law, including but not limited to, the Clean Air Act, all federal regulations promulgated under the Clean Air Act, and any other applicable laws, including the Virginia State Implementation Plan.

E. Permitting Requirements

Within the 12 month period following entry of this Order, Mirant must cooperate with VaDEQ in the development of operating permit emission limits protective of all NAAQS. Mirant agrees that the obligations of this Order, to the extent they have not been completed, may become obligations in the operating permit issued by VaDEQ. Mirant further agrees that during the implementation of this Order, it will prepare and submit to EPA and VaDEQ an analysis of the applicability of NSR/PSD to the PRGS due to the installation of Trona injection and any additional fugitive emissions resulting from that installation.

V. PARTIES BOUND

This Order shall apply to and be binding upon Mirant, its agents, successors, and assigns and upon all persons, contractors and consultants acting under or for Mirant, or persons acting in concert with Mirant who have actual knowledge of this Order or any combination thereof with respect to matters addressed in this Order. No change in ownership or corporate or partnership status will in any way alter Mirant's responsibilities under this Order.

In the event of any change in ownership or control of the PRGS, Mirant shall notify the EPA in writing at least thirty (30) days in advance of such change and shall provide a copy of this Order to the transferee-in-interest of the PRGS, prior to any agreement for transfer.

VI. RESPONSES TO ORDER

Information required to be submitted to EPA under this Order must be sent to:

Chief, Air Enforcement Branch
Air Protection Division,

U.S. Environmental Protection Agency, Region 3
1650 Arch St.
Philadelphia, PA 19103

And

Douglas J. Snyder
Assistant Regional Counsel
Office of Regional Counsel (3RC10)
U.S. Environmental Protection Agency, Region 3
1650 Arch St.
Philadelphia, PA 19103

VII. EFFECT OF COMPLIANCE ORDER

As set forth in Section 113(a)(4) of the Act, 42 U.S.C. § 7413(a)(4), nothing in this Administrative Compliance Order by Consent shall prevent EPA from assessing any penalties, or otherwise affect or limit the United States' authority to enforce other provisions of the Act, or affect any person's obligations to comply with any Section of the Act or with any term or condition of any permit or applicable implementation plan promulgated or approved under the Act. Further, nothing in this Order shall limit or otherwise preclude the United States from taking criminal or additional civil judicial or administrative enforcement action against Mirant or any third parties with regard to the PRGS pursuant to any other federal or state law, regulation or permit condition, or for Mirant's failure to comply with any requirements of this Order. Nothing herein shall be construed to limit the authority of the EPA to undertake action against any person, including Mirant, in response to any condition that EPA determines may present an imminent and substantial endangerment to the public health, public welfare or the environment. EPA reserves any rights and remedies available to it to enforce the provisions of this Order, the Act and its implementing provisions, and of any other federal laws or regulations for which it has jurisdiction following the entry of this Order.

For the purposes of this proceeding only, Mirant hereby expressly waives its right to any appeal of this Order which it may have under Section 307(b) of the CAA, 42 U.S.C. § 7607(b), and waives the right to challenge the terms of this Order in any action taken to enforce this Order pursuant to Section 113(b) of the CAA, 42 U.S.C. § 7413(b).

VIII. ENFORCEMENT

Failure to comply with this Order may result in a judicial or administrative action for appropriate relief, including civil penalties, as provided in Section 113 of the Act, 42 U.S.C. § 7413. EPA retains full authority to enforce the requirements of the Clean Air Act, 42 U.S.C. §§ 7401-7642, and nothing in this Order shall be construed to limit that authority except as otherwise provided herein.

IX. CERTIFICATION OF REPORTS

Any notice, report, certification, data presentation, or other document submitted by Mirant under or pursuant to this Order, which discusses, describes, demonstrates, or supports any finding or makes any representation concerning Mirant's compliance or non-compliance with any requirement(s) of this Order, shall be certified by a responsible corporate official of Mirant. The term "responsible corporate official" means (a) the Chairman or Chief Operating Officer of Mirant, or (b) Vice President of Operations for PRGS.

23. The certification required by the preceding paragraph of this Order shall be in the following form:

Except as provided below, I certify that the information contained in or accompanying this (type of submission) is true, accurate, and complete. As to (the/those) portion(s) of this (type of submission) for which I cannot personally verify (its/their) accuracy, I certify under the penalty of law that this (type of submission) and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Signature: _____

Name(print): _____

X. EFFECTIVE DATE AND OPPORTUNITY FOR CONFERENCE

24. By signing this Order, Mirant agrees that it has had an opportunity to confer on the terms of this Order with EPA and thereby waives its opportunity pursuant to Section 113(a)(4) to confer further with EPA concerning the violation(s) alleged in the above Order before the Order takes effect. Therefore, this Order shall be effective upon Mirant's receipt of a copy of the Order signed by the Director of the Air Protection Division, Region 3, or her designee. This Order shall expire one year after execution of the Order, in accordance with Section 113(a)(4) of the CAA, unless it is terminated sooner by EPA.

XI. FAILURE TO PERFORM

25. In the event of an inability or anticipated inability on the part of Mirant to perform any of the actions or work required by this Order in the time and manner required herein, Mirant shall notify EPA orally within twenty-four (24) hours of such event (or, if the event occurs on a Friday

or Saturday, Sunday, or legal holiday, no later than the following business day) and in writing as soon as possible, but in no event more than three (3) days after such event. Such notice shall set forth the reason(s) for, and the expected duration of, the inability to perform; the actions taken and to be taken by Mirant to avoid and mitigate the impact of such inability to perform; and the proposed schedule for completing such actions. Such notification shall not relieve Mirant of any obligation of this Order. Mirant shall take all reasonable actions to prevent and minimize any delay.

XII. BUSINESS CONFIDENTIALITY

26. Mirant is entitled to assert a claim of business confidentiality covering all or part of any requested information, in the manner described in 40 C.F.R. § 2.203(b), unless such information is "emission data" as defined in 40 C.F.R. § 2.301(a)(2). Information subject to a claim of business confidentiality will be made available to the public only in accordance with the procedures set forth in 40 C.F.R. Part 2, Subpart B. Unless a confidentiality claim is asserted at the time requested information is provided, EPA may make this information available to the public without further notice to you.

XIII. COPIES OF ADMINISTRATIVE COMPLIANCE ORDER BY CONSENT


A copy of this Order will be sent to James Sydnor, Virginia Department of Environmental Quality.

Dated: June 1, 2006


Judith Katz, Director
Air Protection Division
U.S. Environmental Protection Agency
Region III

The undersigned represents that he or she is a duly authorized representative of Mirant Potomac River, LLC for the purpose of signing this Order, and that Mirant agrees to the terms of this Order.

Dated: June 1, 2006


Robert Driscoll
Chief Operating Officer

APPENDIX C

***Federal Register* Notice of Emergency Action and
Correspondence with the Council on Environmental Quality**

[This page intentionally left blank]

ACTION: Notice of public meeting agenda.

DATE AND TIME: Thursday, February 2, 2006, 10 a.m.–1 p.m.

PLACE: Hyatt Regency (Valley Forge Room), 400 New Jersey Avenue, NW., Washington, DC 20001. (Metro Stop: Union Station).

AGENDA: The Commission will receive the following reports: Title II Requirements Payments Update; and updates on other administrative matters. The Commission will receive presentations on the following topics: Implementation of the EAC Voting System Certification Program.

This meeting will be open to the public.

FOR FURTHER INFORMATION CONTACT: Bryan Whitener. Telephone: (202) 566–3100.

Ray Martinez III,

Vice-Chairman, U.S. Election Assistance Commission.

[FR Doc. 06–607 Filed 1–18–06; 3:32 pm]

BILLING CODE 6820–KF–M

DEPARTMENT OF ENERGY

Emergency Order To Resume Limited Operation at the Potomac River Generating Station, Alexandria, VA, in Response to Electricity Reliability Concerns in Washington, DC

AGENCY: Department of Energy.

ACTION: Notice of emergency action.

SUMMARY: Pursuant to 10 CFR 1021.343, the U.S. Department of Energy is issuing this Notice to document emergency actions that it has taken, and to set forth the steps it intends to take in the future, to comply with the National Environmental Policy Act (NEPA) in the matter described in this Notice.

On August 24, 2005, Mirant Corporation, and its wholly owned subsidiary, Mirant Potomac River, LLC (collectively referred to herein as Mirant), ceased operations at its Potomac River Generating Station (the “Plant”) in Alexandria, Virginia, after modeling that it conducted indicated that the Plant’s operations were causing exceedances of the National Ambient Air Quality Standards (NAAQS) of the Clean Air Act. On the same day, the District of Columbia Public Service Commission (DCPSC) filed with the U.S. Department of Energy (DOE or “Department”), a petition for an emergency order pursuant to section 202(c) of the Federal Power Act (FPA), asserting that the Plant’s closure reduced the reliability of the electrical

supply to much of the central business district of the District of Columbia, many federal institutions, the Georgetown area in DC, as well as other portions of Northwest DC, and the District of Columbia Water and Sewer Authority’s Blue Plains Advanced Water Treatment Plant (collectively referred to herein as the “Central DC area”), placing these electrical customers in risk of a blackout.

After an exhaustive review of the facts, and consultation with Federal and state officials responsible for environmental compliance and the private entities responsible for electricity transmission, the Secretary of the Department of Energy on December 20, 2005, issued an emergency order (the “Order”) directing the Plant’s owner, Mirant, to generate electricity at the coal-fired Plant under certain, limited circumstances. The section below on “Further Information” includes information on how to obtain paper and electronic copies of the Order.

In emergency situations such as this one, the Council on Environmental Quality (CEQ) Regulations Implementing the Procedural Requirements of NEPA at 40 CFR 1506.11 provide that a federal agency may take an action with significant environmental impacts without observing the provisions of the NEPA regulations associated with preparing an Environmental Impact Statement (EIS). Instead, the agency should consult with CEQ to determine what alternative arrangements the agency will take in lieu of preparing a normal NEPA EIS. DOE has consulted with CEQ about alternative arrangements it will take in this matter and is publishing this notice to inform the public of those arrangements pursuant to DOE’s NEPA regulations at 10 CFR 1021.343.

Consistent with its consultation with CEQ, DOE will implement the following alternative arrangements: (1) Prepare a Special Environmental Analysis (SEA) that will examine the potential impacts from issuance of the order, and identify potential mitigation measures; (2) provide opportunities for public involvement by disseminating information related to the environmental effects of Mirant’s operations and by accepting public comment on this notice, the compliance plan Mirant submitted to DOE, and the SEA; (3) continue consultations with appropriate agencies with regard to relevant environmental issues; and (4) identify in the SEA any steps that DOE believes can be taken to mitigate the impacts from its Order.

DATES: Comments on this notice and on issues to be addressed in the SEA should be submitted to DOE on or before February 21, 2006.

ADDRESSES: Comments should be addressed to: Lawrence Mansueti, Permitting, Siting, and Analysis Division, Office of Electricity Delivery and Energy Reliability (OE–20), U.S. Department of Energy, 1000 Independence Avenue, SW., Washington, DC 20585–0119; telephone: 202–586–2588; fax: 202–586–5860; Lawrence.Mansueti@hq.doe.gov.

FOR FURTHER INFORMATION CONTACT: For further information on this Notice, to obtain paper copies of the Order and compliance plan, to submit comments on the compliance plan, or for information on the emergency activities related to the Plant, contact Mr. Mansueti at the above address. In addition, all publicly available documents, including the Order and compliance plan, are available on DOE’s Web site for this matter at http://www.electricity.doe.gov/about/dcpsc_docket.cfm or via hyperlinks from that Web site (referred to herein as the “Mirant matter Web site”). Copies of the SEA will also be available on the DOE NEPA Web site at <http://www.eh.doe.gov/nepa/>.

For information on the DOE NEPA process, please contact: Carol M. Borgstrom, Director, Office of NEPA Policy and Compliance (EH–42), U.S. Department of Energy, 1000 Independence Avenue, SW., Washington, DC 20585–0119; telephone: 202–586–4600; fax: 202–586–7031; or leave a toll-free message at: 1–800–472–2756.

SUPPLEMENTARY INFORMATION:

Procedural Background

On August 19, 2005, Mirant submitted to the Virginia Department of Environmental Quality (DEQ) a computerized emissions modeling study Mirant had conducted of its Plant that indicated that emissions from the Plant caused or contributed to significant localized exceedances of the NAAQS. Also on August 19, 2005, DEQ issued a letter to Mirant which requested “that Mirant *immediately* undertake such action as is necessary to ensure protection of human health and the environment, in the area surrounding the Potomac River Generating Station, including the potential reduction of levels of operation, or potential shut down of the facility.” (emphasis in original). On August 24, 2005, Mirant shut down all five of the generating units at the Plant, and on the same day, the District of Columbia Public Service

Commission (DCPSC) filed an Emergency Petition and Complaint with DOE and the Federal Energy Regulatory Commission (FERC) pursuant to the Federal Power Act (FPA). The DCPSC requested the Secretary of Energy to find that an emergency existed under section 202(c) of the FPA and to issue an order directing Mirant to continue operation of the Plant. The basis for the petition was that the shutdown of the Plant “* * * will have a drastic and potentially immediate effect on the electric reliability in the greater Washington, DC, area and could expose hundreds of thousands of consumers, agencies of the Federal Government and critical federal infrastructure to curtailments of electric service, load shedding and, potentially, blackouts.” On September 20, 2005, Mirant restarted its unit number one on an 8/8/8 basis—that is, in any given 24-hour period, the unit runs for eight hours at its maximum level of 88 MW, eight hours at its minimum level of 35 MW, and has eight hours when it does not run. DOE has been informed that both the U.S. Environmental Protection Agency (EPA) and DEQ acknowledge that the operation of this unit in this manner does not result in any modeled NAAQS exceedances.

Electricity Reliability

The coal-fired Mirant Plant consists of five generating units, two of which are cycling units that range in output from 35 MW to 88 MW, and three of which are baseload units that range in output from 35 MW to 102 MW. The Plant is one of only three sources of electricity to the Central DC area. The other two sources are two 230,000-volt (230 kV) transmission lines that deliver electricity from other generating sources in the regional electric grid operated by PJM Interconnection (PJM). Although there are other generating units in close physical proximity to the Central DC area, there are no transmission lines that would allow delivery of power from these other units to reach the Central DC area. Under North American Electric Reliability Council (NERC) standards, at a minimum, the power system must carry at least enough contingency reserves of electricity to cover the most severe single contingency. The standards require that an area's system always be operated with sufficient reserves to compensate for the sudden failure of the area's most important single generator or transmission line. Based on the fact that the Central DC area has only three sources of supply, the Plant and the two 230 kV transmission lines, in order to maintain a minimally reliable electric power

system, the Plant must be available to run when one of the 230 kV lines is out of service, because if the remaining line failed there would be no other source of electricity to serve the Central DC area load.

The outage of one of these two lines is not merely a theoretical possibility. Since 2000, there have been 34 one-line outages for maintenance, and seven occasions where one of the lines has failed unexpectedly. DOE has been informed that, prior to 2000, there were two occasions when both of the lines failed simultaneously. Moreover, just days before issuance of the Order, PJM informed DOE on December 16, 2005, that on the previous night, “one of the two circuits critical to providing service to the District tripped. Continued [electric] service to certain load within the District was at that time entirely dependent on the remaining circuit.” Fortunately, full service to the line that failed was restored by the morning of December 16, 2005. Nonetheless, there can be no assurance that the Central DC area would be so lucky next time. In addition, the Potomac Electric Power Company (PEPCO) informed DOE that it needed to perform maintenance on the lines in January of 2006.

The Order

On December 20, 2005, DOE found that in the circumstances presented, an emergency existed within the meaning of section 202(c) of the FPA because of the reasonable possibility an outage would occur that would cause a blackout, the number and importance of facilities and operations in our Nation's Capital that would be potentially affected by such a blackout, the extended number of hours of any blackout that might in fact occur, and the fact that the current situation violated applicable reliability standards. PEPCO has applied to the DCPSC to construct two additional 230 kV lines that would supply electricity to the Central DC area and in the same application, proposed building two new 69kV lines to supply the Blue Plains wastewater treatment plant. Once completed, these lines will likely provide a high level of electricity reliability in the Central DC area, even in the absence of production from the Plant. However, it will likely take 18–24 months to construct the new lines.

Based on this finding, on December 20, 2005, DOE issued an Order requiring Mirant to, among other things, (1) operate the Plant to produce the amount of power (up to its full capabilities) needed to meet demand in the Central DC area during any period in which one or both of the 230kV lines serving the

Central DC area is out of service as specified by PJM for the duration of the outage, and (2) keep as many generating units in operation and take all other measures to reduce the start-up time of units not in operation, for the purpose of providing electricity reliability, as feasible, as determined by DOE after consideration of the plan submitted by Mirant pursuant to the Order and after consultation with EPA, without regard to cost, and without causing or significantly contributing to any exceedance of the NAAQS. A blackout in the Central DC area would have drastic impacts on the environment, as well as for the employees and citizens of the Central DC area, affecting hundreds of thousands of residents and workers, as well as public safety and protection facilities, including hospitals, police, and fire facilities. In addition, DOE has been informed that within 24 hours of a blackout in the Central DC area, untreated sewage from the Blue Plains Wastewater Treatment plant would be discharged into the Potomac River.

The time period for DOE's Order extends through October 1, 2006.

Mirant's Compliance Plan

Pursuant to DOE's Order, Mirant submitted a compliance plan (referred to as the Operating Plan by Mirant) on December 30, 2005. The plan outlines a proposed temporary phase, and two options for a proposed intermediate phase, Option A and Option B. All proposals include the use of “trona” (sodium sesquicarbonate, a naturally occurring substance similar to baking soda) and/or lower sulfur coal to manage air emissions. On January 4, 2006, DOE authorized Mirant to “immediately take the necessary steps to implement Option A of the intermediate phase proposed in the implementation plan,” stating that “Mirant represents that implementation of this option will produce no NAAQS exceedances.” DOE will work with EPA to verify the accuracy of that representation. DOE is still in the process of reviewing the other proposals described in Mirant's compliance plan in consultation with EPA.

NEPA Compliance Actions

Pursuant to CEQ regulations at 40 CFR 1506.11, DOE consulted with CEQ on December 20, 2005, December 22, 2005, January 13, 2006, and January 17, 2006, about formulating a plan for alternative arrangements. Under the agreed upon alternative arrangements plan, which will expire October 1, 2006, unless extended, DOE will:

1. *Prepare a Special Environmental Analysis (SEA).* The SEA will examine potential impacts resulting from issuance of the Order, and describe further DOE decisionmaking regarding reasonable future alternatives and potential further mitigation actions DOE may take in this matter. The analysis will present reasonably foreseeable impacts from possible changes in operations of the Plant over the time until two additional transmission lines planned by PEPCO are installed. DOE intends to issue its SEA no later than August 2006 and will make it available to the public on the DOE NEPA and Mirant matter Web sites as well as announce its availability in the **Federal Register**. DOE will consider information contained in the SEA, and public input received on the SEA, in any future decisionmaking in this matter.

2. *Provide Opportunities for Public Involvement.* DOE is currently accepting public comments on the compliance plan that DOE required Mirant to submit under the DOE Order. DOE also invites public comments on this Notice, as well as on issues to be addressed in the SEA. DOE will consider public input in determining appropriate mitigation measures and any additional actions DOE may take as DOE adaptively manages implementation of the Order. DOE will post on the Mirant matter Web site publicly available information (not exempt from disclosure under the Freedom of Information Act) regarding the environmental effects of ongoing or alternative operations of the Plant (e.g., reasonably available ambient air quality data and results of air quality modeling), that the Department receives from Mirant, EPA, and DEQ.

3. *Continue Agency Consultations.* DOE will continue to consult with EPA and DEQ concerning information on emissions, modeling results, potential mitigation measures, and any changes to the operation of the Plant. EPA will act as a "cooperating agency" (see 40 CFR 1501.6 and 1508.5) for purposes of providing reasonably available public information regarding the environmental effects of operations of the Plant to be disseminated via DOE's Mirant matter Web site and evaluated in the SEA.

4. *Identify Mitigation.* DOE will identify in its SEA any steps that it believes can be taken to mitigate the impacts from its Order. DOE will continue to track the impacts of its Order and public input and provide for appropriate mitigation where practicable. DOE will publish on its Web sites, as noted above, its discussion of which mitigation measures are

adopted for any future decision, and if not, why they are not adopted.

DOE may modify, in consultation with CEQ, the foregoing alternative arrangements as conditions warrant and will notify the public in the **Federal Register** if it does so.

Issued in Washington, DC, on January 18, 2006.

John Spitaleri Shaw,

Assistant Secretary for Environment, Safety and Health.

[FR Doc. 06-570 Filed 1-19-06; 8:45 am]

BILLING CODE 6450-01-P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

[Project No. 12481-002]

AMG Energy, LLC; Notice of Surrender of Preliminary Permit

January 12, 2006.

Take notice that AMG Energy, LLC, permittee for the proposed Selden Dam Project, has requested that its preliminary permit be terminated. The permit was issued on April 20, 2004, and would have expired on March 31, 2007.¹ The project would have been located on the Black Warrior River in Greene and Hale Counties, Alabama.

The permittee filed the request on December 7, 2005, and the preliminary permit for Project No. 12481 shall remain in effect through the thirtieth day after issuance of this notice unless that day is a Saturday, Sunday, part-day holiday that affects the Commission, or legal holiday as described in section 18 CFR 385.2007, in which case the effective date is the first business day following that day. New applications involving this project site, to the extent provided for under 18 CFR Part 4, may be filed on the next business day.

Magalie R. Salas,

Secretary.

[FR Doc. E6-598 Filed 1-19-06; 8:45 am]

BILLING CODE 6717-01-P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

[Project No. 12485-002]

AMG Energy, LLC; Notice of Surrender of Preliminary Permit

January 12, 2006.

Take notice that AMG Energy, LLC, permittee for the proposed Claiborne Hydroelectric Project, has requested that its preliminary permit be terminated. The permit was issued on June 28, 2004, and would have expired on May 31, 2007.¹ The project would have been located on the Alabama River in Monroe County, Alabama.

The permittee filed the request on December 7, 2005, and the preliminary permit for Project No. 12485 shall remain in effect through the thirtieth day after issuance of this notice unless that day is a Saturday, Sunday, part-day holiday that affects the Commission, or legal holiday as described in section 18 CFR 385.2007, in which case the effective date is the first business day following that day. New applications involving this project site, to the extent provided for under 18 CFR part 4, may be filed on the next business day.

Magalie R. Salas,

Secretary.

[FR Doc. E6-599 Filed 1-19-06; 8:45 am]

BILLING CODE 6717-01-P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

[Docket No. RP03-36-015]

Dauphin Island Gathering Partners; Notice of Negotiated Rate

January 13, 2006.

Take notice that on January 9, 2006, Dauphin Island Gathering Partners (Dauphin Island) tendered for filing as part of its FERC Gas Tariff, First Revised Volume No. 1, the revised tariff sheets listed below to become effective February 9, 2006.

Twenty-Fourth Revised Sheet No. 9.

Nineteenth Revised Sheet No. 10.

Seventh Revised Sheet No. 359.

Third Revised Sheet No. 427.

Dauphin Island states that these tariff sheets reflect changes to its statement of negotiated rates and nonconforming transportation and reserve commitment agreement tariff sheets.

¹ 107 FERC ¶ 62,053.

¹ 107 FERC ¶ 62,287.

[This page intentionally left blank]



Department of Energy
Washington, DC 20585

January 18, 2006

Ms. Dinah Bear, General Counsel
Council on Environmental Quality
Executive Office of the President
722 Jackson Place, NW
Washington, DC 20503

Dear Ms. Bear:

The purpose of this letter is to document the Department of Energy's (DOE) consultations with the Council on Environmental Quality (CEQ) regarding compliance with the National Environmental Policy Act (NEPA) analyses and documentation requirements associated with the issuance of an emergency order under section 202(c) of the Federal Power Act (the Order) as a result of the shutdown of the Potomac River Generating Station (the Plant) in Alexandria, Virginia, on August 24, 2005. We thank you and others at CEQ for consulting with DOE on this matter on December 20 and 22, 2005, and January 13 and 17, 2006.

As you are aware, DOE issued its Order on December 20, 2005, requiring the owners of the Plant, Mirant Corporation and its wholly owned subsidiary, Mirant Potomac River, LLC (collectively referred to herein as Mirant), to generate electricity in certain limited circumstances. Due to the emergency nature of this matter, DOE issued the Order, despite potentially significant environmental impacts, without observing all of the normal provisions of the CEQ Regulations for Implementing the Procedural Requirements of the National Environmental Policy Act (NEPA) [40 CFR Parts 1500-1508]. Therefore, DOE is pursuing alternative arrangements to comply with NEPA, as provided in Section 1506.11 of the CEQ regulations. As a result of our discussions with CEQ, we propose the following alternative arrangements, which will expire October 1, 2006, unless extended:

1. Issuance of a *Federal Register* Notice, in accordance with DOE's NEPA regulations at 10 CFR 1021.343. The enclosed draft *Federal Register* Notice documents the emergency action that DOE has taken and actions it intends to pursue in the near term to address the electricity reliability emergency in the District of Columbia. The Notice provides background on Plant operations, outlines the Order DOE issued on December 20, 2005, and acknowledges potential environmental impacts from the Order. The Notice also describes DOE's continuing public involvement and preparation of a Special Environmental Analysis, as discussed below.
2. Prepare a Special Environmental Analysis (SEA). The SEA will examine potential impacts resulting from issuance of the Order, and describe further DOE decisionmaking regarding reasonable future alternatives and potential further




Printed with soy ink on recycled paper

mitigation actions DOE may take in this matter. The analysis will present reasonably foreseeable impacts from possible changes in operations of the Plant over the time until two additional transmission lines planned by Potomac Electric Power Company are installed. DOE intends to issue its SEA no later than August 2006 and will make it available to the public on the NEPA and Mirant matter websites as discussed in the enclosed Notice as well as announce its availability in the *Federal Register*. DOE will consider information contained in the SEA, and public input received on the SEA, in any future decisionmaking in this matter.

3. Provide Opportunities for Public Involvement. DOE is currently accepting public comments on the compliance plan that DOE required Mirant to submit under the DOE Order. DOE also invites public comments on this Notice as well as on issues to be addressed in the SEA. DOE will consider public input in determining appropriate mitigation measures and any additional actions DOE may take as DOE adaptively manages implementation of the Order. DOE will post on DOE's Mirant matter website publicly available information (not exempt from disclosure under the Freedom of Information Act) regarding the environmental effects of ongoing or alternative operations of the Plant (e.g., reasonably available ambient air quality data and results of air quality modeling) that the Department receives from Mirant, the Environmental Protection Agency (EPA), and the Virginia Department of Environmental Quality (DEQ).
4. Continue Agency Consultations. DOE will continue to consult with EPA and DEQ concerning information on emissions, modeling results, potential mitigation measures, and any changes to the operation of the Plant. EPA will act as a "cooperating agency" for purposes of providing reasonably available public information regarding the environmental effects of operations of the Plant to be disseminated via DOE's Mirant matter website and evaluated in the SEA.
5. Identify Mitigation. DOE will identify in its SEA any steps that it believes can be taken to mitigate the impacts from its Order. DOE will continue to track the impacts of its Order and public input and provide for appropriate mitigation where practicable. DOE will publish on its websites as noted above its discussion of which mitigation measures are adopted for any future decision, and if not, why they are not adopted.

We welcome any further suggestions you may have regarding our efforts to comply with NEPA under these emergency circumstances. Thank you for your assistance.

Sincerely,



John Spitaleri Shaw
Assistant Secretary for
Environment, Safety and Health

Enclosure



EXECUTIVE OFFICE OF THE PRESIDENT
COUNCIL ON ENVIRONMENTAL QUALITY
WASHINGTON, D.C. 20503

January 18, 2006

John Spitaleri Shaw
Assistant Secretary for
Environment, Safety and Health
Department of Energy
Washington, DC 20585

Dear Mr. Shaw:

This letter is in response to your January 18, 2006 letter documenting the Department of Energy's (DOE) request, under 40 C.F.R. 1506.11 and 10 CFR 1021.343, that the Council on Environmental Quality (CEQ) provide alternative arrangements for National Environmental Policy Act (NEPA) compliance. Consultation with CEQ is necessary to provide for a NEPA process that addresses the environmental effects of proposals for DOE action needed to maintain a minimally reliable electric power system for the central area of the District of Columbia (DC).

Your letter accurately reflects DOE's consultations with CEQ prior to and following issuance of its December 20, 2005 Order, which requires owners of the Potomac River Generating Station to generate electricity as necessary to address the current limitations of the electricity transmission system that serves central DC. The alternative arrangements proposed in your January 18, 2006 letter are limited to the immediate actions necessary to reduce electricity supply risks to acceptable levels, provide for local involvement and informed decision-making, and otherwise comply with NEPA in a manner appropriate to the nature and scope of the emergency described in the associated Federal Register notice.

Your proposal of alternative arrangements for NEPA compliance is accepted by CEQ. Thank you for your diligent coordination with CEQ. We plan to follow the implementation of these alternative arrangements closely and will remain available for consultation with DOE in this matter at any time.

Sincerely,

A handwritten signature in cursive script, reading "Dinah Bear", is written over a horizontal line.

Dinah Bear
General Counsel

[This page intentionally left blank]

APPENDIX D

Consultation Letters with the U.S. Fish and Wildlife Service and the National Marine Fisheries Service

[This page intentionally left blank]

August 17, 2006

U.S. Fish and Wildlife Service
Threatened and Endangered Species Branch
Chesapeake Bay Office
177 Admiral Cochrane Drive
Annapolis, MD 21401
ATTN: Mary Ratnaswamy

**RE: Informal Consultation under Section 7 of the Endangered Species Act (ESA)
for Operation of the Potomac River Generating Station in Alexandria,
Virginia, Pursuant to DOE Order.**

Dear Ms. Ratnaswamy:

This letter is intended to serve as informal consultation under section 7 of the ESA. In this regard, the Department of Energy (DOE) requests that you indicate if there are any additional protected species and habitat (beyond those described below) that should be considered for this ongoing action. If there are not any additional species or habitats and if you agree that the Plant would not impact any species when operating under the DOE Order, we request your concurrence that the operation of the Plant under the terms of the DOE Order would not adversely impact Federally listed or proposed threatened or endangered species or designated or proposed critical habitat and that the consultation requirements of section 7 of the ESA have been satisfied.

Background: On August 24, 2005, Mirant Corporation, and its wholly owned subsidiary, Mirant Potomac River, LLC (collectively referred to herein as Mirant), ceased operations at its Potomac River Generating Station (the "Plant") in Alexandria, Virginia, after modeling that it conducted indicated that the Plant's operations were causing exceedances of the National Ambient Air Quality Standards (NAAQS) of the Clean Air Act.

Also on August 24, 2005, the District of Columbia (D.C.) Public Service Commission filed an *Emergency Petition and Complaint* with DOE pursuant to section 202(c) of the Federal Power Act.

On December 20, 2005, after an exhaustive review of the facts and consultation with Federal and state officials responsible for environmental compliance and the private entities responsible for operation of the region's electrical grid, the Secretary of Energy issued an emergency order (the "Order") directing Mirant to generate electricity at the coal-fired Plant under certain, limited circumstances. On June 1, 2006, Mirant entered into an Administrative Consent Order (ACO) with the Environmental Protection Agency (EPA) regarding the operation of the Plant. On June 2, 2006, DOE instructed Mirant to comply with the ACO and operate as required under it.

After consultations with the Council on Environmental Quality (CEQ), DOE's Office of Electricity Delivery and Energy Reliability decided to prepare a special environmental analysis (SEA) under the emergencies provision of CEQ's National Environmental Policy Act (NEPA) Implementing Regulations (40 CFR 1506.11) and the emergency circumstances provision of DOE's own NEPA implementing regulations [10 CFR 1021.343(a)]. The SEA will document the assessment of the impacts associated with the emergency activities under DOE Order 202-05-03. The time period for DOE's Order extends to October 1, 2006; however, the SEA also addresses the 15-month period from October 1, 2006, through December 31, 2007, at which time new transmission lines are expected to be available to provide a high level of electric reliability to customers in the Central D.C. area, even in the absence of production from the Plant.

The Plant: The Potomac River Generating Station began operation in 1949 and is capable of producing 482 megawatts of electric power. The Plant site encompasses 28 acres (11 has) near D.C. and Reagan National Airport on the western bank of the Potomac River (Figure 1). Most of the property is used for power generation, coal storage, office buildings, and parking areas. The site was relatively remote when the power plant was built, but Alexandria has grown up around it. The Plant is beneath the flight path of Reagan National Airport.

EPA issued a National Pollutant Discharge Elimination System (NPDES) permit to the Plant on April 20, 2000, authorizing discharges into the Potomac River. The Virginia Department of Environmental Quality approved a Stationary Source Permit to Operate on September 18, 2000, and a Phase II Acid Rain Permit on February 23, 2003.

Coal combustion ash from the Plant is sent to the Brandywine Fly Ash Facility, which is located in southeastern Prince George's County, Maryland (Figure 2). Water from this landfill discharges into the upper reaches of Mataponi Creek.

Action at the Plant under DOE's Order: The DOE Order resulted in no new disturbances from construction at the Plant site. The provisions of DOE's Order and subsequent instructions to Mirant have, however, caused changes in the level of operation at the Plant. These changes have reduced the operating level of the Plant to below that at which it was historically operating before August 24, 2005, but increased the operating level above that at which it was operating between August 24 and December 20, 2005. To reduce sulfur dioxide (SO₂) emissions, Mirant has been using a compound known as "trona" (sodium sesquicarbonate, a naturally occurring substance similar to baking soda) and/or lower sulfur coal. Thus, even if the Plant were operating at the same level as before August 24, 2005, its emissions of SO₂ would be lower.

Threatened and Endangered (T&E) Species Impacts: Because the Plant site is heavily industrialized and surrounded by development in the City of Alexandria, no Federally listed or proposed threatened or endangered species are known or likely to occur on the Plant site. Also, there is no known designated or proposed critical habitat in the area of the action.

Of the permits issued for the Plant or landfill, only the NPDES permit for the Plant mentions T&E species. That permit states that two species listed by the U.S. Fish and Wildlife Service (FWS) under the ESA occur or may occur at locations near the Plant. These are the endangered Hay's Spring amphipod (*Stygobromus hayi*) and the threatened bald eagle (*Haliaeetus leucocephalus*).

The Plant's NPDES permit states, "The FWS and NMFS indicate that at the present time [i.e., April 20, 2000] there is no evidence that the ongoing wastewater discharges covered by this permit are adversely affecting these Federally listed species." Furthermore, "(w)astewater discharges, construction, or any other activity that adversely affects a Federally listed endangered or threatened species are [sic] not authorized under the terms of this permit."

The Hay's Spring amphipod occurs only in a small area in Rock Creek in D.C. The bald eagle is unlikely to occur near the Plant as the area around it is developed and provides no suitable habitat. There has been no known impact to these species due to the Plant's operation prior to the DOE Order. Thus, since there has been no impact to Federally listed threatened or endangered species when the Plant was operating at the higher historical level before August 24, 2005, adverse impacts to such species from the lower level of operation at the Plant under DOE's Order would not be expected.

Since the DOE Order is scheduled to expire on October 1, 2006, receipt of your reply and/or concurrence before that date will allow DOE to consider your comments in determining what, if any, future actions to take in this matter.

If you need additional information or wish to discuss this matter further, please contact me at (202) 586-5935.

Sincerely,

Anthony J. Como
Director, Permitting and Siting
Office of Electricity Delivery and
Energy Reliability
U.S. Department of Energy

Enclosures (2)

[This page intentionally left blank]

August 17, 2006

Northeast Regional Office
National Marine Fisheries Service
Protected Resource Division
One Blackburn Drive
Gloucester, MA 01930
Attn: Julie Crocker

**RE: Informal Consultation under Section 7 of the Endangered Species Act (ESA)
for Operation of the Potomac River Generating Station in Alexandria,
Virginia, Pursuant to DOE Order.**

Dear Ms. Crocker:

This letter is intended to serve as informal consultation under section 7 of the ESA. In this regard, the Department of Energy (DOE) requests that you indicate if there are any additional protected species and habitat (beyond those described below) that should be considered for this ongoing action. If there are not any additional species or habitats and if you agree that the Plant would not impact any species when operating under the DOE Order, we request your concurrence that the operation of the Plant under the terms of the DOE Order would not adversely impact Federally listed or proposed threatened or endangered species or designated or proposed critical habitat and that the consultation requirements of section 7 of the ESA have been satisfied.

Background: On August 24, 2005, Mirant Corporation, and its wholly owned subsidiary, Mirant Potomac River, LLC (collectively referred to herein as Mirant), ceased operations at its Potomac River Generating Station (the "Plant") in Alexandria, Virginia, after modeling that it conducted indicated that the Plant's operations were causing exceedances of the National Ambient Air Quality Standards (NAAQS) of the Clean Air Act.

Also on August 24, 2005, the District of Columbia (D.C.) Public Service Commission filed an *Emergency Petition and Complaint* with DOE pursuant to section 202(c) of the Federal Power Act.

On December 20, 2005, after an exhaustive review of the facts and consultation with Federal and state officials responsible for environmental compliance and the private entities responsible for operation of the region's electrical grid, the Secretary of Energy issued an emergency order (the "Order") directing Mirant to generate electricity at the coal-fired Plant under certain, limited circumstances. On June 1, 2006, Mirant entered into an Administrative Consent Order (ACO) with the Environmental Protection Agency (EPA) regarding the operation of the Plant. On June 2, 2006, DOE instructed Mirant to comply with the ACO and operate as required under it.

After consultations with the Council on Environmental Quality (CEQ), DOE's Office of Electricity Delivery and Energy Reliability decided to prepare a special environmental analysis (SEA) under the emergencies provision of CEQ's National Environmental Policy Act (NEPA) Implementing Regulations (40 CFR 1506.11) and the emergency circumstances provision of DOE's own NEPA implementing regulations [10 CFR 1021.343(a)]. The SEA will document the assessment of the impacts associated with the emergency activities under DOE Order 202-05-03. The time period for DOE's Order extends to October 1, 2006; however, the SEA also addresses the 15-month period from October 1, 2006, through December 31, 2007, at which time new transmission lines are expected to be available to provide a high level of electric reliability to customers in the Central D.C. area, even in the absence of production from the Plant.

The Plant: The Potomac River Generating Station began operation in 1949 and is capable of producing 482 megawatts of electric power. The Plant site encompasses 28 acres (11 ha) near the D.C. and Reagan National Airport on the western bank of the Potomac River (Figure 1). Most of the property is used for power generation, coal storage, office buildings, and parking areas. The site was relatively remote when the power plant was built, but Alexandria has grown up around it. The Plant is beneath the flight path of Reagan National Airport.

EPA issued a National Pollutant Discharge Elimination System (NPDES) permit to the Plant on April 20, 2000, authorizing discharges into the Potomac River. The Virginia Department of Environmental Quality approved a Stationary Source Permit to Operate on September 18, 2000, and a Phase II Acid Rain Permit on February 23, 2003.

Coal combustion ash from the Plant is sent to the Brandywine Fly Ash Facility, which is located in southeastern Prince George's County, Maryland (Figure 2). Water from this landfill discharges into the upper reaches of Mataponi Creek.

Action at the Plant under DOE's Order: The DOE Order resulted in no new disturbances from construction at the Plant site. The provisions of DOE's Order and subsequent instructions have, however, caused changes in the level of operation at the Plant. These changes have reduced the operating level of the Plant to below that at which it was historically operating before August 24, 2005, but increased the operating level above that at which it was operating between August 24 and December 20, 2005. To reduce sulfur dioxide (SO₂) emissions, Mirant has been using a compound known as "trona" (sodium sesquicarbonate, a naturally occurring substance similar to baking soda) and/or lower sulfur coal. Thus, even if the Plant were operating at the same level as before August 24, 2005, its emissions of SO₂ would be lower.

Threatened and Endangered (T&E) Species Impacts: Because the Plant site is heavily industrialized and surrounded by development in the City of Alexandria, no Federally listed or proposed threatened or endangered species are known or likely to occur on the Plant site. Also, there is no known designated or proposed critical habitat in the area of the action.

Of the permits issued for the Plant or landfill, only the NPDES permit for the Plant mentions T&E species. That permit states that one species listed by the National Marine Fisheries Service (NMFS) under the ESA, the endangered shortnose sturgeon (*Acipenser brevirostrum*), occurs or may occur at locations near the Plant.

The Plant's NPDES permit states, "The FWS and NMFS indicate that at the present time [i.e., April 20, 2000] there is no evidence that the ongoing wastewater discharges covered by this permit are adversely affecting these Federally listed species." Furthermore, "(w)astewater discharges, construction, or any other activity that adversely affects a Federally listed endangered or threatened species are [sic] not authorized under the terms of this permit."

The Shortnose Sturgeon Recovery Plan reports that one shortnose sturgeon was captured in 1996 at the mouth of Potomac Creek off the Potomac River downstream from the Plant. However, there are no other recent reports of it occurring in the Potomac River; therefore, there has been no known impact to this species due to the Plant's operation prior to the DOE Order. Since there has been no known impact to Federally listed threatened or endangered species when the Plant was operating at the higher historical level before August 24, 2005, adverse impacts to such species from the lower level of operation at the Plant under DOE's Order would not be expected.

Since the DOE Order is scheduled to expire on October 1, 2006, receipt of your reply and/or concurrence before that date will allow DOE to consider your comments in determining what, if any, future actions to take in this matter.

If you need additional information or wish to discuss this matter further, please contact me at (202) 586-5935.

Sincerely,

Anthony J. Como
Director, Permitting and Siting
Office of Electricity Delivery and
Energy Reliability
U.S. Department of Energy

Enclosures (2)

[This page intentionally left blank]



UNITED STATES DEPARTMENT OF COMMERCE
National Oceanic and Atmospheric Administration
NATIONAL MARINE FISHERIES SERVICE
NORTHEAST REGION
One Blackburn Drive
Gloucester, MA 01930-2298

OCT - 3 2006

Anthony J. Como, Director
Permitting and Siting
Office of Electricity Delivery and Energy Reliability
US Department of Energy
Washington, DC 20585

Dear Mr. Como,

This is in response to your letter dated August 17, 2006 requesting consultation pursuant to Section 7 of the Endangered Species Act (ESA) of 1973, as amended, regarding the operation of Mirant's Potomac River Generating Station in Alexandria, Virginia.

The Potomac River Generating Station is a coal fired plant located on the western bank of the Potomac River. The Plant began operation in 1949. On August 24, 2005, Mirant ceased operations at its Plant after modeling indicated that the Plant's operations were causing exceedences of the National Ambient Air Quality Standards of the Clean Air Act. On December 20, 2005, the Secretary of Energy issued an emergency order directing Mirant to generate electricity at the Plant under certain circumstances. On June 1, 2006, Mirant entered into an Administrative Consent Order (ACO) with the US Environmental Protection Agency (EPA) regarding the operation of the Plant. The DOE requires the Plant to operate at lower levels and to reduce sulfur dioxide emissions by using a compound known as "trona" (sodium sesquicarbonate) and/or lower sulfur coal. On June 2, 2006, the Department of Energy (DOE) instructed Mirant to comply with the ACO and operate as required under it. Operation of the Plant is necessary to ensure an uninterrupted supply of electricity to the District of Columbia. DOE has indicated that its order to comply with the ACO is scheduled to expire on October 1, 2006. The operation of the Plant from October 1, 2006 through summer 2007 under the terms of the DOE Order is the subject of this consultation. The DOE has made the determination that the operation of the Plant under the Order is not likely to adversely affect any species listed under the jurisdiction of NOAA's National Marine Fisheries Service (NMFS) and has requested that NMFS concur with this determination.


As noted in your letter, the only species listed under the jurisdiction of NMFS that may be present in the vicinity of the proposed project is the endangered shortnose sturgeon (*Acipenser brevirostrum*). During the 1996-2005 time period, the incidental capture of seventy-two different shortnose sturgeon in the Chesapeake Bay and its tributaries had been reported via the US Fish and Wildlife Service Atlantic sturgeon reward program. This number includes six shortnose sturgeon captured incidentally in fishing gear in the Potomac River. Additionally, researchers conducting a survey for shortnose sturgeon in the river captured one mature egg bearing female



in September 2005 and an additional mature egg bearing female in the same location in March 2006. Both fish have been outfitted with sonic tags and are being actively tracked by researchers. The female caught in September overwintered in the Potomac River near Mattawoman Creek. One of the females was documented at the presumed spawning grounds near Little Falls in the spring of 2006. The occurrence of pre-spawning females in the Potomac River suggests that a spawning population of shortnose sturgeon continues to exist in this river system. The Plant is located approximately 24 miles upstream of the suspected overwintering area. Population dynamics of shortnose sturgeon in the Potomac River have not been documented. However, based on patterns in other river systems, shortnose sturgeon likely migrate past the Plant while moving to and from the spawning grounds near Little Falls in the spring (March – June). It is unknown if shortnose sturgeon would occur in this region of the river during other times of the year. If appropriate forage items are present, shortnose sturgeon could also occur in the area in the summer and fall while foraging.

The continuation of operations from October 1, 2006 through summer 2007, would not result in any new construction or in-water disturbances at the plant. The only aspect of the Plant's continued operation that has the potential to impact shortnose sturgeon is the discharge of waste water from the Plant to the Potomac River. These discharges are authorized under a NPDES permit issued by the EPA. NMFS has previously consulted with the EPA on the NPDES permit for the Plant and determined that the discharges are not likely to adversely affect shortnose sturgeon. While the past operation of the plant has resulted in air quality impairments, there is no information available that indicates that the operation of the plant has had an adverse effect on water quality in the Potomac River. No other impacts from the operation of the Plant under the DOE order are likely. As such, NMFS concurs with DOE's determination that the continued operation of the Plant through summer 2007 is not likely to adversely affect any species listed under NMFS jurisdiction. Therefore, no further consultation pursuant to section 7 of the ESA is required. Should project plans change or new information become available that changes the basis for this determination, or a new species be listed or critical habitat designated, consultation should be reinitiated. Should you have any questions about this correspondence please contact Julie Crocker at (978) 281-9300 ext. 6530.

Sincerely,



Patricia A. Kurkul
Regional Administrator

Cc: Scida, F/NER3
Nichols, F/NER4
Williams, GCNE



United States Department of the Interior

FISH AND WILDLIFE SERVICE
Chesapeake Bay Field Office
177 Admiral Cochrane Drive
Annapolis, MD 21401
410/573-4575



November 20, 2006

*RE: Informal Consultation under Section 7 of the Endangered Species Act (ESA) for
Operation of the Potomac River generating Station in Alexandria, Va.*

Dear Mr. Como,

This responds to your letter, received November 20, 2006, requesting information on the presence of species which are federally listed or proposed for listing as endangered or threatened in the above referenced project area. We have reviewed the information you enclosed and are providing comments in accordance with section 7 of the Endangered Species Act (87 Stat. 884, as amended; 16 U.S.C. 1531 *et seq.*).

Except for occasional transient individuals, no proposed or federally listed endangered or threatened species are known to exist within the project impact area. Therefore, no Biological Assessment or further section 7 consultation with the U.S. Fish and Wildlife Service is required. Should project plans change, or should additional information on the distribution of listed or proposed species become available, this determination may be reconsidered.

This response relates only to federally protected threatened or endangered species under our jurisdiction. Limited information is currently available regarding the distribution of other rare species in the District of Columbia. However, the Nature Conservancy and National Park Service (NPS) have initiated an inventory of rare species within the District. For further information on such rare species, you should contact Mary Pfaffko of the National Park Service at (202)-535-1739.

An additional concern of the Service is wetlands protection. Federal and state partners of the Chesapeake Bay Program have adopted an interim goal of no overall net loss of the Basin's remaining wetlands, and the long term goal of increasing the quality and quantity of the Basin's wetlands resource base. Because of this policy and the functions and values wetlands perform, the Service recommends avoiding wetland impacts. All wetlands within the project area should be identified, and if alterations of wetlands is proposed, the U.S. Army Corps of Engineers, Baltimore District, should be contacted for permit requirements. They can be reached at (410) 962-3670.

We appreciate the opportunity to provide information relative to fish and wildlife issues, and

thank you for your interests in these resources. If you have any questions or need further assistance, please contact Devin Ray at (410) 573-4531.

Sincerely,

A handwritten signature in cursive script that reads "Mary Ratnaswamy". The signature is written in black ink and is positioned above the printed name and title.

Mary J. Ratnaswamy, Ph.D.
Program Supervisor, Threatened and Endangered Species

APPENDIX E

Organizational Conflict of Interest Statement

[This page intentionally left blank]

**NEPA DISCLOSURE STATEMENT FOR PREPARATION OF A
SPECIAL ENVIRONMENTAL ANALYSIS FOR ACTIONS TAKEN UNDER
DOE ORDER 202-05-3 REGARDING OPERATION OF THE POTOMAC RIVER
GENERATING STATION IN ALEXANDRIA, VIRGINIA**

CEQ Regulations at 40 CFR 1506.5(c), which have been adopted by the DOE (10 CFR 1021), require contractors who will prepare an environmental impact statement to execute a disclosure specifying that they have no financial or other interest in the outcome of the project. The term "financial interest or other interest in the outcome of the project" for purposes of this disclosure is defined in the March 23, 1981, guidance "Forty Most Asked Questions Concerning CEQ's National Environmental Policy Act Regulations," 46 FR 18026-18038 at Question 17a and b.

"Financial or other interest in the outcome of the project" includes "any financial benefit such as a promise of future construction or design work in the project, as well as indirect benefits the contractor is aware of (e.g., if the project would aid proposals sponsored by the firm's other clients)." 46 FR 18026-10838 at 10831.

In accordance with these requirements, the offeror and any proposed subcontractors hereby certify as follows: [check either (a) or (b) to assure consideration of your proposal].

- (a) X Offeror and any proposed subcontractor have no financial or other interest in the outcome of the project.
- (b) Offeror and any proposed subcontractor have the following financial or other interest in the outcome of the project and hereby agree to divest themselves of such interest prior to award of this contract.

Financial or Other Interests

- 1.
- 2.
- 3.

Certified by:



Signature

Gary K. Jacobs,
Director, Environmental Sciences Division
Printed Name and Title

Oak Ridge National Laboratory,
Managed for the U.S. Department of Energy
by UT-Battelle, LLC
Company

11-1-06

Date

[This page intentionally left blank]

APPENDIX F

Glossary

[This page intentionally left blank]

GLOSSARY

Anadromous - species that spend their adult lives in saltwater and spawn in freshwater.

Ash - the mineral content of a product remaining after complete combustion.

Baseload - generating units that produce power at a steady rate for extended periods.

Biochemical oxygen demand - a standard quantitative measure of water pollution. It is the amount of oxygen consumed in the biological oxidation (by bacteria or other microorganisms) of organic material in a unit volume of waste water, as measured over a five-day period.

Biochemical oxygen demand sometimes is divided into two components: carbonaceous oxygen demand and nitrogenous oxygen demand. Carbonaceous biochemical oxygen demand is the result of the breakdown of organic molecules such as cellulose and sugars, while nitrogenous oxygen demand is the result of the breakdown of proteins.

Biocide - a substance (e.g., chlorine) that is toxic or lethal to many organisms and is used to treat water.

Blowdown - the portion of steam or water removed from a boiler at regular intervals to prevent excessive accumulation of dissolved and suspended materials.

Bottom ash - combustion residue composed of large particles that settle to the bottom of a combustor from where they can be physically removed.

Calcining - the effects of heating a substance to a high temperature (below the melting or fusing point) at which point loss of moisture, reduction or oxidation, or the decomposition of carbonates and other compounds occurs.

Candidate species - plants and animals native to the United States for which the Fish and Wildlife Service or the National Marine Fisheries Service has sufficient information on biological vulnerability and threats to justify proposing to add them to the threatened and endangered species list, but cannot do so immediately because other species have a higher priority for listing. The Services determine the relative listing priority of candidate taxa in accordance with general listing priority guidelines published in the *Federal Register*. (See endangered species and threatened species.)

Cooling water - water that is heated as a result of being used to cool steam and condense it to water.

Cyanobacteria - blue-green algae.

Diadromous - fish spending part of their lives in both fresh and salt water.

Downwash (building) - the downward movement of an elevated plume toward the area of low pressure created on the lee side of a structure in the wake around which the air flows.

Electrostatic precipitator - a device that removes particles from a stream of exhaust gas. It imparts an electrical charge to the particles, which causes them to adhere to metal plates that can be rapped to cause the particles to fall into a hopper for disposal.

Endangered species - plants or animals that are in danger of extinction through all or a significant portion of their ranges and that have been listed as endangered by the Fish and Wildlife Service or the National Marine Fisheries Service following the procedures outlined in the Endangered Species Act and its implementing regulations (50 CFR 424). (See threatened species.) The lists of endangered species can be found in 50 CFR 17.11 (wildlife), 50 CFR 17.12 (plants), and 50 CFR 222.23(a) (marine organisms). The state of Virginia also lists species as endangered under its Endangered Species Act.

Entrainment - incorporation of any life stage of fish and shellfish with water flow entering and passing through a cooling water intake structure and into an industrial, municipal or electric utility power plant cooling water system.

Estuary - region of interaction between rivers and near-shore ocean waters, where tidal action and river flow mix fresh and salt water. Such areas include bays, mouths of rivers, salt marshes, and lagoons. These brackish water ecosystems shelter and feed marine life, birds, and wildlife. (See wetlands.)

Fall line - the boundary zone where the upland piedmont region meets the coastal plain. Waterfalls and rapids occur where rivers and streams cross the fall line.

Finfish - a fish with fins (which is most fish), in contrast to shellfish, crayfish, and jellyfish (which are not fish).

Fly ash - combustion residue composed of fine particles (e.g., soot) that are entrained with the draft leaving the combustor.

Fresh water - water with a low concentration of salts (typically less than 1,000 parts per million of dissolved solids).

Hazardous waste - a category of waste regulated under the Resource Conservation and Recovery Act (RCRA). To be considered hazardous, a waste must be a solid waste under RCRA and must exhibit at least one of four characteristics described in 40 CFR 261.20 through 40 CFR 261.24 (i.e., ignitability, corrosivity, reactivity, or toxicity) or be specifically listed by the Environmental Protection Agency in 40 CFR 261.31 through 40 CFR 261.33.

Impingement - the entrapment of any life stage of fish and shellfish on the outer part of an intake structure or against a screening device during intake water withdrawal.

Leachate - solution or product obtained by leaching, in which a substance is dissolved by the action of a percolating liquid.

Load following - power generating units that are capable of changing power levels quickly as demand rises or falls. They are also known as cycling units.

pH - a measure of the relative acidity or alkalinity of a solution, expressed on a scale from 0 to 14, with the neutral point at 7. Acid solutions have pH values lower than 7, and basic (i.e., alkaline) solutions have pH values higher than 7.

Plume (atmospheric) - a visible or measurable, elongated pattern of emissions spreading downwind from a source through the atmosphere.

Pozzolanitic - material that when mixed with water “sets,” like cement.

Riparian - areas adjacent to rivers and streams with a differing density, diversity, and productivity of plant and animal species relative to nearby uplands.

Saline - describes water with high concentrations of salts (typically more than 10,000 parts per million dissolved solids), making it unsuitable for use.

Stratosphere - the portion of the atmosphere 10 to 25 mi (16 to 40 km) above the earth's surface.

Threatened species - any plants or animals that are likely to become endangered species within the foreseeable future throughout all or a significant portion of their ranges and which have been listed as threatened by the Fish and Wildlife Service or the National Marine Fisheries Service following the procedures set out in the Endangered Species Act and its implementing regulations (50 CFR 424). (See endangered species.) The lists of threatened species can be found at 50 CFR 17.11 (wildlife), 17.12 (plants), and 227.4 (marine organisms). The state of Virginia also lists species as threatened under its Endangered Species Act.

Tidal river - a river segment with fresh water (salinity less than 500 mg/L) and a net seaward flow direction throughout the water column.

Transmission (electric) - movement of electrical power from the source where it is produced to end users.

Trona - a naturally occurring chemical compound, sodium sesquicarbonate, similar to baking soda.

Troposphere - the layer of the atmosphere closest to the earth's surface.

Watershed - the region draining into a river, river system, or other body of water.

Wetlands - areas that are inundated or saturated by surface water or groundwater at a frequency and duration sufficient to support, and that under normal circumstances do support, a prevalence of vegetation typically adapted for life in saturated soil conditions, including swamps, marshes, bogs, and similar areas.

Wind rose - a graph in which the frequency of wind blowing from each direction is plotted as a bar that extends from the center of the diagram. Wind speeds are denoted by bar widths and shading; the frequency of wind speed within each wind direction is depicted according to the length of that section of the bar.

Attachment I

MPSC Case No. U-21090, Settlement Agreement

April 20, 2022

Ms. Lisa Felice
Executive Secretary
Michigan Public Service Commission
7109 West Saginaw Highway
Post Office Box 30221
Lansing, MI 48909

General Offices:
One Energy Plaza
Jackson, MI 49201

Tel: (517) 788-0550
Fax: (517) 768-3644

*Washington Office:
1730 Rhode Island Ave. N.W.
Suite 1007
Washington, DC 20036

Tel: (202) 778-3340
Fax: (202) 778-3355

Writer's Direct Dial Number: (517) 788-1846
Writer's E-mail Address: robert.beach@cmsenergy.com

LEGAL DEPARTMENT
SHAUN M. JOHNSON
Senior Vice President
and General Counsel

MELISSA M. GLEESPEEN
Vice President, Corporate
Secretary and Chief
Compliance Officer

KELLY M. HALL
Vice President and Deputy
General Counsel

Emerson J. Hilton
Adam C. Smith
Bret A. Totoraitis
Assistant General Counsel

Robert W. Beach
Ian F. Burgess
Don A. D'Amato
Gary A. Gensch, Jr.
Matthew D. Hall
Georgine R. Hyden
Katie M. Knue
Robert F. Marvin
Jason M. Milstone
Rhonda M. Morris
Deborah A. Moss*
Maxwell K. Multer
Chantez L. Pattman
Michael C. Rampe
Scott J. Sinkwitz
Theresa A.G. Staley
Janae M. Thayer
Anne M. Uitvlugt
Aaron L. Vorce
Attorney

RE: Case No. U-21090 – In the Matter of the Application of Consumers Energy Company for Approval of an Integrated Resource Plan under MCL 460.6t, certain accounting approvals, and for other relief.

Dear Ms. Felice:

Pursuant to Rule 431, R 792.10431, enclosed for electronic filing in the above-captioned proceeding, please find a **Settlement Agreement** which is intended to resolve all outstanding issues in this proceeding. The Settlement Agreement has been executed by Consumers Energy Company, the Michigan Public Service Commission Staff, Michigan Environmental Council, the Natural Resources Defense Council, the Sierra Club, Attorney General Dana Nessel, Environmental Law and Policy Center, Vote Solar, Ecology Center, Union of Concerned Scientists, Urban Core Collective, Citizens Utility Board of Michigan, Hemlock Semiconductor Operations, LLC, Michigan Energy Innovation Business Council, Institute for Energy Innovation, Clean Grid Alliance, Michigan Electric Transmission Company, LLC, and Great Lakes Renewable Energy Association.

Also included are the signatures of the following parties who do not join the settlement but are offering a statement of non-objection: Michigan Public Power Agency and Midland Cogeneration Venture, LP.

Energy Michigan Inc., Wolverine Power Supply Cooperative Inc., the Mackinac Center for Public Policy, Residential Customer Group, the Biomass Merchant Plants¹, and the Association of Businesses Advocating Tariff Equity have not signed the settlement and have not indicated that they will sign a statement of non-objection.

The Company respectfully requests that, pursuant to Rule 431(3), the Commission establish a reasonable time for response to this submittal, but in no event later than 14 days from April 20, 2022.

¹ The BMPs consist of: Cadillac Renewable Energy, LLC, Genesee Power Partners Limited Partnership, Decker Energy-Grayling, LLC, Hillman Power Company, LLC, Tondu Corporation, National Energy of Lincoln, LLC, f/k/a Viking Energy of Lincoln, LP and National Energy of McBain, f/k/a Viking Energy of McBain, LLC.

This is a paperless filing and is therefore being filed only in PDF. I have enclosed a Proof of Service showing electronic service upon the parties.

Sincerely,

A handwritten signature in black ink, appearing to read 'RWB', with a horizontal line extending to the right.

Digitally signed by
Robert W. Beach
Date: 2022.04.20 09:59:15
-04'00'

Robert W. Beach

cc: Parties per Attachment 1 to the Proof of Service

STATE OF MICHIGAN
BEFORE THE MICHIGAN PUBLIC SERVICE COMMISSION

In the matter of the application of	)	
CONSUMERS ENERGY COMPANY	)	
for Approval of an Integrated Resource Plan	)	Case No. U-21090
under MCL 460.6t, certain accounting	)	
approvals, and for other relief.	)	
_____	)	

SETTLEMENT AGREEMENT

Pursuant to MCL 24.278 and Rule 431 of the Michigan Administrative Hearing System’s Rules of Practice and Procedure before the Michigan Public Service Commission (“MPSC” or the “Commission”), the undersigned parties agree as follows:

WHEREAS, on June 30, 2021 Consumers Energy Company (“Consumers Energy” or the “Company”) filed an Application requesting approval of the Company’s Integrated Resource Plan (“IRP”) pursuant to Section 6t of 2016 PA 341, MCL 460.6t, the Commission’s June 7, 2019 Order Approving Settlement Agreement in Case No. U-20165, and all other orders and applicable law. The Company filed testimony and exhibits in support of its positions concurrently with its Application.

WHEREAS, the initial prehearing conference was held on July 22, 2021 before Administrative Law Judge (“ALJ”) Sally L. Wallace. Beyond the Company, the parties to the IRP are: the MPSC Staff (“Staff”); the Attorney General; Hemlock Semiconductor Operations, LLC (“HSC”); the Biomass Merchant Plants (“BMPs”)¹; Michigan Environmental Council, Natural Resources Defense Council, and Sierra Club (“MNS”); Great Lakes Renewable Energy

¹ The BMPs consist of: Cadillac Renewable Energy, LLC, Genesee Power Partners Limited Partnership, Decker Energy-Grayling, LLC, Hillman Power Company, LLC, Tondur Corporation, National Energy of Lincoln, LLC, f/k/a Viking Energy of Lincoln, LP and National Energy of McBain, f/k/a Viking Energy of McBain, LLC.

Association (“GLREA”), Environmental Law and Policy Center, the Ecology Center, Vote Solar, and the Union of Concerned Scientists (collectively, the Clean Energy Organizations (“CEO”)); Residential Customer Group (“RCG”); Association of Businesses Advocating Tariff Equity (“ABATE”); Michigan Energy Innovation Business Council, Institute for Energy Innovation, and the Clean Grid Alliance (collectively, “Michigan EIBC/IEI/CGA”); Energy Michigan, Inc. (“Energy Michigan”); Midland Cogeneration Venture Limited Partnership (“MCV”); Michigan Electric Transmission Company, LLC (“METC”); Michigan Public Power Agency (“MPPA”); Wolverine Power Supply Cooperative (“Wolverine”); the Citizens Utility Board (“CUB”); the Mackinac Center for Public Policy (“Mackinac”); and the Urban Core Collective (“UCC”). 1 TR 11-12, 22.

WHEREAS, Consumers Energy filed testimony and exhibits requesting approval of the Company’s IRP Proposed Course of Action (“PCA”) in its entirety, as the most reasonable and prudent means of meeting the Company’s energy and capacity needs through 2040. The Company specifically requested the Commission to make the following determinations:

- (i.) Approve Consumers Energy’s PCA, which is inclusive of all proposals presented by the Company in this case, including the battery deployment program, as the most reasonable and prudent means of meeting the energy and capacity needs of the Company and its customers;
- (ii.) Approve the Company’s acquisition and proposed purchase costs for the New Covert Generating Facility (“Covert Plant”) and Dearborn Industrial Generation (“DIG Plant”), the Livingston Generating Station (“Livingston Plant”), and the Kalamazoo River Generating Station (“Kalamazoo Plant”), in the manner proposed by the Company, and proposed Energy Waste Reduction (“EWR”), Demand Response (“DR”), and Conservation Voltage Reduction (“CVR”) costs which will be commenced by the Company within three years following the Commission’s expected approval of the Company’s IRP;
- (iii.) Approval of the selection and proposed purchase of the DIG, Kalamazoo, and Livingston plants, by the Company from its affiliate, CMS Enterprises. The transaction was a result of a competitive solicitation and is compliant with the Commission’s Code of Conduct requirements. In the alternative, while complying with all other provisions of the Code of Conduct, the Company

requests a waiver of the asset transfer provision of the Code of Conduct, Mich Admin Code R 460.10108(4), for the acquisition of the DIG, Livingston, and Kalamazoo plants, from CMS Enterprises;

- (iv.) Approve the Company's proposal to recover the unrecovered book balances of D.E. Karn ("Karn") Units 3 and 4 and J.H. Campbell ("Campbell") Units 1, 2, and 3, including decommissioning costs, through regulatory asset treatment, with full return, over the design lives of those units;
- (v.) Approve the Company's proposals to: (i) defer employee retention costs related to the proposed accelerated retirements of Karn Units 3 and 4 and Campbell Units 1, 2, and 3, and (ii) defer retirement transition costs for future recovery;
- (vi.) Approve the Company's proposed modifications to its Public Utility Regulatory Policies Act of 1978 ("PURPA") construct and the Company's proposed competitive procurement process and the use of that competitive procurement process for: (i) determining PURPA avoided costs rates, and (ii) determining and addressing the Company's capacity position under PURPA;
- (vii.) Determine that the Company has no PURPA capacity need so long as the Company is implementing the PCA, with the competitive procurement process proposed by the Company; and
- (viii.) Approve the Company's proposed Financial Compensation Mechanism ("FCM") for any new, or newly amended, Power Purchase Agreements ("PPAs") entered into by the Company.

Staff and other intervening parties filed testimony and exhibits addressing various issues.

NOW THEREFORE, for purposes of settlement of Case No. U-21090, the undersigned parties agree as follows:

1. The parties agree that the Company's PCA, as modified in this Settlement Agreement, should be approved as the most reasonable and prudent means of meeting the Company's energy and capacity needs over the 5-year, 10-year, and 15-year time horizons. The parties agree that the Company will file its next IRP consistent with the requirements of MCL 460.6t.

2. The parties agree that the PCA shall include the Company's proposed purchase of the Covert Plant in 2023 but shall not include the ownership of the DIG, Kalamazoo, and

Livingston plants. The parties agree that the identified capital costs that the Company will incur for DR (\$23,751,000), CVR (\$9,736,315), and the purchase of the Covert Plant (\$815 million) in the next three years (June 2022 – June 2025) are reasonable and prudent and approved for cost recovery purposes and will be included in rates in a future Company rate case consistent with MCL 460.6t(11) and (17). The parties further agree to the approval of the projected capacity value provided by the Covert Plant and the DR (projected to achieve a total of 641 MW (657 Zonal Resource Credits (“ZRCs”)) by 2025), CVR (projected to achieve 136,351 MWh savings by 2025, 56.81 MW savings by 2025), and EWR (projected to achieve 545,305 MWh savings in 2025, 879 MW savings by 2025) resources included in the PCA during the next three years. The parties further agree that the Company shall continue to file an annual reporting template with the Commission addressing the implementation of the approved DR and CVR resources above.

3. The parties agree to the approval of the battery deployment program as proposed by Company witness Richard T. Blumenstock. The parties agree that the Company will conduct stakeholder outreach to solicit feedback regarding the battery deployment program prior to the issuance of the first battery deployment program competitive solicitation. The approval to recover the costs associated with the batteries acquired in the battery deployment program will be sought in future electric rate cases.

4. The parties agree that (i) Karn Units 3 and 4 will be retired on or before May 31, 2031, absent extraordinary circumstances that require prolonged operation, such as a System Support Resource designation by Midcontinent Independent System Operator, Inc. (“MISO”) or other emergent issues within the Company’s generation portfolio which require continued

operation of Karn Units 3 and 4 to maintain sufficient supply; and (ii) Campbell Units 1, 2, and 3 will be retired on or before May 31, 2025.

5. The parties agree that the Company will not file an application for a financing order for the unrecovered book balance and decommissioning costs of Campbell Units 1, 2, and 3. The parties agree that the Commission will permit Consumers Energy to recover the unrecovered book balance of Campbell Units 1, 2, and 3 through the Company's proposed regulatory asset treatment, with a return equal to the Company's weighted average cost of capital ("WACC") premised on the return on equity approved by the Commission in rate cases prior to the retirement date of those units and a 9.0% return on equity after the retirement date of those units, as part of the Company's electric rates over the current design lives of those units. The 9.0% return on equity will be used to modify the capital structure filed with each rate case and the return on equity will be the only modification to the capital structure used to calculate the return on the regulatory asset after the retirement date of the units. The parties further agree that the Company will be permitted to record a regulatory asset for actual decommissioning spending for Campbell Units 1, 2, and 3, with a return on the regulatory asset, with subsequent rate recovery in a rate case after a review of the reasonableness and prudence of the expenses. Recovery of the associated decommissioning and ash disposal costs will be treated as follows:

- a. The decommissioning costs, less salvage value, related to Campbell Units 1, 2, and 3 and the ash disposal costs related to Campbell Units 1, 2, and 3 will be recorded, as spent, to a regulatory asset; and
- b. The Company may request recovery in future base rate proceedings, and upon Commission determination that the Company has incurred those costs as the result of reasonable and prudent actions, they shall be included in rates. The Company will ensure that the amounts recovered through a regulatory asset account are net of any accumulated depreciation amounts.

6. The parties agree that subsequent to the Commission's order approving this Settlement Agreement, the Company shall issue a competitive solicitation ("the One-Time Solicitation") which will include the following parameters:

- a. The One-Time Solicitation will seek projects which will provide the Company with capacity credit in the MISO Zone 7 starting in the 2025 Planning Year;
- b. The One-Time Solicitation will include two all source tranches:
 - i. The first tranche will seek up to 500 ZRCs of capacity and associated energy and renewable energy credits ("RECs"), if applicable, from PPAs with terms up to 10 years. This tranche will seek dispatchable, non-intermittent generation capable of dispatching up or down in every hour of the year in response to wholesale energy market signals, providing capacity which meets the Local Clearing Requirement of MISO Zone 7; and
 - ii. The second tranche will seek up to 200 ZRCs of capacity and associated energy and RECs, if applicable, secured from unaffiliated third parties via PPAs or other third-party agreements that do not result in Company ownership with terms up to 25 years, at the discretion of the bidder. This tranche will seek intermittent resources and dispatchable, non-intermittent clean capacity resources (including battery storage resources), providing capacity which meets the Local Clearing Requirement of MISO Zone 7. This tranche will furthermore take into consideration the ability of the offered capacity to meet the Local Clearing Requirement of MISO Zone 7 for the duration of the contract length. Prior to the issuance of the second tranche portion of the One-Time Solicitation, the Company shall hold a stakeholder meeting including parties to this case and energy storage developers to discuss methods to improve RFPs and response to solicitations with respect to stand-alone storage projects and hybrid-storage projects.
- c. The Company's acquisition of the 700 ZRCs and associated energy and RECs, if applicable, sought in the One-Time Solicitation shall be considered incorporated into the PCA approved in Paragraph 1 of this Settlement Agreement. However, the actual selected bid(s) will be submitted in Case No. U-21090 for Commission approval subsequent to the completion of the One-Time Solicitation;
 - i. In that approval proceeding, the Commission shall: (i) confirm whether the solicitation process followed by the Company is consistent with the requirements of the Settlement Agreement; (ii) grant approval of the recovery of the costs associated with the selected project(s) pursuant to applicable law or make a preliminary finding that the costs associated

with the project(s) that prevail in the solicitation are reasonable and prudent; and (iii) grant any other approvals or findings necessary as required or provided by applicable law.

- d. The One-Time Solicitation will not be used to set the Company's avoided costs rates or capacity needs under PURPA.

7. The parties agree to the approval of the Company's proposed accounting request to defer expense related to the Campbell site severance and retention agreement, utilizing a regulatory asset to record the deferred amounts. The deferred amounts for 2022 will be capped at \$26 million. All amounts deferred for 2022 and beyond will be reviewed in future rate cases. This Settlement Agreement does not permit the Company to defer amounts related to the Campbell site severance and retention agreement outside of 2022.

- a. Consumers Energy will publicly file in Case No. U-21090 its community transition plan for Karn Units 1 through 4 within 150 days of all four Karn Units ceasing operation; and
- b. Consumers Energy will develop a draft community transition plan for the Campbell site. During the development of this draft community transition plan for the Campbell site, Consumers Energy will consult with community-based organizations and community members living in the area surrounding the retired assets on the community transition plan before finalizing and filing it for informational purposes in Case No. U-21090.

8. The parties agree to the extension of the annual competitive bidding process used to acquire the supply-side resource technologies specified in the PCA, as approved in Case No. U-20165 (collectively the "Annual Solicitations" and individually an "Annual Solicitation"), with certain modifications included below:

- a. Qualifying Facilities ("QFs") that the Company has a legal obligation to purchase from under PURPA (such facilities are referred to as "QFs" in this Settlement Agreement), may bid any technology into the Annual Solicitation but will be required to submit an offer consistent with the PPA terms sought in the Annual Solicitation;
- b. The competitive bid process shall be administered by an independent third party. The evaluation criteria and process is to be made available to all bidders submitting responses for the specific technology requested by the

Company, as part of the RFP, to ensure transparency. QFs may bid any technology that meets the requirements of PURPA. A ranking of proposals is to be used by the independent third party and provided to the Company for selection;

- c. In its September 9, 2021 Order in Case No. U-20852 the Commission adopted competitive bidding guidelines titled “Competitive Procurement Guidelines for Rate-Regulated Electric Utilities (Not for PUPRA Compliance) and “Competitive Procurement Guidelines For Rate-Regulated Electric Utilities for PURPA Avoided Cost and Capacity Determination.” The “Objective” of the adopted guidelines provides that when the guidelines are utilized by utilities, it is presumed that resulting projects and contracts are reasonable and prudent and in the event utilities diverge from the guidance provided in the guidelines, it is expected that the utility will provide sufficient justification in order to receive Commission approval and recovery. In the Annual Solicitation process, the Company will follow the Commission’s adopted guidelines, including the ability to diverge from the guidance as provided in the guidelines;
- d. The first competitive solicitation for the Company pursuant to this Settlement Agreement will be conducted no later than December 31, 2022. New full avoided cost rates stemming from each competitive solicitation will be filed with the Commission for review and approval within 30 days of the conclusion of each competitive solicitation;
- e. The Company will seek term lengths for competitively bid projects up to 25 years, at the discretion of the bidder;
- f. The Company will seek to acquire the target amount of capacity identified in the PCA for each Annual Solicitation period and may exceed that target amount depending on the amount of bids, the size of projects bid, cost and value, and variations in project commercial operation dates. Total newly acquired capacity will be reconciled against the amount of capacity projected in the PCA in the Company’s next IRP. (For example, if the Company acquired more capacity than planned, the proposed resource plan in the next IRP would incorporate that additional capacity with a potential reduction in the capacity needed going forward.);
- g. If the Company is unable to meet the target capacity amount identified in the PCA in any given Annual Solicitation, the remaining "open" capacity will not be offered to QFs. The remaining capacity would instead be addressed through the process described in Paragraph 8.f.;
- h. The parties agree and acknowledge that there are supply chain, energy security, labor, and environmental benefits associated with robust, local clean energy manufacturing capabilities. As part of the Company’s competitive bidding process, the parties agree that the Company will, to the extent

reasonably possible, incorporate clear, fair, and transparent criteria in the bid evaluation process to recognize value associated with clean energy supply chain diversification and sustainability, including intended use of Michigan manufactured components and low-carbon manufacturing as verifiable by life cycle assessment and/or disclosure using public, third-party verified environmental product declarations. The Company agrees to consult with parties to the settlement on the details of such bid evaluation criteria. Nothing in this settlement alters the opportunity for stakeholders and potential bidders to review and comment on any new proposed bidding criteria through the process as set forth in the MPSC's competitive bidding guidelines approved in MPSC Case No. U-20852 on September 9, 2021;

- i. The parties agree that the Annual Solicitation process does not restrict the Company's ability to make short-term capacity additions to address capacity shortfalls which cannot reasonably be addressed through the Annual Solicitation process; and
- j. The Company may pursue supply-side resource pilots for new and emerging technologies outside of an Annual Solicitation subject to cost and project approval in its future rate cases.

9. The parties agree that the new capacity that the Company intends to procure through the PCA, in each Annual Solicitation, shall be: (i) acquired through a competitive bidding process; and (ii) approximately 50% will be from PPAs and other third-party agreements that do not result in Company ownership and approximately 50% will be owned by the Company, as acquired through a competitive bidding process. The new capacity acquired from PPAs or other third-party agreements that do not result in Company ownership will not compete against the new capacity which will be owned by the Company. The Company will use commercially reasonable efforts to maintain the 50%/50% proportion for new IRP resources from 2022 through the Company's next IRP proceeding, and in no event shall any given annual solicitation result in the Company owning more than 60% of the new capacity acquired in such solicitation. The Company, in its sole discretion, may also choose to acquire more than 50% of its new capacity from third parties. The parties further agree that the Company's affiliates will

be prohibited from bidding on the portion of the Company's new capacity acquired from third parties.

10. The parties agree to the approval of the extension of the Company's FCM approved in Case No. U-20165 equal to the product of: (i) the annual PPA payment, and (ii) the Company's after-tax WACC based on its total capital structure, which is currently 5.62%, as updated from time to time by the MPSC in electric rate case final orders. The FCM will be applicable to all new PPAs, but will not apply to PPA amendments, PURPA PPAs, and Voluntary Green Pricing PPAs. The Company shall also not receive an FCM on any PPAs executed under the Company's Renewable Energy Plan. The FCM will be subject to the cap, as provided in Attachment A of the Settlement Agreement. The parties agree that nothing in this Settlement Agreement is intended to waive the requirements of MCL 460.6t(15).

11. The parties agree to the extension of the Company's PURPA avoided cost construct, as approved in Case No. U-20165 (based on the Company's Annual Solicitations), with certain modifications included below:

- a. The Company's PURPA avoided cost construct will be subject to review in the Company's future IRP filings, as opposed to separate biennial filings;
- b. QFs 150 kWac and below are eligible to receive full avoided cost rates regardless of the Company's capacity needs;
- c. Within 180 days subsequent to the Commission's approval of this Settlement Agreement, the Company shall initiate stakeholder outreach to develop a simplified agreement, tariff-based program, or other mechanism which will allow QFs 150 kWac and below to receive full avoided cost rates. Subsequent to the completion of the stakeholder outreach, at the earliest practicable date, the Company will file a proposal with the Commission for approval;
- d. When the Company does not have a PURPA capacity need, QFs above 150 kWac, that the Company has a legal obligation to purchase from under PURPA, are eligible to receive the Company's energy-only avoided cost rates. The Company's energy-only avoided cost rates shall be based on a forecast of LMPs for the first 5 years and actual LMPs for years 6 through 10. The

Company's energy-only avoided cost rates shall not include a payment for capacity;

- e. Current existing QFs, at or below the Company's PURPA must-purchase obligation MW threshold, with a PURPA-based PPA with the Company as of January 1, 2019 shall receive new PPAs, regardless of the Company's capacity need, upon the expiration of their current PPAs based on the Company's full avoided cost rates at the time of PPA expiration. QFs that entered a PPA with the Company prior to January 1, 2019 at an amount less than full avoided cost rates, such as reduced avoided cost rates based on the Planning Resource Auction ("PRA") rate and forecasted or actual LMPs and energy-only rates which only include an energy rate and do not provide a payment for capacity, shall not automatically receive a new PPA at the full avoided cost rate when their current PPA expires. QFs that have entered a PPA with the Company after January 1, 2019 are not eligible to receive a new full avoided cost rate PPA with the Company regardless of the Company's capacity need;
- f. QFs that the Company has a legal obligation to purchase from under PURPA, and which are eligible for full avoided cost rates, may select PPA terms up to 20 years; and
- g. QFs up to 5 MWac, that the Company has a legal obligation to purchase from under PURPA, are eligible for the Company's PURPA Standard Offer Tariff and Standard Offer Contract. The terms of the Standard Offer Contract will also be updated from using the MISO methodology for capacity accreditation at the time of PPA execution, to the average of the MISO methodologies at the time of PPA execution and delivery under the PPA. Within 30 days following the Commission's approval of this Settlement Agreement, the Company shall file revised Standard Offer tariff sheets and a revised Standard Offer contract, to reflect the Standard Offer construct and rates approved as part of this Settlement Agreement. Parties shall be given 14 calendar days subsequent to the Company's filing to provide comments to the Commission.

12. The Company has no PURPA capacity need so long as the Company is implementing the Commission-approved PCA, as provided in Paragraph 1, including the competitive Annual Solicitation process for future capacity needs.

13. The parties agree that the Company will donate \$5 million in 2022 to a low-income fund that provides bill assistance to Consumers Energy's electric customers. The Company will also donate \$2 million annually to the same low-income fund each year during the amortization period for the regulatory asset, provided in Paragraph 5 of this Settlement

Agreement, with each annual donation contingent on the Company filing and the Commission approving a Voluntary Revenue Refund (“VRR”). The donations described in this paragraph will not be recovered in rates and Consumers Energy will consult with the Attorney General and Staff on the low-income fund receiving the donations. The Company will provide an annual report to the Commission each year a donation is made. If known, the report will include the number of households served, the number of households over 150% of the federal poverty level (“FPL”), and number under 150% of the FPL. For those households 150% of FPL and under, the report will explain, if known, whether they are receiving the funds because they exhausted other benefits such as the Michigan Energy Assistance Program or State Emergency Relief.

14. In future IRPs, beginning with its next IRP, the Company will (i) collect the necessary data to compute marginal line losses and report these with average line losses and (ii) include marginal line losses and avoided transmission and distribution costs in its evaluation of all distributed resources, including residential DR potential.

15. Consumers Energy agrees to develop a distributed generation as a resource model approach that considers economic distribution connected solar to be modeled by bundling resources installed at the customer level to compare the total economic costs to the utility of distributed generation as a resource to other selectable supply-side resources, consistent with the methodology used for EWR. The Company will develop a model that accounts for all utility costs and/or incentives associated with participating and non-participating distributed generation customers. The Company agrees to present the model approach for stakeholder review and feedback prior to the next IRP. The model approach, including any incorporated stakeholder feedback, will be included into the Company’s next IRP.

16. The parties agree that Consumers Energy's IRP set forth a proposal to be Carbon Neutral by 2040 and retire all coal generation by 2025, 14 years ahead of the original timeline. These retirements include two substantial coal and gas units totaling approximately 2,000 MW. To replace the capacity, Consumers Energy has proposed adding existing natural gas-fired generation and plans to add about 8,000 MW of solar generation by 2040, to dramatically reduce the use of fossil fuel resources. The next IRP should consider transmission and how it can facilitate the mitigation of reliability and economic impacts to the electric system. The parties also agree that strategic investment in electric transmission needs continual assessment to understand the role of transmission in allowing for the most economic path to meeting the state's energy goals while complementing Michigan's Load Serving Entities' ("LSE") objectives. Michigan is transitioning its generation portfolio and must take the appropriate steps to increase system reliability, resiliency, flexibility, and affordability. Michigan will be better positioned by taking a forward-looking approach regarding resource adequacy. The state should continue to recognize and support the value of a multitude of resources such as Solar, Wind, DR, and Distributed Energy Resources which assist in an "all of the above" approach. Transmission is essential in delivering the reliability of these resources. The value of transmission can be even further realized by leveraging those transmission resources to better assist the Consumers Energy IRP. This will allow MISO LRZ 7 to access broader pools of generation resources, be better situated for future demands placed on the system, mitigate unnecessary risks, and increase performance of those "all of the above" resources to serve the demands of Michigan's customers reliably and economically.

17. The parties agree that the Company will include the following analysis in its next IRP:

- a. The Company will provide total emissions, in lbs or tons, and rate of emissions, in lbs or tons per MWh and per MMBtu, for each owned power plant unit, or units that the Company has a power purchase agreement with, for the last 5 years of operation (for existing units) and projected for the next 5 years (for all units) for the following pollutants: carbon dioxide, nitrogen oxides, sulfur dioxide, volatile organic compounds (“VOCs”), and primary particulate matter (“PM2.5”);
- b. The Company will calculate the annual PM2.5-related health impacts associated with each power plant’s emissions. The modeling will include the impacts from primary PM2.5 emissions and PM2.5 precursors emissions (nitrogen oxides, sulfur dioxide, VOCs). The Company will use one model to evaluate the number and economic value of PM2.5-related health impacts of these emissions. The Company may use COBRA or BenMAP (which will require pollutant change inputs from another model such as InMAP) for these calculations, or models that are of equal or greater complexity and accuracy. The Company will report the total number and economic value of PM2.5-related health impacts across the US for the chosen model and spatially by Michigan county or at a higher resolution;
- c. The Company will use the MiEJScreen mapping and screening tool, or, if the MiEJScreen tool is not yet finalized, the EPA Environmental Justice Screening and Mapping Tool (“EJSCREEN”), to assess populations in a 1-mile and 3-mile buffer around each power plant location, including reporting total populations and any indicators and total index results above the 75th percentile;
- d. The Company will report projected low-income energy efficiency participation levels, low-income load-reduction data, and publicly available rooftop solar adoption rates. If available, information on rooftop solar adoption by low-income customers will be provided;
- e. The Company will include a narrative discussion of how the data obtained in a-d were considered by the utility; and
- f. To the extent that the Commission formally adopts revised Integrated Resource Plan Filing Requirements and/or revised Michigan Integrated Resource Planning Parameters that address environmental emissions, health impacts from emissions, or environmental justice, such filing requirements will supersede the terms of this Paragraph 17.

18. The parties agree that the Company will take the following steps to engage and gather input from the public prior to the filing of its next IRP with the Commission:

- a. Host meetings about the topic of the filing at a variety of times, during the daytime and the evening, with the Company providing equivalent content and equivalent and sufficient time for robust public response at each session;
- b. Host meetings about the topics in the filing with a roughly equal mix between (i) in-person meetings and (ii) virtual or hybrid meetings;
- c. For the duration of the proceedings before the MPSC, make available on its website recordings of (i) all virtual or hybrid meetings and (ii) to the extent feasible, any portion of an in-person meeting in which the Company is (a) addressing all participants in the meeting and/or (b) receiving public feedback and/or questions in a format intended to be heard by all participants in the meeting at the same time;
- d. When requested 10 business days prior to a meeting, provide translations of materials for the benefit of those communities whose first language is not English, based on the demographics of the community;
- e. When requested within 30 days subsequent to a meeting, the Company will use best efforts to provide a translation of recordings of the community meeting in a language specified by the person requesting the translation. Such translation recordings will be provided within 15 business days, subject to the Company's best efforts, after the request is received. If the Company is unable, after a good faith effort, to find or reasonably engage the services of a translator capable of translating the recording into the language requested, the Company will not be obligated to provide the translation;
- f. When requested at least 10 business days prior to an in-person meeting, the Company will use best efforts to include at least one live interpreter who can translate in the requested language. If the Company is unable, after a good faith effort, to find or reasonably engage the services of a translator capable of translating the meeting into the language requested, the Company will not be obligated to provide the translation;
- g. Coordinate with community-based organizations when organizing and promoting meetings about the filing. The Company will solicit input regarding the time, place, and manner of the meetings from the community organizations, in addition to any other meetings the Company wishes to hold of its own accord;
- h. Use best efforts to present the details of the integrated resource planning process in accessible, non-technical language that includes, but is not limited to, descriptions of the impacts of the Company's plans on communities, the environment, and public health;
- i. Include in its filings a concise general statement of the basis and purpose of the comments received by the Company and how the Company considered,

addressed, or rejected the issues raised in those comments in the IRP (as practicable); and

- j. Subsequent to the issuance of the Commission's order approving this Settlement Agreement, the Company agrees to meet with UCC to discuss potential stakeholder outreach prior to or subsequent to future electric rate case filings.

19. The parties agree that the Company will do the following with respect to combined heat and power ("CHP") resources:

- a. Within 180 days of the effective date of the Commission's order approving the settlement, the Company will initiate a voluntary survey among its commercial and industrial customers to gauge interest in CHP (the "CHP survey"), with survey responses intended to be used by the Company to support the evaluation of: (1) the types of CHP that customers prefer, with regard to size, technology and overall configuration, on both the demand side and supply side, including co-ownership arrangements and other potential partnerships with the Company, and: (2) non-confidential information regarding locations within the Consumers Energy territory that may be most appropriate for deployment of CHP. The CHP survey will be conditioned on respondent approval of the public release of all information provided by the respondent in response to the survey. Nothing in this section is intended to require the public release of any confidential and/or commercially sensitive customer or Company information;
- b. Within 360 days of the effective date of the Commission's order approving the settlement, the Company will share the results of the CHP survey in the Case No. U-21090 e-docket, including a summary of the types of CHP that customers prefer, with regard to size, technology, and overall configuration, on both the demand side and supply side, including co-ownership arrangements and other potential partnerships with the Company; and a summary of non-confidential information regarding locations within the Company's territory that may be most appropriate for deployment of CHP, according to the CHP survey results;
- c. In its next IRP proceeding, the Company will model behind-the-meter CHP representative of a demand-side resource based upon the results from the CHP survey as appropriate; and
- d. In its next IRP proceeding, the Company will model front-of-the-meter CHP configurations based upon the results from the CHP survey as appropriate.

20. This settlement is entered into for the sole and express purpose of reaching a compromise among the parties. All offers of settlement and discussions relating to this settlement are, and shall be considered, privileged under MRE 408. If the Commission approves this Settlement Agreement without modification, neither the parties to this Settlement Agreement nor the Commission shall make any reference to, or use, this Settlement Agreement or the order approving it, as a reason, authority, rationale, or example for taking any action or position or making any subsequent decision in any other case or proceeding; provided, however, such references may be made to enforce or implement the provisions of this Settlement Agreement and the order approving it.

21. This Settlement Agreement is based on the facts and circumstances of this case and is intended for the final disposition of Case No. U-21090. So long as the Commission approves this Settlement Agreement without any modification, the parties agree not to appeal, challenge, or otherwise contest the Commission order approving this Settlement Agreement. Except as otherwise set forth herein, the parties agree and understand that this Settlement Agreement does not limit any party's right to take new and/or different positions on similar issues in other administrative proceedings, or appeals related thereto.

22. This Settlement Agreement is not severable. Each provision of the Settlement Agreement is dependent upon all other provisions of this Settlement Agreement. Failure to comply with any provision of this Settlement Agreement constitutes failure to comply with the entire Settlement Agreement. If the Commission rejects or modifies this Settlement Agreement or any provision of the Settlement Agreement, this Settlement Agreement shall be deemed to be withdrawn, shall not constitute any part of the record in this proceeding or be used for any other purpose, and shall be without prejudice to the pre-negotiation positions of the parties.

23. The parties agree that approval of this Settlement Agreement by the Commission would be reasonable and in the public interest.

24. The parties agree to waive Section 81 of the Administrative Procedures Act of 1969 (MCL 24.281), as it applies to the issues resolved in this Settlement Agreement, if the Commission approves this Settlement Agreement without modification.

WHEREFORE, the undersigned parties respectfully request the Commission to approve this Settlement Agreement on an expeditious basis and to make it effective in accordance with its terms by final order.

MICHIGAN PUBLIC SERVICE COMMISSION STAFF

By: **Spencer Sattler**
Digitally signed by Spencer Sattler
Date: 2022.04.19 14:00:30 -04'00'

Date: April 19, 2022

Spencer A. Sattler, Esq.
Amit T. Singh, Esq.
Nicholas Q. Taylor, Esq.
Assistant Attorneys General
7109 West Saginaw Highway
Post Office Box 30221
Lansing, MI 48909

CONSUMERS ENERGY COMPANY

By:  Digitally signed by
Robert W. Beach
Date: 2022.04.19
11:44:05 -04'00'

Date: April 19, 2022

Shaun M. Johnson (P69036)
Bret A. Totoraitis (P72654)
Robert W. Beach (P73112)
Anne M. Uitvlugt (P71641)
Gary A. Gensch (P66912)
Theresa A. G. Staley (P56998)
Michael C. Rampe (P58189)
Ian F. Burgess (P82892)
One Energy Plaza
Jackson, Michigan 49201
Attorneys for Consumers Energy Company

ATTORNEY GENERAL, DANA NESSEL

By: **Celeste R. Gill** Digitally signed by
Celeste R. Gill
Date: 2022.04.19
15:03:37 -04'00'

Date: _____

Celeste Gill, Esq.
Assistant Attorney General
Michigan Dept. of Attorney General,
Special Litigation Unit
6th Floor Williams Building
Post Office Box 30755
Lansing, MI 48909

Tracy Jane Andrews, Esq.
Olson, Bzdok & Howard, P.C.
420 East Front Street
Traverse City, MI 49686

GREAT LAKES RENEWABLE ENERGY ASSOCIATION

By: *Don L. Keskey*
Don L. Keskey, Esq.
Brian W. Coyer, Esq.
Public Law Resource Center PLLC
333 Albert Avenue, Suite 425
East Lansing, MI 48823

Date: April 19, 2022

MICHIGAN ENVIRONMENTAL COUNCIL

By:  Digitally signed by
Christopher M. Bzdok
Date: 2022.04.19
12:05:00 -04'00'

Christopher M. Bzdok, Esq.
Lydia Barbash-Riley, Esq.
Olson, Bzdok & Howard, P.C.
420 East Front Street
Traverse City, MI 49686

Date: April 19, 2022

NATURAL RESOURCES DEFENSE COUNCIL



Digitally signed by
Christopher M. Bzdok
Date: 2022.04.19
12:05:50 -04'00'

By:

Christopher M. Bzdok, Esq.
Lydia Barbash-Riley, Esq.
Olson, Bzdok & Howard, P.C.
420 East Front Street
Traverse City, MI 49686

Date: April 19, 2022

SIERRA CLUB

Michael C. Soules
Digitally signed by
Michael C. Soules
Date: 2022.04.19
12:08:37 -04'00'

By:

Michael C. Soules
Earthjustice
1001 G Street NW, Suite 1000
Washington, DC 20001

Date: April 19, 2022

Christopher M. Bzdok, Esq.
Lydia Barbash-Riley, Esq.
Olson, Bzdok & Howard, P.C.
420 East Front Street
Traverse City, MI 49686

CITIZENS UTILITY BOARD OF MICHIGAN



Digitally signed
by Holly L., Hillyer
Date: 2022.04.19
12:29:05 -04'00'

By:

Abigail R. Hawley, Esq.
Holly L. Hillyer, Esq.
Olson, Bzdok & Howard, P.C.
420 East Front Street
Traverse City, MI 49686

Date: April 19, 2022

MICHIGAN ENERGY INNOVATION BUSINESS COUNCIL, INSTITUTE FOR ENERGY
INNOVATION, AND CLEAN GRID ALLIANCE

By: **Laura A. Chappelle**
Laura A. Chappelle, Esq.
Justin K. Ooms, Esq.
Timothy J. Lundgren, Esq.
Potomac Law Group
120 N. Washington Square, Suite 300
Lansing, MI 48933

Digitally signed by
Laura A. Chappelle
Date: 2022.04.19
12:42:00 -04'00'

Date: April 19, 2022

MICHIGAN ELECTRIC TRANSMISSION COMPANY, LLC

By: **Richard**
Aaron
Richard J. Aaron, Esq.
Dykema Gossett PLLC
201 Townsend Street, Suite 900
Lansing, MI 48933

Digitally signed by: Richard Aaron
DN: CN = Richard Aaron email =
raaron@dykema.com C = US O =
Dykema
Date: 2022.04.19 12:07:55 -04'00'

Date: April 19, 2022

Lisa Agrimonti, Esq.
Fredrikson & Bryon, P.A.
115 West Allegan, Suite 700
Lansing, MI 48933

Amy Monopoli, Esq.
ITC Holdings Corp.
27175 Energy Way
Novi, MI 48377

ENVIRONMENTAL LAW & POLICY CENTER, VOTE SOLAR, ECOLOGY CENTER, AND
UNION OF CONCERNED SCIENTISTS

By: 
Margrethe Kearney, Esq.
Environmental Law & Policy Center
146 Monroe Ctr St. NW, Ste 422
Grand Rapids, Michigan 49503

Date: April 19, 2022

HEMLOCK SEMICONDUCTOR OPERATIONS LLC

By: **Jennifer
Utter
Heston**  Digitally signed by
Jennifer Utter
Heston
Date: 2022.04.19
13:15:32 -04'00'

Jennifer Utter Heston, Esq.
Fraser Trebilcock Davis & Dunlap, P.C.
124 West Allegan, Suite 1000
Lansing, MI 48933

Date: April 19, 2022

URBAN CORE COLLECTIVE



By:

Nicholas Leonard, Esq.
Andrew Bashi, Esq.
Great Lakes Environmental Law Center
Local Counsel for Urban Core Collective
4444 2nd Avenue
Detroit, MI, 48201

19-April-2022

Date:

Mark N. Templeton, Esq.
Robert A. Weinstock, Esq.
University of Chicago Law School –
Abrams Environmental Law Clinic
6020 South University Avenue
Chicago, IL 60637

The following parties do not wish to be signatories to this Settlement Agreement; however they have agreed to sign below to indicate non-objection to the Settlement Agreement.

MICHIGAN PUBLIC POWER AGENCY

By: Nolan J. Moody Digitally signed by Nolan J. Moody
Date: 2022.04.19 12:19:10 -04'00'

Date: April 19, 2022

Nolan J. Moody, Esq.
Peter H. Ellsworth, Esq.
Dickinson Wright PLLC
123 W. Allegan Street, Suite 900
Lansing, MI 48933

MIDLAND COGENERATION VENTURE LIMITED PARTNERSHIP

By: **John Janiszewski**
Digitally signed by: John Janiszewski
DN: CN = John Janiszewski email
= jjaniszewski@dykema.com C =
US O = Dykema Gossett, PLLC
Date: 2022.04.20 09:49:53 -04'00'

John A. Janiszewski, Esq.
Dykema Gossett PLLC
201 Townsend Street, Suite 900
Lansing, MI 48933

Date: April 20, 2022

ATTACHMENT A

ATTACHMENT A

Contract Year	Total Rate (\$/MWh)
2019	\$ 55.54
2020	\$ 57.49
2021	\$ 59.38
2022	\$ 61.28
2023	\$ 63.25
2024	\$ 65.24
2025	\$ 67.24
2026	\$ 69.24
2027	\$ 71.23
2028	\$ 73.18
2029	\$ 75.08
2030	\$ 76.95

STATE OF MICHIGAN

BEFORE THE MICHIGAN PUBLIC SERVICE COMMISSION


In the matter of the application of)
CONSUMERS ENERGY COMPANY)
for Approval of an Integrated Resource Plan)
under MCL 460.6t, certain accounting)
approvals, and for other relief.)
_____)

Case No. U-21090

PROOF OF SERVICE

STATE OF MICHIGAN)
) SS
COUNTY OF JACKSON)

Melissa K. Harris, being first duly sworn, deposes and says that she is employed in the Legal Department of Consumers Energy Company; that on April 20, 2022, she served an electronic copy of the **Settlement Agreement**, upon the persons listed in Attachment 1 hereto, at the e-mail addresses listed therein.



Melissa K. Harris

Subscribed and sworn to before me this 20th day of April 2022.



Crystal L. Chacon, Notary Public
State of Michigan, County of Ingham
My Commission Expires: 05/25/24
Acting in the County of Jackson

ATTACHMENT 1 TO CASE NO. U-21090

**Administrative Law Judge
(Electronic Copy of Public Materials)**

Hon. Sally L. Wallace
Administrative Law Judge
7109 West Saginaw Highway
Post Office Box 30221
Lansing, MI 48909
wallaces2@michigan.gov

**Counsel for the Michigan Public
Service Commission Staff
(Electronic Copy of Confidential
Materials)**

Spencer A. Sattler, Esq.
Amit T. Singh, Esq.
Nicholas Q. Taylor, Esq.
Megan Kolioupoulos
Assistant Attorneys General
7109 West Saginaw Highway
Post Office Box 30221
Lansing, MI 48909
sattlers@michigan.gov
singha9@michigan.gov
taylorn10@michigan.gov
kolioupoulosm@michigan.gov

**Counsel for Attorney General,
Dana Nessel
(Electronic Copy of Confidential
Materials)**

Celeste Gill, Esq.
Assistant Attorney General
Michigan Dept. of Attorney General,
Special Litigation Unit
6th Floor Williams Building
Post Office Box 30755
Lansing, MI 48909
Gillc1@michigan.gov
AG-ENRA-Spec-Lit@michigan.gov

Tracy Jane Andrews, Esq.
Olson, Bzdok & Howard, P.C.
420 East Front Street
Traverse City, MI 49686
tjandrews@envlaw.com

**Counsel for the Great Lakes Renewable
Energy Association
(Electronic Copy of Confidential
Materials)**

Don L. Keskey, Esq.
Brian W. Coyer, Esq.
Public Law Resource Center PLLC
333 Albert Avenue, Suite 425
East Lansing, MI 48823
donkeskey@publiclawresourcecenter.com
bwcoyer@publiclawresourcecenter.com

**Counsel for the Cadillac Renewable
Energy, LLC, Genesee Power Station
Limited Partnership, Decker Energy-
Grayling, LLC, Hillman Power
Company, LLC, Tondur Corporation,
Viking Energy of Lincoln, LLC., and
Viking Energy of McBain, LLC
(Electronic Copy of Confidential
Materials)**

Thomas J. Waters, Esq.
The Running Wise Law Firm
1501 Cass Street, Ste. D
Traverse City, MI 49684
tjw@runningwise.com

**Counsel for the Association of Businesses
Advocating Tariff Equity ("ABATE")
and Gerdau Macsteel, Inc.
(Electronic Copy of Confidential
Materials)**

Michael Pattwell, Esq.
James J. Fleming, Esq.
Clark Hill PLC
212 East César E. Chávez Avenue
Lansing, MI 48906
mpattwell@clarkhill.com
jfleming@clarkhill.com

Stephen A. Campbell, Esq.
Clark Hill PLC
500 Woodward Avenue, Suite 3500
Detroit, MI 48226
scampbell@clarkhill.com

ATTACHMENT 1 TO CASE NO. U-21090

Counsel for the Michigan Environmental Council (“MEC”), Natural Resources Defense Council (“NRDC”), Sierra Club, and Citizens Utility Board of Michigan (“CUB”)

(Electronic Copy of Confidential Materials)

Christopher M. Bzdok, Esq.
Lydia Barbash-Riley, Esq.
Kimberly Flynn, Legal Assistant
Karla Gerds, Legal Assistant
Breanna Thomas, Legal Assistant
Olson, Bzdok & Howard, P.C.
420 East Front Street
Traverse City, MI 49686
chris@envlaw.com
lydia@envlaw.com
kimberly@envlaw.com
karla@envlaw.com
breanna@envlaw.com
cub.legal@cubofmichigan.org

Counsel for CUB

(Electronic Copy of Public Materials)

Abigail R. Hawley, Esq.
Holly L. Hillyer, Esq.
Olson, Bzdok & Howard, P.C.
420 East Front Street
Traverse City, MI 49686
abbie@envlaw.com
holly@envlaw.com

Counsel for Sierra Club

(Electronic Copy of Confidential Materials)

Michael C. Soules
Earthjustice
1001 G Street NW, Suite 1000
Washington, DC 20001
msoules@earthjustice.org

**Counsel for Midland Cogeneration Venture Limited Partnership
(Electronic Copy of Confidential Materials)**

John A. Janiszewski, Esq.
Dykema Gossett PLLC
201 Townsend Street, Suite 900
Lansing, MI 48933
jjaniszewski@dykema.com

Counsel for Michigan Energy Innovation Business Council (“EIBC”), Institute for Energy Innovation (“IEI”), and Clear Grid Alliance

(Electronic Copy of Confidential Materials)

Timothy J. Lundgren, Esq.
Laura A. Chappelle, Esq.
Justin K. Ooms, Esq.
Potomac Law Group
120 N. Washington Square, Suite 300
Lansing, MI 48933
tlundgren@potomacclaw.com
lchappelle@potomacclaw.com
jooms@potomacclaw.com

Counsel for Energy Michigan, Inc. (“Energy Michigan”),

(Electronic Copy of Confidential Materials)

Timothy J. Lundgren, Esq.
Laura A. Chappelle, Esq.
Justin K. Ooms, Esq.
Potomac Law Group
120 N. Washington Square, Suite 300
Lansing, MI 48933
tlundgren@potomacclaw.com
lchappelle@potomacclaw.com
jooms@potomacclaw.com

ATTACHMENT 1 TO CASE NO. U-21090

**Counsel for Michigan Electric
Transmission Company, LLC (“METC”)
(Electronic Copy of Confidential
Materials)**

Richard J. Aaron, Esq.
Dykema Gossett PLLC
201 Townsend Street, Suite 900
Lansing, MI 48933
raaron@dykema.com

Lisa Agrimonti, Esq.
Fredrikson & Bryon, P.A.
115 West Allegan, Suite 700
Lansing, MI 48933
lagrimonti@fredlaw.com

Amy Monopoli, Esq.
ITC Holdings Corp.
27175 Energy Way
Novi, MI 48377
amonopoli@itctransco.com

**Counsel for Wolverine Power Supply
Cooperative, Inc.
(Electronic Copy of Confidential
Materials)**

Jason T. Hanselman, Esq.
Dykema Gossett PLLC
201 Townsend Street, Suite 900
Lansing, MI 48933
jhanselman@dykema.com

Joseph J. Baumann, Esq.
Wolverine Power Supply Cooperative, Inc.
10125 W. Watergate Road
Cadillac, MI 49601
jbaumann@wpsci.com

**Counsel for Environmental Law & Policy
Center (“ELPC”), Vote Solar, Ecology
Center, and Union of Concerned
Scientists**

**(Electronic Copy of Confidential
Materials)**

Margrethe Kearney, Esq.
Environmental Law & Policy Center
146 Monroe Ctr St. NW, Ste 422
Grand Rapids, Michigan 49503
mkearney@elpc.org

Heather Vogel, Paralegal
Environmental Law & Policy Center
35 W. Wacker Drive, Suite 1600
Chicago, IL 60601
hvogel@elpc.org
mpscdocket@elpc.org

Nikhil Vijaykar, Esq.
Environmental Law & Policy Center
35 W. Wacker Drive, Suite 1600
Chicago, IL 60601
nvijaykar@elpc.org

**Counsel for Hemlock Semiconductor
Corporation (“HSC”)
(Electronic Copy of Confidential
Materials)**

Jennifer Utter Heston, Esq.
Angela R. Babbitt
Fraser Trebilcock Davis & Dunlap, P.C.
124 West Allegan, Suite 1000
Lansing, MI 48933
jheston@fraserlawfirm.com
ababbitt@fraserlawfirm.com

ATTACHMENT 1 TO CASE NO. U-21090

**Counsel for Residential Customer Group
(Electronic Copy of Confidential
Materials)**

Don L. Keskey, Esq.
Brian W. Coyer, Esq.
Public Law Resource Center PLLC
333 Albert Avenue, Suite 425
East Lansing, MI 48823
donkeskey@publiclawresourcecenter.com
bwcoyer@publiclawresourcecenter.com

**Counsel for Urban Core Collective
(Electronic Copy of Public Materials)**

Nicholas Leonard, Esq.
Andrew Bashi, Esq.
Great Lakes Environmental Law Center
Local Counsel for Urban Core Collective
4444 2nd Avenue
Detroit, MI, 48201
nicholas.leonard@glelc.org
andrew.bashi@glelc.org

**(Electronic Copy of Confidential
Materials)**

Mark N. Templeton, Esq.
Robert A. Weinstock, Esq.
Simone Gewirth, Assistant
University of Chicago Law School –
Abrams Environmental Law Clinic
6020 South University Avenue
Chicago, IL 60637
templeton@uchicago.edu
rweinstock@uchicago.edu
sgewirth@uchicago.edu
aelc_mpsc@lawclinic.uchicago.edu

**Counsel for Michigan Public Power
Agency
(Electronic Copy of Confidential
Materials)**

Nolan J. Moody, Esq.
Peter H. Ellsworth, Esq.
Dickinson Wright PLLC
123 W. Allegan Street, Suite 900
Lansing, MI 48933
nmoody@dickinsonwright.com
pellsworth@dickinsonwright.com

**Counsel for the Mackinac Center for
Public Policy
(Electronic Copy of Confidential
Materials)**

Derk Wilcox, Esq.
wilcox@mackinac.org

(Electronic Copy of Public Materials)

Jason Hayes, Esq.
The Mackinac Center for Public Policy
Legal Foundation
140 West Main Street
PO Box 568
Midland, MI 48640
hayes@mackinac.org

Attachment II

Campbell Clean Air Markets Permit Data
April through June 2025

Campbell Clean Air Markets Permit Data_April through June 2025

State	Facility Name	Facility ID	Date	Gross Load (MWh)	Steam Load (1000 lb)	SO2 Mass (short tons)	CO2 Mass (short tons)	NOx Mass (short tons)	Heat Input (mmBtu)
MI	J H Campbell	1710	4/1/2025	32089		26.073	34432.5	11.808	328302.7
MI	J H Campbell	1710	4/2/2025	32172		26.708	33475.6	12.115	319178.4
MI	J H Campbell	1710	4/3/2025	32151		26.75	34020	11.657	324369.8
MI	J H Campbell	1710	4/4/2025	32355		26.805	34989.3	13.344	333611.8
MI	J H Campbell	1710	4/5/2025	32139		26.271	34246.3	11.888	326528.9
MI	J H Campbell	1710	4/6/2025	31057		26.898	33385.1	12.257	318317
MI	J H Campbell	1710	4/7/2025	32303		25.336	34027.9	11.128	324446.2
MI	J H Campbell	1710	4/8/2025	31873		24.933	34003.7	10.998	324215.6
MI	J H Campbell	1710	4/9/2025	32176		27.797	34070.5	11.174	324853.1
MI	J H Campbell	1710	4/10/2025	31764		25.402	33952.3	12.089	323724.9
MI	J H Campbell	1710	4/11/2025	31496		26.446	33966.7	11.057	323860.3
MI	J H Campbell	1710	4/12/2025	31303		25.894	33729	11.192	321600.7
MI	J H Campbell	1710	4/13/2025	31226		24.015	33475.1	13.026	319173.1
MI	J H Campbell	1710	4/14/2025	31234		24.5	32939.5	11.254	314068.6
MI	J H Campbell	1710	4/15/2025	31080		25.949	32714.6	10.89	311923.8
MI	J H Campbell	1710	4/16/2025	31237		28.469	33287.8	10.532	317387.7
MI	J H Campbell	1710	4/17/2025	29930		21.47	32216	10.808	307168.1
MI	J H Campbell	1710	4/18/2025	28316		19	30354.4	9.414	289421.6
MI	J H Campbell	1710	4/19/2025	25958		18.637	28635.8	8.053	273034.7
MI	J H Campbell	1710	4/20/2025	29482		20.061	32391.4	11.031	308840.6
MI	J H Campbell	1710	4/21/2025	30425		21.088	32404.1	11.24	308962.7
MI	J H Campbell	1710	4/22/2025	25512		21.484	28261.1	8.827	269457.3
MI	J H Campbell	1710	4/23/2025	28850		24.864	31580.4	10.731	301106.5
MI	J H Campbell	1710	4/24/2025	27740		22.961	30597.2	9.892	291741.5
MI	J H Campbell	1710	4/25/2025	29740		22.45	32159.3	10.749	306627
MI	J H Campbell	1710	4/26/2025	31485		22.98	34008.4	10.551	324257.5
MI	J H Campbell	1710	4/27/2025	31466		23.072	34242.8	10.109	326495.2
MI	J H Campbell	1710	4/28/2025	30316		20.833	32845.4	10.909	313170.6
MI	J H Campbell	1710	4/29/2025	30839		22.913	32788.7	10.647	312629
MI	J H Campbell	1710	4/30/2025	31662		24.814	34494.8	10.864	328897.7
MI	J H Campbell	1710	5/1/2025	30322		22.873	32375.1	9.675	308680.3
MI	J H Campbell	1710	5/2/2025	28216		22.048	30575.2	9.443	291522.2
MI	J H Campbell	1710	5/3/2025	22074		16.599	25294.4	6.504	241172.5
MI	J H Campbell	1710	5/4/2025	22073		16.49	25425.5	6.467	242426.9
MI	J H Campbell	1710	5/5/2025	22091		16.615	25436.4	6.548	242529.7
MI	J H Campbell	1710	5/6/2025	26267		19.672	29130.8	9.17	277759.2
MI	J H Campbell	1710	5/7/2025	22090		16.439	25000.1	6.817	238367.6
MI	J H Campbell	1710	5/8/2025	22282		16.695	25383.4	6.809	242021
MI	J H Campbell	1710	5/9/2025	23955		16.419	27064.6	19.309	258050.3
MI	J H Campbell	1710	5/10/2025	24404		16.383	27386.3	7.417	261119.7
MI	J H Campbell	1710	5/11/2025	25767		16.054	29057.5	9.509	277055.4
MI	J H Campbell	1710	5/12/2025	24808		16.787	27681.5	7.82	263933.1
MI	J H Campbell	1710	5/13/2025	24145		16.824	26722.3	8.264	254793.7
MI	J H Campbell	1710	5/14/2025	25800		17.161	27964.9	9.194	266640.6
MI	J H Campbell	1710	5/15/2025	25534		18.358	27393.2	8.68	261184.7
MI	J H Campbell	1710	5/16/2025	25884		21.226	27229.3	8.345	259617.5
MI	J H Campbell	1710	5/17/2025	25873		21.016	27440.9	8.345	261642.6
MI	J H Campbell	1710	5/18/2025	25855		18.826	28098.1	8.359	267907.4
MI	J H Campbell	1710	5/19/2025	22723.05		13.002	24874.5	8.244	237170.66
MI	J H Campbell	1710	5/20/2025	22034		12.248	23798.5	7.7	226912.5
MI	J H Campbell	1710	5/21/2025	22038		13.097	23737.6	8.281	226333.3
MI	J H Campbell	1710	5/22/2025	22045		13.173	23707.6	8.013	226045.4
MI	J H Campbell	1710	5/23/2025	21337		11.495	23456.9	7.645	223656.3
MI	J H Campbell	1710	5/24/2025	17095		11.624	19596.7	5.613	186850.3
MI	J H Campbell	1710	5/25/2025	18308		11.782	20809.7	6.815	198414.4
MI	J H Campbell	1710	5/26/2025	22065		10.3	24626.6	7.598	234809.7
MI	J H Campbell	1710	5/27/2025	19709		12.083	22452	7.241	214074.5
MI	J H Campbell	1710	5/28/2025	18494		9.219	21428.1	6.569	204309.6

MI	J H Campbell	1710	5/29/2025	19371		12.182	22131.8	7.141	211024.6
MI	J H Campbell	1710	5/30/2025	18420		9.888	20933.6	6.03	199597.3
MI	J H Campbell	1710	5/31/2025	18404		10.317	20732	5.945	197672.4
MI	J H Campbell	1710	6/1/2025	18402		11.914	20959.9	5.778	199845.9
MI	J H Campbell	1710	6/2/2025	18407		9.438	21310.7	5.861	203189.3
MI	J H Campbell	1710	6/3/2025	21789		11.032	24122.7	8.487	230003.8
MI	J H Campbell	1710	6/4/2025	23066		11.679	25206.1	9.319	240330.8
MI	J H Campbell	1710	6/5/2025	23020		11.924	25439.3	9.945	242555.2
MI	J H Campbell	1710	6/6/2025	22673		10.928	24945.9	8.261	237852.4
MI	J H Campbell	1710	6/7/2025	22113		10.139	24192.3	7.608	230665.8
MI	J H Campbell	1710	6/8/2025	22118		9.406	23942.1	7.33	228282
MI	J H Campbell	1710	6/9/2025	22424		12.085	24294.9	7.807	231643.1
MI	J H Campbell	1710	6/10/2025	23758		13.433	25759.3	9.594	245607.1
MI	J H Campbell	1710	6/11/2025	23792		12.41	26072.6	9.105	248594.7
MI	J H Campbell	1710	6/12/2025	22556		11.473	25086.9	8.296	239194.8
MI	J H Campbell	1710	6/13/2025	23446		11.804	25661.2	8.688	244672.2
MI	J H Campbell	1710	6/14/2025	23736		12.018	25815.8	8.622	246144.6
MI	J H Campbell	1710	6/15/2025	23745		11.657	25918.3	8.639	247124.3
MI	J H Campbell	1710	6/16/2025	23718		12.609	26091.8	8.733	248775.4
MI	J H Campbell	1710	6/17/2025	23455		11.961	25588.6	8.596	243982
MI	J H Campbell	1710	6/18/2025	22919		12.091	25266	8.742	240905.7
MI	J H Campbell	1710	6/19/2025	24103		13.074	26558.1	9.321	253222.6
MI	J H Campbell	1710	6/20/2025	24333		14.197	26927	9.382	256742.7
MI	J H Campbell	1710	6/21/2025	24347		18.749	26747	9.535	255024.7
MI	J H Campbell	1710	6/22/2025	24318		15.558	26949.7	9.326	256960.4
MI	J H Campbell	1710	6/23/2025	21733.2		9.815	23765.765	7.674	226604.025
MI	J H Campbell	1710	6/24/2025	18225		4.594	19308.1	6.307	184096.5
MI	J H Campbell	1710	6/25/2025	18227		4.722	19374.518	5.734	184729.064
MI	J H Campbell	1710	6/26/2025	18195		6.064	19897.107	7.519	189713.68
MI	J H Campbell	1710	6/27/2025	18362		4.885	20055.01	5.87	191220.855
MI	J H Campbell	1710	6/28/2025	22283		15.205	23612.2	8.273	225135.1
MI	J H Campbell	1710	6/29/2025	22857		19.207	23882.5	7.001	227712.2
MI	J H Campbell	1710	6/30/2025	22247		13.277	23872.2	6.581	227617.2