

Mr. C. S. Haugh, P.E.
Chief, Source Surveillance
New York State Department of Environmental Conservation
Division of Water
Bureau of Watershed Programs
625 Broadway, 4th Floor
Albany, New York 12233-3506

AC-EA
WR:2012:0032
May 16, 2012

SUBJECT: State Pollutant Discharge Elimination System (SPDES) Discharge Monitoring Report (DMR) for the Period April 1 through April 30, 2012, SPDES Permit No. NY-0000973, West Valley Demonstration Project (WVDP)

Dear Mr. Haugh:

The West Valley Demonstration Project SPDES DMR for the reporting period April 1 through April 30, 2012 including the Net Iron calculation sheet is provided as Attachment A.

Please note that there was no discharge at outfall 001 and internal outfall 01B during this period.


As required in Title 6 of the New York Codes, Rules, and Regulations (6NYCRR) Part 750-2.5(e)(3), the New York Environmental Laboratory Accreditation Program (NYELAP) numbers for the laboratories performing analysis for this DMR are as follows:

1. TestAmerica - Buffalo: NY Lab No. 10026;
2. URS Corp.: NY Lab No. 10474; and
3. General Engineering Laboratories: NY Lab No. 11501.

Also, 6NYCRR Part 750-2.5(e)(3) requires reporting of Method Detection Limits (MDLs), where monitoring is not performed under ELAP. To that end, the MDLs for Settleable Solids and Total Residual Chlorine analyses, performed by the CHBWV wastewater treatment facility, are 0.1 ml/L and 0.01 mg/L, respectively.

If you have any questions, please contact Moira N. Maloney of the U.S. Department of Energy West Valley Demonstration Project (DOE-WVDP) at (716) 942-4255 or David P. Klenk of my staff at (716) 942-4061.

Very truly yours,



John D. Rendall, Manager
Regulatory Strategy

JDR:DPK:bnj

Attachment: A) SPDES DMR for April 1 through April 30, 2012 Monitoring Period

cc: M. A. Jackson, NYSDEC-Region 9 DOW
E. W. Wohlers, Cattaraugus County Health Department
J. M. Dundas, DOE-WVDP, AC-DOE
M. P. Krentz, DOE-WVDP, AC-DOE
M. N. Maloney, DOE-WVDP, AC-DOE
J. J. Baker, CHBWV, WV-PL6
H. H. Dukes, CHBWV, WV-PL6
L. E. Bennett, CHBWV, AC-PRES (Public Reading Room)
W. N. Kean, URS SMS, AC-URS
D. P. Klenk, CHBWV, AC-EA
J. D. Rendall, CHBWV, AC-EA
R. L. Scharf, CHBWV, WV-PL6
A. W. Upshaw, CHBWV, WV-PL6
B. N. Jeffery, CHBWV, AC-BUS, (Letter Log)

ATTACHMENT A
SPDES DISCHARGE MONITORING REPORT - APRIL 1 THROUGH APRIL 30, 2012
NET IRON EFFLUENT CONCENTRATION CALCULATION
WEST VALLEY DEMONSTRATION PROJECT, SPDES PERMIT NO. NY-0000973

$$\text{OUTFALL 001} = M1 = \frac{(X1 + X2) \cdot V1}{2} = 0.00 \text{ mg/month}$$

$$X1 = 0.000 \text{ mg/L}$$

$$X2 = 0.000 \text{ mg/L}$$

$$V1 = 0.000 \text{ L/month}$$

*Note: There was no discharge at outfall 001 during this monitoring period.

$$\text{OUTFALL 007} = M7 = \frac{(X1 + X2) \cdot V7}{2} = 15416.13 \text{ mg/month}$$

$$X1 = 0.0499 \text{ mg/L}$$

$$X2 = 0.0377 \text{ mg/L}$$

$$V7 = 351966.49 \text{ L/month}$$

$$\text{RAW WATER} = MRW = \frac{(X1 + X2 + X3 + X4) \cdot VRW}{4} = 541527.13 \text{ mg/month}$$

$$X1 = 0.234 \text{ mg/L}$$

$$X2 = 0.275 \text{ mg/L}$$

$$X3 = 0.354 \text{ mg/L}$$

$$X4 = 1.06 \text{ mg/L}$$

$$VRW = 1126421.48 \text{ L/month}$$

$$\text{IRON DISCHARGE CONCENTRATION} = \frac{M1 + M7 - MRW}{V1 + V7} = 0.00 \text{ mg/L}$$

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)**

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585
FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799
ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	001-M
PERMIT NUMBER	DISCHARGE NUMBER

DMR Mailing ZIP CODE: 14171-9799
MAJOR
(SUBR 09)
OUTFALL 001 MONTHLY PROC WW, GW, STO
External Outfall

MONITORING PERIOD			
MM/DD/YYYY		TO	MM/DD/YYYY
FROM 04/01/2012			04/30/2012

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Sulfate (as S)	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00154 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Once Per Batch	COMP24
Oxygen demand, ultimate	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00181 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	22 DAILY MX	mg/L		Twice Per Batch	CALCTD
Oxygen, dissolved (DO)	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00300 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	3 MINIMUM	*****	Req. Mon. MAXIMUM	mg/L		Twice Per Batch	GRAB
BOD, 5-day, 20 deg. C	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00310 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	10 DAILY MX	mg/L		Twice Per Batch	COMP24
pH	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 MINIMUM	*****	8.5 MAXIMUM	SU		Once Per Batch	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	30 MO AVG	45 DAILY MX	mg/L		Twice Per Batch	COMP24
Solids, settleable	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00545 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.3 DAILY MX	mL/L		Twice Per Batch	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
J. D. Rendall, Manager		716-942-4602	05/15/2012
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)**

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)


NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585
FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799
ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	001-M
PERMIT NUMBER	DISCHARGE NUMBER

DMR Mailing ZIP CODE: 14171-9799
MAJOR
(SUBR 09)
OUTFALL 001 MONTHLY PROC WW, GW, STO
External Outfall
No Discharge ☒

MONITORING PERIOD				
MM/DD/YYYY			MM/DD/YYYY	
FROM 04/01/2012		TO	04/30/2012	

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Oil & Grease	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	15 DAILY MX	mg/L		Once Per Batch	GRAB
Nitrogen, nitrite total (as N)	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00615 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.1 DAILY MX	mg/L		Once Per Batch	COMP24
Nitrogen, nitrate total (as N)	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00620 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Once Per Batch	COMP24
Nitrogen, Kjeldahl, total (as N)	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00625 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Batch	COMP24
Sulfide, dissolved, (as S)	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00746 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.4 DAILY MX	mg/L		Once Per Batch	COMP24
Arsenic, total recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00978 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.15 DAILY MX	mg/L		Once Per Batch	COMP24
Cobalt, total recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00979 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.005 DAILY MX	mg/L		Once Per Batch	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.			TELEPHONE	DATE
J. D. Rendall, Manager		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		716-942-4602	05/15/2012
TYPED OR PRINTED				AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)**

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585
FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799
ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	001-M
PERMIT NUMBER	DISCHARGE NUMBER

DMR Mailing ZIP CODE: 14171-9799
MAJOR
(SUBR 09)
OUTFALL 001 MONTHLY PROC WW, GW, STO
External Outfall

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM	04/01/2012	TO	04/30/2012

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Selenium, total recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00981 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.004 DAILY MX	mg/L		Once Per Batch	GRAB
Iron, total (as Fe)	SAMPLE MEASUREMENT	*****	*****	*****	*****						
01045 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Batch	COMP24
Aluminum, total (as Al)	SAMPLE MEASUREMENT	*****	*****	*****	*****						
01105 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	2 MO AVG	4 DAILY MX	mg/L		Once Per Batch	COMP24
Vanadium, total recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****						
01128 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.014 DAILY MX	mg/L		Once Per Batch	GRAB
Nitrogen, ammonia, total (as NH3)	SAMPLE MEASUREMENT	*****	*****	*****	*****						
34726 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	1.5 MO AVG	2.1 DAILY MX	mg/L		Twice Per Batch	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT				*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	*****		Twice Per Batch	CONTIN
Chlorine, total residual	SAMPLE MEASUREMENT	*****	*****	*****	*****						
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.1 DAILY MX	mg/L		Once Per Batch	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
J. D. Rendall, Manager		716-942-4602		05/15/2012
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)**

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585
FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799
ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	001-M
PERMIT NUMBER	DISCHARGE NUMBER


DMR Mailing ZIP CODE: 14171-9799

MAJOR
(SUBR 09)
OUTFALL 001 MONTHLY PROC WW, GW, STO
External Outfall

MONITORING PERIOD			
MM/DD/YYYY		TO	MM/DD/YYYY
04/01/2012			04/30/2012

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Solids, total dissolved	SAMPLE MEASUREMENT	*****	*****	*****	*****						
70295 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Batch	GRAB
Mercury, total (as Hg)	SAMPLE MEASUREMENT	*****	*****	*****	*****						
71900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	50 MO AVG	Req. Mon. DAILY MX	ng/L		Once Per Batch	GRAB
Surfactants (linear alkylate sulfonate)	SAMPLE MEASUREMENT	*****	*****	*****	*****						
81646 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Once Per Batch	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE	DATE
J. D. Rendall, Manager			716-942-4602	05/15/2012
TYPED OR PRINTED	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)**

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585
FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799
ATTN: BRYAN C BOWER, DIRECTOR

NY0000973
PERMIT NUMBER

007-M
DISCHARGE NUMBER

DMR Mailing ZIP CODE: 14171-9799

MAJOR
(SUBR 09)
SANITARY, NC COOLING WATER, UTILITY WA
External Outfall

MONITORING PERIOD

MM/DD/YYYY	TO	MM/DD/YYYY
04/01/2012		04/30/2012

FROM

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Oxygen demand, ultimate	SAMPLE MEASUREMENT	*****	*****	*****	*****	<3.69	<3.69	mg/L	0	01/30	CA
00181 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	22 DAILY MX	mg/L		Monthly	CALCTD
Oxygen, dissolved (DO)	SAMPLE MEASUREMENT	*****	*****	*****	12	*****	12	mg/L	0	02/30	GR
00300 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	3 MINIMUM	*****	Req. Mon. MAXIMUM	mg/L		Twice Per Month	GRAB
BOD, 5-day, 20 deg. C	SAMPLE MEASUREMENT	*****	*****	*****	*****	<2.0	<2.0	mg/L	0	02/30	24
00310 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	10 DAILY MX	mg/L		Twice Per Month	COMP24
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.9	*****	8.1	SU	0	02/30	GR
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 MINIMUM	*****	8.5 MAXIMUM	SU		Twice Per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	*****	*****	*****	*****	<4.0	<4.0	mg/L	0	02/30	24
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	30 MO AVG	45 DAILY MX	mg/L		Twice Per Month	COMP24
Solids, settleable	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.1	<0.1	ml/L	0	02/30	GR
00545 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.3 DAILY MX	ml/L		Twice Per Month	GRAB
Oil & Grease	SAMPLE MEASUREMENT	*****	*****	*****	*****	<1.4	<1.4	mg/L	0	02/30	GR
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	15 DAILY MX	mg/L		Twice Per Month	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
J. D. Rendall, Manager TYPED OR PRINTED		716-942-4602	05/15/2012
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code	NUMBER
			MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585
FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799
ATTN: BRYAN C BOWER, DIRECTOR

NY0000973
PERMIT NUMBER

007-M
DISCHARGE NUMBER

DMR Mailing ZIP CODE: 14171-9799

MAJOR
(SUBR 09)
SANITARY, NC COOLING WATER, UTILITY WA
External Outfall

MONITORING PERIOD

MM/DD/YYYY	MM/DD/YYYY
04/01/2012	04/30/2012

FROM TO

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Nitrogen, nitrite total (as N) 00615 1 0 Effluent Gross	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.02	<0.02	mg/L	0	01/30	24
	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.1 DAILY MX	mg/L		Monthly	COMP24
Nitrogen, Kjeldahl, total (as N) 00625 1 0 Effluent Gross	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.15	<0.15	mg/L	0	01/30	24
	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Monthly	COMP24
Iron, total (as Fe) 01045 1 0 Effluent Gross	SAMPLE MEASUREMENT	*****	*****	*****	*****	0.044	0.050	mg/L	0	02/30	24
	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	COMP24
Nitrogen, ammonia, total (as NH3) 34726 1 0 Effluent Gross	SAMPLE MEASUREMENT	*****	*****	*****	*****	0.046	0.058	mg/L	0	02/30	24
	PERMIT REQUIREMENT	*****	*****	*****	*****	1.49 MO AVG	2.1 DAILY MX	mg/L		Twice Per Month	COMP24
Flow, in conduit or thru treatment plant 50050 1 0 Effluent Gross	SAMPLE MEASUREMENT	0.005	0.008	MGD	*****	*****	*****	*****	0	01/30	CN
	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	*****		Monthly	CONTIN
Chlorine, total residual 50060 1 0 Effluent Gross	SAMPLE MEASUREMENT	*****	*****	*****	*****	0.02	0.02	mg/L	0	01/30	GR
	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.1 DAILY MX	mg/L		Monthly	GRAB
Solids, total dissolved 70295 1 0 Effluent Gross	SAMPLE MEASUREMENT	*****	*****	*****	*****	828	944	mg/L	0	02/30	GR
	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice Per Month	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
J. D. Rendall, Manager		716-942-4602		05/15/2012
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585
FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799
ATTN: BRYAN C BOWER, DIRECTOR


NY0000973	007-M
PERMIT NUMBER	DISCHARGE NUMBER

DMR Mailing ZIP CODE: 14171-9799
MAJOR
(SUBR 09)
SANITARY, NC COOLING WATER, UTILITY WA
External Outfall

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
FROM 04/01/2012	TO 04/30/2012

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total (as Hg)	SAMPLE MEASUREMENT	*****	*****	*****	*****	9.71	9.71	ng/L	0	01/30	GR
71900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Reg. Mon. MO AVG	200 DAILY MX	ng/L		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE	DATE
J. D. Rendall, Manager TYPED OR PRINTED			716-942-4602	05/15/2012
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

**NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)**

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585
FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799
ATTN: BRYAN C BOWER, DIRECTOR


NY0000973	01B-M
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
FROM 04/01/2012	TO	04/30/2012	

DMR Mailing ZIP CODE: 14171-9799
MAJOR
(SUBR 09)
MERCURY PRETREATMENT
Internal Outfall

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow rate	SAMPLE MEASUREMENT				*****	*****	*****	*****			
00056 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	gal/d	*****	*****	*****	*****		Weekly	CONTIN
Mercury, total (as Hg)	SAMPLE MEASUREMENT	*****	*****	*****	*****						
71900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	50 DAILY MX	ng/L		Twice Per Batch	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE	DATE	
J. D. Rendall, Manager TYPED OR PRINTED			716-942-4602	05/15/2012	
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585
FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799
ATTN: BRYAN C BOWER, DIRECTOR


NY0000973	116-M
PERMIT NUMBER	DISCHARGE NUMBER

DMR Mailing ZIP CODE: 14171-9799
MAJOR
(SUBR 09)
PSEUDO MON. POINT @FRANKS CRK
Internal Outfall

MONITORING PERIOD				
MM/DD/YYYY			MM/DD/YYYY	
FROM 04/01/2012		TO	04/30/2012	

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Solids, total dissolved	SAMPLE MEASUREMENT	*****	*****	*****	*****						
70295 Z 0 Instream Monitoring	PERMIT REQUIREMENT	*****	*****	*****	*****	Reg. Mon. MO AVG	500 DAILY MX	mg/L		Twice Per Discharge	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE	DATE
J. D. Rendall, Manager TYPED OR PRINTED			716-942-4602	05/15/2012
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

IF PSEUDO MONITORING POINT REPORT IS NOT REQUIRED DURING THE MONITORING PERIOD, EITHER CHECK THE NO DISCHARGE BOX OR ENTER 'NODI A' IN PLACE OF A MEASUREMENT TO INDICATE A GENERAL PERMIT EXEMPTION.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585
FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799
ATTN: BRYAN C BOWER, DIRECTOR


NY0000973	SUM-N
PERMIT NUMBER	DISCHARGE NUMBER

DMR Mailing ZIP CODE: 14171-9799
MAJOR
(SUBR 09)
SUM OF OUTFALLS 1 & 7
Internal Outfall

MONITORING PERIOD			
MM/DD/YYYY		MM/DD/YYYY	
04/01/2012	FROM	04/30/2012	TO

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Iron, total (as Fe)	SAMPLE MEASUREMENT	*****	*****	*****	*****	0.00	0.00	mg/L	0	01/30	CA
01045 2 0 Effluent Net	PERMIT REQUIREMENT	*****	*****	*****	*****	Reg. Mon. MO AVG	1 DAILY MX	mg/L		Monthly	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE	DATE
J. D. Rendall, Manager			716-942-4602	05/15/2012
TYPED OR PRINTED			SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)