

CH2MHILL • BWXT West Valley, LLC

West Valley Demonstration Project

Mr. C. S. Haugh, P.E.
Chief, Source Surveillance
New York State Department of Environmental Conservation
Division of Water
Bureau of Watershed Programs
625 Broadway, 4th Floor
Albany, New York 12233-3506

AC-EA
WR:2016:0014
March 8, 2016

SUBJECT: State Pollutant Discharge Elimination System (SPDES) Discharge Monitoring Report (DMR) for the Reporting Period February 1 through February 29, 2016, SPDES Permit No. NY-0000973, West Valley Demonstration Project (WVDP)

Dear Mr. Haugh:

The West Valley Demonstration Project's SPDES DMR for the reporting period February 1 through February 29, 2016, including the Net Iron and Total Dissolved Solids (TDS) concentration sheets, is attached. All results for this report are within effluent discharge limits specified in the permit.

Please note there was no discharge at outfall 007 or internal outfall 01B during this period.


As required in Title 6 of the New York Codes, Rules, and Regulations (6NYCRR) Part 750-2.5(e)(3), the New York Environmental Laboratory Accreditation Program (NYELAP) identification numbers for the laboratories performing analysis for this DMR are as follows:

1. TestAmerica Buffalo: NY Lab No. 10026; and
2. General Engineering Laboratories: NY Lab No. 11501.

Also, 6NYCRR Part 750-2.5(e)(3) requires reporting of Method Detection Limits (MDLs), where monitoring is not performed under ELAP. To that end, the MDLs for Total Residual Chlorine analysis performed by the CHBWV wastewater treatment facility personnel is 0.01 mg/L.

If you have any questions, please contact Moira Maloney of the U.S. Department of Energy West Valley Demonstration Project (DOE-WVDP) at (716) 942-4255 or William Kean at (716) 942-4865.

Sincerely,



John D. Rendall, Manager
Regulatory Strategy

JDR:WKN:bnj

Attachment: SPDES DMR for February 1 through February 29, 2016 Monitoring Period

cc: M. A. Stein, NYSDEC-Region 9 DOW
E. W. Wohlers, Cattaraugus County Health Department
J. M. Dundas, DOE-WVDP
M. N. Maloney, DOE-WVDP
J. J. Baker, CHBWV
L. E. Bennett, CHBWV (Public Reading Room)
J. L. Casper, CHBWV
W. N. Kean, CHBWV
D. P. Klenk, CHBWV
R. L. Scharf, CHBWV
B. N. Jeffery, CHBWV (Letter Log)

ATTACHMENT

SPDES DISCHARGE MONITORING REPORT - FEBRUARY 1 THROUGH FEBRUARY 29, 2016
NET IRON EFFLUENT CONCENTRATION CALCULATION
WEST VALLEY DEMONSTRATION PROJECT, SPDES PERMIT NO. NY-0000973

$$\text{OUTFALL 001} = M1 = \frac{(X1 + X2) V1}{2} = 1101002.67 \text{ mg/month}$$

$$X1 = 0.145 \text{ mg/L}$$

$$X2 = 0.123 \text{ mg/L}$$

$$V1 = 8216437.82 \text{ L/month}$$

$$\text{OUTFALL 007} = M7 = \frac{(X1 + X2) V7}{2} = 0.00 \text{ mg/month}$$

$$X1 = 0.00 \text{ mg/L}$$

$$X2 = 0.00 \text{ mg/L}$$

$$V7 = 0.00 \text{ L/month}$$

Note: There was no discharge from outfall 007 during this monitoring period.

$$\text{RAW WATER} = MRW = \frac{(X1 + X2 + X3 + X4) VRW}{4} = 0.00 \text{ mg/month}$$

$$X1 = 0.00 \text{ mg/L}$$

$$X2 = 0.00 \text{ mg/L}$$

$$X3 = 0.00 \text{ mg/L}$$

$$X4 = 0.00 \text{ mg/L}$$

$$VRW = 0.00 \text{ L/month}$$

Note: Raw water from the reservoir system is no longer used for process water.

$$\text{IRON DISCHARGE CONCENTRATION} = \frac{M1 + M7 - MRW}{V1 + V7} = 0.13 \text{ mg/L}$$

ATTACHMENT (Cont'd)

SPDES DISCHARGE MONITORING REPORT - FEBRUARY 1 THROUGH FEBRUARY 29, 2016
TOTAL DISSOLVED SOLIDS (TDS) CONCENTRATION CALCULATION - MONITORING POINT 116
WEST VALLEY DEMONSTRATION PROJECT, SPDES PERMIT No. NY-0000973

Date: February 3, 2016

$$\begin{aligned} C4 &= ((Q1)(C1) + (Q2)(C2) + (Q3)(C3)) / Q4 \\ &= ((0.314 \text{ MGD})(706 \text{ mg/L}) + (3.07 \text{ MGD})(194 \text{ mg/L}) + (0.259 \text{ MGD})(124 \text{ mg/L})) / (3.643 \text{ MGD}) \\ &= 233 \text{ mg/L} \end{aligned}$$

Date: February 8, 2016

$$\begin{aligned} C4 &= ((Q1)(C1) + (Q2)(C2) + (Q3)(C3)) / Q4 \\ &= ((0.314 \text{ MGD})(703 \text{ mg/L}) + (0.86 \text{ MGD})(224 \text{ mg/L}) + (0.259 \text{ MGD})(94 \text{ mg/L})) / (1.413 \text{ MGD}) \\ &= 305 \text{ mg/L} \end{aligned}$$

-
- Q1 = Flow at Outfall 001, million gallons per day (MGD).
- C1 = Total Dissolved Solids (TDS) concentration at Outfall 001, mg/L.
- Q2 = Flow in Franks Creek, MGD (without Outfall 001), measured at WNSP006 just prior to, and shortly after the discharge event.
- C2 = TDS concentration in Franks Creek measured at WNSP006 just prior to, and shortly after the discharge event.
- Q3 = Flow of augmentation water, MGD, if required.
- C3 = TDS concentration in augmentation water, MGD.
- Q4 = Q1 + Q2 + Q3, MGD (Flow in Franks Creek, including Outfall 001).
- C4 <= 500 mg/L (calculated TDS concentration at 116 in Franks Creek, which includes Outfall 001).

DISCHARGE MONITORING REPORT (DMR)

OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. DEPT OF ENERGY
 ADDRESS: 1000 INDEPENDENCE AVE SW
 WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ

LOCATION: 10282 ROCK SPRINGS ROAD
 WEST VALLEY, NY 14171- 9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	001-M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
2/1/2016	2/29/2016

DMR Mailing ZIP CODE: 14171- 9799
 MAJOR
 (SUBR 09)
 OUTFALL 001 MONTHLY PROC WW, GW, S1
 External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Sulfate [as S]	SAMPLE MEASUREMENT	*****	*****	*****	*****	68	68	mg/L	0	01/BA	24
00154 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Once per Batch	COMP24
Oxygen demand, ultimate	SAMPLE MEASUREMENT	*****	*****	*****	*****	<5.93	<6.29	mg/L	0	02/BA	CA
00181 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	22 DAILY MX	mg/L		Twice per Batch	CALCTD
Oxygen, dissolved [DO]	SAMPLE MEASUREMENT	*****	*****	*****	*****	14	15	mg/L	0	02/BA	GR
00300 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	3 MINIMUM	Req. Mon. MAXIMUM	mg/L		Twice per Batch	GRAB
BOD, 5- day, 20 deg. C	SAMPLE MEASUREMENT	*****	*****	*****	*****	<2.0	<2.0	mg/L	0	02/BA	24
00310 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	10 DAILY MX	mg/L		Twice per Batch	COMP24
pH	SAMPLE MEASUREMENT	*****	*****	*****	*****	8.1	8.1	SU	0	01/BA	GR
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	6.5 MINIMUM	8.5 MAXIMUM	SU		Once per Batch	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	*****	*****	*****	*****	<4.0	<4.0	mg/L	0	02/BA	24
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	30 MO AVG	45 DAILY MX	mg/L		Twice per Batch	COMP24
Solids, settleable	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.1	<0.1	ml/L	0	02/BA	GR
00545 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.3 DAILY MX	ml/L		Twice per Batch	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
John D. Rendall, Manager		716-942-4602		03/03/2016
TYPED OR PRINTED		AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ


LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171- 9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	001- M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
2/1/2016	2/29/2016

DMR Mailing ZIP CODE: 14171- 9799
MAJOR
(SUBR 09)
OUTFALL 001 MONTHLY PROC WW, GW, S1
External OutfallNo Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Oil & Grease	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	<1.4	<1.4	mg/L	0	01/BA	GR
Nitrogen, nitrite total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00615 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	15 DAILY MX	mg/L		Once per Batch	GRAB
Nitrogen, nitrate total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00620 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	<0.02	<0.02	mg/L	0	01/BA	24
Nitrogen, Kjeldahl, total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.1 DAILY MX	mg/L		Once per Batch	COMP24
00625 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	0.091	0.091	mg/L	0	01/BA	24
Sulfide, dissolved, [as S]	SAMPLE MEASUREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Once per Batch	COMP24
00746 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	0.64	0.72	mg/L	0	02/BA	24
Arsenic, total recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice per Batch	COMP24
00978 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	<0.05	<0.05	mg/L	0	01/BA	24
Cobalt, total recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.4 DAILY MX	mg/L		Once per Batch	COMP24
00979 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	0.00061	0.00061	mg/L	0	01/BA	24
	SAMPLE MEASUREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.15 DAILY MX	mg/L		Once per Batch	COMP24
	PERMIT REQUIREMENT	*****	*****	*****	*****	<0.0006	<0.0006	mg/L	0	01/BA	GR
	SAMPLE MEASUREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.005 DAILY MX	mg/L		Once per Batch	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
John D. Rendall, Manager			716-942-4602		03/03/2016
TYPED OR PRINTED			AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ


LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171- 9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	001- M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
2/1/2016	2/29/2016

DMR Mailing ZIP CODE: 14171- 9799
MAJOR
(SUBR 09)
OUTFALL 001 MONTHLY PROC WW, GW, S1
External OutfallNo Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Selenium, total recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00981 1 0	PERMIT REQUIREMENT	*****	*****	*****	*****	<0.0004	<0.0004	mg/L	0	01/BA	GR
Effluent Gross						Req. Mon.	.004	mg/L		Once per Batch	GRAB
Iron, total [as Fe]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
01045 1 0	PERMIT REQUIREMENT	*****	*****	*****	*****	0.134	0.145	mg/L	0	02/BA	24
Effluent Gross						Req. Mon.	Req. Mon.	mg/L		Twice per Batch	COMP24
Aluminum, total [as Al]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
01105 1 0	PERMIT REQUIREMENT	*****	*****	*****	*****	0.145	0.145	mg/L	0	01/BA	24
Effluent Gross						2	4	mg/L		Once per Batch	COMP24
Vanadium, total recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****						
01128 1 0	PERMIT REQUIREMENT	*****	*****	*****	*****	<0.0015	<0.0015	mg/L	0	01/BA	GR
Effluent Gross						Req. Mon.	.014	mg/L		Once per Batch	GRAB
Nitrogen, ammonia, total [as NH3]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
34726 1 0	PERMIT REQUIREMENT	*****	*****	*****	*****	0.086	0.097	mg/L	0	02/BA	24
Effluent Gross						1.5	2.1	mg/L		Twice per Batch	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.314	0.437	MGD	*****	*****	*****	*****	0	02/BA	CN
50050 1 0	PERMIT REQUIREMENT	Req. Mon.	Req. Mon.	MGD	*****	*****	*****	*****		Twice per Batch	CONTIN
Effluent Gross		MO AVG	DAILY MX								
Chlorine, total residual	SAMPLE MEASUREMENT	*****	*****	*****	*****						
50060 1 0	PERMIT REQUIREMENT	*****	*****	*****	*****	0.04	0.04	mg/L	0	01/BA	GR
Effluent Gross						Req. Mon.	.1	mg/L		Once per Batch	GRAB
						MO AVG	DAILY MX				

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
John D. Rendall, Manager			716-942-4602		03/03/2016
TYPED OR PRINTED			AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ

LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171- 9799


ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	001- M
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
2/1/2016	2/29/2016

DMR Mailing ZIP CODE: 14171- 9799
MAJOR
(SUBR 09)
OUTFALL 001 MONTHLY PROC WW, GW, S1
External OutfallNo Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Solids, total dissolved	SAMPLE MEASUREMENT	*****	*****	*****	*****						
70295 1 0	PERMIT REQUIREMENT	*****	*****	*****	*****	705	706	mg/L	0	02/BA	GR
Effluent Gross						Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice per Batch	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
71900 1 0	PERMIT REQUIREMENT	*****	*****	*****	*****	5.8	5.8	ng/L	0	01/BA	GR
Effluent Gross						50 MO AVG	Req. Mon. DAILY MX	ng/L		Once per Batch	GRAB
Surfactants [linear alkylate sulfonate]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
81646 1 0	PERMIT REQUIREMENT	*****	*****	*****	*****	<0.004	<0.004	mg/L	0	01/BA	GR
Effluent Gross						Req. Mon. MO AVG	.04 DAILY MX	mg/L		Once per Batch	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE
John D. Rendall, Manager			716-942-4602	03/03/2016
TYPED OR PRINTED			AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ


LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171- 9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	007- M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
2/1/2016	2/29/2016

DMR Mailing ZIP CODE: 14171- 9799
MAJOR
(SUBR 09)
SANITARY, NC COOLING WATER, UTILITY &
External OutfallNo Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Oxygen demand, ultimate	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00181 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	22 DAILY MX	mg/L		Monthly	CALCTD
Oxygen, dissolved [DO]	SAMPLE MEASUREMENT	*****	*****	*****		*****					
00300 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	3 MINIMUM	*****	Req. Mon. MAXIMUM	mg/L		Twice per Month	GRAB
BOD, 5- day, 20 deg. C	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00310 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	10 DAILY MX	mg/L		Twice per Month	COMP24
pH	SAMPLE MEASUREMENT	*****	*****	*****		*****					
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 MINIMUM	*****	8.5 MAXIMUM	SU		Twice per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	30 MO AVG	45 DAILY MX	mg/L		Twice per Month	COMP24
Solids, settleable	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00545 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.3 DAILY MX	mL/L		Twice per Month	GRAB
Oil & Grease	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	15 DAILY MX	mg/L		Twice per Month	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE
John D. Rendall, Manager			716-942-4602	03/03/2016
TYPED OR PRINTED			AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ


LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	007- M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
2/1/2016	2/29/2016

DMR Mailing ZIP CODE: 14171-9799
MAJOR
(SUBR 09)
SANITARY, NC COOLING WATER, UTILITY &
External OutfallNo Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Nitrogen, nitrite total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00615 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.1 DAILY MX	mg/L		Monthly	COMP24
Nitrogen, Kjeldahl, total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00625 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Monthly	COMP24
Iron, total [as Fe]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
01045 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice per Month	COMP24
Nitrogen, ammonia, total [as NH3]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
34726 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	1.49 MO AVG	2.1 DAILY MX	mg/L		Twice per Month	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT				*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	*****		Monthly	CONTIN
Chlorine, total residual	SAMPLE MEASUREMENT	*****	*****	*****	*****						
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.1 DAILY MX	mg/L		Monthly	GRAB
Solids, total dissolved	SAMPLE MEASUREMENT	*****	*****	*****	*****						
70295 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice per Month	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
John D. Rendall, Manager			716-942-4602		03/03/2016
TYPED OR PRINTED			AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ


LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	007- M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
2/1/2016	2/29/2016

DMR Mailing ZIP CODE: 14171-9799
MAJOR
(SUBR 09)
SANITARY, NC COOLING WATER, UTILITY V
External OutfallNo Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
71900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	50 DAILY MX	ng/L		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE		DATE
John D. Rendall, Manager			716-942-4602		03/03/2016
TYPED OR PRINTED			AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. DEPT OF ENERGY
 ADDRESS: 1000 INDEPENDENCE AVE SW
 WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ

LOCATION: 10282 ROCK SPRINGS ROAD
 WEST VALLEY, NY 14171- 9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	01B- M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
2/1/2016	2/29/2016

DMR Mailing ZIP CODE: 14171- 9799

MAJOR


(SUBR 09)

MERCURY PRETREATMENT

Internal Outfall

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow rate	SAMPLE MEASUREMENT				*****	*****	*****	*****			
00056 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	gal/d	*****	*****	*****	*****		Weekly	CONTIN
Mercury, total [as Hg]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
71900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	50 DAILY MX	ng/L		Twice per Batch	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		TELEPHONE	DATE
John D. Rendall, Manager				716-942-4602	03/03/2016
TYPED OR PRINTED			AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ


LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	116- M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
2/1/2016	2/29/2016

DMR Mailing ZIP CODE: 14171-9799
MAJOR
(SUBR 09)
PSEUDO MON. POINT @FRANKS CRK
Internal OutfallNo Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Solids, total dissolved	SAMPLE MEASUREMENT	*****	*****	*****	*****	269	305	mg/L	0	02/BA	CA
70295 Z 0 Instream Monitoring	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	500 DAILY MX	mg/L		Twice per Discharge	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE		DATE
John D. Rendall, Manager			716-942-4602		03/03/2016
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

IF PSEUDO MONITORING POINT REPORT IS NOT REQUIRED DURING THE MONITORING PERIOD, EITHER CHECK THE NO DISCHARGE BOX OR ENTER 'NODISCH' IN PLACE OF A MEASUREMENT TO INDICATE A GENERAL PERMIT EXEMPTION.

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004


PERMITTEE NAME/ADDRESS (Include Facility Name/Location if
NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585
FACILITY: WEST VALLEY DEMONSTRATION PROJ
LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799
ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	SUM- N
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
2/1/2016	2/29/2016

DMR Mailing ZIP CODE: 14171-9799
MAJOR
(SUBR 09)
SUM OF OUTFALLS 1 & 7
Internal Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Iron, total [as Fe] 01045 2 0 Effluent Net	SAMPLE MEASUREMENT	*****	*****	*****	*****	0.13	0.13	mg/L	0	01/30	CA
	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	1 DAILY MX	mg/L		Monthly	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		TELEPHONE		DATE
John D. Rendall, Manager			716-942-4602		03/03/2016
TYPED OR PRINTED			AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)