

CH2MHILL • BWXT West Valley, LLC

West Valley Demonstration Project

Mr. C. S. Haugh, P.E.
Chief, Source Surveillance
New York State Department of Environmental Conservation
Division of Water
Bureau of Watershed Programs
625 Broadway, 4th Floor
Albany, New York 12233-3506

WV-RHWF
WR:2017:0170
February 23, 2017

SUBJECT: State Pollutant Discharge Elimination System (SPDES) Discharge Monitoring Report (DMR) for the Reporting Period January 1 through January 31, 2017, SPDES Permit No. NY-0000973, West Valley Demonstration Project (WVDP)

REFERENCE: Letter DW:2017:0192 (JMD:369906-455.1.3), B. C. Bower to R. E. Wither, "Delegation of Signature Authority for State Pollutant Discharge Elimination System (SPDES) NetDMR Electronic Reports, U.S. Department of Energy West Valley Demonstration Project (DOE-WVDP), SPDES No. NY-0000973," dated February 8, 2017

Dear Mr. Haugh:

The West Valley Demonstration Project (WVDP) SPDES DMR for the reporting period January 1 through January 31, 2017 including the Net Iron calculation, and the Total Dissolved Solids Concentration Calculation sheets is attached. All results for this report are within the effluent discharge limits specified in the permit.

The WVDP is continuing to make progress towards the completion of the necessary steps to submit future DMRs electronically through the NetDMR reporting program. The WVDP discussed our progress towards this goal via a teleconference call with Mr. Christopher Birr on January 18, 2017. Mr. Birr informed the WVDP that NYSDEC is allowing the submission of paper DMR's into 2017. Furthermore, on February 8, 2017, the WVDP submitted a signature authority letter, which included the completed subscriber agreement authorization form (reference). The WVDP is currently awaiting New York State Department of Environmental Conservation's approval of that document. It is the WVDP's intention to begin submitting DMRs electronically with the February 2017 reporting period.

Please note that there was no discharge at outfall 007 or internal outfall 01B during this period.

As required in Title 6 of the New York Codes, Rules, and Regulations (6NYCRR) Part 750-2.5(e)(3), the New York Environmental Laboratory Accreditation Program (NYELAP) identification numbers for the laboratories performing analysis for this DMR are as follows:

1. TestAmerica Buffalo: NY Lab No. 10026; and
2. General Engineering Laboratories: NY Lab No. 11501.

Also, 6NYCRR Part 750-2.5(e)(3) requires reporting of Method Detection Limits (MDLs), where monitoring is not performed under ELAP. To that end, the MDLs for Total Residual Chlorine analysis performed by the CHBWV wastewater treatment facility personnel is 0.01 mg/L.

If you have any questions, please contact Moira Maloney of the U.S. Department of Energy West Valley Demonstration Project (DOE-WVDP) at (716) 942-4255 or William Kean at (716) 942-4865.

Sincerely,

A handwritten signature in cursive script, appearing to read "Christine B. Lee".

Christine B. Lee, Acting Manager
Regulatory Strategy & Engineering

JDR:WNK:bnj

Attachment: SPDES DMR for January 1 through January 31, 2017 Monitoring Period

cc: M. A. Stein, NYSDEC-Region 9 DOW
E. W. Wohlers, Cattaraugus County Health Department
J. M. Dundas, DOE-WVDP
M. N. Maloney, DOE-WVDP
J. J. Baker, CHBWV
L. E. Bennett, CHBWV (Public Reading Room)
J. L. Casper, CHBWV
W. N. Kean, CHBWV
D. P. Klenk, CHBWV
C. B. Lee, CHBWV
B. N. Jeffery, CHBWV (Letter Log)

ATTACHMENT

SPDES DISCHARGE MONITORING REPORT - JANUARY 1 THROUGH JANUARY 31, 2017
NET IRON EFFLUENT CONCENTRATION CALCULATION
WEST VALLEY DEMONSTRATION PROJECT, SPDES PERMIT NO. NY-0000973

$$\text{OUTFALL 001} = M1 = \frac{(X1 + X2) V1}{2} = 3314149.80 \text{ mg/month}$$

$$X1 = 0.299 \text{ mg/L}$$

$$X2 = 0.317 \text{ mg/L}$$

$$V1 = 10760226.62 \text{ L/month}$$

$$\text{OUTFALL 007} = M7 = \frac{(X1 + X2) V7}{2} = 0.00 \text{ mg/month}$$

$$X1 = 0.00 \text{ mg/L}$$

$$X2 = 0.00 \text{ mg/L}$$

$$V7 = 0.00 \text{ L/month}$$

Note: There was no discharge from outfall 007 during this monitoring period.

$$\text{RAW WATER} = MRW = \frac{(X1 + X2 + X3 + X4) VRW}{4} = 0.00 \text{ mg/month}$$

$$X1 = 0.00 \text{ mg/L}$$

$$X2 = 0.00 \text{ mg/L}$$

$$X3 = 0.00 \text{ mg/L}$$

$$X4 = 0.00 \text{ mg/L}$$

$$VRW = 0.00 \text{ L/month}$$

Note: Raw water from the reservoir system is no longer used for process water.

$$\text{IRON DISCHARGE CONCENTRATION} = \frac{M1 + M7 - MRW}{V1 + V7} = 0.31 \text{ mg/L}$$

ATTACHMENT (Cont'd)

SPDES DISCHARGE MONITORING REPORT - JANUARY 1 THROUGH JANUARY 31, 2017
TOTAL DISSOLVED SOLIDS (TDS) CONCENTRATION CALCULATION - MONITORING POINT 116
WEST VALLEY DEMONSTRATION PROJECT, SPDES PERMIT No. NY-0000973

Date: January 11, 2017

$$\begin{aligned} C4 &= ((Q1)(C1) + (Q2)(C2) + (Q3)(C3)) / Q4 \\ &= ((0.365 \text{ MGD})(730 \text{ mg/L}) + (3.070 \text{ MGD})(227 \text{ mg/L}) + (0.360 \text{ MGD})(120 \text{ mg/L})) / (3.795 \text{ MGD}) \\ &= 265 \text{ mg/L} \end{aligned}$$

Date: January 17, 2017

$$\begin{aligned} C4 &= ((Q1)(C1) + (Q2)(C2) + (Q3)(C3)) / Q4 \\ &= ((0.365 \text{ MGD})(710 \text{ mg/L}) + (1.492 \text{ MGD})(146 \text{ mg/L}) + (0.360 \text{ MGD})(120 \text{ mg/L})) / (2.217 \text{ MGD}) \\ &= 235 \text{ mg/L} \end{aligned}$$

-
- Q1 = Flow at Outfall 001, million gallons per day (MGD).
- C1 = Total Dissolved Solids (TDS) concentration at Outfall 001, mg/L.
- Q2 = Flow in Franks Creek, MGD (without Outfall 001), measured at WNSP006 just prior to, and shortly after the discharge event.
- C2 = TDS concentration in Franks Creek measured at WNSP006 just prior to, and shortly after the discharge event.
- Q3 = Flow of augmentation water, MGD, if required.
- C3 = TDS concentration in augmentation water, MGD.
- Q4 = Q1 + Q2 + Q3, MGD (Flow in Franks Creek, including Outfall 001).
- C4 <= 500 mg/L (calculated TDS concentration at 116 in Franks Creek, which includes Outfall 001).

DISCHARGE MONITORING REPORT (DMR)

OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. DEPT OF ENERGY
 ADDRESS: 1000 INDEPENDENCE AVE SW
 WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ

LOCATION: 10282 ROCK SPRINGS ROAD
 WEST VALLEY, NY 14171- 9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	001- M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
1/1/2017	1/31/2017

DMR Mailing ZIP CODE: 14171- 9799
 MAJOR
 (SUBR 09)
 OUTFALL 001 MONTHLY PROC WW, GW, ST
 External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Sulfate [as S]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00154 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	81	81	mg/L	0	01/BA	24
Oxygen demand, ultimate	SAMPLE MEASUREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Once per Batch	COMP24
00181 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	<7.37	<8.03	mg/L	0	02/BA	CA
Oxygen, dissolved [DO]	SAMPLE MEASUREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	22 DAILY MX	mg/L		Twice per Batch	CALCTD
00300 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	11	14	mg/L	0	02/BA	GR
BOD, 5- day, 20 deg. C	SAMPLE MEASUREMENT	*****	*****	*****	*****	3 MINIMUM	Req. Mon. MAXIMUM	mg/L		Twice per Batch	GRAB
00310 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	<2.1	2.1	mg/L	0	02/BA	24
pH	SAMPLE MEASUREMENT	*****	*****	*****	*****	7.8	7.8	SU	0	01/BA	GR
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	6.5 MINIMUM	8.5 MAXIMUM	SU		Once per Batch	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	*****	*****	*****	*****	<4.0	<4.0	mg/L	0	02/BA	24
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	30 MO AVG	45 DAILY MX	mg/L		Twice per Batch	COMP24
Solids, settleable	SAMPLE MEASUREMENT	*****	*****	*****	*****	<0.1	<0.1	ml/L	0	02/BA	GR
00545 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.3 DAILY MX	ml/L		Twice per Batch	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
Christine B. Lee, Manager			208-569-8984		02/23/2017
TYPED OR PRINTED			AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ


LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171- 9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	001- M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
1/1/2017	1/31/2017

DMR Mailing ZIP CODE: 14171- 9799
MAJOR
(SUBR 09)
OUTFALL 001 MONTHLY PROC WW, GW, ST
External OutfallNo Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Oil & Grease	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00556 1 0	PERMIT REQUIREMENT	*****	*****	*****	*****	<1.4	<1.4	mg/L	0	01/BA	GR
Effluent Gross						Req. Mon. MO AVG	15 DAILY MX	mg/L		Once per Batch	GRAB
Nitrogen, nitrite total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00615 1 0	PERMIT REQUIREMENT	*****	*****	*****	*****	<0.02	<0.02	mg/L	0	01/BA	24
Effluent Gross						Req. Mon. MO AVG	.1 DAILY MX	mg/L		Once per Batch	COMP24
Nitrogen, nitrate total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00620 1 0	PERMIT REQUIREMENT	*****	*****	*****	*****	0.039	0.039	mg/L	0	01/BA	24
Effluent Gross						Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Once per Batch	COMP24
Nitrogen, Kjeldahl, total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00625 1 0	PERMIT REQUIREMENT	*****	*****	*****	*****	0.94	1.1	mg/L	0	02/BA	24
Effluent Gross						Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice per Batch	COMP24
Sulfide, dissolved, [as S]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00746 1 0	PERMIT REQUIREMENT	*****	*****	*****	*****	<0.05	<0.05	mg/L	0	01/BA	24
Effluent Gross						Req. Mon. MO AVG	.4 DAILY MX	mg/L		Once per Batch	COMP24
Arsenic, total recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00978 1 0	PERMIT REQUIREMENT	*****	*****	*****	*****	<0.0013	<0.0013	mg/L	0	01/BA	24
Effluent Gross						Req. Mon. MO AVG	.15 DAILY MX	mg/L		Once per Batch	COMP24
Cobalt, total recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00979 1 0	PERMIT REQUIREMENT	*****	*****	*****	*****	<0.0006	<0.0006	mg/L	0	01/BA	GR
Effluent Gross						Req. Mon. MO AVG	.005 DAILY MX	mg/L		Once per Batch	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
Christine B. Lee, Manager			208-569-8984		02/23/2017
TYPED OR PRINTED				AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. DEPT OF ENERGY
 ADDRESS: 1000 INDEPENDENCE AVE SW
 WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ

LOCATION: 10282 ROCK SPRINGS ROAD
 WEST VALLEY, NY 14171-9799


ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	001-M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
1/1/2017	1/31/2017

DMR Mailing ZIP CODE: 14171-9799
 MAJOR
 (SUBR 09)
 OUTFALL 001 MONTHLY PROC WW, GW, ST
 External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Selenium, total recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00981 1 0	PERMIT REQUIREMENT	*****	*****	*****	*****	<0.0004	<0.0004	mg/L	0	01/BA	GR
Effluent Gross						Req. Mon. MO AVG	.004 DAILY MX	mg/L		Once per Batch	GRAB
Iron, total [as Fe]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
01045 1 0	PERMIT REQUIREMENT	*****	*****	*****	*****	0.31	0.32	mg/L	0	02/BA	24
Effluent Gross						Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice per Batch	COMP24
Aluminum, total [as Al]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
01105 1 0	PERMIT REQUIREMENT	*****	*****	*****	*****	0.087	0.087	mg/L	0	01/BA	24
Effluent Gross						2 MO AVG	4 DAILY MX	mg/L		Once per Batch	COMP24
Vanadium, total recoverable	SAMPLE MEASUREMENT	*****	*****	*****	*****						
01128 1 0	PERMIT REQUIREMENT	*****	*****	*****	*****	<0.0015	<0.0015	mg/L	0	01/BA	GR
Effluent Gross						Req. Mon. MO AVG	.014 DAILY MX	mg/L		Once per Batch	GRAB
Nitrogen, ammonia, total [as NH3]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
34726 1 0	PERMIT REQUIREMENT	*****	*****	*****	*****	0.26	0.30	mg/L	0	02/BA	24
Effluent Gross						1.5 MO AVG	2.1 DAILY MX	mg/L		Twice per Batch	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0.365	0.426	MGD	*****	*****	*****	*****	0	02/BA	CN
50050 1 0	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	*****		Twice per Batch	CONTIN
Chlorine, total residual	SAMPLE MEASUREMENT	*****	*****	*****	*****						
50060 1 0	PERMIT REQUIREMENT	*****	*****	*****	*****	0.04	0.04	mg/L	0	01/BA	GR
Effluent Gross						Req. Mon. MO AVG	.1 DAILY MX	mg/L		Once per Batch	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE	DATE
Christine B. Lee, Manager TYPED OR PRINTED	208-569-8984 AREA Code NUMBER		02/23/2017 MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

Form Approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ

LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171- 9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	001- M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
1/1/2017	1/31/2017

DMR Mailing ZIP CODE: 14171- 9799

MAJOR

(SUBR 09)

OUTFALL 001 MONTHLY PROC WW, GW, ST
External OutfallNo Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Solids, total dissolved	SAMPLE MEASUREMENT	*****	*****	*****	*****						
70295 1 0	PERMIT REQUIREMENT	*****	*****	*****	*****	720	730	mg/L	0	02/BA	GR
Effluent Gross						Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice per Batch	GRAB
Mercury, total [as Hg]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
71900 1 0	PERMIT REQUIREMENT	*****	*****	*****	*****	5.8	5.8	ng/L	0	01/BA	GR
Effluent Gross						50 MO AVG	Req. Mon. DAILY MX	ng/L		Once per Batch	GRAB
Surfactants [linear alkylate sulfonate]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
81646 1 0	PERMIT REQUIREMENT	*****	*****	*****	*****	0.005	0.005	mg/L	0	01/BA	GR
Effluent Gross						Req. Mon. MO AVG	.04 DAILY MX	mg/L		Once per Batch	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Christine B. Lee, Manager TYPED OR PRINTED		208-569-8984		02/23/2017
		AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. DEPT OF ENERGY

ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ

LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	007- M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
1/1/2017	1/31/2017

DMR Mailing ZIP CODE: 14171-9799

MAJOR

(SUBR 09)

SANITARY, NC COOLING WATER, UTILITY A
External OutfallNo Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Oxygen demand, ultimate	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00181 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	22 DAILY MX	mg/L		Monthly	CALCTD
Oxygen, dissolved [DO]	SAMPLE MEASUREMENT	*****	*****	*****		*****					
00300 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	3 MINIMUM	*****	Req. Mon. MAXIMUM	mg/L		Twice per Month	GRAB
BOD, 5- day, 20 deg. C	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00310 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	10 DAILY MX	mg/L		Twice per Month	COMP24
pH	SAMPLE MEASUREMENT	*****	*****	*****		*****					
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 MINIMUM	*****	8.5 MAXIMUM	SU		Twice per Month	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	30 MO AVG	45 DAILY MX	mg/L		Twice per Month	COMP24
Solids, settleable	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00545 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.3 DAILY MX	mL/L		Twice per Month	GRAB
Oil & Grease	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00556 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	15 DAILY MX	mg/L		Twice per Month	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE	DATE
Christine B. Lee, Manager		208-569-8984	02/23/2017
TYPED OR PRINTED			
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code	NUMBER
			MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. DEPT OF ENERGY
 ADDRESS: 1000 INDEPENDENCE AVE SW
 WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ

LOCATION: 10282 ROCK SPRINGS ROAD
 WEST VALLEY, NY 14171-9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	007- M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
1/1/2017	1/31/2017

DMR Mailing ZIP CODE: 14171-9799

MAJOR


(SUBR 09)

SANITARY, NC COOLING WATER, UTILITY

External Outfall

No Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Nitrogen, nitrite total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00615 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.1 DAILY MX	mg/L		Monthly	COMP24
Nitrogen, Kjeldahl, total [as N]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
00625 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Monthly	COMP24
Iron, total [as Fe]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
01045 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice per Month	COMP24
Nitrogen, ammonia, total [as NH3]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
34726 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	1.49 MO AVG	2.1 DAILY MX	mg/L		Twice per Month	COMP24
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT				*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	*****		Monthly	CONTIN
Chlorine, total residual	SAMPLE MEASUREMENT	*****	*****	*****	*****						
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	.1 DAILY MX	mg/L		Monthly	GRAB
Solids, total dissolved	SAMPLE MEASUREMENT	*****	*****	*****	*****						
70295 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	mg/L		Twice per Month	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE		DATE
Christine B. Lee, Manager TYPED OR PRINTED			208-569-8984		02/23/2017
			AREA Code	NUMBER	MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

Form approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ

LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	007- M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
1/1/2017	1/31/2017

DMR Mailing ZIP CODE: 14171-9799
MAJOR
(SUBR 09)
SANITARY, NC COOLING WATER, UTILITY V
External OutfallNo Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Mercury, total [as Hg]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
71900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	50 DAILY MX	ng/L		Monthly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
Christine B. Lee, Manager		208-569-8984		02/23/2017
TYPED OR PRINTED		AREA Code	NUMBER	MM/DD/YYYY

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

Form approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ

LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171- 9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	01B- M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
1/1/2017	1/31/2017

DMR Mailing ZIP CODE: 14171- 9799
MAJOR
(SUBR 09)
MERCURY PRETREATMENT
Internal OutfallNo Discharge ☒

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Flow rate	SAMPLE MEASUREMENT				*****	*****	*****	*****			
00056 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	gal/d	*****	*****	*****	*****		Weekly	CONTIN
Mercury, total [as Hg]	SAMPLE MEASUREMENT	*****	*****	*****	*****						
71900 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	50 DAILY MX	ng/L		Twice per Batch	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
Christine B. Lee, Manager					
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		208-569-8984	02/23/2017
		AREA Code	NUMBER	MM/DD/YYYY	

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

DISCHARGE MONITORING REPORT (DMR)

Form approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ


LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171- 9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	116- M
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
1/1/2017	1/31/2017

DMR Mailing ZIP CODE: 14171- 9799
MAJOR
(SUBR 09)
PSEUDO MON. POINT @FRANKS CRK
Internal OutfallNo Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Solids, total dissolved 70295 Z 0 Instream Monitoring	SAMPLE MEASUREMENT	*****	*****	*****	*****				0	02/DS	CA
	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	250 500 DAILY MX	265 mg/L		Twice per Discharge	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.			TELEPHONE	DATE
Christine B. Lee, Manager				208-569-8984	02/23/2017
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code	NUMBER MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

IF PSEUDO MONITORING POINT REPORT IS NOT REQUIRED DURING THE MONITORING PERIOD, EITHER CHECK THE NO DISCHARGE BOX OR ENTER 'NO DATA' IN PLACE OF A MEASUREMENT TO INDICATE A GENERAL PERMIT EXEMPTION.

DISCHARGE MONITORING REPORT (DMR)

Form approved
OMB No. 2040-0004

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if

NAME: U.S. DEPT OF ENERGY
ADDRESS: 1000 INDEPENDENCE AVE SW
WASHINGTON, DC 20585

FACILITY: WEST VALLEY DEMONSTRATION PROJ

LOCATION: 10282 ROCK SPRINGS ROAD
WEST VALLEY, NY 14171-9799

ATTN: BRYAN C BOWER, DIRECTOR

NY0000973	SUM- N
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
1/1/2017	1/31/2017

DMR Mailing ZIP CODE: 14171-9799
MAJOR
(SUBR 09)
SUM OF OUTFALLS 1 & 7
Internal OutfallNo Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Iron, total [as Fe]	SAMPLE MEASUREMENT	*****	*****	*****	*****	0.31	0.31	mg/L	0	01/30	CA
01045 2 0 Effluent Net	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	1 DAILY MX	mg/L		Monthly	CALCTD

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE	
Christine B. Lee, Manager		208-569-8984		02/23/2017	
TYPED OR PRINTED		AREA Code	NUMBER	MM/DD/YYYY	

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR
AUTHORIZED AGENT

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)