


# Quantifying the Value of CSP with Thermal Energy Storage



**Paul Denholm, Mark Mehos**

**Presentation to the SunShot CSP  
Program Review**

**April 23, 2013**

# Overall Motivation

---

- What is the addition of TES to a CSP plant actually worth?
- Dispatchable energy
- Ancillary services
- Firm capacity
- System Flexibility


# DOE supported analysis to date

- Implement concentrating solar power (CSP) with thermal energy storage (TES) in a commercial production cost model
  - Develop approaches that can be used by utilities and system planners to incorporate CSP in standard planning tools
- Evaluate the optimal dispatch of CSP with TES
  - How would a plant actually be used to minimize system production cost?
- Quantify the value of adding storage to CSP in a high renewable energy (RE) scenario in California
  - How does TES change the value of CSP?

# Analytic Approaches

- Price-Taker
  - Simulates a relatively small CSP plant that does not affect prices
  - Dispatches CSP against historical prices
  - Cannot perform forward-looking analysis in a future system
  - Limited in scope, but relatively low-cost effort
- Full-grid simulation
  - Use production cost (unit commitment and economic dispatch) model
  - Can simulate future grid mixes
  - Can evaluate interaction of CSP with the grid
  - Can be costly and time consuming to develop and implement

# Example analysis – CSP in California



## California:

- Detailed plant performance curves
- Integer constraints

## Rest of Western Electricity Coordinating Council (WECC):

- Simple plant performance curves
- Linear operation

# California Independent System Operator (CAISO) Scenarios

Scenario	Region	Incremental Capacity (MW)							
		Biomass/ Biogas	Geo- thermal	Small Hydro	Solar Photovoltaics (PV)	Distributed Solar	CSP	Wind	TOTAL
Trajectory	CREZ-North CA	3	0	0	900	0	0	1,205	2,108
	CREZ-South CA	30	667	0	2,344	0	3,069	3,830	9,940
	Out-of-State	34	154	16	340	0	400	4,149	5,093
	Non-CREZ	271	0	0	283	1,052	520	0	2,126
	<i>Scenario Total</i>	<i>338</i>	<i>821</i>	<i>16</i>	<i>3,867</i>	<i>1,052</i>	<i>3,989</i>	<i>9,184</i>	<i>19,266</i>
Environmentally Constrained	CREZ-North CA	25	0	0	1,700	0	0	375	2,100
	CREZ-South CA	158	240	0	565	0	922	4,051	5,935
	Out-of-State	222	270	132	340	0	400	1,454	2,818
	Non-CREZ	399	0	0	50	9,077	150	0	9,676
	<i>Scenario Total</i>	<i>804</i>	<i>510</i>	<i>132</i>	<i>2,655</i>	<i>9,077</i>	<i>1,472</i>	<i>5,880</i>	<i>20,530</i>
Cost- Constrained	CREZ-North CA	0	22	0	900	0	0	378	1,300
	CREZ-South CA	60	776	0	599	0	1,129	4,569	7,133
	Out-of-State	202	202	14	340	0	400	5,639	6,798
	Non-CREZ	399	0	0	50	1,052	150	611	2,263
	<i>Scenario Total</i>	<i>661</i>	<i>1,000</i>	<i>14</i>	<i>1,889</i>	<i>1,052</i>	<i>1,679</i>	<i>11,198</i>	<i>17,493</i>
Time- Constrained	CREZ-North CA	22	0	0	900	0	0	78	1,000
	CREZ-South CA	94	0	0	1,593	0	934	4,206	6,826
	Out-of-State	177	158	223	340	0	400	7,276	8,574
	Non-CREZ	268	0	0	50	2,322	150	611	3,402
	<i>Scenario Total</i>	<i>560</i>	<i>158</i>	<i>223</i>	<i>2,883</i>	<i>2,322</i>	<i>1,484</i>	<i>12,171</i>	<i>19,802</i>

Note: CREZ = Competitive Renewable Energy Zone

# Approach

---

1. Start with base case – Get total production cost
  - Base case is a 32% scenario, produced by reducing PV generation in Southern CA
  - Also adjusted reserve requirements
2. Add a generator – Get total production cost
3. Subtract – Difference is operational benefit of added generator
4. Calculate capacity benefits separately

# CSP Scenarios

Four scenarios, each with an added plant producing approximately equivalent annual energy:

1. CSP plant with 6 hours of storage
  - 762 MW, SM = 2.0
  - Generates about 3,050 GWh, or enough to provide about 1.0% of California demand
  - No change in reserve requirements
2. CSP with reserves
  - Same as before, but can provide regulation, load-following, and spin
3. Solar PV
  - 1548 MW
  - This plant also required additional reserves due to uncertainty and variability
4. Flat block (baseload) resource
  - 359 MW of constant output with zero fuel costs



# Reserves

---

- Three classes of ancillary service requirements were included (Contingency, Regulation, Flexibility)
  - Contingency reserves not modified
  - Regulation and flexibility requirements based on variation of net load using WWSIS II methods

# Operational Value Results


---

PLEXOS generates hour sources of costs for system operation:


1. Operational fuel
2. Variable operations and maintenance (O&M)
3. Startup (fuel + start O&M)
4. Emissions

Examining dispatch can explain the origin and differences of these costs.

# January Price and Dispatch




System net load and marginal price for January 31–February 2




System marginal price and corresponding CSP generation on January 31–February 2

# June Price and Dispatch



System net load and marginal price for June 24–26


System marginal price and corresponding CSP generation on June 24–26



# Operation with Reserves


- Much more part-load operation
  - Plant without reserves operates at full output during about 66% of on-line hours
  - Plant providing reserves operates at full output during about 11% of on-line hours
- Stays on line longer
  - 25% fewer starts
- Operates at lower output even when price is high

# Operation with Reserves



System marginal price and corresponding CSP generation on January 31–February 2

System marginal price and corresponding CSP generation on June 24–26



# Total Operational Value

	Operational Value per Unit of Delivered Energy (\$/MWh)			
	Baseload	PV	CSP (no Reserves)	CSP (with Reserves)
Fuel	33.9	29.1	38.9	54.0
Variable O&M	4.7	4.4	5.2	6.0
Start	0.1	-2.3	2.1	4.7
Emissions	21.9	22.7	20.1	18.3
<b>Total</b>	<b>60.6</b>	<b>53.9</b>	<b>66.2</b>	<b>83.0</b>


# Capacity Value

---

- Operation value considers only the variable costs of system operation
- Capacity value represents the ability of CSP to displace fossil or other conventional generation resources
- Determined by the ability of a resource to provide generation during periods of highest net load periods




# Capacity Value




Output during the highest-price hours

# Capacity Value (Previous Study)



Arizona



# Capacity Value

	Flat Block	PV	CSP with TES
Capacity Credit (%)	100	47	100
Capacity Value (Low / High) (\$/kW)	55 / 212	26 / 100	55 / 212
Capacity Value of Energy (Low / High) (\$/MWh)	6.3 / 24.7	10.7 / 41.3	13.6 / 52.3

“Low” case assumes the cost of new capacity is \$55/kW-yr,  
“High” case assumes the cost of new capacity is \$212/kW-yr

# Total Operational and Capacity Value


	Value per Unit of Delivered Energy (\$/MWh)			
	Baseload	PV	CSP (no Reserves)	CSP (with Reserves)
Fuel	33.9	29.1	38.9	54.0
Variable O&M	4.7	4.4	5.2	6.0
Start	0.1	-2.3	2.1	4.7
Emissions	21.9	22.7	20.1	18.3
Capacity (Low / High)	6.3 / 24.7	10.7 / 41.3	13.6 / 52.3	13.6 / 52.3
<b>Total</b>	66.8 / 84.7	64.6 / 95.3	79.8 / 118.5	96.6 / 135.3

Higher emissions benefits from PV and baseload generators are from avoided out-of-state coal generation. CSP times its output to avoid mostly higher-value, in-state gas generation.

# Value Difference


	Difference in Value per Unit of Delivered Energy for a CSP Plant Providing Reserves (\$/MWh)		
	Baseload	PV	CSP (no Reserves)
Fuel	20.1	24.9	15.1
Variable O&M	1.3	1.6	0.8
Start	4.6	7.0	2.7
Emissions	-3.6	-4.4	-1.8
Capacity (Low / High)	7.3 / 20.8	2.8 / 8.1	0 / 0
<b>Total (Low / High)</b>	29.8 / 50.6	32.0 / 40.1	16.8 / 16.8

# Challenges of Higher Solar Penetration




System marginal price and corresponding CSP generation on July 21–23. Short price spike partially driven by decrease in PV output.

# Example Dispatch in CAISO



PV looks good – high energy and capacity value


# Too much of a good thing?





# Current System Flexibility


## Limited by Baseload Capacity




Price/Load Relationship in PJM

### Below Cost Bids

Plant operators would rather sell energy at a loss than incur a costly shutdown. Solar/wind may be curtailed under these conditions




# Example 20% Annual Contribution from PV




WECC-Wide Simulation May 10-13 – 16% of PV is curtailed (5% annual)

# PV Curtailment



# PV Cost Impact



# What Can CSP/TES do?

---


- **Shift solar generation with very high efficiency (close to 100%)**
- **Add a flexible source of generation with low minimum generation constraints**
- **Provide firm capacity that can replace retiring generators instead of supplementing their output**

# What Can CSP/TES do?

---


- **Lets examine just the benefits of energy shifting**

# Add Dispatchable CSP – 25% solar



May 10-13 with 15% Contribution from PV and 10% from Dispatchable CSP -  
Solar contribution goes up, curtailment goes down (2% annual)

# Curtailment CSP+PV




Curtailment of solar assuming a equal mix (on an energy basis) of PV and CSP




# Add the Flexibility of CSP...

- CSP has large operating range and high ramp rates
- Firm capacity can replace retiring generators with limited flexibility

This is real performance data from the ERCOT gas steam fleet, including some old clunkers




# CSP Flexibility Impact




25% Contribution from PV and 10% from Dispatchable CSP where CSP Reduces the Minimum Generation Constraint

# Impact of Reduce Min Gen Constraint




# Increased Use of PV




Increase in PV penetration as a function of CSP penetration assuming a maximum PV marginal curtailment rate of 20%.

# High Penetration Scenarios



CSP Penetration in de-carbonized energy scenarios

CSP as a critical component to system operation



# Project Next Steps

---

- Different CSP technologies and configurations
- More scenarios (RE mix, higher penetration)
- Sub-hourly dispatch
- More detailed understanding of CSP plants providing reserves
- Optimization of WECC units
- Natural gas prices
- CSP scheduling

# Conclusions


---

- CSP with thermal energy storage has been simulated in several grid simulation tools
- TES can add several quantifiable benefits including dispatchable energy, ancillary services, and firm capacity
- CSP with TES can actually complement other variable generation sources including solar PV and act as an enabling technology to achieve higher overall penetration of renewable energy

# References

- Madaeni, S. H., R. Sioshansi, and P. Denholm. “Estimating the Capacity Value of Concentrating Solar Power Plants with Thermal Energy Storage: A Case Study of the Southwestern United States” IEEE Transactions on Power Systems.
- Denholm, P., Y. Wan, M. Hummon, and M. Mehos. (2013). Analysis of Concentrating Solar Power with Thermal Energy Storage in a California 33% Renewable Scenario. NREL Report No. TP-6A20-58186.
- Denholm, P. R. Margolis, T. Mai, G. Brinkman, E. Drury, M. Hand, and M. Mowers (2013). “Bright Future – Solar Power as a Major Contributor to the U.S. Grid” IEEE Power and Energy 11(2) 22-32.
- Denholm, P., and M. Hummon. (2012). Simulating the Value of Concentrating Solar Power with Thermal Energy Storage in a Production Cost Model. NREL Report No. TP-6A20-56731
- Denholm, P., M. Hand, T. Mai, R. Margolis, G. Brinkman, E. Drury, M. Mowers, and C. Turchi. (2012) “The Potential Role of Concentrating Solar Power in High Renewables Scenarios in the United States.” NREL/TP-6A20-56294.
- Madaeni, S., R. Sioshansi, and P. Denholm. (2012) "How Thermal Energy Storage Enhances the Economic Viability of Concentrating Solar Power" Proceedings of the IEEE 100(2) 335-347.
- Denholm, P. and M. Mehos. (2011) “Enabling Greater Penetration of Solar Power via the Use of Thermal Energy Storage” NREL Report No. TP-6A20-52978.
- Brinkman, G.L., P. Denholm, E. Drury, R. Margolis, and M. Mowers. (2011) “Toward a Solar-Powered Grid - Operational Impacts of Solar Electricity Generation” IEEE Power and Energy 9, 24-32.
- Sioshansi, R. and P. Denholm. (2010) “The Value of Concentrating Solar Power and Thermal Energy Storage.” IEEE Transactions on Sustainable Energy. 1 (3) 173-183.





**Contact:**

**Paul Denholm**

**[paul.denholm@nrel.gov](mailto:paul.denholm@nrel.gov)**