# U.S. Department of Energy
## Categorical Exclusion Determination Form

Program or Field Office: EERE-RW/EECBG

Project Title: Building Retrofits

Location: Texas City of Haltom

Proposed Action or Project Description: American Recovery and Reinvestment Act: ☒

Haltom City Recreation Center and Fleet Facilities Building Energy Management Systems Retrofits:
-Upgrade of the existing software key to a medium key.
-Controllers, sensors, and associated control wiring for split systems.
-Digital display space temperature sensor with set point adjustment and override.
-Supply air temperature monitoring at each unit for preventative maintenance.
-Tie in to existing energy management system with color graphics.
-Link graphics so that all Haltom City facilities with the similar energy management systems can be seen at the same time.

Categorical Exclusion(s) Applied:

X - B2.2 Installation of/improvements to building/equipment instrumentation (remote controls, emergency warning systems, monitors)

X - B5.1 Actions to conserve energy

X- A1 - Routine administrative/financial/personnel actions

*-For the complete DOE National Environmental Policy Act regulations regarding categorical exclusions, see Subpart D of 10 CFR10 21 Click Here

This action would not: threaten a violation of applicable statutory, regulatory, or permit requirements for environment, safety, and health, including DOE and/or Executive Orders; require siting, construction, or major expansion of waste storage, disposal, recovery, or treatment facilities, but may include such categorically excluded facilities; disturb hazardous substances, pollutants, contaminants, or CERCLA-excluded petroleum and natural gas products that pre-exist in the environment such that there would be uncontrolled or unpermitted releases; or adversely affect environmentally sensitive resources (including but not limited to those listed in paragraph B.(4)) of Appendix B to Subpart D of 10 CFR 1021). Furthermore, there are no extraordinary circumstances related to this action that may affect the significance of the environmental effects of the action; this action is not "connected" to other actions with potentially significant impacts, is not related to other proposed actions with cumulatively significant impacts, and is not precluded by 40 CFR 1506.1 or 10 CFR 1021.211.

Based on my review of information conveyed to me and in my possession (or attached) concerning the proposed action, as NEPA Compliance Officer (as authorized under DOE Order 451.1B), I have determined that the proposed action fits within the specified class(es) of action, the other regulatory requirements set forth above are met, and the proposed action is hereby categorically excluded from further NEPA review.

NEPA Compliance Officer: Othalene J. Lawrence Date Determined: Aug 23, 2010

Comments: Webmaster: Lawrence Wiggins Digitally signed by Lawrence Wiggins DN: cn=Lawrence Wiggins, o=EES, ou, email=Lawrence.Wiggins@hq.doe.gov, c=US Date: 2010.08.25 11:39:45 -04'00'

Submit to Webmaster
Submit via Email
Submit to Website
Print Form for Records

THINK BEFORE YOU PRINT