

PMC-EF2a

(20402)

**U.S. DEPARTMENT OF ENERGY
EERE PROJECT MANAGEMENT CENTER
NEPA DETERMINATION**



RECIPIENT:North Carolina Department of Commerce, State Energy Office

STATE: NC

PROJECT TITLE : Energy Conservation Programs in Transportation - Western Piedmont Community College

Funding Opportunity Announcement Number	Procurement Instrument Number	NEPA Control Number	CID Number
	DE-EE0000771	GFO-0000771-017	0

Based on my review of the information concerning the proposed action, as NEPA Compliance Officer (authorized under DOE Order 451.1A), I have made the following determination:

CX, EA, EIS APPENDIX AND NUMBER:

Description:

B5.1 Actions to conserve energy, demonstrate potential energy conservation, and promote energy-efficiency that do not increase the indoor concentrations of potentially harmful substances. These actions may involve financial and technical assistance to individuals (such as builders, owners, consultants, designers), organizations (such as utilities), and state and local governments. Covered actions include, but are not limited to: programmed lowering of thermostat settings, placement of timers on hot water heaters, installation of solar hot water systems, installation of efficient lighting, improvements in generator efficiency and appliance efficiency ratings, development of energy-efficient manufacturing or industrial practices, and small-scale conservation and renewable energy research and development and pilot projects. The actions could involve building renovations or new structures in commercial, residential, agricultural, or industrial sectors. These actions do not include rulemakings, standard-settings, or proposed DOE legislation.

Rational for determination:

Western Piedmont Community College in North Carolina proposes to use \$124,133 of EECBG funding to replace 183 Metal Halide light fixtures with more efficient induction lights. The light fixtures are outdoor area lighting fixtures for roads, parking lots, and walkways throughout the WPCC campus.

The exact fixtures replaced are:

- (120) 400 W Metal Halide Cobra Heads with 200 W Induction
- (5) 400 W Metal Halide Cobra Heads with photocell with 200 W Induction with photocell
- (27) 250 W Metal Halide Cobra Heads with 120 W Induction
- (25) 250 W Metal Halide Post Tops with 120 W Induction
- (6) 400 W Metal Halide Post Tops with 200 W Induction

Old light bulbs will be dealt with according to the recipient's waste stream plan and therefore this project is not expected to have any adverse environmental impact.

Based on the above information this project is categorically excluded from further NEPA review under CX number B 5.1, Actions to Conserve Energy.

NEPA PROVISION

DOE has made a final NEPA determination for this award

Insert the following language in the award:

Note to Specialist :

Completed by Bill Knapp

SIGNATURE OF THIS MEMORANDUM CONSTITUTES A RECORD OF THIS DECISION.

NEPA Compliance Officer Signature: 
NEPA Compliance Officer

Date: 12/21/10

FIELD OFFICE MANAGER DETERMINATION

Field Office Manager review required

NCO REQUESTS THE FIELD OFFICE MANAGER REVIEW FOR THE FOLLOWING REASON:

- Proposed action fits within a categorical exclusion but involves a high profile or controversial issue that warrants Field Office Manager's attention.
- Proposed action falls within an EA or EIS category and therefore requires Field Office Manager's review and determination.

BASED ON MY REVIEW I CONCUR WITH THE DETERMINATION OF THE NCO :

Field Office Manager's Signature: _____
Field Office Manager

Date: _____