

# ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION

## Rocky Mountain Region, Western Area Power Administration

### Alcova-Casper North and South 115-kV Transmission Lines Structure Replacement and Road Maintenance Project Natrona County, Wyoming

- A. Brief Description of Proposal:** Western Area Power Administration (Western) proposes to perform routine maintenance on certain wood-pole structures and conduct road maintenance and repairs and re-establish the access road right-of-way (ROW) on the Alcova-Casper North and South (A-CASN and A-CASS) 115-kV Transmission Lines. The structures were identified as deficient and in need of repair or replacement by Western crews. Work would occur on private, BLM and State lands in Natrona County, Wyoming.

Routine maintenance actions proposed for the A-CASN Transmission Line include:

1. The replacement of wood crossarms and pole structures at 0/8, 6/1, 6/7, 11/7, 13/5, 14/9, 18/9, 23/1, 23/6, and 27/2.
2. Landing construction at structures 0/8, 5/7, 9/8, 18/9, 21/6, 22/2, 23/7, 25/1, and 25/2. The landing construction will include grading a level parking area near the structure, approximately 40 feet in diameter, to facilitate level parking and crane truck stabilization and truck turning radius.
3. Road maintenance from structures 0/8 to 0/9; 9/3 to 9/4; and 21/5 to 24/3.

Routine maintenance actions proposed for the A-CASS Transmission Line include:

1. The replacement of wood crossarms and pole structures at 5/1, 5/8, 12/8, 14/6, 15/7, 17/2, 17/6, 19/1, 19/5, 20/2, 21/1, 21/2, 21/6, 21/7, 21/8, 21/9, 22/6, 24/2, 25/2, 25/5, 25/7, 25/9, 27/5, and 27/8.
2. Landing construction at structures 5/5, 19/1, 21/6, 21/9, 22/4, 22/6, 25/2, and 25/5. The landing construction will include grading a level parking area near the structure, approximately 40 feet in diameter, to facilitate level parking and crane truck stabilization and truck turning radius.
3. Road maintenance improvements from structures 11/1 to 13/2; 14/3 to 17/6; 19/3 to 19/4; 20/6 to 22/5 and at structures 19/1 and 25/2.

This work may be accomplished using a rubber-tired motor grader, track dozer, backhoe, a crane, manlift, backhoe, rubber-tired pressure digger/derrick, skid steer loader, pole trailer, and line trucks. All work will be confined to Western's ROW easements.

- B. Number and Title of the Categorical Exclusion Being Applied:** (See text in 10 CFR Part 1021, Subpart D.)

#### **B1.3 Routine Maintenance.**

**Routine maintenance activities** and custodial services for buildings, structures, rights-of-way, infrastructures (including, but not limited to, pathways, roads, and railroads), vehicles and equipment, and localized vegetation and pest control, during which operations may be suspended and resumed, provided that the activities would be conducted in a manner in accordance with applicable requirements. Custodial services are activities to preserve facility appearance, working conditions, and sanitation (such as cleaning, window washing, lawn mowing, trash collection, painting, and snow removal). **Routine maintenance activities, corrective (that is, repair), preventive, and predictive, are required to maintain and**

## ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION

### Rocky Mountain Region, Western Area Power Administration

#### Alcova-Casper North and South 115-kV Transmission Lines Structure Replacement and Road Maintenance Project Natrona County, Wyoming

preserve buildings, structures, infrastructures, and equipment in a condition suitable for a facility to be used for its designated purpose. Such maintenance may occur as a result of severe weather (such as hurricanes, floods, and tornados), wildfires, and other such events. **Routine maintenance may result in replacement to the extent that replacement is in-kind and is not a substantial upgrade or improvement.** In-kind replacement includes installation of new components to replace outmoded components, provided that the replacement does not result in a significant change in the expected useful life, design capacity, or function of the facility. Routine maintenance does not include replacement of a major component that significantly extends the originally intended useful life of a facility (for example, it does not include the replacement of a reactor vessel near the end of its useful life). Routine maintenance activities include, but are not limited to:

- (a) Repair or replacement of facility equipment, such as lathes, mills, pumps, and presses;
- (b) Door and window repair or replacement;
- (c) Wall, ceiling, or floor repair or replacement;
- (d) Reroofing;
- (e) Plumbing, electrical utility, lighting, and telephone service repair or replacement;
- (f) Routine replacement of high-efficiency particulate air filters;
- (g) Inspection and/or treatment of currently installed utility poles;
- (h) Repair of road embankments;**
- (i) Repair or replacement of fire protection sprinkler systems;
- (j) Road and parking area resurfacing, including construction of temporary access to facilitate resurfacing, and scraping and grading of unpaved surfaces;
- (k) Erosion control and soil stabilization measures (such as reseeded, gabions, grading, and revegetation);
- (l) Surveillance and maintenance of surplus facilities in accordance with DOE Order 435.1, "Radioactive Waste Management," or its successor;
- (m) Repair and maintenance of transmission facilities, such as replacement of conductors of the same nominal voltage, poles, circuit breakers, transformers, capacitors, crossarms, insulators, and downed powerlines, in accordance, where appropriate, with 40 CFR part 761 ("Polychlorinated Biphenyls Manufacturing, Processing, Distribution in Commerce, and Use Prohibitions") or its successor;**
- (n) Routine testing and calibration of facility components, subsystems, or portable equipment (such as control valves, in-core monitoring devices, transformers, capacitors, monitoring wells, lysimeters, weather stations, and flumes);
- (o) Routine decontamination of the surfaces of equipment, rooms, hot cells, or other interior surfaces of buildings (by such activities as wiping with rags, using strippable latex, and minor vacuuming), and removal of contaminated intact equipment and other material (not including spent nuclear fuel or special nuclear material in nuclear reactors); and
- (p) Removal of debris.**

C. **Regulatory Requirements in 10 CFR 1021.410 (b):** (See full text in regulation and attached checklist.)

## ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION

### Rocky Mountain Region, Western Area Power Administration

#### Alcova-Casper North and South 115-kV Transmission Lines Structure Replacement and Road Maintenance Project Natrona County, Wyoming

- 1) The proposed action fits within a class of actions listed in Appendix A or B to Subpart D. For classes of actions listed in Appendix B, the following conditions are integral elements. To fit within a class, the proposal must not:
  - Threaten a violation of applicable statutory, regulatory, or permit requirements for environment, safety, and health, or similar requirements of DOE or Executive Orders;
  - Require siting and construction or major expansion of waste storage, disposal, recovery, or treatment facilities (including incinerators), but the proposal may include categorically excluded waste storage, disposal, recovery, or treatment actions or facilities;
  - Disturb hazardous substances, pollutants, contaminants, or CERCLA-excluded petroleum and natural gas products that preexist in the environment such that there would be uncontrolled or unpermitted releases;
  - Have the potential to cause significant impacts on environmentally sensitive resources. An environmentally sensitive resource is typically a resource that has been identified as needing protection through Executive Order, statute, or regulation by Federal, State, or local government, or a federally recognized Indian tribe. An action may be categorically excluded if, although sensitive resources are present, the action would not have the potential to cause significant impacts on those resources (such as construction of a building with its foundation well above a sole-source aquifer or upland surface soil removal on a site that has wetlands). Environmentally sensitive resources include, but are not limited to those listed in paragraph B. (4) (see Attachment A).
- 2) There are no extraordinary circumstances related to the proposal that may affect *the significance of the environmental effects of the proposal*.
- 3) The proposal is not "connected" to other actions with potentially significant impacts, is not related to other proposed actions with cumulatively significant impacts, and is not precluded by 40 CFR 1506.1 or 10 CFR 1021.211.

#### **D. Special Stipulations Pertaining to the Proposal:**

This Categorical Exclusion is valid for one year after the signature date. If routine maintenance work has not commenced within that time or the scope of work changes, Western's Environmental Division must be contacted for an updated environmental review.

**An archaeological monitor is required for this project. Please notify Western's Environmental Division at least two weeks prior to the beginning of work so that the monitor can be on site when your crews are ready.**

**To comply with the Migratory Bird Treaty Act, maintenance work should be scheduled outside the March 1 through July 31 general nesting periods. If the maintenance work is to be done during this period, contact Western's Environmental Division so that they may**

**ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION**

**Rocky Mountain Region, Western Area Power Administration**

**Alcova-Casper North and South 115-kV Transmission Lines  
Structure Replacement and Road Maintenance Project  
Natrona County, Wyoming**

**arrange for a survey to be conducted in advance of the maintenance crews to identify active nests that are to be avoided.**

If any cultural materials are discovered during construction, work in the area shall halt immediately, Western's Regional Preservation Officer shall be contacted, and the material be evaluated by an archaeologist or historian meeting the Secretary of the Interior's Professional Qualification Standards (48 FR 22716, Sept. 1983).

If any used treated wood poles or crossarms are donated, Western will obtain a signed "acknowledgment of receipt" of Western's Consumer Information Sheet for Treated Wood Poles and Crossarms from the person receiving the used poles and/or crossarms.

All equipment used will be cleaned prior to use in the area to prevent transporting of invasive plant or noxious weed seeds.

Disturbed areas not needed for maintenance access will be reseeded using native plant species that are preferred browse of pronghorn and mule deer.

Western shall exercise care to preserve the natural landscape and shall conduct this construction operation to prevent any unnecessary destruction, scarring, or defacing of the natural surroundings in the project vicinity. Except where clearing is required for permanent works, or excavation operations, vegetation shall be preserved and shall be protected from damage by Western's construction operations and equipment.

Structure sites and other disturbed areas will be located at least 100 feet, where practical, from rivers, streams (including ephemeral streams), ponds, lakes, and reservoirs.

To minimize impacts to the environment and prevent damage to access roads, operation of off-road equipment will not be permitted during periods of heavy rains, when soils are wet, or when excessive soil damage may occur due to unsuitable operating conditions. No construction or routine maintenance activities shall be performed during periods when the soil is too wet to adequately support construction equipment. If equipment creates ruts in excess of six inches deep, the soil shall be deemed too wet to adequately support construction equipment.

**ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION**

**Rocky Mountain Region, Western Area Power Administration**

**Alcova-Casper North and South 115-kV Transmission Lines  
Structure Replacement and Road Maintenance Project  
Natrona County, Wyoming**

**E. Determination:** Based on my review of information provided to me and in my possession concerning the proposed action, I determined that the proposed action fits within the specified class of actions, the other regulatory requirements set forth above are met, and the proposed action is categorically excluded from requirements for an EA or an EIS.

  
Signature

Date: 2/9/15

Gene Iley, Jr.  
NEPA Compliance Officer  
Rocky Mountain Customer Service Region  
Western Area Power Administration

Prepared by: Brian Little

**ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION**

Rocky Mountain Region, Western Area Power Administration

Alcova-Casper North and South 115-kV Transmission Lines  
Structure Replacement and Road Maintenance Project  
Natrona County, Wyoming

**ATTACHMENT A**

**Conditions That Are Integral Elements of the Classes  
of Actions in Appendix B That Apply to This Proposal**

Checklist for Categorical Exclusion Determination, revised Nov. 2011

<b>Application of Categorical Exclusions (1021.410)</b>	<b>Disagree</b>	<b>Agree</b>	<b>Unknown</b>
(b)(1) The proposal fits within a class of actions that is listed in appendix B to subpart D.		X	
(b)(2) There are no extraordinary circumstances related to the proposal that may affect the significance of the environmental effects of the proposal. Extraordinary circumstances are unique situations presented by specific proposals, including, but not limited to, scientific controversy about the environmental effects of the proposal; uncertain effects or effects involving unique or unknown risks; and unresolved conflicts concerning alternate uses of available resources.		X	
(b)(3) The proposal has not been segmented to meet the definition of a categorical exclusion. Segmentation can occur when a proposal is broken down into small parts in order to avoid the appearance of significance of the total action. The scope of a proposal must include the consideration of connected and cumulative actions, that is, the proposal is not connected to other actions with potentially significant impacts (40 CFR 1508.25(a)(1)), is not related to other actions with individually insignificant but cumulatively significant impacts (40 CFR 1508.27(b)(7)), and is not precluded by 40 CFR 1506.1 or § 1021.211 of this part concerning limitations on actions during EIS preparation.		X	
<b>B. Conditions that are Integral Elements of the Classes of Actions in Appendix B.</b>	<b>NO</b>	<b>YES</b>	<b>Unknown</b>
(1) Threaten a violation of applicable statutory, regulatory, or permit requirements for environment, safety and health, or similar requirements of DOE or Executive Orders.	X		
(2) Require siting and construction or major expansion of waste storage, disposal, recovery, or treatment facilities (including incinerators), but the proposal may include categorically excluded waste storage, disposal, recovery, or treatment actions or facilities.	X		
(3) Disturb hazardous substances, pollutants, contaminants, or CERCLA-excluded petroleum and natural gas products that preexist in the environment such that there would be uncontrolled or unpermitted releases.	X		
(4) Have the potential to cause significant impacts on	X		

**ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION**

**Rocky Mountain Region, Western Area Power Administration**

**Alcova-Casper North and South 115-kV Transmission Lines  
Structure Replacement and Road Maintenance Project  
Natrona County, Wyoming**

<p>environmentally sensitive resources. An environmentally sensitive resource is typically a resource that has been identified as needing protection through Executive Order, statute, or regulation by Federal, state, or local government, or a federally recognized Indian tribe. An action may be categorically excluded if, although sensitive resources are present, the action would not have the potential to cause significant impacts on those resources (such as construction of a building with its foundation well above a sole-source aquifer or upland surface soil removal on a site that has wetlands). Environmentally sensitive resources include, but are not limited to:</p>			
<p>(i) Property (such as sites, buildings, structures, and objects) of historic, archaeological, or architectural significance designated by a Federal, state, or local government, or property determined to be eligible for listing on the National Register of Historic Places;</p>	X		
<p>(ii) Federally-listed threatened or endangered species or their habitat (including critical habitat) or Federally-proposed or candidate species or their habitat (Endangered Species Act); state-listed or state-proposed endangered or threatened species or their habitat; Federally-protected marine mammals and Essential Fish Habitat (Marine Mammal Protection Act; Magnuson-Stevens Fishery Conservation and Management Act); and otherwise Federally-protected species (such as under the Bald and Golden Eagle Protection Act or the Migratory Bird Treaty Act);</p>	X		
<p>(iii) Floodplains and wetlands (as defined in 10 CFR 1022.4, —Compliance with Floodplain and Wetland Environmental Review Requirements: “Definitions,” or its successor);</p>	X		
<p>(iv) Areas having a special designation such as Federally- and state-designated wilderness areas, national parks, national monuments, national natural landmarks, wild and scenic rivers, state and Federal wildlife refuges, scenic areas (such as National Scenic and Historic Trails or National Scenic Areas), and marine sanctuaries;</p>	X		
<p>(v) Prime or unique farmland, or other farmland of statewide or local importance, as defined at 7 CFR</p>	X		

**ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION**

**Rocky Mountain Region, Western Area Power Administration**

**Alcova-Casper North and South 115-kV Transmission Lines  
Structure Replacement and Road Maintenance Project  
Natrona County, Wyoming**

658.2(a), —Farmland Protection Policy Act: Definitions, or its successor;			
(vi) Special sources of water (such as sole-source aquifers, wellhead protection areas, and other water sources that are vital in a region); and	X		
(vii) Tundra, coral reefs, or rain forests; or	X		
(5) Involve genetically engineered organisms, synthetic biology, governmentally designated noxious weeds, or invasive species, unless the proposed activity would be contained or confined in a manner designed and operated to prevent unauthorized release into the environment and conducted in accordance with applicable requirements, such as those of the Department of Agriculture, the Environmental Protection Agency, and the National Institutes of Health.	X		