FY12 DOE/NETL Transmission Reliability R&D Internal Program Review

Automated Reliability Reports (ARR)

Grid Reliability Performance Metrics Using Model-Less Algorithms Prototype Development and Field Demonstration at MISO

Carlos Martinez – Advanced Systems Researchers (ASR)

June 12-13, 2012 Washington, D.C.





Presentation Outline

- Automatic Reliability Reports (ARR) Background
- Grid Reliability Metrics Prototype Objectives
- Technical Accomplishments during FY2012 and Next Action Items
- Risk Factors Affecting Timely Completion
- Follow up Work for FY13
- Overview of prototype at MISO: Architecture, Grid Monitoring Visualization and Grid Reliability Tracking Grid Automatic Reliability Report (GARR)



Automatic Reliability Reports (ARR) Background and 2012 Objective

October 2008

September 2009

September 2010

August 2011

September 2012

DOE/FERC Research Funding Approved. LoadGeneration
Adequacy
Performance
Research,
Prototype,
Field Test
Completed
and Delivered
To NERC/FERC

Theoretical Study and Simulations
For Grid
Reliability
Performance
Metrics Using
Model-Less
Algorithms and
Monitoring
Visualizations
and Reports
In Progress

Research
on Grid
Reliability
Metrics,
Reports and
Visualization
Using
Model-Less
Algorithms
Completed

Prototype
Development
and Field
Demonstration
at MISO
for Grid
Performance
Monitoring,
Visualization &
Tracking Using
Model-Less
Algorithms and
Phasor Data





Automatic Reliability Reports (ARR) Prototype Development and Tests Objectives

- Specify, develop and field test a prototype for monitoring and tracking Grid Reliability Performance Metrics using model-less methods, monitoring visualizations and tracking reports utilizing phasor measurements to estimate reliability performance metrics pertaining for:
 - Voltage bounds
 - Thermal ratings
 - Stability limits
- Prototype development with MISO as industry partner using their phasor infrastructure, their BPS Grid phasor data and operational expertize
- Prototype Field Demonstration will take place at MISO
- Assess phasor data quality and research processes and filters for estimating grid performance metrics uncertainty



Technical Accomplishments to Complete in FY 2012

- COMPLETED Define, create and deliver the prototype functional specification including model-less algorithms, monitoring visualization and tracking reports
- COMPLETED Identify and define with MISO the Grid phasor data adequate for testing and validating model-less algorithms
- COMPLETED Off-line test and validation of grid reliability performance metrics using model-less algorithms and MISO Grid phasor data for agreed normal and disturbance days
- COMPLETED Functional specification revision to include MISO feedback on Grid monitoring visualization and Grid reliability tracking reports
- IN PROGRESS Deployment of prototype in MISO phasor infrastructure for Field Demonstration
- IN PROGRESS MISO verification of off-line tests and validation results
- IN PROGRESS Tune performance metrics algorithms and thresholds using results from MISO validations



MISO Grid Prototype Next Action Items

- CERTS, June 2012 Complete off-line model/metrics validation using 2011-2012 abnormal events phasor data – "Disturbance Days"
- CERTS, August 2012 Tune model, metrics, thresholds, visuals and reports for MISO, using phasor data for Eastern 2011 five largest abnormal East events, and MISO critical lines from a list of 13 lines
- CERTS, August 2012 Prepare and submit Prototype Field Test plan
- MISO, September 2012 Review CERTS Prototype final Functional Specification and upgrade prototype code version-1 in their system
- CERTS-MISO, September 2012 Start a six month Field Test concluding with a Final Report including conclusions and recommendations



Risk Factors Affecting Timely Completion

- Grid Phasor Data Availability:
 - Waiting for Host PMU installations and readiness
- Grid Phasor Data Quality:
 - Phasor Data Quality. Experience using phasor measurements is demonstrating the need for better phasor data quality filters and performance metrics uncertainty estimates
- Completion of Prototype Deployment at MISO
 - Availability of MISO personnel and IT Contractors




Follow up Work to Consider for FY 2013 Funding

- Continue and complete the Field Demonstration with MISO for improving models, performance metrics, monitoring visualization, tracking automatic reports, and getting MISO coordinators experience
- Assess grid phasor data quality and availability using field demonstration results and research more effective phasor data quality filters and estimation of grid performance metrics uncertainties
- Research to identify and define a grid reliability composite index using this project grid performance metrics and MISO reliability coordinators experience during the Field Demonstration



Prototype Development at MISO

Prototype Code Version-1 Running in Real-Time



Prototype Radial Visual for Multiple Simultaneous Grid **Performance Metrics**





MISO 345KV BPS Grid Used for Prototype Preliminary Off-Line Validations







Prototype Monitoring and Tracking System

OBJECTIVE: Monitor frequency, voltage and stability in an <u>integrated</u> manner, using <u>consistent</u> notifications, <u>simple</u> graphical visualizations, <u>model-less</u> algorithms and <u>phasor</u> measurements
Target Users: MISO Reliability Coordinators


GRID RELIABILITY ALARMS

Using NERC Criteria Identify:
Frequency Alarms
Voltage Alarms
Angle-Across-System Alarm

GRID MONITORING VISUALIZATION

3 level visuals: composite index, performance metrics and measurements





GRID RELIABILITY TRACKING

Automatically and On Demand Create & Broadcast the 24 Hour Grid Perform. Report





Prototype Monitoring Visualization

INFORMATION LEVELS DESIGN: interactive Composite Index, Performance Metrics and Specific Grid Phasor Measurements







Prototype Grid Reliability Tracking Using a Daily Report Template - 2 Page Summary

MIS

DAILY RELIABILITY PERFORMANCE REPORT

Report from: 03/02/12 12:00 AM

DISCLAIMER- The event Frequency Response is an approximate esti

mate value using the best available 1-second phasor frequency data, ACE

1. INTRODUCTION

The objective of this report is to provide a daily summary of loadgeneration control and Grid reliability performance for the MISO Bulk Power System (BPS) using phasor measurements. The MISO daily report presents:

Largest Frequency and Voltage Event of the Day:

- · Frequency-Time profile for the largest frequency event of the
- Estimation of Frequency Response and key parameters for largest frequency event
- Voltage-Time profile for the largest voltage event of the day
- Estimation of Voltage and key parameters for largest voltage

Grid Adequacy Performance Section:

- · Summary table with largest stability, voltage and thermal margins for key transmission lines
- Statistical performance boxplot charts for the voltage and current profiles at key transmission lines.

2. LARGEST FREQUENCY AND VOLTAGE EVENTS OF

2.1 Largest Frequency Event Data - 1 Second Frequency Time

Event Frequency at points A, B, and C are shown in the frequency response table. The frequency for this event dropped 0.065Hz (point-A - point-C) and stabilized (point-B) in 21 seconds.



Fig 1 - 1-Second Frequency-Time Graph (Extend to 15 Minutes)

2.2 Largest Frequency Event Data - Estimated Frequency

The event reached a lowest frequency of 59.942 (Point C) Hz and started returning to normal in about 21 seconds.

| FR = MWLoss/10*DeltaFreq | MWLoss = Max(DeltaACE(BA))- Const*10*FreqBias*DeltaFreq | | |
|---------------------------------|--|--|--|
| DeltaFreq = FreqA - FreqB | EI Const = 0.6, WI Const = 0.6, ERCOT = 0.3 | | |
| FreqA=Avg of t-2Sec to t-16Sec | | | |
| FreqA=Avg of t+19Sec to t+52Sec | | | |
| Event Summary: Date/Time | 3/2/2012 2:53:18 PM | | |
| Frequency at Point A [Hz] | 60,007 | | |
| Frequency at Point B [Hz] | 59.94 | | |
| Delta Frequency | -0.067 | | |
| BA with Highest Delta ACE | PJM | | |
| Highest Delta ACE [MW] | -1239 | | |
| FreqBias of the BA [MW/0.1Hz] | -1497 | | |
| MW Loss [MW] | 1841 | | |
| Estimated Event FreqResp | -2747 | | |

The interconnection responded to the largest event with an estimated frequency response of about -2747 MW/0.1Hz over performing the yearly committed value of -2601 MW/0.1 Hz. (additional performance parameters will be included)

2.3 Largest Voltage Event Data - 1 Second Voltage - Current

Figure 2 shows the voltage and current profiles at a sub-second resolution during the 03/02/12 disturbance at 14:53 EST.




Fig 2 - Voltage and Current Profile at Disturbance on 03/02/12 at 14:53 EST

MIS DAILY RELIABILITY PERFORMANCE REPORT

2.3 Largest Voltage Event Data - Esimated Response Table with significant voltage event parameters (WORK IN PROG-

| Voltage Event Parameters | | | | | | |
|--------------------------|--|--|--|--|--|--|
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |

3. MISO GRID ADEQUACY PERFORMANCE

3.1 Summary Table with Largest Stability, Voltage and Thermal Margin for Key Transmission Lines

The summary table below shows the MISO transmission line with the most critical and risky margins during the last 24 hours.

| MISO Grid Performance Margins | | | | | | | |
|-------------------------------|--------------------------------|-----------------|-------------------|-------------------|-------------------|--|--|
| Hour | MISO Transmis- sion Line | ANGLE MARGIN | VOLTAGE MARGIN | THERMAL MARGIN | Observa- tions | | |
| 20 | STA1 - 2 | 0.309 | 0.718 | NA | | | |
| 21 | STA2 - 3 | 0.309 | 0.718 | NA | | | |
| 22 | STA3 - 4 | 0.309 | 0.718 | NA | | | |
| 22 | STA4 - 5 | 0.309 | 0.718 | NA | | | |
| 19 | STA5 - 6 | 0.309 | 0.718 | NA | | | |
| 23 | STA6 - 7 | 0.309 | 0.718 | NA | | | |

3.1 Statistical Performance Boxplot Chart for the Voltage and Current Profiles at Key Transmission Lines

The boxplot show the voltage and current distribution for each hour




Fig 3 - Voltage and Current Distribution For Each Hour of the Day fot STA1

CONFIDENTIAL - Covered under ASR-MISO Data Confidentiality Agreement



Report from: 03/02/12 12:00 AM

to 03/02/12 11:59 PM

QUESTIONS

