

### CSP Program Summit 2016

# **CSP Systems Analysis**

Craig Turchi

Sr. Engineer, National Renewable Energy Laboratory craig.turchi@nrel.gov

energy.gov/sunshot

### **CSP Systems Analysis**




National Renewable Energy Laboratory

SuNLaMP Award NREL-1651

Total Budget \$2,250,000

Period of Performance 10/1/2016 to 9/30/2018





### **Project Goal**

- The role of the CSP Systems Analysis project is to evaluate CSP technologies in support of the DOE subprogram to assess progress toward DOE goals and guide the direction of DOE and NREL program resources.
- The project simulates CSP system performance and develops new and upgraded CSP tools for NREL's System Advisor Model (SAM).

### **3-Year Project Objectives**

#### Task 1. CSP Cost Tracking

- Track and assess CSP component and system costs as reported by the industry,
- Perform targeted cost validation on key subsystems, and
- Report CSP costs to DOE to serve as a benchmark for program metrics and progress.

### Task 2. Supercritical CO<sub>2</sub> Power Cycle Modeling

- Increase simulation speed and accuracy to make sCO<sub>2</sub> cycle model codes compatible with NREL's SAM framework,
- Compare annual performance of the most common sCO<sub>2</sub> cycle configurations, recompression and partial-cooling, within a CSP system model,
- Validate performance estimates from an sCO<sub>2</sub> cycle model versus experimental data, and
- Make recommendations to industry related to the selection and operating mode of sCO<sub>2</sub> power cycles for CSP applications.

### **3-Year Project Objectives**


#### Task 3. Optical Modeling of Power Tower Systems

 Develop and implement SolTrace performance and interface enhancements, enabling new analysis capabilities, and transfer SolarPILOT and SolTrace model capabilities to industry and researchers via a SAM webinar.


#### Task 4. Thermal-Application Modeling Tools for SAM

- Separate SAM's linear collector performance models from constraints associated with power conversion systems,
- Simplify and clarify SAM's user interface for simulations of thermal-only systems,
- Validate performance estimates from a SAM thermal-system model versus experimental data, and
- Perform a case study to highlight the potential of solar industrial process heat to promote early adopters

- Updated costs for SAM
- Industry cost survey drafted



The CSP Systems Analysis team supported the " $\pi$  day" SAM update released on 3-14-16





#### Parabolic Trough Collector Cost Update for the System Advisor Model (SAM)

Parthiv Kurup and Craig S. Turchi National Renewable Energy Laboratory


NREL is a national laboratory of the U.S. Department of Energy Office of Energy Efficiency & Renewable Energy Operated by the Alliance for Sustainable Energy, LLC

This report is available at no cost from the National Renewable Energy Laboratory (NREL) at www.nrel.gov/publications.


Technical Report NREL/TP-6A20-65228 November 2015



- Established framework for sCO<sub>2</sub>
  power cycle modeling in SAM
- Developing off-design performance maps of the recompression sCO<sub>2</sub> power cycle
  - Performance under part-load and varying ambient temperatures is essential for CSP applications



Demonstrated computation speed enhancement for SolTrace ray-tracing tool of over 300x. This public tool aids in solar field and receiver optimization.



Case	# Elements	Description	Base	Time	Factor
			[s]	[s]	
1	100,512	Default SolarPILOT case, 500MWt	11,672	6.7	1,742×
2	100,512	Same as case 1, afternoon sun position, $\theta$ = 23°, $\alpha$ = 253°	8,325	6.4	1,300×
3	6,282	Default case with single-facet heliostats	926.9	2.5	370×
4	95,174	Ivanpah-like facility	6,531	9.6	680×
5	34,188	Hexagonal field with regular layout	5,447	6.1	893×
6	79,812	North field, mixed heliostat templates (small inner, large outer)	6,683	6.2	1,078×

- Ported new code structure for data transfer between
  SAM interface and parabolic trough code
- Harmonized variable names in new code
- Confirmed agreement between old format and new code structure
- Acquired field data to test/validate models





### **Ongoing Work in FY16**

- Update SAM cost defaults based on with industry feedback
- Demonstrate accuracy and increased robustness and speed of sCO<sub>2</sub> recompression cycle model convergence
- Demonstrate improvements in computational speed and flexibility of SolTrace
- Complete new thermal-application model options for SAM: liquid-HTF trough, steam trough, and steam linear Fresnel

## Thank you!





CSP Program Summit 2016