

NASHVILLE DISTRICT WOLF CREEK DAM DISSOLVED OXYGEN RECON EVALUATION

Travis Wiley
Environmental Section
Project Planning Branch
March 27, 2018



“The views, opinions and findings contained in this report are those of the author(s) and should not be construed as an official Department of the Army position, policy or decision, unless so designated by other official documentation.”



**US Army Corps
of Engineers.**



RECONNAISSANCE-LEVEL EVALUATION OF DO IMPROVEMENT (MARCH 2017)

- **Background - Stakeholders requested Corps consider technologies to prevent loss of revenues for Hydropower due to Sluicing/Orifice Gate Release at Wolf Creek (WOL).**
- **Report contains:**
 - **Cumberland River System (Flow, Temperature, etc)**
 - **Discussion of Alternatives (Effectiveness and Cost)**
 - **Future Evaluations (NEPA, Consideration of Effects to Environment)**
 - **Cost for equipment to improve DO**



**US Army Corps
of Engineers.**



WOLF CREEK DAM – LAKE CUMB.

- Six Turbines – 45 MW
- Three Units with Hub Baffle & Air Modifications
- Largest reservoir in Cumberland- 6,089,000 ac-ft
- Provides +65% of Flow Down Cumberland Mainstem
- Penstock @ elevation 610
- Withdrawal Zone between 590'-670'



Wolf Creek Dam




US Army Corps
of Engineers.



SEASONAL STRATIFICATION

Layers develop in lake- low DO Late-July to Mid-Nov.
Temperatures follow same pattern – colder Hypolimnion




ALTERNATIVES CONSIDERED

- No Action- Continued Use of Hub Baffles & Orifice/Sluice Gates
- Auto-Venting Turbines
- Surface Pumps in Forebay
- Hypolimnetic Oxygenation System (TVA Design)
- Inverted Cone (Speece Cone)



US Army Corps
of Engineers.





US Army Corps of Engineers.



ALTERNATIVES CONSIDERED

No Action – Existing Condition

- Hub baffles and sluice/orifice gates
- Hub baffles add up to 1.5mg/L
- Loss of \$800-870K power annually
- D.O. and temperature unchanged



Auto-Venting Turbines

- Used at Norris (TVA) and J. Strom Thurmond (JST)
- JST D.O. was 1.5-3.0 mg/l above baseline
- Not expected to substantially alter temperatures from baseline



Surface Pumps

- Cherokee and Douglas Dams (TVA)
- For WOL: 14 mixer units
- DO increase of 0.25 mg/l above baseline observed at Cherokee per mixer unit
- Increased water temperatures would be expected



Hypolimnetic Oxygen System

- Liquid Oxygen Supplied by Truck (Cherokee 80 tons/day)
- Due to higher cost TVA uses to top off after hub baffles / surface mixers
- D.O. improvement would vary based on amount of oxygen infused
- Not expected to substantially alter temperatures from baseline



US Army Corps
of Engineers

SUMMARY OF ALTERNATIVES

| Technology (Design Life years) | D.O. Impacts (observed) | Temp. Impacts (estimated) | Estimated Capital Cost (\$Million) | Estimated Average Annual O&M Cost | Estimated Total Annual Cost | NEPA Required EA/EIS |
|--|---|------------------------------|--|--|-----------------------------------|----------------------------|
| No Action | 0 | same | \$ 0 | minimal | \$0.87M* | none |
| Auto-Venting Turbine (35) | 1.5 -3.0 mg/l | minimal | \$20M | minimal | \$0.909M | EA |
| Surface Pumps (20) | 0.25 mg/l per mixer | raise | \$5M | \$0.09M | \$0.425M | EA/EIS |
| Oxygen Diffusers (20) | Dependent on amount of oxygen infused | minimal | \$2.5M (120 tons/day) | \$0.37M | \$2.043M | EA |
| *Average Annual Cost to Hydro Due to Sluicing for D.O.: \$.8M-.87M | | | | | | |



SYSTEM CONSIDERATIONS

Temperature:

- Balancing Trout & Native Mussels
 - Trout in WOL tailwater (some warming of reach)
 - Native (Listed) mussels reach d/s COR- ESA Compliance
- Cooling water for Gallatin

Discharge:

- Mainstem Flow: WOL (65%), DAL (15%), CEN (16%)
- Hydropower
- Navigation



US Army Corps
of Engineers.



Questions



Tim Higgs, Chief, Environmental Section
615-736-7863
timothy.a.higgs@usace.army.mil



**US Army Corps
of Engineers.**

