

# sCO<sub>2</sub> Power Cycle with Integrated Thermochemical Energy Storage Using an MgO-Based sCO<sub>2</sub> Sorbent in Direct Contact with Working Fluid

DE-EE0008126

CSP Program Summit

Oakland, CA



March 18-19, 2019



**ECHOGEN**  
power systems

# Program summary

- Thermochemical energy storage using  $\text{MgO} + \text{CO}_2 = \text{MgCO}_3$  reversible reaction with  $\text{sCO}_2$  power cycle
- $\text{CO}_2$  generated/consumed stored by  $\text{sCO}_2$  inventory control system (ICS)
- Reactor and ICS storage in underground pressure vessel
- Overall technology requirements:
  - >50% cycle thermodynamic efficiency
  - >95% exergetic storage efficiency
  - Storage system cost < \$15/kWth



# Program goals

---


- Refine/improve MgO sorbent performance, complete design of commercial-scale reactor / storage system
- Conduct lab-scale test of integrated sCO<sub>2</sub> loop / TCES system
- Complete techno-economic analysis of full-scale (100MWe) power block + TCES system

# MgO Sorbent Development


- SR tested 26 MgO based lab-scale sorbents in HTR for capacity, durability and production cost.
  - Absorption capacity: 2-6 hr charge/discharge cycles at pressures of 100-300 atm (600-670°C), > 0.25 g CO<sub>2</sub>/g sorbent
  - Degradation: < 1% loss in capacity over 25 cycles
  - Cost of sorbent material (including processing) plus containment less than 9\$/kWh<sub>th</sub>.
- Identified “MgO coated with 40wt% Na<sub>2</sub>CO<sub>3</sub> promoter (MC30P\_coated\_40wt%)” for large batch sorbent production (~100kg) for lab prototype system testing

sample name	weight gain (≥0.25 g/g)	Energy density (≥500 MJ/m <sup>3</sup> )	cost (\$/kWh <sub>th</sub> )		
			sorbent	containment	total (≤9)
E13 pellet 0% promoter	0.125	398	5.89	3.21	9.11
E13 pellet 10% promoter	0.165	581	4.98	2.20	7.18
E13 pellet 20% promoter	0.228	872	3.95	1.47	5.42
E13 pellet 22% promoter	0.188	733	4.85	1.74	6.60
E13 pellet 40% promoter	0.211	941	4.84	1.36	6.19
E19(older) pellet 40% promoter	0.330	1474	1.23	0.87	2.10
SR1.1 powder 0% promoter	0.717	1139	1.02	1.12	2.15
SR1.1 pellet 0% promoter	0.351	761	2.09	1.68	3.77
SR1.1 powder 10% promoter	0.833	1537	0.99	0.83	1.82
SR1.1 pellet 10% promoter	0.574	1424	1.44	0.90	2.33
SR1.1 powder 20% promoter	0.825	1282	1.09	1.00	2.09
SR1.1 pellet 20% promoter	0.615	1204	1.46	1.06	2.52
SR1.1 powder 40% promoter	0.826	865	1.23	1.48	2.71
SR1.1 pellet 40% promoter	0.723	1299	1.41	0.98	2.39
E3 pellet 20% promoter	0.149	500	6.03	2.55	8.59
E4 pellet 20% promoter	0.300	778	3.00	1.64	4.64
E5 pellet 20% promoter	0.069	163	13.04	7.86	20.90
E6 pellet 20% promoter	0.149	293	6.05	4.36	10.41
E19(new) pellet 20% promoter	0.245	420	3.68	3.04	6.72
E26 pellet 20% promoter	0.255	437	3.54	2.92	6.46
SR1.1Pcal_coated_40wt%	0.772	2081	1.32	0.61	1.93
MC30P_coated_40wt%	0.735	1968	1.39	0.65	2.04
Mg-citrateP_coated_carbon_sintered_40wt%	0.731	1735	1.39	0.74	2.13
Mg-citrateP_coated_carbon_40wt%	0.789	1699	1.29	0.75	2.04
Mg-citrateP_carbon_sintered_40wt%	0.668	1586	1.52	0.81	2.33
Mg-citrateP_carbon_40wt%	0.739	1739	1.38	0.73	2.11

# MgO Sorbent Development




*Samples are individually wrapped in steel mesh and banded with copper wire, after test the meshed is substantially oxidized*



*Cold side including pressure transducer, two thermocouple probes, RTD, fill valve and cold vessel with thermoelectric modules and heat sinks.*

# Lab Scale sCO<sub>2</sub>/TCES Test Loop

- Lab scale test loop design is complete
- Design Target: 700°C, 20 MPa, 0.2 kg/s CO<sub>2</sub> flow rate
- Stage-I testing and commissioning (without HTR and TCES) of sCO<sub>2</sub> test loop is complete.
  - Max CO<sub>2</sub> Temperature= 522°C (Stage 1 heater design point)
  - Max Coil Temperature=594°C
  - Max Heater Element Temperature=942°C
  - Max Pump Discharge Pressure=11.5 MPa (fixed-orifice limit)



# Lab Scale Testing: sCO<sub>2</sub> Radiant Heaters

- Material: TP316H
- Size: 1"OD x 0.120" wall
- Spec: B31.3 A269
- 4-pass Config. approx. 27 linear ft
- Max Coil Temperature YTD: 594°C
- CO<sub>2</sub> Outlet Temp: 522°C



**Low Temperature Radiant Heater (PHX1)**



- Material: N07740
- Spec: B31.1 Code Case 190
- Size: 1.25"OD x 0.156" wall
- Coil Config. Approx. 72 linear ft
- Max conditions
  - Max Temp= 759°C
  - Max Pressure= 20.68MPa
  - Design Flow= 0.2 - 0.3kg/s



**High Temperature Radiant Heater (PHX2)**



# Lab Scale Testing: TCES Reactor Design

- Lab scale reactor design is complete for phase-II testing
- Design based on planned charging/ discharging rate of 20kW with a cycle time of approximately 2 hours
- Reactor Body
  - 24" Schd. 160 A106 Gr. B Pipe
  - Design pressure 20 MPa
  - Approx. Dry Weight: 7000lb




# Full-scale (100MWe) TCES + sCO<sub>2</sub> Power Cycle Transient Modeling

Sorbent particle diameter	3 mm
Sorbent bed void fraction	0.5
Reactor frontal diameter	20 m
Reactor length	20 m
Active sorbent density	6171.3 mol/m <sup>3</sup>







# TCES + sCO<sub>2</sub> Power Cycle Transient Modeling

- Drive turbine throttle valve CO<sub>2</sub> high pressure control = 30.4 MPa
- System low pressure controlled using inventory control system = 10.21MPa




# TCES + sCO<sub>2</sub> Power Cycle Transient Modeling



- During BP1, SR tested and identified a MgO based sorbent for large-batch production (100kg) for lab scale testing of integrated sCO<sub>2</sub>/TCES system in BP2.
- Stage-I testing and commissioning of sCO<sub>2</sub> test loop is complete.
- Stage-II testing of high temperature heater is slightly delayed due to manufacturer delay in Inconel 740H tube supply.
- Stage-III testing during BP2 involves complete testing of lab scale integrated sCO<sub>2</sub> loop/TCES reactor test loop.
- The result of the transient simulation indicated that with proper cycle design, and TCES reactor capacity, the SunShot targets of 100MW capacity, and 10hours storage could be met.
- Operation and control of the cycle appears feasible, and based on the kinetics of the sorbent/CO<sub>2</sub> reaction, adequate charging and generation rates are achievable.

# Stage-I sCO<sub>2</sub> Loop Testing: PHX1



Primary Heater Model  
CO<sub>2</sub> Outlet Temperature Data Comparison





# Stage-I sCO<sub>2</sub> Loop Testing: Pump and Recuperator

- CAT Pump
- Model:6821K.CO2
- Rated Flow: 25GPM
- Max Discharge Pressure: 20.7 MPa
- Motor Size: 30HP

- Manufacturer: VPE
- Microchannel heat exchanger
- Design Code: ASME BPV Code Section VIII Div I
- Core/Nozzle Material: SS 316L
- Design UA=3kW/K
- Design dP=0.3MPa





# TCES + sCO<sub>2</sub> Power Cycle Transient Modeling

