Kersey West - Willoby 115-kV Transmission Line Structure Replacements Weld County, Colorado Project Number: 2019-054 Expiration Date: December 31, 2023

- A. <u>Brief Description of Proposal</u>: Western Area Power Administration (WAPA) proposes to replace existing Structures 28/8, 28/9, and 29/2 along its Kersey West Willoby (KRW-WBY) 115-kV Transmission Line in Weld County, Colorado. The existing wood H-frame structures will be replaced in-kind, using the existing structure holes. The full scope of this project will include removing the existing structures, re-auguring the existing structure holes, installing the new structures, backfilling the structure holes, and installing new hardware. Equipment may include bucket trucks, truck-mounted augers, cranes, utility trucks, pick-up trucks, skid-steer loaders, pole trailers, and equipment trailers. Work will occur on private land, and will be confined to WAPA's right-of-way (ROW). Existing access routes will be used and no road maintenance or new road construction will occur.
- **B.** <u>Number and Title of the Categorical Exclusion Being Applied</u>: (See text in 10 CFR Part 1021, Subpart D.)

B1.3. Routine Maintenance

- C. <u>Regulatory Requirements in 10 CFR Part 1021.410 (b)</u>: (See full text in regulation and attached checklist.)
 - 1) The proposed action fits within a class of actions listed in Appendix A or B to Subpart D.

For classes of actions listed in Appendix B, the following conditions are integral elements. To fit within a class, the proposal <u>must not</u>:

- Threaten a violation of applicable statutory, regulatory, or permit requirements for environment, safety, and health, or similar requirements of DOE or Executive Orders;
- Require siting and construction or major expansion of waste storage, disposal, recovery, or treatment facilities (including incinerators), but the proposal may include categorically excluded waste storage, disposal, recovery, or treatment actions or facilities;
- Disturb hazardous substances, pollutants, contaminants, or CERCLA-excluded petroleum and natural gas products that preexist in the environment such that there would be uncontrolled or unpermitted releases;
- Have the potential to cause significant impacts on environmentally sensitive resources. An environmentally sensitive resource is typically a resource that has been identified as needing protection through Executive Order, statute, or regulation by Federal, State, or local government, or a federally recognized Indian tribe. An action may be categorically excluded if, although sensitive resources are present, the action would not have the potential to cause significant impacts on those resources (such as construction of a building with its foundation well above a sole-source aquifer or upland surface soil removal on a site that has wetlands). Environmentally sensitive resources include, but are not limited to, those listed in paragraph B. (4) (see Attachment A).

Kersey West - Willoby 115-kV Transmission Line Structure Replacements Weld County, Colorado Project Number: 2019-054 Expiration Date: December 31, 2023

- 2) There are no extraordinary circumstances related to the proposal that may affect the significance of the environmental effects of the proposal.
- The proposal is not "connected" to other actions with potentially significant impacts, is not related to other proposed actions with cumulatively significant impacts, and is not precluded by 40 CFR Part 1506.1 or 10 CFR Part 1021.211.

D. <u>Special Stipulations Pertaining to the Proposal</u>:

- 1) If the scope of work of this project changes, RMR's Environment Department must be contacted to determine whether additional environmental review is required.
- 2) **This Categorical Exclusion expires December 31, 2023**. If all project work has not been completed by the expiration date, or if the need for an environmental compliance extension is anticipated, RMR's Environment Department must be contacted for an updated environmental review.
- 3) Any injured or orphaned birds, and all active nest relocations, must be immediately reported to the RMR Avian Protection Leads at 970-593-8803. Any dead birds must be reported to the RMR Avian Protection Leads within twenty-four (24) hours of discovery. Additional documentation, such as photographs and GPS coordinates, may be requested to support RMR's reporting requirements to the U.S. Fish and Wildlife Service.
- 4) Transmission line and substation components must be designed and constructed in conformance with the most current editions of *Suggested Practices for Avian Protection on Power Lines and Reducing Avian Collisions with Power Lines*, both published by the Avian Power Line Interaction Committee (APLIC), to minimize avian collision and electrocution risk while maintaining safe and reliable electrical service.
- 5) If any cultural resources are inadvertently discovered during implementation of the proposed action, work within 100-feet of the discovery area must halt immediately, and RMR's Archaeologist must be contacted immediately. Work in the area of discovery must not resume until notification to proceed is provided by RMR's Archaeologist.
- 6) If any possible human remains are inadvertently discovered during implementation of the proposed action, work within 100-feet of the discovery area must halt immediately and RMR's Archaeologist must be notified immediately by telephone (no later than 24 hours from the time of discovery). A reasonable effort must be made to protect the remains from looting and/or further damage. Work in the area of discovery must not resume until notification to proceed is provided by RMR's Archaeologist.

Kersey West - Willoby 115-kV Transmission Line Structure Replacements Weld County, Colorado Project Number: 2019-054 Expiration Date: December 31, 2023

- 7) To prevent the transport of non-native and invasive plants and animals, including noxious weeds and aquatic nuisance species, work crews must thoroughly wash all vehicles and equipment (trailers, trucks, UTVs, etc.) before entering the action area and working on the project.
- 8) Activities involving the use of fuel, oil, hydraulic fluid, or other petroleum products must comply with RMR's Spill Response Plan (SRP).
- **E.** <u>Determination</u>: Based on my review of information provided to me and in my possession concerning the proposed action, I have determined that the proposed action fits within the specified class of actions, the other regulatory requirements set forth above are met, and the proposed action is categorically excluded from requirements for an EA or an EIS.

Signature and Date

Brian Little NEPA Compliance Officer Rocky Mountain Customer Service Region Western Area Power Administration

Prepared by: Jodee Miller

ENVIRONMENTAL REVIEW FOR CATEGORICAL EXCLUSION DETERMINATION

Rocky Mountain Region, Western Area Power Administration

Kersey West - Willoby 115-kV Transmission Line Structure Replacements Weld County, Colorado Project Number: 2019-054 Expiration Date: December 31, 2023

ATTACHMENT A Conditions That Are Integral Elements of the Classes of Actions in Appendix B That Apply to This Proposal Checklist for Categorical Exclusion Determination, revised Nov. 2011

Application of Categorical Exclusions (1021.410)	Disagree	Agree	Unknown
(b)(1) The proposal fits within a class of actions that is listed in appendix B to		Х	
subpart D.			
(b)(2) There are no extraordinary circumstances related to the proposal that may		Х	
affect the significance of the environmental effects of the proposal, including, but			
not limited to, scientific controversy about the environmental effects of the			
proposal; uncertain effects or effects involving unique or unknown risks; and			
unresolved conflicts concerning alternate uses of available resources.			
(b)(3) The proposal has not been segmented to meet the definition of a categorical		Х	
exclusion. Segmentation can occur when a proposal is broken down into small			
parts in order to avoid the appearance of significance of the total action. The scope			
of a proposal must include the consideration of connected and cumulative actions,			
that is, the proposal is not connected to other actions with potentially significant			
impacts (40 CFR Part 1508.25(a)(1)), is not related to other actions with			
individually insignificant but cumulatively significant impacts (40 CFR Part			
1508.27(b)(7)), and is not precluded by 40 CFR Part 1506.1 or § 1021.211 of this			
part concerning limitations on actions during EIS preparation.	NO	VEC	TT1
B. Conditions that are Integral Elements of the Classes of Actions in Appendix	NO	YES	Unknown
	X		
(1) Threaten a violation of applicable statutory, regulatory, or permit requirements	Λ		
for environment, safety and health, or similar requirements of DOE or Executive Orders.			
	X		
(2) Require siting and construction or major expansion of waste storage, disposal,	Λ		
recovery, or treatment facilities (including incinerators), but the proposal may			
include categorically excluded waste storage, disposal, recovery, or treatment actions or facilities.			
	X		
(3) Disturb hazardous substances, pollutants, contaminants, or CERCLA-excluded petroleum and natural gas products that preexist in the environment such that	Λ		
there would be uncontrolled or unpermitted releases.			
	X		
(4) Have the potential to cause significant impacts on environmentally sensitive resources. An environmentally sensitive resource is typically a resource that	Λ		
has been identified as needing protection through Executive Order, statue, or			
regulation by Federal, State, or local government, or a federally-recognized			
Indian tribe. An action may be categorically excluded if, although sensitive			
resources are present, the action would not have the potential to cause			
significant impacts on those resources (such as construction of a building with			
its foundation well above a sole-source aquifer or upland surface soil removal			
on a site that has wetlands). Environmentally sensitive resources include, but			
are not limited to:			
(i) Property (such as sites, buildings, structures, and objects) of historic,	X		
archaeological, or architectural significance designated by a Federal,			
State, or local government, or property determined to be eligible for			
listing on the National Register of Historic Places;			

Kersey West - Willoby 115-kV Transmission Line Structure Replacements Weld County, Colorado Project Number: 2019-054 Expiration Date: December 31, 2023

	Federally-listed threatened or endangered species or their habitat (including critical habitat) or Federally-proposed or candidate species or their habitat (Endangered Species Act); state-listed or State-proposed endangered or threatened species or their habitat; Federally-protected marine mammals and Essential Fish Habitat (Marine Mammal Protection Act; Magnuson-Stevens Fishery Conservation and Management Act); and otherwise Federally-protected species (such as under the Bald and Golden Eagle Protection Act or the Migratory Bird Treaty Act);	X	
	Floodplains and wetlands (as defined in 10 CFR Part 1022.4, —Compliance with Floodplain and Wetland Environmental Review Requirements: "Definitions," or its successor);	X	
	Areas having a special designation such as Federally- and state- designated wilderness areas, national parks, national monuments, national natural landmarks, wild and scenic rivers, state and Federal wildlife refuges, scenic areas (such as National Scenic and Historic Trails or National Scenic Areas), and marine sanctuaries;	X	
	Prime or unique farmland, or other farmland of statewide or local importance, as defined at 7 CFR Part 658.2(a), —Farmland Protection Policy Act: Definitions, or its successor;	X	
(vi)	Special sources of water (such as sole-source aquifers, wellhead protection areas, and other water sources that are vital in a region); and	X	
(vii)	Tundra, coral reefs, or rain forests; or	X	
desig would unaut applie	ve genetically engineered organisms, synthetic biology, governmentally nated noxious weeds, or invasive species, unless the proposed activity d be contained or confined in a manner designed and operated to prevent thorized release into the environment and conducted in accordance with cable requirements, such as those of the Department of Agriculture, the ronmental Protection Agency, and the National Institutes of Health.	X	