



**SOLAR ENERGY
TECHNOLOGIES OFFICE**
U.S. Department Of Energy



Coordinated Ramping Product & Regulation Procurement in CAISO Using Probabilistic Solar Power Forecasts

Benjamin F. Hobbs, bhobbs@jhu.edu

Theodore & Kay Schad Professor of Environmental Management
O'Connor Sustainable Research Institute, The Johns Hopkins University
Chair, CAISO Market Surveillance Committee

Venkat Krishnan, Venkat.Krishnan@nrel.gov

Senior Engineer
Power System Engineering Center
National Renewable Energy Laboratory

SETO Workshop on Solar Forecasting
May 5-6, 2021

Team members:

Paul Edwards, Haiku Sky, Ibrahim Krad, Elina Spyrou (NREL)
Carlo Siebensschuh, Hendrik Hamann, Rui Zhang (IBM)
Jie Zhang, Binghui Li, Li He (University of Texas-Dallas)
Josephine Wang, Shu Zhang (JHU)

*Thanks to staff from CAISO and MISO
(especially A. Motley, G. Bautista, C.
Loutan, R. Webb, S. Rose, B. Borissov)
and SETO for advice and data. Usual
disclaimer applies.*

This material is based upon work supported by the U.S. Department of Energy's Office of Energy Efficiency and Renewable Energy (EERE) under Solar Energy Technologies Office (SETO) Agreement Number EE0008215.

This work was authored in part by the National Renewable Energy Laboratory, operated by Alliance for Sustainable Energy, LLC, for DOE under Contract No. DE-AC36-08GO28308. The views expressed do not necessarily represent the views of the DOE or the U.S. Government. The U.S. Government retains and the publisher, by accepting the article for publication, acknowledges that the U.S. Government retains a nonexclusive, paid-up, irrevocable, worldwide license to publish or reproduce the published form of this work, or allow others to do so, for U.S. Government purposes.

Overview

CAISO & MISO Consultation / Assessment *Thrust 4*

Results

Data,
System
Descrip-
tions,
Assess-
ments

Watt-Sun
Thrust 1

Probabilistic Solar
Forecasts

Net Load
Ramp
Uncertainty,
ACE
Thrust 2

Ramp Product ,
Regulation
Requirements

System
Simulation
Thrust 4

Cost Savings &
Reliability Improvements


RAVIS
Visualiza-
tion
Thrust 3

Ramp
Uncertainty

Ramp Alerts &
Flexibility Needs


1. Comparison of Watt-Sun to base method: P-P index
2. Using solar forecasting prediction intervals to predict ramp & regulation: the Pareto method
3. Simulation of cost-reliability effects of solar-conditioned ramp requirements on CAISO system
4. Visualization: Resource Forecast and Ramp Visualization for Situational Awareness (RAVIS)

Probabilistic Watt-Sun Flowchart (IBM)



Used quantile regression to deploy probabilistic forecast models

- Quantiles of solar as function of independent variables
- Example results for 2 hr-ahead forecasts



Evaluation of Watt-Sun

Assessment: Relative Improvement of the PP-Plot Metric

Temporal

- Train: Sept. 1st, '18 - Feb. 29th, '20
- Test: Mar. 1st, '20 - June 1st, '20

Spatial


- 24 stations




Map: 24 reference stations

Calibration Quality of Watt-Sun vs. Persistence


Assessment: Relative Improvement of the PP-Plot Metric



A. **Baseline**: PP-Plot




B. **Watt-Sun**: PP-Plot




C. Relative PP-Plot Metric Improvement of **Watt-Sun**

Daily Values of Metric

Assessment: Relative Improvement of the PP-Plot Metric



Longest Run per Station with Metric Improvement > 20%



1. Comparison of Watt-Sun to base method: P-P index
2. Using solar forecasting prediction intervals to predict ramp & regulation: the Pareto method
3. Simulation of cost-reliability effects of solar-conditioned ramp requirements on CAISO system
4. Visualization: Resource Forecast and Ramp Visualization for Situational Awareness (RAVIS)

Flexible Ramping Product: CAISO, MISO, SPP


- CAISO: need to forecast three components in real-time:
 - Expected 5 minute ramp forecast
 - Uncertainty in up direction (97.5th percentile)
 - Uncertainty in down direction (2.5th percentile)
- Uncertainty distributions are presently unconditional
 - CAISO revising to condition requirements on wind, load, solar forecasts (www.caiso.com/StakeholderProcesses/Flexible-ramping-product-refinements)

Quantile Analysis: Continuous classifier shows potential to adjust net load ramp “up uncertainty” (JHU)

Two Way Classification Results


11 a.m.-2 p.m. May 2019:

97.5% Cutoff (Ramp Requirement) for Each Day Type



Upward Error Quantile Regression Results

11 a.m.-2 p.m. May 2019 (dashed blue lines are, from top to bottom respectively: 90th, 75th, 50th, 25th estimated percentiles)




Out-of-Sample Pareto Analysis of Requirements

Methods:

- Compare performance of MW requirement method relative to ISO baseline method using multiple criteria
- Criteria:
 1. Reliability: fraction of intervals in which MW need exceeds requirement (“shortage”)
 2. Cost: total MW-hour / \$ cost of requirement
- Assessment procedure:
 - Simulate rolling estimation method (out-of-sample test)
 - Baseline: histograms of N previous days’ realizations of MW need in that interval
 - Alternative: statistical or ML-based estimate of MW need
 - All methods: rescale amount or vary target reliability
 - Tradeoff: more requirements → less shortage but more cost

MW-hour
or \$




0

Fraction intervals
with shortage


kNN/PCA-based Method for Flexible Ramp Requirements (UTD)

- Shown: kNN-based FRP requirements: Reliability-oversupply tradeoffs Feb. 2020.
 - 1-D classifiers from solar site 2 using various predictors
- Multisite/PCA classifiers perform even better



Out-of-Sample Pareto Analysis of Weather-Aware Regulation Requirements Using Solar Forecasts (JHU)

Quantile Regression-based regulation requirements: Tradeoffs between reliability (fraction of 1-min average adjusted ACE > requirement) & MW supply. (Unconditional and 1- & 3-variable rolling regressions)



Preliminary results:

- *ISO baseline method performs well*
- *Adding forecast variables sometimes improves*

1. Comparison of Watt-Sun to base method: P-P index
2. Using solar forecasting prediction intervals to predict ramp & regulation: the Pareto method
3. Simulation of cost-reliability effects of solar-conditioned ramp requirements on CAISO system
4. Visualization: Resource Forecast and Ramp Visualization for Situational Awareness (RAVIS)

Benefits Assessment using Simulations (NREL)

FRP Analysis March 9-15: Baseline vs. New Flexible Ramp Requirements


Flexible Down Requirement, Baseline vs NewFRP



- Decrease in peaker units scheduling
- Reduction in production costs

- Improvement in reliability
- Expected reduction in generation scarcity and price spike!
- Reduction in renewable curtailment

Flexible Up Requirement, Baseline vs NewFRP



Simulation Results – CAISO-like IEEE 118-bus System

- FESTIV market clearing process modified with CAISO operating rules
- IEEE 118 simulated for 3-weeks in March (9-29 2020):

	Baseline (Scenario 1)	New FRP (Scenario 2)	Perfect NO uncertainty
Total Production Cost [\$M]	23.45	23.05 (1.7% savings)	23.00
Total Uncertainty Cost [\$M]	0.45	0.05 (~90% savings)	

- Uncertainty induced costs reduced by a daily average of 44%
 - Savings in production cost from lower FRP (reduction in peaker units)
 - Higher FRP reduces generation scarcity events and real-time price spikes
 - More flexible generation, with lower min. gen → Reduced curtailment

Total VG Curtailment [GWh]	69.1	63.9 (more VG)
-------------------------------	------	----------------

Results – Large 1820-node WECC / CAISO system

~**1,820 buses**: 1782 buses for CAISO and 38 for other WECC regions and trading hubs

Copper plate analysis

~\$0.27M (1.7%) savings in uncertainty induced costs in 21 days

- \$0.27M savings in 21 days ~ extrapolate to \$4.7M/yr
- ~ **\$19.5K (12.7%) savings in FRP procurement costs ~ 340K/yr FRP cost savings**
FRP clearing amount * FRP market clearing price (duals)

With full network


~\$0.5M (~3.8%) savings in uncertainty induced costs in 21 days

- \$0.5M savings in 21 days ~ Extrapolate to ~\$9M/yr, comparable to annual FRP costs
- Further simulation results forthcoming from HPC

1. Comparison of Watt-Sun to base method: P-P index
2. Using solar forecasting prediction intervals to predict ramp & regulation: the Pareto method
3. Simulation of cost-reliability effects of solar-conditioned ramp requirements on CAISO system
4. Visualization: Resource Forecast and Ramp Visualization for Situational Awareness (RAVIS)

Open-source link to code: <https://github.com/ravis-nrel/ravis>

Resource Forecasts and ramp Visualization for Situational Awareness (RAVIS) (NREL)



RAVIS: a modular dashboard for viewing:

- forecast timeline
- spatially relevant forecasts & events
- details of specific events as desired, including market data

Design: RAVIS's technology suite is assembled to *provide optimum visualization facility*

- Takes *advantage of web application technologies* and tooling
- These technologies *enable deployment in any environment*, using any operating system

San Diego

Black dot: BA/substation node
 Orange line: transmission >75%
 Orange dot: PV resource

Regional View

mapbox

San Diego- Regional Solar Power Forecast

Event: None
 Mean: 4 mw
 Upper 95% Prob.: 391 mw
 Lower 5% Prob.: 0 mw

1249 MW (TOTAL CAPACITY)
 505 MW (FORECAST MAXIMUM)
 0 MW (FORECAST MINIMUM)

San Diego- Net Load Forecast and Available Flexibility

Event: None
 Mean: 1404 mw
 Available Down Flex.: 1142 mw
 Upper 95% Prob.: 1548 mw
 Lower 5% Prob.: 1248 mw
 Available Up Flex.: 1615 mw

1617 MW (PEAK LOAD)
 1434 MW (FORECAST MAXIMUM)
 938 MW (FORECAST MINIMUM)

EVENT OUTLOOK

Generator	Status
MOST ACTIVE	
GENERATOR 55	Active
GENERATOR 64	Active
GENERATOR 62	Active
GENERATOR 59	Active
SAN DIEGO	
GENERATOR 58	Active

- Net-load forecasts, or each component,
- Available generation flexibility,
- Network nodes,
- Transmission,
- Prices

Sorted ramp events: “most active”
(e.g., most events in the next 5 hours)

Summary of features visualized in RAVIS

1) Site-specific probabilistic solar power forecasts:

Hovering reveals forecast data and other meta data; ramp size and direction are shown by circle and arrow

2) Time series forecast data: Clicking a site/region shows individual site-specific probabilistic forecast time series

3) Event alerts (e.g., ramp alerts), at site as well as regional level

4) User can configure visualization parameters

- a) Specific sites or user-defined aggregate regions
- b) Ramp definition customizable by end user

5) Data from market clearing engine integrated with forecasts viewer

- a) **On map:** Network topology, nodal prices, transmission congestion
- b) **On time series:** Available generation flexibility, plotted against net-load forecasts.

Open Source Publicly Accessible / Extensions

Extendable:

- Transmission & Distribution grids with Grid-edge visibility
- **Ongoing project:** Sensor data and cyber threats integration
 - (DOE CESER-funded project Situational Awareness and Grid Analytics (SAGA) project at NREL)

1) Open-source link to code: <https://github.com/ravis-nrel/ravis>

2) Documentation published@ <https://www.nrel.gov/docs/fy21osti/79746.pdf>.

P. Edwards, H. Sky, and V. Krishnan. 2021. *RAVIS: Resource Forecast and Ramp Visualization for Situational Awareness—An Introduction to the Open-Source Tool and Use Cases*. Golden, CO: National Renewable Energy Laboratory. NREL/TP-5D00-79746.

Conclusion

CAISO & MISO Consultation / Assessment

Results

Simulation


Cost Savings &
Reliability Improvements

Visualiza-
tion

Ramp Alerts &
Flexibility Needs

- We conclude that probabilistic forecasts are a highly promising way to condition A/S requirements on up-to-date weather forecasts
- **Future:** convolve wind, retail load, and solar forecasts for fuller picture


Questions?





Backup Slides

9.1A Continuous Improvements of Watt-Sun

Longest Run per Station with a relative PP-Plot Metric Improvement above 20% / 30%
(24h Horizon; March 1st, 2020 - June 1st 2020; i.e. 92 days)



PCA/kNN-based Method for FRP Estimation (UTD)



kNN-based FRP requirements: Reliability-oversupply, tradeoffs Feb. 2020. (1-D classifiers from solar site 2 using various predictors)

PCA-based kNN analysis of FRP requirements from multiple sites