

Sodium receiver design

Gen3 CSP Summit
August 25, 2021

Joe Coventry
Chief Investigator
Australian National University (ANU)




NREL Award # 34209 (agreement number)

ARENA



Australian Government
Australian Renewable
Energy Agency




Receiver and Heliostat Field Capacity

- System design output 50 MW_e
- Solar multiple ~3.0
- Temperature range: 520°C to 740°C.
- Nominal receiver output: 350 MW_{th}
- Nominal field output: 445 MW_{th}

Key design parameters	Value
Heliostat dimensions	7.07 m x 7.07 m (50 m ²)
Actuation type	Azimuth-elevation drives
Mirror reflectance	95%
Mirror cover ratio	97%
Average soiling level	95%
Optical error in calm conditions (wind speed below 10 m/s)	1.5 mrad (surface normal conical error)
Optical error in windy conditions (wind speed over 10 m/s)	2 mrad (surface normal conical error)
Wind speed operational threshold	15 m/s

Heliostat field sizing

- SolarPILOT & Solstice used in field layout and sizing.
- It is beneficial to oversize the field by around 15%
- Heliostat costs (\$75/m²) from the 2020 SunShot target





Sodium Receiver Design

- “Traditional” cylindrical receiver concept:
 - Planar banks of parallel pipes headers
 - Standard pipe dimensions
- Flow-path layout adapted to liquid sodium properties: 12 tube banks, 4 flow-paths.


Key design parameters	Value
Receiver pipe banks active height	14.5 m
Receiver diameter	14 m
Receiver pipe banks width	3.62 m
Number of pipe banks	12
Number of pipes per bank	59
Number of flow-paths	4
Pipe external diameter	60.3 mm
Pipe wall thickness	1.2 mm
Pipe spacing	1 mm
Pipe alloy	Inconel 740H
Solar weighted absorptance	98%
Thermal wavelengths emittance	91%

energy.gov/solar-office





Sodium vs. chloride salt

- Significantly higher flux limits possible with sodium than chloride salt




Temperature (left) and equivalent thermoelastic stress (right)



Maximum allowable net flux for (a) ternary chloride salt and (b) liquid sodium, using the ASME Section VIII Div. 2 Elastic Ratcheting Analysis Method with indefinite creep life.



Elastic vs. Inelastic analysis method

- Implementation of the new “Design Guidance for High Temperature Concentrating Solar Power Components” (ANL-20/03)
- There is significant benefit in using the inelastic analysis method for the range of temperatures of interest




Improved heliostat aiming strategy

- A new modified deviation-based aiming (MDBA) method was implemented¹
- Three parameters control the heliostat aiming: the aiming extent, a shape exponent and an asymmetry factor (A)
- Solar flux on each tube bank is kept under the limits, but as close to those limits as possible
- This helps minimise receiver size, and maximise output



Commercial-Scale Sodium Receiver Performance Summary

	Summer			Equinox				Winter		
	Noon	Noon +2h	Noon +6	Noon	Noon +2h	Noon +4h	Noon +5h	Noon	Noon +2h	Noon +4h
DNI (W/m ²)	950	930	520	980	950	805	590	930	875	510
Field utilization	0.882	0.926	1.000	0.877	0.937	1.000	1.000	1.000	1.000	1.000
Field efficiency	0.647	0.632	0.416	0.639	0.618	0.539	0.420	0.590	0.562	0.369
Intercept efficiency	0.978	0.972	0.962	0.968	0.955	0.961	0.957	0.952	0.957	0.950
Solar absorption efficiency	0.987	0.987	0.987	0.987	0.987	0.987	0.987	0.987	0.987	0.987
Thermal efficiency	0.923	0.924	0.830	0.921	0.922	0.906	0.846	0.920	0.913	0.792
Receiver efficiency	0.912	0.912	0.819	0.909	0.910	0.895	0.835	0.908	0.901	0.782
Receiver and intercept efficiency	0.891	0.886	0.788	0.881	0.869	0.860	0.799	0.865	0.862	0.743
Overall efficiency	0.577	0.560	0.328	0.563	0.537	0.463	0.335	0.511	0.484	0.274
Spillage loss (MW _{th})	8.78	10.93	6.17	12.58	17.96	12.48	7.97	19.26	15.70	7.09
Solar power through aperture (MW _{th})	384.0	384.1	154.2	385.1	383.8	307.8	176.2	383.0	346.6	133.7
Solar reflection loss (MW _{th})	4.92	4.93	1.98	4.94	4.92	3.95	2.26	4.91	4.44	1.71
Emission loss (MW _{th})	25.4	25.4	22.5	26.3	26.1	25.0	23.5	26.5	26.1	24.0
Convection loss (MW _{th})	3.57	3.56	3.34	3.64	3.62	3.53	3.41	3.66	3.62	3.46
Net thermal power to the HTF (MW _{th})	350.0	350.2	126.3	350.2	349.2	275.4	147.1	347.9	312.4	104.5
Peak absorbed flux (kW)	1062	1087	583	1040	1067	1013	670	1047	1019	514
Peak tube wall temperature (K)	1052	1052	1035	1053	1051	1053	1039	1049	1055	10328
Peak fraction of allowable flux	0.94	0.95	0.51	0.91	0.90	0.90	0.62	0.94	0.93	0.48
Max HTF velocity (m/s)	2.75	2.96	1.14	2.97	2.91	2.44	1.35	2.90	2.67	0.93
Receiver pressure drop (MPa)	0.041	0.048	0.007	0.048	0.046	0.032	0.010	0.046	0.039	0.005





Thank you!

Associate Professor Joe Coventry
Solar Thermal Group, School of Engineering
Australian National University
T +612 6125 2643
E joe.coventry@anu.edu.au


Acknowledgement

I would like to acknowledge the contributions of all the Australian (ASTRI) team who contributed to the Gen3 Liquids Pathway project, included John Pye, Charles-Alexis Asselineau, Felix Venn, William Logie, Armando Fontalvo, Shuang Wang, Robbie McNaughton, Daniel Potter, Theodore Steinberg and Geoffrey Will.

ANU's sodium research is supported by the Australian Solar Thermal Research Institute (ASTRI), a program supported by the Australian Government through the Australian Renewable Energy Agency (ARENA)

Backup slides

Capital Cost Breakdown at Commercial Scale



- Financial assumptions from DOE recommended values
- Further details in the final report [NREL/TP-5700-79323](https://www.nrel.gov/docs/fy18/tp-5700-79323.html)

Item		1×50 MW _e module	100 MW _e system (2×50 MW _e)
Heliostat field			
	Heliostats	\$ 54,212,373	\$ 108,424,746
	Site improvements	\$ 7,228,316	\$ 14,456,633
Sodium receiver		\$ 26,260,650	\$ 52,521,300
Tower		\$ 16,339,938	\$ 32,679,876
Sodium loop			
	Sodium valves	\$ 907,980	\$ 1,815,960
	Sump tank	\$ 1,252,129	\$ 2,504,259
	Inlet vessel	\$ 218,298	\$ 436,597
	Purification skid	\$ 298,479	\$ 596,959
	Sodium pumps	\$ 3,800,633	\$ 7,601,267
	Argon system	\$ 94,999	\$ 189,999
	Instrumentation and control	\$ 328,314	\$ 656,628
	Additional sodium piping	\$ 1,207,663	\$ 2,415,326
Sodium and salt piping			
	Riser [†]	\$ 1,426,598	\$ 2,853,197
	Downcomer [†]	\$ 4,533,284	\$ 9,066,568
	Salt piping	\$ 697,596	\$ 1,395,192
Salt storage			
	Tank and salt costs	\$ 54,968,250	\$ 109,936,501
	Cold salt pump	\$ 2,772,615	\$ 5,545,230
	Hot salt pump	\$ 2,079,462	\$ 4,158,924
	Salt valves	\$ 2,106,720	\$ 4,213,440
	N ₂ ullage gas system	\$ 2,860,000	\$ 5,720,000
Power block and HXs			
	Sodium-to-salt HX	\$ 10,290,385	\$ 20,580,770
	Salt-to-CO ₂ PHX	\$ 26,576,576	\$ 53,153,151
	s-CO ₂ power block	\$ 41,025,831	\$ 82,051,663
Direct capital cost subtotal		\$ 261,487,093	\$ 522,974,186
Contingency (10%)		\$ 26,148,709	\$ 52,297,419
Total direct capital cost		\$ 287,635,802	\$ 575,271,604
EPC and owner costs (9%)		\$ 25,887,222	\$ 51,774,444
Land cost		\$ 11,260,647	\$ 22,521,293
Total capital (installed cost)		\$ 324,783,671	\$ 649,567,342



Pilot-scale Sodium Receiver Design

- Flat “billboard” style design
- Key design criteria:
 - Safety, reliability and structural integrity
 - Similarity with the proposed commercial receiver design
 - Performance
 - Cost

Parameter	Value
Design thermal capacity	1 MW _{th}
Design sodium inlet temperature	520°C
Design sodium outlet temperature	740°C
Design total sodium mass flow rate	3.7 kg/s
Flow paths	2
Flow path inlet location	Top of inner-most panel
Flow path outlet location	Bottom of outer-most panel
Panels per flow path	3
Tubes per panel	11
Irradiated length per tube (height of billboard)	1.77 m
Tube wall-to-wall spacing (within panels)	1.2 mm
Tube wall-to-wall spacing (between adjacent panels)	4.0 mm
Tube OD	25.4 mm
Tube thickness	1.65 mm
Tube material	Alloy 740H (seamless)
Tube coating	High performance solar-selective coating
Overall irradiated width of billboard	1.77 m

energy.gov/solar-office


Do not distribute beyond project team.



Pilot-scale Sodium Receiver Performance Modelling


- Performance modelling in Heliosim
- Conservative allowable flux limits
- Maximum tube wall temperature disparities <30 K
- Pilot-scale efficiencies will be lower than commercial-scale

Date	Spring equinox		Summer solstice		Winter solstice	
Hours relative to solar noon	0	+3	0	+3	0	+3
DNI (W/m ²)	1055	1000	1020	980	960	800
HTF thermal output (kw)	1018	1002	1012	1031	1003	1000
Aperture interception efficiency (%)	85.3	81.3	84.8	78.8	82.7	79.3
Receiver efficiency (%)	83.6	83.4	83.9	83.9	83.5	83.5
Combined interception and receiver efficiency (%)	71.3	67.9	71.1	66.1	69.1	66.2




energy.gov/solar-office

Do not distribute beyond project team.





Net flux through the tube crown




Bulk sodium temperature

Sodium Balance of Plant – Overall Layout



Sodium Safety and Acceptance



- Safety is core to the success of the sodium pathway and is the highest priority
- System design to minimise risk
 - Sodium contained in or near the tower within an isolation zone
 - Rapid drain back of all sodium to a sump tank if there is an incident
 - Secondary containment in a spill tray
 - The best action plan for fire fighters is likely No Action – let any fire burn out naturally

Design safety

- Good system design
- Minimized sodium inventory
- Adherence to high quality and performance standards
- Suitable material selections
- Fire safety engineering

Safety requirements

- Ensure containment, i.e. high integrity against rupture, leakage or corrosion
- Maintain high sodium purity
- Use steel liners & trays over concrete
- Ensure rapid draining
- Early leak detection systems
- Avoid proximity to water
- Separation of sodium and people
- Appropriate PPE

Sodium Safety and Acceptance

- Learning from the past
 - Review of literature (e.g. Sodium-NaK Engineering Handbook)
 - Understanding of risks (sodium chemistry to human factors)
 - Lessons learnt in design (mainly from nuclear facilities)
 - Review of sodium incidents, what happened, why, lessons learnt
- Learning from experts
 - Sodium suppliers (MSSA)
 - Researchers (Sandia, U. Wisconsin, ANL)
 - Operating labs (KIT, ANL, KAERI)
 - Operating plants (Vast Solar)
 - Use of expert consultants (Creative Engineering, Claude Reed, David Wait)
 - HAZMAT experts (NSW Fire Brigade)
- Study visit to Karlsruhe Institute of Technology, Germany, Aug 2017
- Sodium Safety & Handling workshop, Argonne National Lab, Mar 2019
- Technical meeting on Sodium Technologies, KAERI, Daejeon, Korea, Sep 2019
- Sodium Bankability Workshop, Seattle, Feb 2020



ANU visit to KIT sodium loop, Karlsruhe, Germany, Aug 2017



Sodium Safety & Handling workshop, ANL, Mar 2019

Sodium Safety and Acceptance

- Learning by doing
 - Development of the high-temperature sodium laboratory at ANU
 - Development of the CSIRO and Sandia test loops (in progress)
 - HAZIDs, HAZOPs, FMEA (ANU, CSIRO, Sandia and other partners)
 - Handling sodium (cutting, transport, clean-up)
 - Controlled burning and explosive reactions with water
 - Fire fighting methods and fire extinguishing
 - Experience with different PPE
 - Chemical compatibility testing (e.g. Na, CO₂, PCMs)
 - Stakeholder engagement (ARENA, EPA, fire services, etc)
 - Training courses



Sodium Fire Training and Demonstration day,
Canberra 2016



Sodium burn tests at SNL, Jun 2020