



Engine Driven Combined Heat and Power: Arrow Linen Supply

Bruce Hedman
ICF International

December 2, 2008


Power-Gen International

Arrow Linen CHP Demonstration


- Original installations supported by NYSERDA
- Data monitoring and analysis supported by DOE
- Team consisted of Oak Ridge National Lab, Energy Solution Center and ICF International

Arrow Linen Supply, Brooklyn, New York

- Laundry service for restaurants in New York area
- Operates 6 days per week 4:00 am to 4:00 pm
- Annual energy bills:
 - \$235,000 Electricity
 - \$670,000 Natural Gas
- Peak demand = 370 kW
- Average demand = 260 kW



Existing Thermal System




Arrow Linen Supply CHP System


- Two 150 kW Coast Intelligen reciprocating engine packages
- Rich-burn Mann engines
- Induction generators
- Net power output = 284 kW
- Thermal recovery = 1.44 MMBtu/hr
- Fuel consumption = 3.10 MMBtu/hr
- Electric load following




CHP System Schematic



Daily CHP Load Profile




Monthly Power Consumption




CHP System Operating Parameters

| | Design | Average |
|------------------------------------|---------------|----------------|
| Gross Generator Output, kW | 300 | 206 |
| Net Generator Output, kW | 284 | 195 |
| System Electrical Efficiency, % | 31.3% | 26.2% |
| Fuel Consumption, MMBtu/hr | 3.10 | 2.54 |
| Thermal Energy Recovered, MMBtu/hr | 1.44 | 1.28 |
| Power-to-Heat Ratio | 0.67 | 0.52 |
| Overall CHP Efficiency | 77.7% | 76.4% |


Delayed Start Sets High Billing Demand




Daily Profile After Control Correction



CHP System Siting



CHP System Support Platform



CHP System on Roof



Total Installed Costs

| Item | Cost |
|------------------------------------|-------------|
| Generators, equipment installation | \$508,000 |
| Electrical | \$320,000 |
| Professional fees | \$73,000 |
| Miscellaneous construction costs | \$120,000 |
| Total installed costs | \$1,021,000 |
| Total installed costs, \$/kW | \$3,403 |
| Non-typical costs | \$316,000 |
| Typical installed costs, \$/kW | \$2,350 |

12 Month Energy Profile

| | W/O CHP November 2005 thru October 2006 (Calculated) | With CHP November 2005 thru October 2006 (Actual) |
|---|---|--|
| CHP System Average Electric Output, kW | n/a | 197 |
| Facility's Peak Demand, kW | 378 | 378 |
| Average Monthly Grid Demand, kW | 257 | 60 |
| Average Monthly Peak Demand Reduction, kW | n/a | 120 |
| Purchased power, kWh | 1,250,658 | 369,200 |
| CHP Generated Power, kWh | n/a | 881,458 |
| CHP Thermal Recovery, MMBtu/yr | n/a | 5,780 |
| Boiler Fuel, MMBtu/yr | 47,899 | 40,675 |
| CHP Fuel, MMBtu/yr | n/a | 11,501 |

Operating Cost Savings

| | W/O CHP November 2005 thru October 2006 (Calculated) | With CHP November 2005 thru October 2006 (Actual) |
|---|--|---|
| Fuel Costs | | |
| CHP Natural Gas Cost | n/a | \$127,507 |
| Boiler Natural Gas Cost | \$667,497 | \$567,670 |
| <i>Total Fuel Cost</i> | <i>\$667,497</i> | <i>\$695,177</i> |
| Electricity Costs | | |
| Electricity Commodity Cost | \$182,131 | \$53,665 |
| Electric Demand Cost | \$49,806 | \$34,018 |
| Miscellaneous Billing Charges | 0 | (\$12,710) |
| <i>Total Purchased Electricity Cost</i> | <i>\$231,947</i> | <i>\$74,973</i> |
| <i>Incremental CHP O&M (based on \$0.015/kWh)</i> | <i>n/a</i> | <i>\$13,222</i> |
| Total Costs | \$899,444 | \$783,372 |
| Annual Savings | n/a | \$116,073 |

Simple Payback

| | Costs |
|--|--------------|
| Total Installed Costs, \$ | \$1,021,000 |
| Total Installed Costs, \$/kW | \$3,403 |
| Operating Savings (no incentives), \$ | \$116,073 |
| <i>Simple Payback (no incentives), years</i> | <i>8.8</i> |
| NYSERDA Capital Cost Incentive, \$ | \$417,831 |
| Net Installed Costs, \$ | \$603,169 |
| NYC Production Incentive, \$/year | \$47,726 |
| Net Operating Savings (w/incentives), \$ | \$163,799 |
| <i>Simple Payback (w/incentives), years</i> | <i>3.7</i> |

Success Factors

- Designer/Installer had experience with the equipment and with working in New York City
- System is designed to be highly efficient
- Full service maintenance contract
 - System has 98.9% operating availability
- Aggressively pursued incentives
- Internal champion

Energy and CO2 Impacts

| Annual Emissions Analysis | | | | | |
|--|------------|----------------------------------|------------------------------|--------------------------|-------------------|
| | CHP System | Displaced Electricity Production | Displaced Thermal Production | Emissions/Fuel Reduction | Percent Reduction |
| NOx (tons/year) | 0.20 | 0.89 | 0.36 | 1.06 | 84% |
| SO2 (tons/year) | 0.00 | 3.16 | 0.00 | 3.16 | 100% |
| CO2 (tons/year) | 672 | 818 | 423 | 569 | 46% |
| Carbon (metric tons/year) | 166 | 202 | 105 | 141 | 46% |
| Fuel Consumption (MMBtu/year) | 11,484 | 10,347 | 7,231 | 6,094 | 35% |
| Equivalent Acres of Pine and Fir Forests | | | | 117 | |
| Equivalent Passenger Vehicles | | | | 94 | |

This CHP project will reduce emissions of Carbon Dioxide (CO2) by 569 tons per year

This is equal to 141 metric tons of carbon equivalent (MTCE) per year

This reduction is equal to the annual carbon stored by 117 acres of pine and fir forests



OR

This reduction is equal to the carbon emissions of 94 passenger vehicles per year



Questions?

- Bruce Hedman
ICF International
Arlington, VA
703-373-6632
bhedman@icfi.com