

CHP Case No.	CHP Facility Name and Location			Year CHP In Service	Complementary Technologies		Type(s) of Building Applications Served by System										Power Generation from CHP Prime Mover(s) Only		Total On-site System Capacity			
					TES	TIC	Edu	Med	Airport	Govt	Comm	Indust	Other	District	Technology Type and Details		MW(e)	MW(e)	MMB/h	tons		
	Name of Facility, Owner, or Operator	City	State																			
1	California State Polytechnic University	Pomona	CA	1989	yes		yes							yes	1 x 0.35 MW Caterpillar gas-fired recip engine	0.4	0.4	60	4,950			
2	California State University - Long Beach	Long Beach	CA	1987	yes		yes							yes	1 x 0.2 MW Caterpillar gas-fired recip engine	0.2	0.2	50	5,000			
3	California State University - Northridge	Northridge	CA	2001	yes		yes							yes	1 x 180 kW Capstone Microturbine	0.2	0.2	50	3,750			
4	California State University - San Diego	San Diego	CA	2003	yes		yes							yes	1 x 3 (+2 future x 5) MW NG-fired CTs	13.0	17.4	116	4,000			
5	El Paso - Badger Creek	Bakersfield	CA	1990		yes						yes			1 x 33.8 MW GE LM5000 NG-fired CT	35.0	48.0		800			
6	El Paso - Bear Mountain	Bakersfield	CA	1992		yes						yes			1 x 33.8 MW GE LM5000 NG-fired CT	35.0	48.0		800			
7	El Paso - Chalk Cliff	Maricopa	CA	1988		yes						yes			1 x 33.8 MW GE LM5000 NG-fired CT	35.0	48.0		800			
8	El Paso - Corona Cogen	Corona	CA	2002		yes						yes			1 x 33.8 MW GE LM5000 NG-fired CT	37.0	37.0	0	2,000			
9	El Paso - Live Oak	Bakersfield	CA	1991		yes						yes			1 x 33.8 MW GE LM5000 NG-fired CT	35.0	48.0		800			
10	El Paso - McKittrick	McKittrick	CA	1991		yes						yes			1 x 33.8 MW GE LM5000 NG-fired CT	35.0	48.0		800			
11	El Paso - San Joaquin	Lathrop	CA	1987		yes						yes			1 x 33.8 MW GE LM5000 NG-fired CT	35.0	48.0		1,400			
12	Hanford Joint Union School District	Hanford	CA	1988	yes	yes	yes								1 NG-fired cogen	0.1	0.1		85			
13	Norwalk Metropolitan State Hospital	Norwalk	CA	1988	yes	yes		yes							1 x 22 MW GE LM2500 NG-fired CT	28.0	28.0	35	1,500			
14	Occidental College	Los Angeles	CA		yes		yes						yes				0.3	10	1,000			
15	Stanford University	Palo Alto	CA	1987	yes		yes						yes	1 x 39.2 MW GE NG-fired CT	39.2	49.9	720	20,000				
16	Texaco Cogeneration Co.	San Ramon	CA		yes(95)	yes(95)					yes			1 NG-fired CT	38.0	38.0		378				
17	Tractebel Power - Ripon Cogen	Ripon	CA	1988		yes(97)					yes			1 x 52 MW GE/IHI STIG LM5000 NG-fired CT	35.0	52.0		2,000				
18	University of California - Los Angeles	Los Angeles	CA	1994	yes		yes						yes	2 x 14.5 NG-fired CTs	29.0	48.0	105	21,600				
19	University of California - San Diego	San Diego	CA		yes		yes						yes	2 x CTs	25.6							
20	Fort Lupton Cogeneration Corp.	Fort Lupton	CO			yes					yes			5 x 40 MW NG-fired CTs	200.0			2,200				
21	The Energy Network	Hartford	CT	1989	yes					yes	yes			yes	1 x 3.9 MW Solar Centaur 50 NG-fired CT	3.9	3.9					
22	Yale University	New Haven	CT	1997	yes		yes							yes	3 x 6 MW Nova Pinone GT + 3 x 1.5 MW diesel e	22.5	22.5	640	33,200			
23	CSW - Mulberry Cogen	Bartow	FL	1992		yes						yes			1 x 85 MW GE Frame 7EA NG-fired CT	85.0			4,000			
24	Reedy Creek (Disney World)	Lake Buena Vista	FL	1988	yes	yes					yes			yes	1 x 32 MW GE LM5000 NG-fired CT	32.0	40.0	90	14,425			
25	U.S. Air Force		FL	planned		planned				yes					4 x 30 kW NG-fired microturbine	0.1	0.1		450			
26	Kalaeloa Partners L.P.	Kapolei	HI			yes(98)					yes				2 x 74.6 MW ABB type 11N fuel-oil-fired CTs	149.2	200.7					
27	Trigen-Peoples District Energy	Chicago	IL	1997	yes	yes				yes	yes			yes	3 x 1.1 MW Turbomeca Makila TI, NG-fired CTs	3.3	3.3	370	16,800			
28	University of Evansville	Evansville	IN	1997	yes		yes							yes	1 x 1.1 MW Cooper gas engine	1.1	1.1	100	1,900			
29	University of Iowa	Iowa City	IA	early1900s	yes		yes							yes	none	0.0	21.5	500				
30	University of Maryland	College Park	MD	2002		planned	yes								1 x 60 kW Capstone NG-fired microturbine	0.1	0.1		108			
31	Trigen-Cinergy (General Motors)	Lansing	MI	2001	yes							yes		yes	none	0.0	3.6	280	14,000			
32	University of Michigan	Ann Arbor	MI	1897	yes		yes							yes	2 x 3.5 MW Solar NG-fired CTs	7.0	48.5	1,195				
33	District Energy St. Paul	St. Paul	MN	2003	yes					yes	yes			yes	none	0.0	25.0	764	13,892			
34	Trigen - Kansas City Energy Corporation	Kansas City	MO	1991	planned					yes	yes	yes		yes	none	0.0	86.0	1,250	12,000			
35	Black Hills Power - Las Vegas Cogen	Las Vegas	NV	2002		yes						yes			4 x 45 MW GE LM6000 NG-fired CTs	180.0	180.0		4,000			
36	Princeton University	Princeton	NJ	2005	yes		yes							yes	1 x 14.6 MW GE NG-fired CT	14.6	14.6	332	15,500			
37	Trigen Energy	Trenton	NJ	1983	yes					yes	yes			yes	2 x 6.0 MW diesel recip engines	12.0	12.0	320	11,270			
38	Union County Vo-Tech	Scotch Plains	NJ	2001	yes		yes								microturbines	0.2	0.2		240			
39	Cornell University	Ithaca	NY		yes		yes							yes	none	0.0	8.0	600	28,000			
40	Honeoye Falls High School	Honeoye Falls	NY	2000	yes		yes								reciprocating engine generators	0.6	0.6		170			
41	KIAC Partners (JFK Int'l Airport)	Jamaica	NY	1994		yes				yes				yes	2 x 42.5 MW GE LM6000, NG(or Jet A)-fired CTs	85.0	110.0	450	28,000			
42	TBG Cogen	Hicksville	NY			yes(00)						yes			2 x 21.9 MW GE LM2500 NG-fired CT	43.8						
43	Trigen Energy	Garden City	NY	1991		yes	yes	yes		yes	yes			yes	1 x 42 MW GE MS6001B NG-fired CT	42.0	57.0	830	16,400			
44	University of North Carolina	Chapel Hill	NC	1992	2004		yes							yes	none	0.0	28.0	650	24,400			
45	Trigen Energy	Oklahoma City	OK	1989 / 92		yes				yes	yes			yes	1 x 350kW diesel ('89) + 1 x 520kW CT-gen ('92)	0.9	1.2	296	17,600			
46	Trigen Energy	Tulsa	OK	1989 / 92		yes				yes	yes			yes	1 x 350kW diesel ('89) + 1 x 520kW CT-gen ('92)	0.9	1.3	291	24,150			
47	Trigen Energy	Philadelphia	PA	1998		yes	yes	yes		yes	yes	yes	yes	yes	1 x 120 MW Westinghouse dual-fuel (NG or oil) C	120.0	174.4	1,900	6,000			
48	Baylor University	Waco	TX			yes	yes							yes	1 CT	3.0	3.0	125	7,200			
49	Calpine - Clear Lake Cogen	Pasadena	TX	1982	yes(99)	yes(99)						yes			3 x 105.6 MW Westinghouse 501 D5 NG-fired CT	316.8	412.0		9,500			
50	D/FW International Airport	Dallas / Ft. Worth	TX	2007	yes					yes				yes	CT	110.0		515	41,000			
51	Hunt Oil Company	Dallas	TX			yes(99)						yes			2 x 28 MW GE Frame 5 CTs	56.0						
52	Huntsman Petrochemicals Corp.	Port Neches	TX			yes(95)						yes			2 x 39.6 MW GE Frame 6B NG-fired CTs	79.2	96.0		2,800			
53	Washington State University	Pullman	WA	1982	yes		yes							yes	none	0.0	2.0	538	6,186			
54	Norteshopping Mall	Rio de Janeiro, RJ	Brazil	1996	yes(96)	yes(98)					yes				1 x 1.2 MW Turbomeca Makila NG-fired CT	1.2	1.2	13	2,000			
55	Trigen Energia	Altamira, Tamaulipas	Mexico	2000	yes							yes				17.0	17.0	160	5,500			
56	Climaespaco	Lisbon	Portugal	1998	yes	yes				yes	yes			yes	1 x 5.2 MW Solar Taurus 60 CT	5.2	5.2	93	6,198			

CHP Case No.	Thermally-Activated System Outputs (Associated with the CHP System)											Timing of CHP Project			Local Electric Utility Rate (approximate)			
	Power			Heating			Cooling			Dehumidification		new constr	retro expans	pure retro	on-peak hrs/day	on-peak \$/kWh	off-peak \$/kWh	demand \$/kW-mo
	Technology	MW(e)	% of Tot	Technology	MMB/h	% of Tot	Technology	tons	% of Tot	Technology	cfm							
1	none	0.0	0%				none	0	0%						8	\$0.125	\$0.075	\$6.60
2	none	0.0	0%				none	0	0%						6	\$0.195	\$0.088	\$24.55
3	none	0.0	0%												6	\$0.195	\$0.088	\$24.55
4	steam turbine	4.4	25%	2 x HRSGs for stm htg			1x1000T + 2x400T stm-abs	1,800	45%						7	\$0.016	\$0.012	\$11.26
5	steam turbine	13.0	27%	HRSG			1 x 1-stage stm LiBr abs	800	100%			yes			6	\$0.195	\$0.088	\$24.55
6	steam turbine	13.0	27%	HRSG			1 x 1-stage stm LiBr abs	800	100%			yes			6	\$0.195	\$0.088	\$24.55
7	steam turbine	13.0	27%	HRSG			1 x 1-stage stm LiBr abs	800	100%			yes			6	\$0.195	\$0.088	\$24.55
8	none	0.0	0%	HRSG			none	0	0%				yes		6	\$0.195	\$0.088	\$24.55
9	steam turbine	13.0	27%	HRSG			1 x 1-stage stm LiBr abs	800	100%			yes			6	\$0.195	\$0.088	\$24.55
10	steam turbine	13.0	27%	HRSG			1 x 1-stage stm LiBr abs	800	100%			yes			6	\$0.195	\$0.088	\$24.55
11	steam turbine	13.0	27%	HRSG			1 x 1-stage stm LiBr abs	1,400	100%			yes			6	\$0.188	\$0.095	\$13.35
12	none	0.0	0%	hot water heat recovery			peak-shave for elec recip	85							6	\$0.195	\$0.088	\$24.55
13	steam turbine	7.0	25%	HRSG for steam	35.0	100%	none	0	0%			yes			6	\$0.195	\$0.088	\$24.55
14							none	0	0%						4	\$0.028	\$0.016	\$10.17
15	steam turbine	10.7	21%	HRSG			none	0	0%						6	\$0.188	\$0.095	\$13.35
16	none	0.0	0%	HRSG			none	0	0%						6	\$0.188	\$0.095	\$13.35
17	steam turbine	17.0	33%	HRSG			none	0	0%						6	\$0.188	\$0.095	\$13.35
18	steam turbine	19.0	40%	HRSG	47	45%	stm turb-drvn & stm-abs								4	\$0.028	\$0.016	\$10.17
19				HRSG											7	\$0.016	\$0.012	\$11.26
20	steam turbine(s)						none	0	0%									
21	none	0.0	0%	HRSG		32									16	\$0.056	\$0.039	\$9.13
22	none	0.0	0%				4 x York stm LiBr abs	16,100	48%						16	\$0.056	\$0.039	\$9.13
23				HRSG			none	0	0%						9	\$0.022	\$0.010	\$7.44
24	steam turbine	8.5	21%	HRSG	90	100%	steam-absorption					yes			9	\$0.022	\$0.010	\$7.44
25	none	0.0	0%	hot water heat recovery			none	0	0%	desiccant			yes		9	\$0.023	\$0.006	\$5.81
26	steam turbine	51.5	26%	2 HRSGs	515		none	0										
27	none	0.0	0%	HRSG (exh from 3 CTs)	20	5%	2 x 1-stage stm LiBr abs	1,300	8%	none	0	yes			13	\$0.050	\$0.021	\$16.41
28	none	0.0	0%				1 x 400 T stm-abs	400	21%									
29	3 steam turbines	21.5	100%												15	\$0.032	\$0.023	\$9.85
30	none	0.0	0%	none	0	0%	Broad absorption chiller	17	16%	ATS solid desiccant	3,000		yes		8	\$0.040	\$0.017	\$13.95
31	2 x 1.8 MW stm turbine	3.6	100%	4 x HW HXs	280	100%	none	0	0%			yes			8	\$0.035	\$0.031	\$9.45
32	3x12.5 + 1x4 MW stm tu	41.5	86%												8	\$0.155	\$0.075	\$0.00
33	steam turbine	25.0	100%				2 x LP stm-abs	1,000	7%			yes			12	\$0.035	\$0.026	\$9.26
34	2x40 + 1x6 MW stm turb	86.0	100%	coal (& NG/oil) boilers	1,250	100%	3 x stm turb-driven	6,000	50%	none	0		yes		8	\$0.055	\$0.029	\$6.20
35	none	0.0	0%	HRSG			none	0	0%				yes		6	\$0.056	\$0.014	\$8.22
36	none	0.0	0%	HRSG	182	55%						yes			14	\$0.082	\$0.056	\$8.76
37	none	0.0	0%	2 x waste heat HW HXs	160	50%	3 x 1-stage HW LiBr abs	1,700	15%						14	\$0.082	\$0.056	\$8.76
38	none	0.0	0%	HRSG			none	0	0%				yes					\$10.00
39	steam turbines	8.0	100%				none	0	0%						15	\$0.095	\$0.080	\$9.15
40	none	0.0	0%				none	0	0%			yes						\$5.00
41	steam turbine	25.0	23%	2 x HRSGs	225	50%	steam-absorption	7,000	25%			yes			14	\$0.116	\$0.070	\$23.42
42																		
43	steam turbine	15.0	26%	1 x HRSG	260	31%	stm turb-drvn & stm-abs	16,400	100%			yes						
44	steam turbine	28.0	100%				5 x 1500T Trane stm-abs	7,500	31%						8	\$0.043	\$0.022	\$12.92
45	steam turbine	0.3	27%	1 x HRSG ('92)	6	2%	3 stm-turbine driven	12,500	71%			yes			6	\$0.026	\$0.026	\$7.99
46	476kW stm turb ('97)	0.5	35%	1 x HRSG ('92)	6	2%	4 stm-turb, 1 diesel driven	16,980	70%			yes			6	\$0.026	\$0.026	\$7.99
47	stm turb + 3 cust. BPTs	54.4	31%	1 x HRSG	700	37%	customers' stm-turb & abs	6,000	100%				yes					
48	none	0.0	0%	HRSG	27	21%	steam-absorption	2,250	31%									
49	steam turbine			HRSG and HW			5 x 1-stage HW LiBr abs	8,300	87%				yes		10			
50				HRSG			steam turbine-driven	22,500	55%									
51																		
52	2 x steam turbine	16.8	18%	HRSG			2 x 1-stage HW LiBr abs	2,800	100%									
53	steam turbine	2.0	100%				2 abs (Carrier & Trane)	1,316	21%						24	\$0.034	\$0.034	\$2.25
54	none	0.0	0%	HRSG	13	100%	dbl-effect, LiBr, stm-abs	800	40%	desiccant wheel		yes				\$0.096		
55												yes						
56	none	0.0	0%	1 x HRSG	41	44%	dbl-effect, LiBr, stm-abs	2,900	47%			yes						

CHP Case No.	Thermal Energy Storage (TES)						Turbine Inlet Cooling (TIC)				Reasons Cited for Installing the System(s)
	Technology Type and Details	secondary fluid	S/R temp deg F	design shift	capacity ton-hrs	DSM MW(e)	Technology	Cooling tons	Enhancement MW(e)	%	
1	stratified chilled water, above-ground welded steel CB&I tank	water	42 / 58		25,000	3.9	not applicable	n.a.	n.a.	n.a.	
2	ice storage				40,000		not applicable	n.a.	n.a.	n.a.	
3	stratified chilled water, above-ground welded steel Matrix tank	water	40 / 60		29,000						
4	stratified chilled water, above-ground welded steel SLT tanks (2)	water	40 / 60		22,000						
5	no TES	water		n.a.	0	0.0	water coils for 50.0 F inlet air	800	11.0	46%	economics
6	no TES	water		n.a.	0	0.0	water coils for 50.0 F inlet air	800	11.0	46%	economics
7	no TES	water		n.a.	0	0.0	water coils for 50.0 F inlet air	800	11.0	46%	economics
8	no TES	water		n.a.	0	0.0	water coils	2,000	12.0	48%	economics
9	no TES	water		n.a.	0	0.0	water coils for 50.0 F inlet air	800	11.0	46%	economics
10	no TES	water		n.a.	0	0.0	water coils for 50.0 F inlet air	800	11.0	46%	economics
11	no TES	water		n.a.	0	0.0	water coils for 50.0 F inlet air	1,400	11.0	46%	economics
12	ice-on-coil										
13	500,000 gal chilled water, above-ground welded steel tank	water	45 / 55	partial	3,467	0.6	water coils for 50.0 F inlet air	515	3.3	17%	
14	ice storage				1,500						
15	ice-on-coil(BAC), retro in orig 3 million gal below-ground concrete water tank				93,200						
16	ice harvester (Paul Mueller) 333,000 gal ice tank, weekly design cycle	water		full	14,800	1.3	water coils for 42.0 F inlet air	1,345	7.0	23%	economics
17	no TES	none	n.a.	n.a.	0	0.0	direct NH3 evap coils, 45 F air	2,000	8.0	19%	economics
18	stratified chilled water, below-ground concrete tank	water			30,000						
19	stratified chilled water, above-ground welded steel CB&I tank	water	39 / 55		35,900						
20	no TES	water		n.a.	0	0.0	water coils	2,200			economics
21	stratified chilled water, above-ground welded steel CB&I tank	water	40 / 55		20,000	1.9					
22	3 million gal stratified chilled water, below-ground concrete tank	water									
23	no TES	water		n.a.	0	0.0	water coils	4,000			economics
24	stratified chilled water, above-ground welded steel CB&I tank	water	40 / 58.3	partial	57,000	6.6	water coils for 50.0 F inlet air	2,000	8.0	31%	reliability, flexibility, and economics
25	no TES	water		n.a.	0	0.0	57 F inlet air from bldg's AHUs		6.0	25%	reliable back-up power; plus AC, htg, dom HW, clothes drying
26	no TES			n.a.	0	0.0	evaporative cooling	n.a.	5.0	4%	economics
27	stratified low temp fluid (SoCool), above-ground welded steel CB&I tank	E-G / water	30 / 54	full	123,000	20.0	direct NH3 evap coils, 50 F air	30	0.9	35%	District Energy (CHP-TES) was economic (cap and oper svgs)
28	50,000 gal chilled water storage tank	water					not applicable	n.a.	n.a.	n.a.	
29	stratified chilled water, below-ground concrete tank	water			7,000		not applicable	n.a.	n.a.	n.a.	
30	no TES	water	45 / 55	n.a.	0	0.0	water coils				research & development, demonstration, and field testing
31	stratified water/LT fluid (SoCool), above-ground welded steel CB&I tank	water(LTF)	42 / 62	partial	36,500	5.6	not applicable	n.a.	n.a.	n.a.	efficiency and economics
32	stratified chilled water, below-ground concrete tank (retro of baffle tank)	water	44 / 56		17,000						
33	stratified chilled water, above-ground welded steel CB&I tanks (2)	water	40 / 54-57	partial	65,400	8.6	not applicable	n.a.	n.a.	n.a.	reliability, fuel flexibility, efficiency, and economics
34	stratified low temp fluid (SoCool), above-ground welded steel CB&I tank	SoCool LTF	33 / 53	partial	48,000	6.0	not applicable	n.a.	n.a.	n.a.	economics and more efficient conversion of fuel to useful energy
35	no TES	water		n.a.	0	0.0	water coils	4,000			economics
36	stratified low temp fluid (SoCool), above-ground welded steel tank	SoCool LTF	32 / 64	partial	50,000						reliable steam and electricity, and "a good long-term investment"
37	stratified chilled water, partially-buried concrete tank	water		partial	20,000		not applicable	n.a.	n.a.	n.a.	efficiency and economics
38	ice-on-pipe (Calmac), internal melt	E-G / water		full	1,800	0.2					demand reduction
39	stratified chilled water, above-ground welded steel CB&I tank	water	40 / 55	partial	38,000		not applicable	n.a.	n.a.	n.a.	
40	ice-on-pipe (Calmac), internal melt	E-G / water		partial	450	0.1	not applicable	n.a.	n.a.	n.a.	
41	no TES	water	45 / 55	n.a.	0	0.0	water coils for 50.0 F inlet air				privatized central energy plant - capital for upgrade & expansion
42	no TES	n.a.	n.a.	n.a.	0	0.0	fogging (saturation)	n.a.			
43	no TES	water	43 / 60	n.a.	0	0.0	water coils for 46.5 F inlet air	1,880	8.0	24%	efficiency and economics
44	stratified water/LT fluid (SoCool), above-ground welded steel tank	water(LTF)	41 / 54		40,000		not applicable	n.a.	n.a.	n.a.	
45	no TES	water		n.a.	0	0.0	direct NH3 evap coils, 50 F air				efficiency and economics
46	no TES	water		n.a.	0	0.0	direct NH3 evap coils, 50 F air				efficiency and economics
47	no TES (no central cooling; cooling is thermally-driven at steam user sites)	n.a.	n.a.	n.a.	0	0.0	evap ('98), fog wet compr ('01)	n.a.	15.0	15%	economics and environmental (emissions) benefits
48	no TES	water		n.a.	0	0.0	water coils for 60.2 F inlet air	178			
49	stratified chilled water, above-ground welded steel CB&I tank	water	38 / 64	full	107,000	8.0	water coils for 50.0 F inlet air	18,700	49.0	21%	TIC/TES added power at only \$367/kW, improved heat rate by 4
50	stratified low temp fluid (SoCool), above-ground welded steel CB&I tank	SoCool LTF	36 / 60	partial	90,000						economics and reliability
51	no TES			n.a.	0	0.0	evaporative cooling				
52	no TES	water		n.a.	0	0.0	water coils for 50.0 F inlet air	2,800	11.8	18%	economics
53	stratified chilled water, above-ground welded steel CB&I tank	water	41 / 56	partial	17,750	2.1	not applicable	n.a.	n.a.	n.a.	
54	stratified chilled water storage tank	water					desscnt, CW/CHW coil, 68 F air	n.a.	0.1	16%	economics
55	stratified chilled water, above-ground welded steel tank	water			4,700						economics
56	stratified chilled water, above-ground concrete tank	water	39.2 / 53.6	partial	39,807	4.0	water coils	50	0.8	17%	economics

CHP Case No.	CHP System Capital Cost	System Benefits		Comments	Primary Information Source	Applicable Website Address	
		Economic	Environmental				
1				university campus system	IDEA and J. Andrepont-Cool Solutions		
2				university campus system	IDEA		
3				university campus system			
4	over \$22 million (tax-expt fincng)			university campus system	District Energy, Vol. 88, No. 1, p. 34		
5	not available			independent power / industrial cogen (enhanced oil recovery)	TICA and GTI-00/0140 5M MI 5/01		
6	not available			independent power / industrial cogen (enhanced oil recovery)	TICA and GTI-00/0140 5M MI 5/01		
7	not available			independent power / industrial cogen (enhanced oil recovery)	TICA and GTI-00/0140 5M MI 5/01		
8	not available			independent power / industrial cogen	TICA and M. Solms-The Stellar Group		
9	not available			independent power / industrial cogen (enhanced oil recovery)	TICA and GTI-00/0140 5M MI 5/01		
10	not available			independent power / industrial cogen (enhanced oil recovery)	TICA and GTI-00/0140 5M MI 5/01		
11	not available			independent power / industrial cogen (enhanced oil recovery)	TICA and GTI-00/0140 5M MI 5/01		
12		Increases Cogen Plant On-Peak Capacity		Hanford High School	Energy Solutions, Vol. 1, No. 3		
13				cogen plant and hospital	R. Pasteris-Strategic Energy Services		
14				college campus system	IDEA		
15				university campus system	IDEA and J. Andrepont-Cool Solutions		
16				industrial cogen	Paul Mueller Co., TE-2034, 2000		
17				industrial cogen (paper mill)	Gas Turbine World, V28N2 Mar-Apr '98	<a href="http://www.tractebelusa.com">www.tractebelusa.com</a>	
18				university campus system; IDEA's 1997 System of the Year Award	Carter-Burgess		
19				university campus system	Carter-Burgess		
20	not available			9 ppm NOx at CT, 2.5 at HRSG	university campus system		
21					industrial cogeneration	D. Punwani-Avalon Consulting	
22				urban District Heating & Cooling system	Solar Turbines (930245/294)	<a href="http://www.theenergynetwork.com">www.theenergynetwork.com</a>	
23	not available			university campus system	IDEA and J. Andrepont-Cool Solutions		
24				industrial cogeneration	TICA and M. Solms-The Stellar Group		
25	\$575K projected	under 10-yr simple payback		entertainment/resort campus District Heating & Cooling system	IDEA Proceedings, 6/98		
26				military barracks complex	ASHRAE Seminar 42, 7/2/03		
27	not broken-out for CHP system	DE users saved \$27MM cap + >\$1MM/yr	reduced fuel use by 22%, CO2 by 41%	industrial cogeneration (electricity to elec utility and steam to oil refinery)	Munters corporate website, 7/03	<a href="http://www.munters.com">www.munters.com</a>	
28				TES was key in balancing loads for economical use of CHP ( trigeneration)	Trigen "Capacity Update", 10/1/01	<a href="http://www.tractebelusa.com">www.tractebelusa.com</a>	
29				university campus system	IDEA		
30				university campus system	IDEA and J. Andrepont-Cool Solutions		
31				demonstration of CHP technology and component equipment	ASHRAE Seminar 42, 7/2/03		
32				automotive assembly plant	Trigen "Capacity Update", 10/1/01	<a href="http://www.tractebelusa.com">www.tractebelusa.com</a>	
33				university campus system	IDEA and J. Andrepont-Cool Solutions		
34	\$52 million		reduces coal use by 80%, soot by 50%	burns 280,000 tons/yr of renewable fuel (wood waste), reduces GHG 280,000 tons/yr	District Energy St. Paul	<a href="http://www.districtenergy.com">www.districtenergy.com</a>	
35	not available	Added elec gen w/ zero add'l fuel use	Added elec gen w/ zero add'l emissions	Steam turbine generators replaced PRVs; therefore, get elec gen w/o any add'l fuel use	Trigen "Capacity Update", 10/1/01	<a href="http://www.tractebelusa.com">www.tractebelusa.com</a>	
36	not available			independent power / industrial cogeneration	TICA and M. Solms-The Stellar Group		
37	\$34 million (incl. other projects)	Saves \$3 to 5 million per year	NOx controlled by water injection cut CO2 35.6% (48,572T/yr)	university campus system	J. Andrepont-Cool Solutions		
38				urban District Heating & Cooling system	Trigen "Capacity Update", 10/1/01	<a href="http://www.tractebelusa.com">www.tractebelusa.com</a>	
39				vocational-technology school	Calmac Manufacturing Corporation		
40				university campus system	IDEA and J. Andrepont-Cool Solutions		
41	\$175 million special proj bonds		9 ppm NOx and 1 ppm CO for Cogen Plt	high school	Calmac Manufacturing Corporation		
42				Reported reliability: 98% electrical and 100% thermal. Sized for future load growth.	IDEA Proceedings, 6/97		
43			cut NOx, SO2, CO, PM 93%, CO2 54%	industrial cogeneration	AMCO-Fern Inlet Fogging List, 3/03		
44				District Heating & Cooling system	Trigen "Capacity Update", 10/1/01	<a href="http://www.tractebelusa.com">www.tractebelusa.com</a>	
45				university campus system	J. Andrepont-Cool Solutions		
46			trigenerator cut fuel & emissions 47%	urban District Heating & Cooling system	Trigen "Capacity Update", 10/1/01	<a href="http://www.tractebelusa.com">www.tractebelusa.com</a>	
47	\$167 million	Revenue from electric sales; energy effic.	Added 100 MW, while slashing emissions	urban District Heating & Cooling system	Trigen "Capacity Update", 10/1/01	<a href="http://www.tractebelusa.com">www.tractebelusa.com</a>	
48				70% CHP fuel conversion efficiency (>double U.S. avg). EPA awardee for CHP.	Trigen "Capacity Update", 10/1/01	<a href="http://www.tractebelusa.com">www.tractebelusa.com</a>	
49	\$18 million for TIC/TES system	TIC/TES added power at only \$367/kW	TIC/TES improved heat rate by 4%	university campus system	IDEA Proceedings, 6/99		
50				independent power / industrial cogeneration	ASHRAE AT-01-15-1, 2001 V107 P11		
51				Serves 4.2 million sf of conditioned terminal. Sized for current & future expansion.	District Energy, v88n1/Carter-Burgess		
52				industrial cogeneration (oil refinery)	Munters corporate website, 7/03	<a href="http://www.munters.com">www.munters.com</a>	
53				industrial cogeneration (chemical manufacturing)	TICA and GTI-00/0140 5M MI 5/01		
54	TIC: \$93,220	TIC: 8% more power gen/yr, 3-yr payback	TIC improved heat rate by 2%	university campus system	IDEA and J. Andrepont-Cool Solutions		
55				retail shopping mall	ASHRAE AT-01-15-2, 2001 V107 P11		
56	\$5.6 (40) million equip (tot proj)		Saved 45% energy, 54% CO2(20,000T/yr)	Serves Grupo Primex plastics mfg facility	Trigen "Capacity Update", 10/1/01	<a href="http://www.tractebelusa.com">www.tractebelusa.com</a>	
				Built to serve Parque Expo '98 (World Fair) area, with plans to expand in future.	ASHRAE MN-00-16-2, 2000 V106 Pt2		

CHP Case No.	Name	Title	Affiliation	Address	City, State and Zip Code	Telephone	E-mail
1	Don Johnson		California State Polytechnic University	3801 Temple Avenue	Pomona, CA 91768	909-869-3042	<a href="mailto:dmjohnson@csupomona.edu">dmjohnson@csupomona.edu</a>
2			California State University	1250 Bellflower Boulevard	Long Beach, CA 90840-0127		
3	Tom Brown	Exec Director - Facilities Mgmt	California State University	18111 Nordhoff Street	Northridge, CA 91330-8291	818-677-3914	<a href="mailto:tom.brown@csun.edu">tom.brown@csun.edu</a>
4	Martin E. Holzman	Director of Physical Plant	California State University	5500 Campanile Drive	San Diego, CA 92182	619-594-6000	<a href="mailto:holzman@mail.sdsu.edu">holzman@mail.sdsu.edu</a>
5							
6							
7							
8							
9							
10							
11	Calos Sanchez	Plant Engineer	El Paso Energy			661-393-6885	<a href="mailto:CASA@dyneqy.com">CASA@dyneqy.com</a>
12	Bruce Pickering	District Facilities Director	Hanford Joint Union School District		Hanford, CA		
13	Wayne Kawamoto	Plant Manager	Wheelabrator Norwalk Energy Co., Inc.	11500 Balsam Street	Norwalk, CA 90650	310-929-0887	<a href="mailto:wkawamoto@WM.com">wkawamoto@WM.com</a>
14	Larry Klumas	Director Facilities Management	Occidental College	1600 Campus Road	Los Angeles, CA 90041	213-259-2654	<a href="mailto:klumas@oxy.edu">klumas@oxy.edu</a>
15	Steve N. Briscoombe	Power System Manager	Stanford University	327 Bonair Siding	Palo Alto, CA 94305	650-725-2036	<a href="mailto:steveb@bonair.stanford.edu">steveb@bonair.stanford.edu</a>
16							
17			Tractebel Power, Inc.	1177 West Loop South	Houston, TX 77027		
18	David N. Johnson	Director Energy Services	University of California	731 Circle Drive South, 3rd floor	Los Angeles, CA 90095	310-825-3402	<a href="mailto:johnsond@facnet.ucla.edu">johnsond@facnet.ucla.edu</a>
19	Jack Hug	Ass't V Chancellor Auxil & Plt Svcs	University of California	9500 Gilman Drive	San Diego, CA 92093	619-534-2341	<a href="mailto:jhug@ucsd.edu">jhug@ucsd.edu</a>
20	Tom Mason	Plant Manager				303-857-2012	
21	Derek H. Rudd	Director, DH&C Operations	The Energy Network, Inc.	100 Columbus Boulevard	Hartford, CT 06103-2805	860-727-3491	
22	Roberto Meinrath	Director of Utilities	Yale University	2 Whitney Avenue	New Haven, CT 06520-8297	203-432-6755	<a href="mailto:roberto.meinrath@yale.edu">roberto.meinrath@yale.edu</a>
23							
24	Ed Godwin	Chief Mechanical Engineer	Reedy Creek Energy Services Inc.	P.O. Box 1000	Lake Buena Vista, FL 32830	407-824-4943	<a href="mailto:ed.godwin@disney.com">ed.godwin@disney.com</a>
25	Michael K. West	Building Systems Scientist	AdvanTek Consulting, Inc.	P.O. Box 510504	Melbourne, FL 32951	321-733-1426, x3	<a href="mailto:mwest@advantekinc.com">mwest@advantekinc.com</a>
26	Randy Koncelik	Project Engineer	Kalaeloa Partners L.P.		Kapolei, Oahu, HI		
27	Michael J. Smedley	VP and General Manager	Trigen-Peoples District Energy Co.	2211 S. Martin Luther King, Jr. Drive	Chicago, IL 60616	312-674-1867	<a href="mailto:msmedlev@tpichicago.com">msmedlev@tpichicago.com</a>
28	Larry S. Horn	Dir of Facilities Mgmt & Planning	University of Evansville	1800 Lincoln Avenue	Evansville, IN 47722-0001	812-479-2721	<a href="mailto:lh6@evansville.edu">lh6@evansville.edu</a>
29	Duane DeRaad	Assoc Director Facilities Services	University of Iowa	416 N Hall	Iowa City, IA 52242-1223	319-335-1884	<a href="mailto:duane-deraad@uiowa.edu">duane-deraad@uiowa.edu</a>
30	Reinhard Radermacher	Prof & Dir-Ctr for Env'l Energy Eng'g	University of Maryland	4164 Glenn L. Martin Hall	College Park, MD 20742	301-405-5286	<a href="mailto:raderm@umd.edu">raderm@umd.edu</a>
31	Don Morgan	Plant Manager	Lansing Grand River Utilities	3105 South M.L. King Blvd., #164	Lansing, MI 48910	517-885-7250	<a href="mailto:don.morgan@cinergy.com">don.morgan@cinergy.com</a>
32	William (Bill) Verge	Manager, Utility Systems	University of Michigan	326 East Hoover Avenue	Ann Arbor, MI 48109-1002	734-936-4219	<a href="mailto:bverge@umich.edu">bverge@umich.edu</a>
33	Anders Rydaker	President	District Energy St. Paul, Inc.	76 West Kellogg Boulevard	St. Paul, MN 55102-1611	651-297-8955	<a href="mailto:arydaker@districtenergy.com">arydaker@districtenergy.com</a>
34	Brian P. Kirk	General Manager	Trigen - Kansas City Energy Corporatio	115 Grand Boulevard	Kansas City, MO 64106	816-889-4900	<a href="mailto:bkirk@tpikansascity.com">bkirk@tpikansascity.com</a>
35							
36	Thomas (Tom) Nyquist	Director of Engineering	Princeton University	MacMillan Building	Princeton, NJ 08543-2158	609-258-5472	<a href="mailto:tnyquist@princeton.edu">tnyquist@princeton.edu</a>
37	Robert Dewechter	VP and General Manager	Trigen-Trenton Energy Company	650 South Clinton Avenue	Trenton, NJ 08611	609-396-1892	
38							
39	Robert (Rob) E. McCabe	Sr Mech Engr - Png, Dsgn & Const	Cornell University	Humphreys Service Building	Ithaca, NY 14853-3701	607-255-2976	<a href="mailto:rem5@cornell.edu">rem5@cornell.edu</a>
40	Rick Mandl		Thomas Associates	15 The Commons	Ithaca, NY 14850	607-277-7100	<a href="mailto:rhm@thethomasgroup.com">rhm@thethomasgroup.com</a>
41	John J. Eff	General Manager	Kennedy Int'l Airport Cogen Partners	Building 49	Jamaica, NY 11430	718-995-0546	
42							
43			Trigen-Nassau Energy Corporation	185 Charles Lindbergh Boulevard	Garden City, NY 11530	516-222-2884	
44	Raymond DuBose	Director, Energy Services	University of North Carolina	CB# 1800, Giles F. Horney Building	Chapel Hill, NC 27599-1800	919-966-4100	<a href="mailto:ray_dubose@facilities.unc.edu">ray_dubose@facilities.unc.edu</a>
45	Ken Stone	General Manager	Trigen-Oklahoma Energy Corporation	100 N. Broadway, Liberty Tower, #2035	Oklahoma City, OK 73102	405-272-0388	
46	Sam Kumar	VP and General Manager	Trigen-Tulsa Energy Corporation	505 West 2nd Street	Tulsa, OK 74101	918-582-2212	<a href="mailto:skumar@tpitulsa.com">skumar@tpitulsa.com</a>
47	Kevin Brown	VP and General Manager	Trigen-Philadelphia Energy Corporation	2600 Christian Street	Philadelphia, PA 19146	215-875-6900	<a href="mailto:kbrown@tpiphilly.com">kbrown@tpiphilly.com</a>
48	Don Bagby	Director Facilities Management	Baylor University	P.O. Box 97086	Waco, TX 76798-7086	254-710-6600	<a href="mailto:don_bagby@baylor.edu">don_bagby@baylor.edu</a>
49	Sam Weaver (Dan Maples)	Plant Manager (O&M Supervisor)	Calpine - Clear Lake Cogeneration		Pasadena, TX	281-474-7611	
50	Kevin Cox	Senior Executive VP					
51							
52	Charlie Rice	Operations Manager	Huntsman Petrochemicals Corp.	2701 Spur 136	Port Neches, TX 77651	409-724-4700	
53	Craig S. Benjamin	Ass't Director Facilities Operations	Washington State University	McCluskey Offices	Pullman, WA 99164-1150	509-335-9017	<a href="mailto:craig_benjamin@wsu.edu">craig_benjamin@wsu.edu</a>
54							
55			Trigen Energia S.A. de C.V.	C.M.A. km 16.5, Almacentro Ave. E 101	Apodaca, N.L. 66600 Mexico	52-8-369-3939	
56	Joao de Jesus Ferreira	Administrador - Director Geral	Climaespaco	Av. Duque de Avila, 141, 40	1050 Lisboa, Portugal	351-1-317-1170	<a href="mailto:jesusferreira@mail.telepac.pt">jesusferreira@mail.telepac.pt</a>