

DOE TEAM Initiative

High Tech Buildings

Berkeley Fume Hood

Aerosol Duct Sealing

Presented by:

Geoffrey C. Bell, PE



U.S. Department of Energy
Energy Efficiency and Renewable Energy

DOE TEAM Initiative



U.S. Department of Energy
Energy Efficiency and Renewable Energy



High-Performance Buildings Web Site

High-Performance Building for High-Tech Industries

The screenshot shows a web browser window displaying the website for High-Performance Buildings for High-Tech Industries. The browser's address bar shows the URL <http://hightech.lbl.gov/>. The website features a purple header with the title "High-Performance Buildings for High-Tech Industries" and a search bar. A navigation menu on the left lists various sections: Mission, Issues, Facilities, Technologies, Demos, Design, Events, Library, Links, Team, Advisors, Sponsors, Newsletters, Press, and What's New. The main content area includes a text introduction, a navigation bar for "Laboratories • Cleanrooms • Data Centers", and a collage of images and charts related to energy efficiency and facility design. At the bottom of the page, there is a footer with navigation links: Home, Applications Team, Environmental Energy Technologies Division, Berkeley Lab, Sitemap, Contact, and Disclaimer & Privacy Statement. The browser's taskbar at the bottom shows the Start button, several open applications, and the system tray with the time 3:39 PM.

[Click Here](#)

DOE TEAM Initiative




U.S. Department of Energy
Energy Efficiency and Renewable Energy




“Tame the Hoods...”

Fume hood Energy Consumption




Berkeley Hood Air Divider Technique

**Low-turbulence Intensity
Displacement ventilation
Push-Pull Containment**



(Sectional view)

U.S. Patents # 6,089,970, # 6,428,408



Extensive Standardized Testing...


ASHRAE 110 Testing



- ✓ **ASHRAE 110-1995 tracer gas containment**
- ✓ **Large and small volume smoke**
- ✓ **Sash-movement effect tests**
- ✓ **Dry Ice tests**
- ✓ **Different SF6 flow rates**
- ✓ **Various mannequin heights**

Advanced, Non-standard Testing...

CFD Analyses



- ✓ Side-by-side Equivalent Containment Tests
- ✓ Human-as-Mannequin Testing
- ✓ Cluttered hood interior
- ✓ Helium Bubbles
- ✓ Schlieren flow studies
- ✓ Envelope testing
- ✓ Expert evaluations
- ✓ New SF6 ejector designs
- ✓ Cross drafts

Berkeley Hood: Results and Future...

- Estimated energy reductions to be 70 percent, compared to “standard” constant velocity (CV) fume hood.
- Equivalent containment performance verified with side-by-side ASHRAE 110-1995 testing and LBNL Human-as-Mannequin Testing Protocol
 - Independent testing performed by Exposure Control Technologies
- Two variances were granted by CAL/OSHA to operate the Berkeley hood at 80 FPM at its design sash-height of 18 inches.
 - Total exhaust airflow is one-half of a standard hood’s flow
 - Containment has been verified in this configuration
- ESCO Global has licensed the Berkeley hood technology
 - Commercial hood expected by January 2008

DOE TEAM Initiative



Aerosol Duct Sealing




U.S. Department of Energy
Energy Efficiency and Renewable Energy

Aerosol ductwork sealing

Benefits and features...

- Seals holes up to 3/8" across
- Vinyl polymer is safe
- No lingering odors or off-gassing
- Does not coat ductwork
- Cleaning ductwork not required before sealing
- Cleaning after sealing generally does not hurt seals
- Sealant remains rubbery
- Lasts >10 years




Aerosol wand in operation...

Sealant spray pattern from injection wand



Aerosol sealing apparatus in action...



Aerosol Sealing Results

Buildup of polymer sealant



Recent aerosol duct sealing results...

Building	Fan Flow [cfm]	Initial Leakage [%]	Fraction Sealed	Notes
#1	69,000	19%	87%	4 Floors, 6 coils/floor
#2	93,000	36%	78%	2 Floors, 3 Loops, Hot/Cold/Lab Make-Up 1-2 inject/loop, 2 Fans
	22,000	27%	85%	80 grilles on 2 Floors, single point injection
#3	N/A	3000 cfm ²⁵	93%	Shower/Toilet Exhaust
#4	14,000	19%	87%	Dorm Room Supply, Return was chase with large penetrations
#5	46,200	19%	92%	Downstream Leakage Only, Slot diffusers, Sealed w/Fan On, 3 flrs
	10,000	10%	90%	No Pre-Qualification
#6	16,610	15%	92%	Blew thru terminal system-power induction boxes, pneumatic line connected to pitot inlet
#7	10995	1% - 23%	87%	No Pre-Qualification
#8	8,200	19%	85%	Found undocumented take-offs, 11 stories, penthouse inject

Aerosol Sealing Results at LBNL...

Section (Bldg 70)	Date	Pre-seal cfm25	2-min cfm25	Final cfm25	Post-Seal cfm25	Inj Time minutes	% sealed
3rd Floor Annex Return	11/6/2005	30.7		15.6	14.5	27	53%
3rd Floor Annex Supply	11/6/2005	721	722	835	804	37	-12%
2nd Floor Annex Supply	11/16/2005	403	543	31	30.6	35	92%
1st Floor Corridor	11/20/2005	2373		134	135	171	94%
2nd Floor Corridor	11/30/2005	2805		717	919	240	67%
1st Floor Cold	12/3/2005	3087	1777.2	796	851	189	72%
2nd Floor Cold	12/4/2005	2007	1361.7	262	309	137	85%
1st Floor hot	12/10/2005	1040			273	138	74%
2nd Floor Hot	12/11/2005	1318			346	119	74%
Exhaust	12/23/2005	2277			335	319	85%
Total		15310			3198	1349	79%
Assuming avg leak press of 0.5" H2O		40212			8400		
%Leak at avg leak press of 0.5" H2O		35%			7%		
To keep the same total flow into zones, should be able to reduce fan flow to							80681
%reduction in fan flow							30%
%reduction in fan power							65%

>12% electrical savings in first month!

For More Information



<http://ateam.lbl.gov>

Geoffrey C. Bell, P.E., M. Arch.
510.486.4626
gcbell@lbl.gov



[Click here](#)



[Click here](#)