

PNW-SGDP-TPR-Vol.1-Rev.1.0
PNWD-4438, Volume 1



Pacific Northwest Smart Grid Demonstration Project Technology Performance Report Volume 1: Technology Performance

Battelle Memorial Institute
Pacific Northwest Division
Richland, Washington 99352

Prepared for
U.S. Department of Energy
National Energy Technology Laboratory
Project Management Center
Contract ID: DE-OE0000190

June 2015

LEGAL NOTICE

This report was prepared by Battelle Memorial Institute (Battelle) as an account of sponsored research activities. Neither Client nor Battelle nor any person acting on behalf of either:

MAKES ANY WARRANTY OR REPRESENTATION, EXPRESS OR IMPLIED, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, process, or composition disclosed in this report may not infringe privately owned rights; or

Assumes any liabilities with respect to the use of, or for damages resulting from the use of, any information, apparatus, process, or composition disclosed in this report.

Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by Battelle. The views and opinions of authors expressed herein do not necessarily state or reflect those of Battelle.



This document was printed on recycled paper.

(9/2003)



Pacific Northwest Smart Grid Demonstration Project Technology Performance Report Volume 1: Technology Performance

PNW-SGDP-TPR-Vol.1-Rev.1.0

Approved By:

A handwritten signature in black ink that reads "Ron Melton".

Ron Melton, Battelle Project Director

6/26/2015

Date

A handwritten signature in blue ink that reads "Evan Jones".

Evan Jones, Battelle Project Review Board Chairman

6/24/2015

Date



This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This material is based upon work supported by the U.S. Department of Energy under Award Number DE-OE0000190.

Executive Summary

The Pacific Northwest Smart Grid Demonstration (PNWSGD), a \$179 million project that was co-funded by the U.S. Department of Energy (DOE) in late 2009, was one of the largest and most comprehensive demonstrations of electricity grid modernization ever completed. The project was one of 16 regional smart grid demonstrations funded by the American Recovery and Reinvestment Act. It was the only demonstration that included multiple states and cooperation from multiple electric utilities, including rural electric co-ops, investor-owned, municipal, and other public utilities. No fewer than 55 unique instantiations of distinct smart grid systems were demonstrated at the projects' sites. The local objectives for these systems included improved reliability, energy conservation, improved efficiency, and demand responsiveness.

The demonstration developed and deployed an innovative transactive system, unique in the world, that coordinated many of the project's distributed energy resources and demand-responsive components. With the transactive system, additional regional objectives were also addressed, including the mitigation of renewable energy intermittency and the flattening of system load. Using the transactive system, the project coordinated a regional response across the 11 utilities. This region-wide connection from the transmission system down to individual premises equipment was one of the major successes of the project. The project showed that this can be done and assets at the end points can respond dynamically on a wide scale. In principle, a transactive system of this type might eventually help coordinate electricity supply, transmission, distribution, and end uses by distributing mostly automated control responsibilities among the many distributed smart grid domain members and their smart devices.

PNWSGD: Assembling the Team and Initial Steps

The origins of the demonstration project and eventual deployment of the transactive system can be traced to a Request for Interest jointly issued by the Bonneville Power Administration (BPA) and Battelle Memorial Institute in 2009. Many prospective PNWSGD participants responded to the request, and from these, ten distribution utilities and the University of Washington campus were chosen as demonstration test sites. Because of the BPA's interest in this research, the demonstration's geographical extent naturally included much of the Pacific Northwest. The selection of the 11 participant sites extended the region to represent five Northwest states—Idaho, Montana, Oregon, Washington, and Wyoming. The PNWSGD worked with each of these site owners to understand and document how the smart grid assets to be tested at each site were distributed among and monitored within its distribution system. In short, the project was one of the first and largest efforts to experiment with how to actually implement a smart grid.

Five additional organizations that came to be called "project-level infrastructure providers" were selected to apply their systems expertise, which was critical to the development of the transactive system. 3TIER (now Vaisala) offered measurements and predictions for most of the wind generators. Alstom Grid helped calculate the transactive signals. International Business Machines Corp. (IBM) was the system's chief architect and simulated transactive system performance. QualityLogic, Inc., offered system testing and interoperability expertise. Netezza, which was purchased by IBM during the PNWSGD, offered its massively parallel database appliance. During the course of the project, Spirae, Inc., was added to the group with the task of supporting the utilities in their deployment and testing of their transactive system



components. Battelle Memorial Institute's Pacific Northwest Division (operator of the Pacific Northwest National Laboratory) was asked to be the technical and organizational lead.

The PNWSGD was accomplished in four phases that were scheduled for the timely installation of smart grid hardware and software and the new transactive system. A kickoff meeting was held in December 2009 to share and align participants' expectations for the demonstration. The project followed an aggressive schedule to complete its designs and installations by mid-2012, which was planned to allow for a two-year data collection window before the end of August 2014. Closeout activities, including the drafting of this final technical report, continued into 2015.

Engaging Electricity Users and New Technologies

Although all of the PNWSGD partners played pivotal roles in the project, the demonstration test sites, and their interfaces with the customers who eventually will use and benefit from smart grid technologies, were particularly important elements of the project. One objective of a smart grid is to improve the reliability of electric power for its end users. Toward this, PNWSGD utilities automated their distribution systems to enable more rapid restoration of customers' power after outages, including the application of fault detection, isolation, and restoration. Several of the project's utilities took advantage of automated power-quality alerts that have become available from advanced premises metering to help them more quickly pinpoint and respond to outages, abnormal supply voltages, and other conditions. Still others installed batteries and automated distribution switching to define high-reliability zones, including some that may separate from the rest of the grid and operate as microgrids when they become threatened by power outages.

Another objective of a smart grid is to conserve energy and improve the system's overall efficiency. One of the simplest means to conserve energy is to replace existing equipment with more energy efficient alternatives, as Avista Utilities did when they replaced approximately 800 existing distribution transformers with more efficient smart transformers. Others changed and automated their management of their distribution systems. Examples include using reduced feeder voltages that reduce the power consumed by some end-use loads, correction of power factor that reduces power line losses, or coordinated volt and reactive power control that can both reduce power load and reduce system losses.

Information itself can motivate consumers to conserve energy. Several of the participating utilities informed their customers of their historical electricity consumption via web portals or in-home displays. The University of Washington campus greatly increased the metering of individual buildings on its campus, and it generated new methods to inform building managers and occupants of their historical energy practices, either monthly or in real time. A very interesting effort at the campus was to empower its students, giving them tools to manage energy in their dormitory rooms and engaging them still further via social media.

The participating utilities reported a variety of benefits from their participation in the project and the smart grid technologies they deployed. Anecdotal reports of their experience have been compiled as “A Compilation of Success Stories” by BPA.¹

Bringing Transactive Concepts to Life

The technical centerpiece of the project—the glue that connected the test sites, technologies and electricity resources—was the transactive system, which was implemented to dynamically respond to emerging conditions in the region’s power grid. The transactive system was distributed, providing a means of coordinating behavior of demand-responsive components through a forward-looking incentive signal and forward estimates of load behavior. The transactive system produced incentive signals, constructed by blending energy costs and conditions of the region’s bulk generation and grid. The system’s incentive signals were dynamic in space as well as time, representing variability across 14 geographic zones within the BPA balancing area based on location of the region’s bulk generation resources. The system of incentive signals predicted the delivered costs of energy in the near term and several days into the future. Large demand-side resources engaged by the transactive system included distributed generation, campus chillers and heating, ventilation, and air conditioning, renewable energy generation, and stationary battery energy storage systems. Smaller demand-side resources, often installed at residential premises, included sets of communicating thermostats, water heater controllers, and smart appliances.

The region’s bulk generation and a simplified transmission structure were emulated for the project by Alstom Grid using their energy-management and market-management system tools. The condition of the region’s generation and transmission systems was informed by a combination of actual grid status and static, seasonal representations of diurnal patterns. The bulk delivered costs of electricity were also estimated from this process, much as is done today in regions where locational marginal pricing is practiced. It is the flexibility with which costs and incentives may be dynamically applied in this transactive system that may help mitigate challenges of wind intermittency, encourage economic efficiency, and flatten system load.

While the project’s transactive system did not engage demand-side assets as well as had been hoped, the project was understood from the beginning to not be large enough to by itself have an impact on the grid. A bold step had been taken by the demonstration to launch the transactive system so generally, across such a large region, and to include its predictive days-ahead planning horizon. In order for the system to have been fully proven, no fewer than eight subsystems would have necessarily been accurately and meaningfully deployed. A key result of the project is, however, that much of the transactive system worked as intended. Experience with the transactive system helps prepare the region to operate an increasingly distributed electric power system making maximum use of its growing renewable energy supply and demand-side solutions. The project leaves an updated technical specification for the transactive system that leverages the five years of development and deployment experience. The updated

¹ Bonneville Power Administration. 2015. Pacific Northwest Smart Grid Demonstration Project: A Compilation of Success Stories. Accessed at <https://www.bpa.gov/Pages/home.aspx>.

specification and a corresponding reference implementation provide an important platform for future research into transactive energy systems.

When the project looked at the transactive subsystems (as is done in Chapter 2), about half of the subsystems were found to have performed well. Among the successes, wind resources were accurately stated and predicted within the region by the demonstration. Unit costs and incentives were indeed generated to represent bulk resource costs and the demonstration's stated operational objectives. The incentive signals were meaningfully blended at, and communicated between, the system's multiple nodes. A library of functions was developed that automatically determined times of events to which responsive demand-side assets, such as water heaters, battery energy storage, and thermostats, were to respond.

There is a key observation about the performance of the transactive coordination system as compared to conventional demand response. Even when the responses to the transactive system were automated, utilities placed limits on the number of allowed responses. Customer agreements often specified a maximum number of allowed events in a month. Conventional demand-response programs, either direct load control or otherwise, are generally event-driven and are targeted toward managing few, short-lived incidents like critical peaks. Several well-placed asset responses may be adequate for conventional demand-response programs. Transactive systems, on the other hand, reveal a continuum of incentives to the utilities and asset systems and could engage assets much more dynamically according to each asset's capabilities and the flexibility of the asset's owner. This granularity of responses by many customers enables those customers who are both willing and able to respond (via automated systems) to participate according to their preferences rather than having their participation limited according to predetermined agreements.

In addition to the results gained from the deployment of the transactive system, IBM used a model of the regional system to assess the impact of a scaled up deployment of the transactive system. This simulation showed that the region's peak load might be reduced by about 8% if 30% of the region's loads were responding to the transactive system.

At the end of the project's data collection period, the transactive system was turned off. The regional incentive signals produced using the Alstom tools were not linked to operational needs of the BPA, the regional system operator. In the absence of such linkage, there was no basis for continuing to generate the signals once the research was completed. There are efforts underway to continue to use a small subset of the deployed transactive control system for further regional research. If BPA or other balancing area operators in the region define an incentive signal, the PNWSGD utilities could, in principle, resume the use of their transactive systems.

Exploring Data—and Associated Challenges

Now that the demonstration project has concluded, it leaves behind a rich database—almost 350 billion data records. Organization of the data is based on the 55 smart grid systems defined by the project. An extraordinary effort was needed to accurately specify the many data series that might be used to monitor those smart grid systems. The disparity of data sources, databases, intervals, and utility data practices that was encountered during the demonstration made the challenge even greater. The transactive system featured a predictive time dimension that exponentially increased the volume of data that was automatically collected from the transactive system.



The project's experience is an example of dealing with the vast amounts of new data that become available in a smart grid. In the demonstration, much of that data was found to be unusable. Data cannot be converted into actionable information if its quality is poor or if its units, location, or validity is uncertain. Investments should be made to improve the quality of meter data, databases, and smart grid data processes at all levels. As a part of these investments, there is a need for better tools to be developed for utilities to use in managing the devices and information found in a smart grid.

Moving Forward

Along with data challenges, this report addresses the technical performance of all the smart grid asset systems that were tested at the PNWSGD sites. It also critiques the performance of the transactive system that was featured by the demonstration. After an introductory chapter, the performance of the transactive system is discussed. In the three following chapters, the performances of reliability, conservation and efficiency, and demand-responsive systems are generalized, referring to the 55 smart grid systems that were demonstrated at the PNWSGD sites. The performance of each site owner's smart grid systems is presented in the final 11 chapters.

At its conclusion, the PNWSGD leaves a legacy of smart grid equipment installed with its site owners. Eighty-eight percent of the smart grid assets remain installed and functional after the demonstration. The remainder succumbed to the challenges of grid modernization in the early 21st century. Some of these systems could not be successfully integrated due to interoperability problems with other new and legacy systems with which they needed to interact. Some sets of residential devices were removed after having been installed, due to unexpected safety problems or at the request of residential customers. Some vendors failed to deliver their smart grid products or went out of business during the demonstration. Nine of the removed systems were wind turbines that were taken down at a renewable park due to safety concerns after a tower catastrophically failed and a turbine had thrown a blade. These are considered learning experiences. The demonstration project facilitated the maturation of the smart grid industry, and helped advance our collective thinking about the path forward. Please read further to understand why the participants in the PNWSGD remain optimistic about smart electric power grids of the future.



Acknowledgments

Author:

D Hammerstrom

Battelle Memorial Institute

Coauthors:

D Johnson
C Kirkeby
Y Agalgaonkar
S Elbert
O Kuchar
C Marinovici
R Melton
K Subbarao
Z Taylor
B Scherer
S Rowbotham
T Kain
T Rayome-Kelly
R Schneider
R Ambrosio
J Hosking
S Ghosh
M Yao
R Knori
W Jones
J Pusich-Lester
M Simpson
R Grinberg
K Whitener
S Chandler
M Phan
L Beckett
C Mills
D Garcia
R Bass
W Sanders
M Osborn
W Lei

Avista Utilities
Avista Utilities
Battelle Memorial Institute
Battelle Memorial Institute
Battelle Memorial Institute
Battelle Memorial Institute
Battelle Memorial Institute
Battelle Memorial Institute
Battelle Memorial Institute
Battelle Memorial Institute
Benton PUD
City of Ellensburg
City of Milton-Freewater
Flathead Electric
Flathead Electric
IBM
IBM
IBM
IBM
Lower Valley Energy
Lower Valley Energy
NorthWestern Energy
Peninsula Light Company
Peninsula Light Company
Portland General Electric
Portland General Electric
Portland General Electric
Portland General Electric
Portland General Electric
Portland General Electric
Portland General Electric
Portland General Electric
Portland General Electric
Portland General Electric
Portland General Electric
Portland General Electric

The following individuals and organizations are recognized for their valuable contributions:

Vaisala (formerly 3Tier, Inc.)
M Grundmeyer
J Lerner
P Storck
A Vandervoort

Alstom Grid
M Atkinson
M Chungyoun
J Corkey
H Jaffarbhoj
P Jap





Alstom Grid (Continued)

E Jensen
J Lelivelt
C Shaw
X Wang
G Wooster
M Yao

Avista Utilities

H Cummins
P Duncan
G Fischer
L Jue

Avista Utilities/Washington State University

A Bose
T Ryan

Battelle Memorial Institute

B Akyol
R Anderson
J Bernsen
P Boyd
T Carlon
K Carneau
D Chassin
P Christensen
L Connell
K Cook
A Cooke
J Dahl
G Dayley
T Edgar
M Engels
S Ennor
T Efram
A Faber
N Foster
V Genetti
B Gerber
P Gjefle
A Haas
R Hafen
D Hardman
J Hathaway
K Huston
C Imhoff
J Jao

Battelle Memorial Institute (Continued)

E Jones
R Jones
S Kanyid
D King
S Kowalski
T Ledbetter
O Love
D Manz
T McKenna
J Melland
V Mendon
M Newhouse
L O'Neil
P O'Toole
C Owen
M Parker
R Pratt
C Raymond
N Sargent
B Simanton
S Singh
D Sisk
B Slonecker
A Somani
V Srivastava
S Tackett
B Vyakaranam
M Wagner
F White
D Zimmerman
M Zimmerschied

Benton PUD

C Bartram
R Dunn
J Henderson
J Sanders

Bonneville Power Administration

T Brim
L Hall
T Oliver
K Pruder-Scruggs
S Reed
D Watkins
J Williamson



City of Ellensburg

T Barkley
L Dunbar
B Faubion
B Leader
G Nystedt
J Richmond
B Titus
W Weidert

City of Milton Freewater

B Chadek
M Charlo
City of Milton Freewater
L Hall
R Rambo

CVO Electrical Systems

B Leland
J Newland

Electsolve Technology Solutions & Services, Inc.

J Newland

Flathead Electric

M Johnson

IBM

K Bodell
M Cohen
D Gil
J Hosking
G Janssen
J Kidwell
J Kilbride
J Malczyk
D Melville
S Nathan
D Phan
J Reid
M Rosenfield
B Schloss
B Schmidt
G Soumyadip
S Srinivasan
M Steiner
H Wang

IBM (Continued)

K Warren
A Webb
J Xiong

Idaho Falls Power

V Ashton
J Flowers
M Reed
H Dory

Lower Valley Energy

W Jones
R Knori
J Webb

National Energy Technology Laboratory for the U.S. Office of Electricity Delivery and Energy Reliability

M Sciulli

Netezza

B Walker

NorthWestern Energy

P Corcoran
G Horvath
J Pusich-Lester
B Thomas

Peninsula Light Company

S Anderson
B Draggoo
R Grinberg
J Pilling
M Simpson
D Walden
J White
J Wigle

Portland General Electric

J L Becket
J Dalzell
C Eustis
P Farrell
S Klotz
E Medina
C Mills



Portland General Electric (Continued)

M Mohammadpour
M Moir
J Poppe
J Ross
K Teague
K Whitener

U.S. Office of Electricity Delivery and Energy

Reliability
M Smith

WISDM Corp.

B Burner
M Hansen

QualityLogic, Inc.

G Cooper
B David
D Jollota
S Kang
C Kawasaki
J Mater
M Osborn
L Posson
E Prabhakaran
L Rankin
J Zuber

RAI, Inc.

S Hamilton
B Mantz

Spirae, Inc.

B Becker
M Fanning
J Harrell
S Oliver
O Pacific
A Russell

University of Washington

J Angelosante
J Carlson
J Chapman
C Kennedy
N Menter
J Park
G Sakagawa
J Seidel

U.S. Department of Energy, Pacific Northwest

Site Office

J Erickson

Acronyms and Abbreviations

3TIER	3TIER, Inc., now part of Vaisala
ACS	advisory control signal
AGRS	Avista-generated request signal
AGS	Avista-generated signal
aHLH	average heavy-load hour energy
AMI	advanced metering infrastructure
BPA	Bonneville Power Administration
CAIDI	Customer Average Interruption Duration Index
CPUC	California Public Utilities Commission
CVR	conservation voltage reduction
DA	distribution automation
DDC	direct digital control
DMS	distribution management system
DOE	U.S. Department of Energy
DR	demand response
DRU	demand-response unit
DSG	distributed standby generation
EIOC	Electricity Infrastructure Operations Center
FDIR	fault detection, isolation, and restoration
FEMS	facility energy management system
GE	General Electric
GFA	grid friendly appliances
HAN	home area network
HLH	heavy-load hour
HVAC	heating, ventilating, and air conditioning
IBM	International Business Machines Corp.
iCS	Internet-Scale Control System software
IEEE	Institute of Electrical and Electronics Engineers
IHD	in-home display
IM	impact metric
IST	interval start time
IT	Information Technology
IVVC	integrated volt/VAr control
LCM	load-control module
LLH	light-load hour



LTC	load tap changer
LV	prefix for Lower Valley, Wyoming, project tests
MAIFI	Momentary Average Interruption Frequency Index
MAN	metropolitan area network
MDM	meter data management
O&M	operations and maintenance
OMS	outage management system
OMT	Outage Management Tool
p.u.	per unit
PCT	programmable communicating thermostat
PHEV	plug-in hybrid electric vehicle
PLC	power line carrier
PNWSGD	Pacific Northwest Smart Grid Demonstration
PRB	Project Review Board
PUD	Public Utility District
PV	photovoltaic
RTU	remote terminal unit
SAIDI	System Average Interruption Duration Index
SAIFI	System Average Interruption Frequency Index
SCADA	supervisory control and data acquisition
SCL	Seattle City Light
SEL	Schweitzer Engineering Laboratories
SSPP	Salem Smart Power Project
ST	field site node (of the transactive coordination system topology)
STP	Smart Thermostat Pilot
SVC	static VAr compensator
T&D	transmission and distribution
TFS	transactive feedback signal
TIS	transactive incentive signal
TWACS	Two-Way Automatic Communication System
TZ	transmission zone
UC	unit commitment
UW	University of Washington
VVO	volt/VAr integration and optimization
WECC	Western Electricity Coordinating Council
WSU	Washington State University

Units

\$/h	dollars per hour
°C	degree(s) Celsius
F	Fahrenheit
GW	gigawatts
GWh	gigawatt-hour(s)
kV	kilovolt(s)
kVAr	kilovolt-ampere(s) reactive
kW	kilowatt(s)
kWh	kilowatt-hour(s)
kWh/h	kilowatt-hour(s) per hour
m	meter(s)
mph	miles per hour
MW	megawatt(s)
MWh	megawatt-hour(s)
p.u.	per unit
s	second(s)
VAr	volt-amperes reactive
W	watt(s)
y	year



Contents

Executive Summary	iii
Acknowledgments.....	ix
Acronyms and Abbreviations	xiii
Units.....	xv
1.0 Introduction	1.1
1.1 The PNWSGD Project.....	1.1
1.1.1 Objectives.....	1.2
1.1.2 Regional Geographical Map	1.2
1.2 Technical Approach	1.4
1.3 The Demonstration Test Sites and Asset Systems	1.4
1.4 Demonstration Data and Data Processes	1.7
1.5 Organization of this Report	1.8
2.0 The Transactive System.....	2.1
2.1 Context Needed to Discuss Performance of the PNWSGD Transactive System.....	2.2
2.2 Step 1: The System Must Accurately Represent the Region’s Strategies for the Dispatch of its Energy Resources.....	2.7
2.2.1 Generation Mixes Modeled by the Transactive System.....	2.9
2.2.2 Winter and Summer Peaks	2.14
2.2.3 Generator Outage	2.18
2.2.4 Wind Incidents	2.22
2.2.5 Transmission Incidents	2.30
2.2.6 Relative Accuracy of Resource Predictions	2.35
2.2.7 Step 1 Evaluation Conclusions.....	2.38
2.3 Step 2: The System Must Meaningfully Monetize and Predict Resource Costs and Incentives	2.39
2.3.1 Toolkit Resource and Incentive Functions.....	2.41
2.3.2 The Accuracy of TIS Predictions	2.42
2.3.3 Changes in Monetized Incentive Mix over Time.....	2.48
2.3.4 Lessons Learned Concerning Monetization and Prediction of Resource Costs and Incentives.....	2.50
2.3.5 Step 2 Evaluation Conclusions.....	2.51
2.4 Step 3: Costs and Incentives Must Be Meaningfully Blended and Distributed through the System	2.51
2.4.1 The Transactive Incentive Signal Is a Blended Cost.....	2.52
2.4.2 Distribution of Paired Energy Quantity and Unit Price Confirmed	2.52





- 2.4.3 Lessons Learned Concerning the Blending and Distribution of Incentive Signals..... 2.53
- 2.4.4 Step 3 Evaluation Conclusions..... 2.54
- 2.5 Step 4: Responsive Loads in the System Must Be Able to Allocate Appropriate Responses Using the Incentive Signal..... 2.54
 - 2.5.1 Event-Driven Function Events..... 2.55
 - 2.5.2 Daily Function Events..... 2.59
 - 2.5.3 Continuous Function Events 2.63
 - 2.5.4 Step 4 Analysis Conclusions..... 2.65
- 2.6 Step 5: Responsive Assets Must Accurately Predict the Impacts of Their Responses 2.65
 - 2.6.1 The Utility Sites’ Demonstrated Abilities to Predict Their Total Load 2.65
 - 2.6.2 Asset Models’ Modeled Load 2.77
 - 2.6.3 Step 5 Analysis Conclusions..... 2.82
- 2.7 Step 6: The Plans to Exchange Power with the System Must Be Calculated and Communicated throughout the System 2.83
- 2.8 Step 7: The Modeled Exchange of Energy within the Transactive System Must Be Accurate 2.84
 - 2.8.1 Accuracy of the TFS between Transmission Zones..... 2.84
 - 2.8.2 Accuracy of the Utility Sites’ TFS..... 2.85
 - 2.8.3 Step 7 Analysis Conclusions..... 2.91
- 2.9 Step 8: Resources Must Respond to Dynamic System Load Predictions, Including the Plans from Flexible Loads..... 2.92
- 2.10 Simulation Analysis of the Pacific Northwest Smart Grid Demonstration Transactive System..... 2.92
 - 2.10.1 Introduction to the Simulation and its Objectives..... 2.93
 - 2.10.2 The PNWSGD Transactive System 2.94
 - 2.10.3 Advantages of the Simulation Platform 2.95
 - 2.10.4 Core Design Components of the Simulation Platform..... 2.96
 - 2.10.5 Simulation Scenarios and Experiment Run Setup..... 2.99
 - 2.10.6 Output Analysis..... 2.105
 - 2.10.7 Understanding Transactive Systems 2.106
 - 2.10.8 System-Wide Effects of Transactive Assets 2.109
 - 2.10.9 Responsiveness of the Transactive System..... 2.111
 - 2.10.10 Direction of Transactive Response 2.114
 - 2.10.11 Effect of Wind on Total System-Wide Costs..... 2.116
 - 2.10.12 Interaction of Wind Output and Transactive Response 2.120
 - 2.10.13 Conclusions..... 2.124
 - 2.10.14 Summary and Need for Further Work 2.125





- 3.0 Conservation and Efficiency Test Cases 3.1
 - 3.1 The Power of Information – Portals, In-Home Displays, and Customer Education 3.2
 - 3.2 Replacing Inefficient Equipment and Tuning Existing Equipment..... 3.3
 - 3.3 Efficient Distribution Management 3.4
 - 3.4 Renewable Energy..... 3.5
 - 3.4.1 Solar Renewable Energy Systems..... 3.5
 - 3.4.2 Wind Renewable Energy Systems 3.7

- 4.0 Transactive System Test Cases..... 4.1
 - 4.1 Asset System Summary..... 4.1
 - 4.2 Transactive System Costs..... 4.2
 - 4.3 Addressing Impacts of Demand Charges 4.5
 - 4.4 Summary Asset Responses..... 4.6

- 5.0 Reliability Test Cases 5.1
 - 5.1 Reliability Indices..... 5.1
 - 5.2 Effect of Smart Grid Assets on Reliability 5.2
 - 5.2.1 Effect of AMI on Reliability 5.2
 - 5.2.2 Effect of Advanced Distributed Automation Investment on Reliability 5.3
 - 5.3 Observations and Lessons Learned 5.4

- 6.0 Conclusions 6.1
 - 6.1 General Conclusions..... 6.1
 - 6.2 The PNWSGD Transactive System..... 6.2
 - 6.3 Data and Data Collection Processes 6.5
 - 6.4 Reliability Assets..... 6.7
 - 6.5 Conservation / Efficiency Assets..... 6.7
 - 6.6 Dynamically-Responsive (Transactive) Assets 6.9

- 7.0 Avista Utilities Site Tests 7.1
 - 7.1 Voltage and Reactive Power Optimization 7.5
 - 7.1.1 System Operation and Data Concerning the Voltage Optimization System..... 7.8
 - 7.1.2 Analysis of the Avista Utilities Voltage Optimization System..... 7.24
 - 7.2 Reconductoring 7.54
 - 7.2.1 Data Concerning the Reconductoring 7.55
 - 7.2.2 Analysis of the Impact from Reconductoring 7.56
 - 7.3 Smart, Efficient Transformers 7.56
 - 7.4 Residential Thermostats 7.58





7.4.1	Data concerning the Residential Thermostats.....	7.62
7.4.2	Analysis concerning the Residential Thermostats	7.68
7.5	Advanced Metering Infrastructure, Web Portals.....	7.70
7.5.1	Data Concerning AMI and Web Portal Efficiencies.....	7.72
7.5.2	Analysis of AMI and Portal Efficiencies	7.78
7.6	WSU Bio-Tech Generator for Outage Prevention.....	7.82
7.7	Configuration Control for Optimization (FDIR).....	7.83
7.7.1	Data Concerning Pullman Site Reliability	7.84
7.7.2	Analysis of Pullman Site Electricity Reliability	7.88
7.8	Controllable HVAC Fan Load at 39 Campus Buildings	7.91
7.8.1	Data Concerning Control of the WSU HVAC Fan Loads	7.93
7.8.2	Analysis of the WSU HVAC Fan Loads.....	7.95
7.9	Nine WSU Controllable Chiller Loads.....	7.102
7.9.1	Data Concerning the WSU Controllable Chiller Loads	7.102
7.9.2	Analysis of the WSU Controllable Chiller Loads.....	7.103
7.10	1.4 MW WSU Diesel Generator.....	7.107
7.10.1	Data Concerning the WSU Diesel Generator.....	7.107
7.10.2	Analysis of the WSU Diesel Generator Performance	7.109
7.11	Two 1.1 MW WSU Natural Gas Generators.....	7.111
7.11.1	Data Concerning the Two WSU Natural Gas Generators.....	7.112
7.11.2	Analysis of the Two WSU Natural Gas Generators.....	7.114
7.12	Other Project Activities and Assets.....	7.118
7.12.1	Distribution Management System.....	7.118
7.12.2	Fiber Backhaul Communications.....	7.119
7.12.3	802.11 a/b/g Wireless Communications	7.120
7.12.4	Avista-WSU Curriculum Project	7.120
7.13	Conclusions and Lessons Learned.....	7.120
8.0	Benton PUD Site Tests.....	8.1
8.1	DataCatcher and AMI	8.3
8.1.1	Analysis of Reliability Indices for This Asset System.....	8.4
8.1.2	Abnormal-Temperature Alerts Reported by Advanced Meters	8.5
8.1.3	Low-Voltage Alerts Reported by Advanced Meters.....	8.7
8.1.1	High-Voltage Alerts Reported by Advanced Meters	8.9
8.1.1	Outage Alerts Reported by Advanced Meters.....	8.10
8.2	Demand Shifter and DataCatcher.....	8.13
8.2.1	Data from the Energy Storage Modules.....	8.14
8.2.2	Performance of the Energy Storage Modules	8.16





8.2.3	Conclusions and Lessons Learned	8.19
9.0	City of Ellensburg Site Tests	9.1
9.1	Recloser Switch for Reliability and Outage Prevention.....	9.4
9.2	Polycrystalline Flat-Panel 56 kW PV System	9.5
9.2.1	Baseline Approach	9.6
9.2.2	Data and Data Collection for the Polycrystalline PV Panels	9.6
9.2.3	Performance of the Polycrystalline PV System	9.7
9.3	Thin-Film Solar Panel 54 kW Array	9.13
9.3.1	Data from the Thin-Film Solar Panel System.....	9.14
9.3.2	Performance of the Thin-Film Solar Panel System.....	9.14
9.4	Honeywell WindTronics 1.5 kW Model WT6500	9.18
9.4.1	Data for the Honeywell WindTronics System	9.20
9.4.2	Performance of the Honeywell WindTronics System.....	9.21
9.5	Windspire® 1.2 kW Wind Turbine	9.24
9.5.1	Data for the Windspire System	9.25
9.5.2	Performance of the Windspire Turbine System	9.26
9.6	Home Energy International 2.25 kW Energy Ball® V200	9.29
9.6.1	Data for the Energy Ball System.....	9.31
9.6.2	Performance of the Energy Ball Wind Generation System.....	9.32
9.7	Southwest Windpower 2.4 kW Skystream 3.7®.....	9.35
9.7.1	Data for the Southwest Windpower System	9.36
9.7.2	Performance of the Southwest Windpower System.....	9.37
9.8	Bergey WindPower 10 kW Excel 10.....	9.42
9.8.1	Data for the Bergey WindPower System	9.43
9.8.2	Performance of the Bergey WindPower System.....	9.44
9.9	Tangarie Alternative Power 10 kW Gale® Wind Turbine.....	9.48
9.9.1	Data for the Tangarie System.....	9.50
9.9.2	Performance of the Tangarie System	9.51
9.10	Urban Green Energy 4 kW Wind Turbine	9.53
9.10.1	Data for the Urban Green Energy System.....	9.54
9.10.2	Performance of the Urban Green Energy System	9.55
9.11	Ventera Wind 10 kW VT10 Wind Turbine.....	9.58
9.11.1	Data for the Ventura Wind System	9.60
9.11.2	Performance of the Ventura Wind System.....	9.60
9.12	Wing Power 1.4 kW Wind Turbine.....	9.64
9.12.1	Data for the Wing Power System.....	9.66
9.12.2	Performance of the Wing Power Turbine System.....	9.67





9.13 Conclusions and Lessons Learned..... 9.69

10.0 Flathead Electric Site Tests 10.1

 10.1 Advanced Metering Infrastructure for Outage Recovery 10.6

 10.1.1 Reliability Data 10.8

 10.2 In-Home Displays..... 10.10

 10.2.1 Characterization of In-Home Display System Responses..... 10.13

 10.2.2 In-Home Display System Performance..... 10.16

 10.3 DRUs..... 10.23

 10.3.1 Characterization of DRU System Responses 10.26

 10.3.2 DRU System Performance 10.30

 10.4 Demand-Response Appliances..... 10.37

 10.4.1 Characterization of the Demand-Response Appliance System Responses 10.41

 10.4.2 Demand-Response Appliance System Performance 10.44

11.0 Idaho Falls Power Site Tests 11.1

 11.1 Conservation Voltage Regulation..... 11.5

 11.1.1 Project Data and the Operation of the Voltage Management System..... 11.6

 11.1.2 Analysis of the Impact from Voltage Management 11.10

 11.2 Automated Power Factor Control..... 11.19

 11.2.1 Project Data and Operation of the Automated Power Factor Control..... 11.20

 11.2.2 Analysis Results from the Automated Power Factor Correction 11.23

 11.3 Distribution Automation..... 11.24

 11.3.1 Available Reliability Metrics 11.25

 11.3.2 Analysis of the Impact from Distribution Automation 11.26

 11.4 Water Heater Control 11.26

 11.4.1 Characterization of the Water Heater Control System and Data 11.27

 11.4.2 Water Heater Control Performance..... 11.33

 11.5 Battery Storage (with PHEV and Solar)..... 11.35

 11.5.1 Data from, and Performance of, the Battery Storage System 11.36

 11.6 Thermostat Control..... 11.36

 11.6.1 Thermostat System Operation and Project Data 11.37

 11.6.2 Analysis of the System of Controllable Thermostats..... 11.42

 11.7 In-Home Displays..... 11.46

 11.7.1 Data from the In-Home Display System..... 11.48

 11.7.2 Analysis of the In-Home Display System..... 11.50

 11.8 Conclusions and Lessons Learned..... 11.53





12.0 Lower Valley Energy Site Tests	12.1
12.1 Lower Valley Energy’s Transactive Demand-Charges Function.....	12.6
12.2 AMI and In-Home Energy Displays.....	12.6
12.2.1 Characterization of the In-Home Display System.....	12.7
12.2.2 Performance of the Advanced Metering and In-Home Display System.....	12.10
12.3 DRUs.....	12.13
12.3.1 Characterization of Asset System Responses	12.14
12.3.2 Performance of the Lower Valley Energy DRUs.....	12.17
12.4 DRUs/AMI for Improved System Reliability	12.22
12.4.1 Available Data.....	12.24
12.4.2 Analysis of Trends in the Reliability Indices.....	12.28
12.5 Adaptive Voltage Regulation	12.29
12.5.1 Characterization of Asset System Responses	12.30
12.5.2 Performance of the Dynamic Voltage-Management System.....	12.37
12.6 SVC for Power Factor Improvement.....	12.42
12.6.1 Project Data and Operation of the SVC	12.44
12.6.2 Performance of the SVC	12.47
12.7 Battery Storage System	12.52
12.7.1 Characterization of the Battery System and Data	12.53
12.7.2 Performance of the Battery System.....	12.56
12.8 20 kW Solar PV System.....	12.61
12.8.1 Characterization of the Data.....	12.63
12.8.2 Performance of the PV System	12.65
12.9 Four 2.5 kW WindTronics Wind Turbines.....	12.69
12.10 Conclusions and Lessons Learned.....	12.70
13.0 City of Milton-Freewater Site Tests	13.1
13.1 Transactive Demand-Charges Function	13.5
13.2 Load Control with DRUs	13.6
13.2.1 Characterization of DRU System Responses.....	13.7
13.2.2 DRU System Performance	13.15
13.3 Conservation-Voltage-Regulation Peak Shaving.....	13.26
13.3.1 Characterization of the CVR Peak-Shaving System Responses	13.28
13.3.2 Conservation-Voltage-Regulation Peak-Shaving System Performance	13.32
13.4 Voltage-Responsive, Grid-Friendly DRUs	13.36
13.4.1 Characterization of the Voltage-Responsive Water Heater System.....	13.37
13.4.2 Voltage-Responsive Water Heater System Performance.....	13.38
13.5 Conservation from CVR on Feeders 1–4	13.44





- 13.5.1 Characterization of the CVR System Responses 13.45
- 13.5.2 Conservation-Voltage-Regulation System Performance 13.48
- 13.6 Conclusions and Lessons Learned..... 13.54

- 14.0 NorthWestern Energy Site Tests 14.1
 - 14.1 Automated Voltage and Reactive Power Control – Helena 14.3
 - 14.1.1 Data and System Operation Concerning the Helena IVVC System 14.4
 - 14.1.2 Analysis of the Helena IVVC Systems 14.12
 - 14.2 Fault Detection, Isolation, and Restoration 14.14
 - 14.2.1 Reliability Metrics for the FDIR Circuits 14.14
 - 14.2.2 Anecdotal Results 14.16
 - 14.3 Residential and Commercial Building Demand Response..... 14.17
 - 14.3.1 Characterization of Asset System Responses 14.19
 - 14.3.2 Analysis of NorthWestern Energy’s DR Experience 14.21
 - 14.4 Philipsburg/Georgetown IVVC..... 14.23
 - 14.4.1 Data and Operations Concerning the Philipsburg IVVC System 14.24
 - 14.4.2 Analysis of the Philipsburg IVVC System..... 14.28
 - 14.5 Conclusions and Lessons Learned..... 14.31
 - 14.5.1 Lesson Learned #1: Vendors (Good Experiences and Challenges) 14.32
 - 14.5.2 Lesson Learned #2: Experimental Nature of the Project 14.32
 - 14.5.3 Lesson Learned #3: System Integration (FDIR System) 14.34
 - 14.5.4 Lesson Learned #4: IVVC System Observations..... 14.35

- 15.0 Peninsula Light Company Site Tests..... 15.1
 - 15.1 Load Reduction with Load-Control Modules..... 15.4
 - 15.1.1 Characterization of Asset System Responses and Data 15.5
 - 15.1.2 Performance of the Load-Control Module System 15.10
 - 15.2 Conservation Voltage Reduction with End-of-Line Monitoring..... 15.15
 - 15.2.1 Conservation Voltage Reduction Data..... 15.17
 - 15.2.2 Performance of the Conservation Voltage Reduction System..... 15.20
 - 15.3 Pad-Mounted and Overhead Automated Switching 15.21
 - 15.3.1 Switching System Data 15.22
 - 15.3.2 Switching System Performance 15.25
 - 15.4 Conclusions and Lessons Learned..... 15.28
 - 15.4.1 Accuracy of the System Model is Critical 15.29
 - 15.4.2 Know Integration Dependencies of Software 15.30
 - 15.4.3 Automated Meter Reading Power Line Carrier Technology is Slow but Reliable 15.30





- 15.4.4 Secondary Data Sources are Expensive (Additional Transformers / Sensors)..... 15.31
- 15.4.5 Load Controllers Leveraged the Existing AMR System but with Limited Performance 15.32
- 15.4.6 Involve Operations Personnel in the Selection of Field Devices 15.32
- 15.4.7 Reclosers are the New Overhead Switch 15.32
- 15.4.8 When a Historian is not a Historian 15.33
- 15.4.9 Manage Change..... 15.33

- 16.0 Portland General Electric Site Tests 16.1
 - 16.1 Portland General Electric’s Utility Economic Dispatch Function..... 16.4
 - 16.2 Residential DR 16.5
 - 16.3 Commercial DR..... 16.6
 - 16.3.1 Characterization of Asset System and Data 16.7
 - 16.3.2 Performance of the Commercial DR System..... 16.9
 - 16.4 Commercial Distributed Standby Generation 16.10
 - 16.4.1 Characterization of Asset System Responses and Data 16.11
 - 16.4.2 Performance of the Distributed Generator System 16.12
 - 16.5 Battery Storage in High-Reliability Zone..... 16.14
 - 16.5.1 Battery Storage Data 16.16
 - 16.5.2 Performance of the Battery System..... 16.18
 - 16.6 Distribution Switching and Residential/Commercial Microgrid..... 16.25
 - 16.6.1 Performance of the Distribution Automation System..... 16.27
 - 16.7 Lessons Learned and Conclusions..... 16.27

- 17.0 University of Washington Facilities Services Site Tests 17.1
 - 17.1 Steam Turbine 17.2
 - 17.1.1 System Operation and Data Concerning the 5 MW Steam Turbine Generator..... 17.3
 - 17.1.2 Analysis of the 5 MW Steam Turbine Generator..... 17.5
 - 17.2 Diesel Generators 17.6
 - 17.2.1 System Operation and Data Concerning the Diesel Generators..... 17.7
 - 17.2.2 Analysis of the Diesel Generators..... 17.9
 - 17.3 Solar Renewable Generation 17.9
 - 17.3.1 System Operation and Data Concerning the Solar Renewable Generation 17.10
 - 17.3.2 Analysis of the Potential Power Output from the UW PV Arrays..... 17.13
 - 17.4 Direct Digital Controls in UW Buildings..... 17.16
 - 17.4.1 System Operation and Data Concerning DDC in UW Buildings 17.17
 - 17.4.2 Analysis of the DDC Building Controls 17.20





17.5	Building Advanced Metering Displays and EnergyHub© Devices	17.20
17.5.1	System Operation and Data Concerning Building Advanced Metering Displays and EnergyHub Devices.....	17.22
17.5.2	Analysis of Building Advanced Metering Displays and EnergyHub Devices.....	17.23
17.6	Facilities Energy Management System Data for Campus Building Managers	17.25
17.6.1	System Operation and Data Concerning the Facilities Energy Management System Data for Campus Building Managers.....	17.26
17.6.2	Analysis of the Facilities Energy Management System Data for Campus Building Managers.....	17.27
18.0	References	18.1
Appendix A - Technical Documents Generated by the Pacific Northwest Smart Grid Demonstration		
	Demonstration	A.1
Appendix B - Regional and Subproject Transactive Nodes and Network Topology		
	B.1
Appendix C - Bonneville Power Administration Tiered Rate Methodology.....		
	C.1
Appendix D - Flathead Electric Company 2014 Peak Time Demonstration Project Member Survey Results		
	D.1





Figures

1.1	PNWSGD Geographical Region, Including Participants’ Locations and Major Generation and Transmission Corridors.....	1.3
2.1	Simplified Functional Block Diagram of a Transactive Node.....	2.3
2.2	Composition of Modeled Resources of the Entire Transactive System in the Last Full Project Year Before and After the Energy that Was Exchanged between Transactive Nodes was Reallocated	2.9
2.3	Comparison of Average Relative Resource Mix that Was Modeled by the Transactive System and the Mix from BPA Data for the Same Four Seasons.....	2.11
2.4	Average Relative Resource Mixes Modeled by the PNWSGD Transactive System and According to BPA Data from September 2013 through August 2015.....	2.12
2.5	Average Relative Mix of Generation Resources Available at Each Transmission-Zone Node during the Last Full Year of the PNWSGD	2.13
2.6	Comparison of Total Generation Resource and Load Data for BPA and the PNWSGD Transactive System Model on December 5, 2013	2.15
2.7	Comparison of Total Generation Resource and Load Data for BPA and the PNWSGD Transactive System Model on August 5, 2013	2.17
2.8	Comparison of Total Generation Resource and Load Data for BPA and the PNWSGD Transactive System on February 5, 2014.....	2.19
2.9	Comparison of BPA’s and PNWSGD Transactive System’s Thermal Generation Data on February 5, 2014, when a Significant Thermal Generator Outage Occurred	2.20
2.10	Ratio of Transactive System and BPA Total Resource and Load Powers on February 5, 2014	2.21
2.11	Average Transactive System TIS and for Selected TZ Nodes February 5, 2014, when a Significant Thermal Generator Outage Occurred	2.22
2.12	Comparison of Total Generation Resource and Load Data for BPA and the PNWSGD Transactive System on February 15, 2014.....	2.23
2.13	Comparison of Transactive System Wind Generation, BPA Wind, and BPA Forecast Wind Data from February 15, 2014.....	2.25
2.14	Transactive System Average TIS and TIS in the Oregon Cascades TZ08 on February 15, 2014.....	2.26
2.15	TIS as a Function of Wind Power in the Oregon Cascades TZ08 on February 15, 2014.....	2.26
2.16	Comparison of Total Generation Resource and Load Data for BPA and the PNWSGD Transactive System on March 5, 2014.....	2.28
2.17	Comparison of BPA and PNWSGD Transactive System Wind Generation Data on March 5, 2014	2.29
2.18	Average Transactive System TIS and the TIS at the Oregon Cascades TZ08 on March 5, 2014.....	2.29
2.19	TIS as a Function of Generated Wind Power in the Oregon Cascades TZ08 of the Transactive System.....	2.30



2.20 Comparison of Total Generation Resource and Load Data for BPA and the PNWSGD Transactive System on April 1, 2014..... 2.31

2.21 TFS Flow North of Monroe on April 1, 2014 According to BPA Data and PNWSGD Transactive System Data..... 2.32

2.22 TIS Values on both Sides of the Transmission Outage and the Average TIS for the Entire Transactive System..... 2.33

2.23 Comparison of Total Generation Resource and Load Data for BPA and the PNWSGD Transactive System on April 11, 2014..... 2.34

2.24 Comparison between the Actual Power Flow North of John Day and the Sum of Power Flows between the Transactive System’s Hanford TZ07 and Neighboring Transmission Zones Oregon Cascades and Central Oregon on April 11, 2014 2.35

2.25 Average Total Resource Energies at TZs of the PNWSGD Transactive System Plotted against the Distance into the Future that the Predictions Were Made 2.37

2.26 Average Total Resource Energies at TZs of the PNWSGD Transactive System Plotted against the Distance into the Future that the Predictions were Made 2.38

2.27 Alstom Grid Toolkit Functional Overview 2.40

2.28 Average Monthly Relative Prediction Errors of the TIS Prediction Intervals throughout the Project Months of 2014 at the Fox Island Site 2.43

2.29 Standard Deviations of the Monthly Relative Prediction Errors Eight Months of 2014 at the Fox Island Site 2.44

2.30 Average Relative Prediction Errors of Heavy Load Hours and Light Load Hours at the Fox Island Site from January through August 2014 2.45

2.31 Relative TIS Prediction Errors for the First Eight Months of 2014 at Ten Transactive System Sites..... 2.48

2.32 Comparison of Relative Resource Power Mix and Relative Resource Cost Mix for the North Idaho TZ during August 2013 2.49

2.33 Ordered Relative TIS, Stated as Numbers of Standard Deviations from the Average TIS, Paired with the Cumulative Sum of Event Hours from all the Event-Driven Toolkit Functions during 2014 2.56

2.34 Cumulative Responses of Individual Event-Driven Assets to the Transactive System’s Incentive Signal 2.59

2.35 Ordered Relative TIS, Stated as Numbers of Standard Deviations from the Average TIS, Paired with the Cumulative Sum of Event Hours from All of the Daily-Event Toolkit Functions during 2014 2.61

2.36 Cumulative Responses of Individual Daily-Event Assets to the Ordered Transactive System’s Incentive Signal at Each Transactive Site during 2014..... 2.63

2.37 Discharging and Charging Capacity Hours Advised to the Lower Valley Energy Battery System during 2014 2.64

2.38 Average of the Transactive System’s Relative Load Prediction Errors at the Fox Island Site Site for the Eight Project Months of 2014..... 2.67

2.39 Standard Deviation of the Transactive System’s Relative Load Prediction Errors at the Fox Island Site for Eight Project Months of 2014 2.68



2.40 Average of the Transactive System’s Relative Load Prediction Errors and Standard Deviations of the Average Prediction Errors at the Peninsula Light Company Site for March 2014..... 2.69

2.41 Average of the Transactive System’s Relative Load Prediction Errors at the Fox Island Site by Local Starting Hour 2.70

2.42 Average of the Transactive System’s Relative Interval Prediction Errors during 2014 for the Fox Island, Washington Site for HLH Hours and LLH Hours 2.71

2.43 Average of the Transactive System’s Relative Load Prediction Errors at the Peninsula Light Company Site by Starting Minute of the Hour..... 2.72

2.44 Paired Average Relative Load Prediction Errors and Standard Deviations of those Errors at PNWSGD Utility Sites January–August 2014..... 2.77

2.45 Schematic of the IBM Simulation Platform Built to Simulate the PNW Electricity Grid..... 2.96

2.46 Simplified Model of the Pacific Northwest Electricity Grid 2.98

2.47 Total System-Wide Load in the Summer Data Set in the No-Transactive-Load Case 2.101

2.48 Total System-Wide Wind Generation in the Summer Data Set for the Medium Wind-Penetration Case 2.101

2.49 Average System-Wide Energy Cost of Electricity in the Summer Data Set under the No-Transactive-Load and No-Wind Cases 2.102

2.50 Total System-Wide Load in the Shoulder Data Set in the No-Transactive-Load Case 2.102

2.51 Total System-Wide Wind Generation in the Shoulder Data Set for the Medium Wind-Penetration Case 2.103

2.52 Average System-Wide Cost of Electric Energy in the Shoulder Data Set under the No-Transactive-Load and No-Wind Cases 2.103

2.53 Total System-Wide Load in the Winter Data Set under the Case Having No Transactive Assets..... 2.104

2.54 Total System-Wide Wind Generation in the Winter Data Set for the Medium Wind-Penetration Case 2.104

2.55 Average System-Wide Cost of Electric Energy in the Winter Data Set under the No-Transactive and No-Wind Cases..... 2.105

2.56 Total System-Wide Cost..... 2.106

2.57 Difference in Total System-Wide Load..... 2.107

2.58 Average Cost of Electricity at Nodes..... 2.107

2.59 Total System-Wide Cost..... 2.108

2.60 Difference in Total System-Wide Load..... 2.108

2.61 Average Cost of Electric Energy at Nodes 2.109

2.62 Total System-Wide Cost vs. Total Load for the Base-Case..... 2.110

2.63 Total System-Wide Cost vs. Total Load for High Transactive-Load Case 2.110

2.64 Total System-Wide Cost Expressed as a Scaled Dimensionless Quantity, for the Case that Had No Transactive Load in the Summer Dataset..... 2.112

2.65 Scaled Total System-Wide Load vs. Percentage Change in Total Load under the Medium and High Transactive-Load Penetration Cases 2.113



2.66 Total System-Wide Cost Expressed as a Scaled Dimensionless Quantity, for the No-Transactive-Load Case, using Distinct Colors and Point Types for Each Tercile of the Scaled Total Cost 2.115

2.67 Percentage Change in Total Cost vs. Load for Medium and High Transactive-Load Cases 2.116

2.68 Total Load in System vs. Total System-Wide Cost for the No-Transactive-Load Case, with No, Medium, and High Wind-Penetration Levels 2.117

2.69 Total Wind Output vs. Change in Total System-Wide Costs from the No-Wind Case, with No Transactive Load for Medium and High Wind-Penetration Cases 2.118

2.70 Total System-Wide Cost for a Day in the Summer Data Set, with No Transactive Load and 30% Transactive Load Penetration 2.121

2.71 Effect of Interaction of the High Transactive-Load Penetration with Wind Output..... 2.122

7.1 Layout of the Avista Utilities Test Groups Overlaid on their Distribution Circuits in Pullman, Washington..... 7.2

7.2 Pullman, Washington, Distribution Circuits 7.4

7.3 The Avista Utilities Customer Equipment, Customer Web Portals, and Distribution Automation Systems were Highly Integrated 7.5

7.4 Head-End Phase Voltages on Turner Feeder 111 7.9

7.5 Average of Head-End Phase Voltages at Turner Feeder 111 7.10

7.6 Average of Head-End Phase Voltages at Pullman Site Feeders 7.13

7.7 Averaged End-of-Line Phase Voltages from Turner Feeder 111 7.14

7.8 Averaged End-of-Line Phase Voltages from Turner Feeder 111 7.18

7.9 Real and Reactive Power Time Series for Turner Feeder 111..... 7.19

7.10 Real and Reactive Power Time Series for Pullman Site Feeders..... 7.22

7.11 Series of Temperature Data from Weather Station KPUW at the regional Pullman-Moscow Regional Airport..... 7.23

7.12 Monthly Counts of Capacitor Switching Operations, South Pullman Feeders 7.24

7.13 Histogram of Averaged Per-Unit Phase-Voltage Measurements for Turner Feeder 111 during 2014..... 7.25

7.14 Histograms of the Averaged Per-Unit Phase-Voltage Measurements for 12 Pullman Site Feeders during 2014..... 7.28

7.15 Quartile Distributions of Average Head-End Phase Voltages at Turner Feeder 111..... 7.29

7.16 Quartile Distributions of Average Head-End Phase Voltages when the Integrated Volt/VAr System is Normal and Active 7.32

7.17 Calculated Power Factor for Turner Feeder 111..... 7.33

7.18 Calculated Power Factors for Pullman Site Feeders..... 7.36

7.19 Quartile Distributions of Calculated Power Factor by Project Year for Turner Feeder 115..... 7.37

7.20 Quartile Distributions of Power Factor of Turner Feeder 111 when the IVVC System was Active and Not 7.38

7.21 Quartile Distributions of Power Factor of Pullman, Washington, Feeders when the Feeder’s IVVC System was Active and Not..... 7.41





7.22 Calculated Reduction in Distribution Energy Losses on Two Pullman, Washington, Distribution Feeders each Month..... 7.56

7.23 Subsystems that had to be Integrated to Complete Avista Utilities’ Smart Thermostat System..... 7.61

7.24 Comparison of the Average Power of Premises that Received Residential Load Control Devices and Others that Did Not, by Season..... 7.63

7.25 Average Residential Premises Power Data Collected from Avista Utilities Concerning Customers that had Received STP Thermostats 7.64

7.26 Utility and Transactive System Events by Year and Calendar Month..... 7.65

7.27 Counts of Advised Transactive System Event Intervals by the Months that those Intervals Occurred..... 7.66

7.28 Relative Distribution of Advised Transactive System Event Intervals by the Days of Week that those Intervals Occurred..... 7.67

7.29 Relative Distribution of Advised Transactive System Event Intervals by the Hours of Day that those Intervals Occurred 7.68

7.30 Average Premises Power Data from Test and Baseline Residence Groups..... 7.74

7.31 Ambient Temperature Data from Station KPUW 7.75

7.32 Average Premises Powers of the Test and Baseline Groups as Functions of Ambient Temperature 7.76

7.33 Distribution of the Available Data for the Percent of AMI Meter Reads Completed by 2 AM..... 7.77

7.34 Monthly Average Energy Consumption by the Test and Baseline Premises..... 7.79

7.35 Monthly Average Premises Energies as a Function of Net Degree Days..... 7.81

7.36 Monthly SAIFI Reliability Index for the Combined 13 Pullman Site Feeders..... 7.85

7.37 Monthly SAIDI Reliability Index for the Combined 13 Pullman Site Feeders 7.86

7.38 Monthly CAIDI Reliability Index for the Combined 13 Pullman Site Feeders..... 7.87

7.39 Likelihood that the SAIFIs for the following Months are Significantly Lower than those in the Preceding Months 7.89

7.40 Likelihood that the SAIDIs for the following Months are Significantly Lower than those in the Preceding Months 7.90

7.41 Likelihood that the CAIDIs for the Following Months are Significantly Lower than those in the Preceding Months 7.91

7.42 Power Data Supplied to the PNWSGD by Avista Utilities from which WSU HVAC Fan Reductions were Analyzed 7.95

7.43 Power Time Series from 3 Hours Prior to the Reported Reduction in WSU HVAC Fan Load to 3 Hours after the Events 7.98

7.44 WSU Power Data as a Function of Time of Day, Grouped by Weekday and Season..... 7.99

7.45 Power Measurements and the Modeled Power Measurements that Resulted from Regression Analysis..... 7.100

7.46 Aggregated Power Data Time Series of 5-Minute Data Supplied to the Project Concerning the Controllable WSU Chiller Load..... 7.103





7.47 Aggregated Power Time Series for Days of June 2014, when the Events were Reported to have Occurred 7.104

7.48 Contour Plot of Aggregate Chiller Power as Functions of both the Local Hour and Ambient Temperature 7.105

7.49 Power Time Series from 3 Hours before Reported Events until 3 Hours after Reported Events..... 7.106

7.50 Power Generated by the WSU Diesel Generator 7.108

7.51 Distribution of Nonzero Power Levels that were Generated each Five Minutes by the WSU Diesel Generator 7.109

7.52 Histograms of Nonzero Power Levels Generated by the WSU Diesel Generator when the Transactive System was Actively Requesting Generation and Not..... 7.110

7.53 Contour Plot of Average Power Generation of the WSU Diesel Generator as a Function of Calendar Month and Local Hour of Day 7.111

7.54 Power Generated by the First WSU Natural Gas Generator..... 7.113

7.55 Power Generated by the Second WSU Natural Gas Generator 7.114

7.56 Distribution of Nonzero Power Levels that were Generated each Five Minutes by the First and Second WSU Natural Gas Generators 7.115

7.57 Histograms of Nonzero Powers Generated by the First and Second WSU Gas Generators when the Transactive System was Actively Requesting Generation and Not 7.116

7.58 Contour Plot of Average Power Generation of the First WSU Natural Gas Generator as a Function of Calendar Month and Local Hour of Day 7.117

7.59 Contour Plot of Average Power Generation of the Second WSU Natural Gas Generator as a Function of Calendar Month and Local Hour of Day 7.118

8.1 Benton PUD Layout Diagram..... 8.2

8.2 Counts of Meters Reporting Abnormal Temperature each Month 8.5

8.3 Distributions of Abnormal-Temperature Events by Calendar Year, Calendar Month, Day of Week, and Local Hour..... 8.6

8.4 Counts of Meters Reporting Abnormally Low Voltage Each Month 8.7

8.5 Distribution of Low-Voltage Events by Calendar Year, Calendar Month, Day of Week, and Local Hour 8.8

8.6 Counts of Meters Reporting Abnormally High Voltage Each Month 8.9

8.7 Distribution of High-Voltage Events by Calendar Year, Calendar Month, Day of Week, and Local Hour 8.10

8.8 Counts of Meters Reporting Power Outages each Month..... 8.11

8.9 Distribution of Outage Events by Calendar Year, Calendar Month, Day of Week, and Local Hour 8.13

8.10 Power Data Received from Benton PUD Concerning the Performance of Three 10 kW Energy Storage Modules..... 8.15

8.11 Power Data Received from Benton PUD Concerning the Sum Power Conversion at Two 1 kW Energy Storage Modules 8.16

8.12 Power Generation of the Three 10 kW Energy Storage Modules versus Local Pacific Time 8.17





8.13 Quartile Plot of the Charging and Discharging of the Benton PUD 10 kW Battery Energy Storage Module throughout the Project 8.18

8.14 Sum Power Generation of Two 1 kW Energy Storage Modules versus Local Pacific Time 8.19

9.1 Polycrystalline and Thin-Film Solar Panel Arrays at the City of Ellensburg Renewable Energy Park, Ellensburg, Washington 9.1

9.2 Wind Generators at the City of Ellensburg Renewable Energy Park, Ellensburg, Washington 9.2

9.3 Layout of Renewable Generation at the Ellensburg Renewable Energy Park 9.3

9.4 Arrays of Standard Polycrystalline PV Panels at the Ellensburg Renewable Energy Park 9.5

9.5 Power Curve Calculated for the 56 kW Polycrystalline PV Generator System..... 9.7

9.6 Average HLH and LLH Energy Production for the Polycrystalline PV Array by Calendar Month..... 9.9

9.7 Average Hourly Power Production of the 56 kW Polycrystalline PV System for All Project Hours 9.10

9.8 Average Hourly Production and Variability of Production of the 56 kW Polycrystalline PV System by Season 9.11

9.9 Arrays of Thin-Film PV Panels at the Ellensburg Renewable Energy Park..... 9.13

9.10 Average HLH and LLH Energy that is Generated each Calendar Month by the Thin-Film PV Array 9.16

9.11 Average Solar Power Generation by Hour and Season for the Thin-Film PV Array 9.17

9.12 Residential-Class Honeywell 1.5 kW Turbine Installed at the Ellensburg Renewable Energy Park..... 9.19

9.13 All Data Received Concerning Power Generation for the Honeywell WindTronics System..... 9.21

9.14 Generated Wind Power from the Honeywell WindTronics Wind System as a Function of the Wind Speed that was Measured at the Site at Height 36 Feet..... 9.22

9.15 Average HLH and LLH Energy by Calendar Month for the Honeywell WindTronics System..... 9.22

9.16 Average Power Generation by Hour and Season for the Honeywell WindTronics System 9.23

9.17 1.2 kW Windspire Wind Turbine at the Ellensburg Renewable Energy Park 9.24

9.18 Power Generation from July 2012 through January 2013 for the Windspire System..... 9.26

9.19 Characteristic Power Generation as a Function of Metered Site Wind Speed 36 Feet above the Ground for the Windspire System 9.27

9.20 Average Power Generation by Season and Pacific Time Zone Hour for the Windspire System..... 9.28

9.21 2.25 kW Home Energy International Energy Ball V200 at the Ellensburg Renewable Energy Park..... 9.30

9.22 Power Generated by the Energy Ball V200 Wind Generator by Month..... 9.32

9.23 Diurnal Wind Power Generation Patterns for the Four Seasons for the Energy Ball System..... 9.33



9.24 HLH and LLH Energy Generated Each Calendar Month by the Energy Ball V200 Wind Generation System..... 9.34

9.25 2.4 kW Skystream Wind System at the Ellensburg Renewable Energy Park..... 9.35

9.26 Wind Power Data Submitted by the City of Ellensburg for the Southwest Windpower System..... 9.37

9.27 Power Generated by the Southwest Windpower Skystream 3.7 System as a Function of Wind Speed at 85 Feet 9.38

9.28 Average Diurnal Wind Power Generation by Season for the Southwest Windpower Generator 9.39

9.29 Observed HLH and LLH Energy Generated Each Calendar Month by the Southwest Windpower Generator..... 9.40

9.30 10 kW Bergey Wind System at the Ellensburg Renewable Energy Park 9.42

9.31 Power Generation Data for the Bergey WindPower Excel 10..... 9.44

9.32 Characteristic Power Generation of the Bergey Windpower System as a Function of Wind Speed Measured at 85 Feet 9.45

9.33 Hourly Power Generation of the Bergey Windpower System for Each Season 9.46

9.34 Amounts of HLH and LLH Energy Generated each Calendar Month by the Bergey Windpower System..... 9.47

9.35 10 kW Tangarie Wind System Installed at the Ellensburg Renewable Energy Park..... 9.49

9.36 Collapsed Tangarie Wind System..... 9.49

9.37 Tangarie Wind System Power Generation for the Two Months of 2012 that Data was Available 9.51

9.38 Average Diurnal Power Generation for July and August 2012 while the Tangarie Wind Turbine was Operational..... 9.52

9.39 4 kW Urban Green Energy Wind System at the Ellensburg Renewable Energy Park 9.53

9.40 Power Generation for the Urban Green Energy Wind Turbine System..... 9.55

9.41 Average Diurnal Power Generation by Season for the Urban Green Energy System 9.56

9.42 HLH and LLH Energy Production for the Urban Green Energy System, for Months that Data was Available 9.57

9.43 10 kW Ventera Wind System at the Ellensburg Renewable Energy Park..... 9.59

9.44 Available Power Generation Data from January through October 2013 for the Ventera Wind System..... 9.60

9.45 Characteristic Power Generation as a Function of Wind Speed at 36 Feet for the Ventera Wind System..... 9.61

9.46 Hourly Power Generation Patterns by Season for the Ventera Wind System 9.62

9.47 HLH and LLH Energy Generated as a Function of Calendar Month for the Ventera Wind System..... 9.63

9.48 1.4 kW Wing Power Wind System at the Ellensburg Renewable Energy Park..... 9.65

9.49 Wind Power Generation Data Received by the Project for the Wing Power System..... 9.67

9.50 Hourly Generation Patterns by Season for the Wing Power System..... 9.68





10.1 The Libby and Marion/Kila Sites within the Flathead Electric Cooperative Service Region in the Flathead Valley, Montana 10.1

10.2 Flathead Electric Cooperative’s Communication and Interoperability Design for Their Project Assets..... 10.3

10.3 Layout of Flathead Electric Cooperative Asset Systems among the Two Sites and by Test Group 10.4

10.4 Aclara Model 110 In-Home Display of the Type Used by the Flathead Electric Cooperative Peak Time Project 10.11

10.5 Week Days on which Transactive Events were Advised to the In-Home Displays 10.15

10.6 Hours on which Transactive Events were Advised for the In-Home Displays..... 10.15

10.7 Averaged Load for Libby, Montana, Premises that have In-Home Displays Plotted against a Modeled Baseline of this Same Data for the Months of 2013 10.17

10.8 Measured Change in Power per Premises during Libby, Montana In-Home Display Peak Time Events 10.18

10.9 Measured Impact per Premises during Rebound Hours for Libby, Montana Premises having In-Home Displays Using the Modeled and Controlled Baselines..... 10.19

10.10 Measured Average Impact per Premises during Peak-Time Event Days for Libby, Montana Premises having In-Home Displays Using the Modeled and Controlled Baselines 10.20

10.11 Measured Average Impact per Premises during Event Days for Marion/Kila, Montana Premises having In-Home Displays Using the Modeled and Controlled Baselines 10.21

10.12 Aclara TWACS DRU that was Used to Cycle Water Heaters in the Flathead Electric Cooperative Peak-Time Project 10.24

10.13 Days of Week on which Transactive Events Were Advised for the Libby and Marion/Kila DRUs 10.29

10.14 Local Starting Hours of the Advised Transactive Events for the Libby and Marion/Kila DRUs 10.29

10.15 Average Impact of DRUs during Peak Time Events by Month at the Libby Site Using the Modeled and Controlled Baselines 10.31

10.16 Averaged Monthly DRU Rebound Impacts per Premises at the Libby Site Based on the Modeled and Controlled Baselines 10.32

10.17 Averaged Monthly DRU Rebound Impacts per Premises at the Libby Site Based on the Modeled and Controlled Baselines 10.32

10.18 Averaged Monthly DRU Impacts per Premises at the Libby Site throughout Entire Days that Peak Time Events had Occurred, Based on the Modeled and Controlled Baselines 10.33

10.19 Averaged Monthly DRU Impacts per Premises at the Marion/Kila Site throughout Days that Peak Time Events had Occurred, Based on the Modeled and Controlled Baselines 10.34

10.20 Average Premises Power for Libby DRU Owners Leading Up to and Following the Second Event 10.35

10.21 GE Nucleus™ Home Energy Gateway that was Used in the Flathead Electric Cooperative Peak Time Project 10.38

10.22 Example GE Home Energy Gateway Display 10.38





10.23 Example Web Portal Screen Available to Premises that Used the GE System of Communicating Appliances..... 10.39

10.24 Days on which Transactive Events were Advised for the Group-D Premises in Libby and Marion/Kila..... 10.44

10.25 Hours on which Transactive Events were Advised for the Group-D Premises in Libby and Marion/Kila..... 10.44

10.26 Change in Premises Power by Month during both On-Peak and Off-Peak Events at the Libby Site According to the Modeled and Controlled Baselines..... 10.45

10.27 Change in Premises Power by Month during the Rebound Hour Following Events at the Libby Site According to the Modeled and Controlled Baselines..... 10.46

10.28 Change in Premises Power by Month during Following Event Days at the Libby Site According to the Modeled and Comparison Baseline Approaches 10.47

11.1 Idaho Falls Power Layout Diagram, Page 1 11.3

11.2 Idaho Falls Power Layout Diagram, Page 2 11.4

11.3 Managed Per-Unit Feeder Voltage during the Project..... 11.7

11.4 Per-Unit End-of-Line Voltage Measurements 11.8

11.5 Reported Per-Unit Target Voltages in 2014 11.9

11.6 Feeder Power Data..... 11.10

11.7 Feeder Voltage Plotted Against Target Feeder Voltage 11.11

11.8 Histogram of 2014 Feeder Voltages 11.12

11.9 Calculated Cooling and Heating Regimes by Hour, Based on Feeder Power 11.13

11.10 Tap Changes per Hour 11.17

11.11 Residential Low-Voltage Alarms per Hour 11.18

11.12 Residential High-Voltage Alarms per Hour..... 11.18

11.13 Sum Reactive Power by Month and Year for Available Data from the Two Feeders with Power Factor Control..... 11.21

11.14 Total Real Power by Month and Year for Available Data from the Two Feeders with Power Factor Control..... 11.22

11.15 Power Factors Provided by the Utility versus Power Factors Calculated from Feeder Data for the Two York Feeders 11.23

11.16 Histograms of York Feeder Power Factors Before and After Early December 2013..... 11.24

11.17 Average Premises Power for the 213 Idaho Falls Power Customers Who Received Water Heater Load Controllers..... 11.28

11.18 Count of Test Events According to the Events’ Calendar Month..... 11.30

11.19 Count of Test Events According to the Day they Started 11.31

11.20 Count of Test Events According to the Local Hour they Began..... 11.32

11.21 Percentage of Premises Reported to have Opted Out of Water Heater Events Each Hour..... 11.33

11.22 Idaho Falls Power Battery Storage and PV Array 11.35

11.23 Seasonal Weekday Premises Power for the Idaho Falls Power Residents that had Project Thermostats..... 11.38





11.24 Power per Premises for Residences that Received Project Thermostats 11.39

11.25 Relative Occurrences of Average Premises Power Levels for Residences that Received Project Thermostats 11.40

11.26 Weekdays of Events that Occurred after September 2013..... 11.41

11.27 Count of All Thermostat Events by Calendar Month 11.41

11.28 Count of Events after September 2013 by Their Local Starting Hour..... 11.42

11.29 Percentage of Residents Opting Out of Thermostat Events in a Given Hour from December 2013 through much of March 2014 11.46

11.30 Monthly and 5-Minute Data Made Available to the Project by Idaho Falls Power..... 11.49

11.31 Temperature Data Available to the Project at the Idaho Falls Site 11.50

11.32 Measured Premises Energy Usage from Regression Models of the Test and Comparison Groups from Before and After February 2013 Plotted against the Net Degree-Days that Month..... 11.51

11.33 Monthly Premises Energy Use from Regression Models of the Test and Comparison Groups from Before and After February 2013 Plotted against the Net Degree-Days that Month..... 11.52

12.1 Lower Valley Energy Sites 12.2

12.2 Layout of Lower Valley Energy Test Groups and Asset Systems on their Distribution System..... 12.4

12.3 Bondurant Site where SVC, Solar PV, Wind, and Battery Systems Resided..... 12.5

12.4 Representative Average Per-Premises Power by Season for Lower Valley Energy Cooperative Members..... 12.5

12.5 Average Premises Power of the Test Group that Received In-Home Displays 12.8

12.6 Monthly Average Premises Power for Premises that have Both Advanced Meters and In-Home Displays..... 12.9

12.7 Monthly Average Premises Power for Premises that have Advanced Meters, DRUs, and In-Home Displays 12.10

12.8 Impact of Installing Advanced Premises Metering on Average Premises Power by Calendar Month 12.11

12.9 Change in Premises Power from Installation of Both Advanced Metering and IHDs by Calendar Month 12.12

12.10 Distributions of the Months that DRUs were Truly Engaged and Transactive System DRU Engagements were Advised..... 12.15

12.11 Distributions of Weekdays that the Lower Valley Energy DRUs were Reported to Have Been Engaged and the Transactive System Advised the DRU System to Become Engaged... 12.15

12.12 Histogram of Event Durations for Lower Valley Energy DRU Engagements 12.16

12.13 Local Hours that DRU Engagements..... 12.17

12.14 Average Impact on Premises Power Observed during DRU Curtailment Events Each Project Month According to the Comparison and Modeled Baselines 12.18

12.15 Average Impact during Rebound Hours each Project Month using the Comparison and Modeled Baselines 12.19





12.16 Average Impact throughout Days that DRU Events Occurred Using the Comparison and Modeled Baselines 12.20

12.17 Cumulative System Energy Impact and Cumulative Customer Event Hours throughout the Project 12.21

12.18 Cumulative Impact on System Energy Plotted against Cumulative Customer Hours 12.22

12.19 Quartile Plots of Calculated SAIFI for 16 Lower Valley Energy Distribution Feeders by Year..... 12.25

12.20 Quartile Plots of Calculated SAIDI for 16 Lower Valley Energy Distribution Feeders by Year..... 12.26

12.21 Quartile Plots of Calculated CAIDI for 16 Lower Valley Energy Distribution Feeders by Year..... 12.28

12.22 East Jackson Diurnal Distribution Feeder Weekday Load by Season 12.30

12.23 Per-Unit Feeder Voltages and their Reported Statuses 12.31

12.24 Magnified Part of Per-Unit Voltage Distribution that Shows Reduced-Voltage Occurrences 12.32

12.25 Quartile Plots of all the Measured Per-Unit Feeder Voltages at the Normal and Reduced-Voltage Settings 12.33

12.26 Distribution of the 37 Event Months that Lower Valley Energy Reduced the Voltage on the East Jackson Feeder 12.35

12.27 Distribution of Weekdays that Lower Valley Energy Reduced East Jackson Feeder Voltage..... 12.36

12.28 Distribution of Hours that Voltage-Reduction Events Began..... 12.37

12.29 Cumulative Energy Impact and Cumulative Event Hours when Distribution Voltage was Reported to have been Reduced..... 12.39

12.30 Cumulative Energy Impact as a Function of Cumulative Event Hours 12.40

12.31 Cumulative Energy Impact and Customer Hours at Premises that were Affected by Dynamic Voltage Reductions 12.41

12.32 Cumulative Premises Energy Impact as a Function of Cumulative Customer Event Hours 12.41

12.33 300 kVAr SVC at the Bondurant, Wyoming, Site 12.43

12.34 Averaged Per-Unit Feeder Voltage for the Hoback Feeder that was Affected by the Project’s SVC 12.45

12.35 Reactive Power Levels of the Three Hoback Feeder Phases that were Affected by the Project’s SVC 12.46

12.36 Three-Phase Power Factors at Hoback Substation that were Affected by the Project’s SVC..... 12.47

12.37 Feeder Reactive Power for the Hoback Feeder that was Affected by the Project’s SVC..... 12.48

12.38 Feeder Power for the Hoback Feeder that was Affected by the Project’s SVC..... 12.49

12.39 Averaged Feeder Reactive Power with the SVC Inactive and Active under the Lower and Higher Voltage Strategies 12.50

12.40 Feeder Power Factor with the SVC Inactive and Active Under the Lower and Higher Voltage Strategies 12.51



12.41 Output of the Transactive Function that advised the Battery System when to Charge and Discharge 12.54

12.42 Power Data as the Battery System is Charged and Discharged during Spring and Early Summer 2014..... 12.55

12.43 Correlation of Battery System Charging and Discharging to the Output of the Transactive System Function that Advised the System when to Charge and Discharge 12.56

12.44 Quartile Battery Power each Hour of the Day from March 20 through July 2014 12.57

12.45 Average Battery Charge or Discharge Rates each Hour for the Period from March 20 through July 2014 12.58

12.46 Battery System Cumulative Energy Intake over its Operating Hours 12.59

12.47 Lower Valley Electric Cooperative Solar and Wind Site near their Bondurant Substation..... 12.62

12.48 Complete Series of Solar Generation Power Data Received by the Project from Lower Valley Energy 12.64

12.49 Solar Power by Local Hour and by Project Month after Filtering Out Early 2012 and Later 2014 Data 12.65

12.50 Hourly Solar Power Generation by Seasons 12.66

12.51 Wind Generation Reported to the Project by Lower Valley Energy 12.70

13.1 Layout of Milton-Freewater Test Populations in Relation to One Another and the City’s Distribution Feeders..... 13.2

13.2 Seasonal, Per-Premises Load Shapes for the Homes among the Milton-Freewater DRU Test Groups..... 13.4

13.3 Averaged Monthly Power for Summed Feeders 1–4, 5–13, and 7–10 13.5

13.4 Days and Durations of Milton-Freewater DRU System Events during the Term of the PNWSGD Project 13.8

13.5 Months in which DRU Events were Called by Milton-Freewater 13.9

13.6 Local Starting Hours when DRU Events were Called by Milton-Freewater 13.10

13.7 DRU Curtailment Event from November 1, 2013 13.11

13.8 DRU Curtailment Event from July 16, 2014 13.12

13.9 DRU Curtailment Event from July 15, 2014 13.13

13.10 Advised Transactive DRU Events by Day of Week 13.14

13.11 Advised Transactive DRU Events by Hour 13.14

13.12 Cumulative Sums over Time of Customer Hours and Total Analyzed Change in Energy during Event for the 185 Events in this Analysis..... 13.17

13.13 Cumulative Energy Impact versus. Cumulative Customer Hours for the Milton-Freewater DRUs during the Term of the PNWSGD 13.18

13.14 Event Statistics by Project Month Based on the Modeled Baselines for Feeders 1–4 and Feeders 5–13 13.19

13.15 Event Statistics by Project Month Based on the Controlled Baselines for Feeders 1–4 and Feeders 5–13 13.20

13.16 Rebound-Hour Statistics by Project Month Based on the Modeled Baselines for Feeders 1–4 and Feeders 5–13 13.21





13.17 Rebound-Hour Statistics by Project Month Based on the Controlled Baselines for Feeders 1–4 and Feeders 5–13 13.22

13.18 Event-Day Statistics by Project Month Based on the Modeled Baselines for Feeders 1–4 and Feeders 5–13 13.23

13.19 Event-Day Statistics by Project Month Based on the Controlled Baselines for Feeders 1–4 and Feeders 5–13 13.24

13.20 Correlation between Periods when the Average Distribution Voltage on Feeders 5–13 is Reduced Versus the Periods when it is Reported to have been Reduced 13.28

13.21 Per-Unit Distribution Voltages on Feeders 5–13 after Two Periods having an Intermediate Voltage were Removed..... 13.29

13.22 Durations of the Inferred Events when Voltage had been Reduced on Feeders 5–13 13.30

13.23 Days of Week that Inferred and Advised Transactive Voltage Reductions were Initiated..... 13.31

13.24 Hours that Inferred and Advised Transactive Voltage Reductions were Initiated..... 13.31

13.25 Monthly and Project Power Impact on Feeders 5, 6, 11, 12 and 13 while Voltage was Reduced and Using the Modeled and Controlled Baselines 13.33

13.26 Monthly and Project Rebound-Hour Power Impact on Feeders 5, 6, 11, 12 and 13 Using the Modeled and Controlled Baselines 13.34

13.27 Monthly Averaged Event-Day Power Impacts on Feeders 5, 6, 11, 12 and 13 Using the Modeled and Comparison Baselines..... 13.35

13.28 Power Curtailed per Voltage-Responsive DRU Premises by Month and for the Entire Project using the Modeled and Controlled Baseline..... 13.39

13.29 Average Rebound Power of the Premises that Had Voltage-Responsive Water Heaters in the Hours following Events using the Modeled and Controlled Baselines..... 13.40

13.30 Test Group Per-Premises Power and its Controlled and Modeled Baselines on August 27, 2014..... 13.41

13.31 Change in Average Per-Premises Power Consumption on Days that Voltage had been Reduced Using the Modeled and Controlled Baselines..... 13.42

13.32 Average Per-Unit Voltage on CVR Feeders 1–4 by Project Year, Month, and CVR Status.... 13.46

13.33 Observed CVR Change in Per-Unit Voltage by Project Month when Voltage is Reduced and Normal 13.47

13.34 Example Aggregated Experimental and Baseline Feeder Power Data from 2014 that was Used to Analyze the Impact of CVR at Milton Freewater..... 13.50

13.35 Change in Total Power on Feeders 1–4 Attributable to CVR each Project Month 13.51

13.36 Total Change in Power Attributable to CVR on Feeders 1–4 By Hour and Weekday and Weekend 13.52

14.1 NorthWestern Energy Tests Overlaid on the Helena, Montana and Philipsburg, Montana Distribution Circuits..... 14.2

14.2 Head-End Phase “A” and Phase “B” Voltages Plotted Against the Phase “C” Voltage for the South Side and East Side Circuits..... 14.5

14.3 End-of-Line Per-Unit Phase Voltages as a Function of the Corresponding Head-End Per-Unit Phase Voltages on the South Side Circuit..... 14.8





14.4	Average Head-End Phase Voltages for the South Side Circuit, Including the Simplified IVVC Status for that Circuit	14.9
14.5	Average Head-End Phase Voltages for the East Side Circuit, Including the Simplified IVVC Status for that Circuit	14.10
14.6	Total Real and Reactive Loads on the South Side Circuit	14.11
14.7	Total Real and Reactive Loads on the East Side Circuit	14.12
14.8	Quartile Plots of the Average Per-Unit Head-End Phase Voltages at the South Side and East Side Circuits during their Respective Evaluation Periods	14.13
14.9	Average Premises Power of the DR Golf Course and West Side Test Groups as Functions of Hour of Day	14.20
14.10	Average Premises Power Consumption of Golf Course DR Premises and West Side DR Premises for the Days before, on, and after August 28, 2014, when NorthWestern Conducted DR Tests	14.22
14.11	Head-End Distribution Voltages from Phases “A” and “B” Plotted against the Corresponding Voltage of Phase “C”	14.25
14.12	Average Head-End Per-Unit Phase Voltage for the Philipsburg Feeder that was Under IVVC Control	14.26
14.13	Distribution of the Average Head-End Per-Unit Voltages on the Philipsburg Feeder from March through July 2014 while Voltage Appeared to Have Been Managed.....	14.27
14.14	Real and Reactive Power on the Philipsburg Feeder	14.28
14.15.	Quartile Plot of the Philipsburg Average Head-End Phase Voltages when the IVVC System was Inferred to be Engaged and Not Engaged	14.29
14.16	Filtered Load Power for the Philipsburg Circuit during the Evaluation Period.....	14.30
15.1	Aerial View of Fox Island, Gig Harbor, and Vicinity	15.1
15.2	Layout of the Test Groups and Assets on the Fox Island, Washington, Distribution Circuit	15.3
15.3	Time Series of Daily Mean Power for Premises Test Group that Received Load-Control Modules	15.6
15.4	Total Hourly Distribution Power Measurements and Reported LCM System Status.....	15.7
15.5	Percentage of Calendar Months that LCM Events were Conducted.....	15.8
15.6	Days of the Week that LCM Events were Conducted	15.9
15.7	Local Pacific Time Hour that LCM Events Started.....	15.10
15.8	2013 and 2014 Test-Group Average Daily Premises Power as a Function of the Average Daily Outdoor Temperature.....	15.11
15.9	Average Daily Power of Test-Group Premises, which Received LCMs, and a Candidate Control Group, both as Functions of Outdoor Temperature	15.12
15.10	Average Premises Power on LCM Event and Non-Event Days as Function of Temperature	15.13
15.11	Power Difference: Premises Power During Event Days Less the Temperature-Modeled Power from Non-Event Days.....	15.14
15.12	Average Hourly Distribution Power from Artondale Substation as a Function of Temperature and LCM System Status	15.15





15.13	Average Distribution Feeder Per-Unit Phase Voltage	15.18
15.14	Average Hourly Distribution Feeder Power	15.19
15.15	Average Hourly Distribution Feeder Reactive Power	15.20
15.16	Quartile Plots of Average Per-Unit Distribution Feeder Voltage According to the CVR System Status	15.21
15.17	Monthly SAIDI Values	15.23
15.18	Outage Response Times by Month	15.24
15.19	Peninsula Light Company’s Monthly Restoration Costs during the Project	15.25
15.20	Student’s T-Test Confidence that SAIDI in the Following Months is Smaller than in Prior Months	15.26
15.21	Student’s T-Test Confidence over Time that the Following Month’s Response Times Were Shorter than in Prior Months	15.27
15.22	Confidence Levels when Comparing Restoration Costs before and After Each Project Month	15.28
16.1	Layout of the Portland General Electric Asset Systems on Their South Salem, Oregon, Distribution Circuit	16.3
16.2	Artificial Intelligence was Incorporated into the Smart Power Platform that Engaged the Project’s Transactive Assets	16.5
16.3	Average Power of Commercial Premises	16.8
16.4	Averaged Weekday Diurnal Load Pattern for the Monitored Commercial Premises	16.9
16.5	Distributed Power Generation Reported to the Project by Portland General Electric	16.12
16.6	One of 20 Modular Battery System Racks at the Salem Smart Power Center	16.14
16.7	Eaton Inverters and Isolation Transformer at the Salem Smart Power Center	16.15
16.8	Power Discharged from or Charged into the Battery System	16.17
16.9	Stored Energy and the Charge or Discharge Battery Power from Spring and Summer 2014	16.18
16.10	Battery Power and Stored Energy for Days of July 2014	16.19
16.11	Battery Power and Stored Energy July 9–11, 2014	16.19
16.12	Discharge and Charge Power as Functions of Transactive Incentive Signal Magnitude and Reported System Availability	16.20
16.13	Plot of Battery Power versus its State of Charge that Reveals an Operational Strategy	16.21
16.14	Cumulative Energy Exchanged by the Battery System from Late 2013 to the End of the Project	16.22
16.15	Average Charging and Discharging Power as a Function of Hour of Day	16.23
16.16	Footprint of the Salem Smart Power Project, Salem, Oregon, including its Potential Microgrid Resources and Switches	16.25
16.17	Oxford Rural Feeder High-Reliability–Zone Block Diagram	16.26
17.1	Layout of UW Test Cases	17.2
17.2	Reported Engagement Status of the UW Steam Turbine Generator	17.4
17.3	Output of the 5 MW UW Steam Turbine Generator	17.5





17.4 Reported Engagement Status for Two Diesel Generators..... 17.7

17.5 Diesel Generator Power Output during 2013 and 2014..... 17.8

17.6 Quartile Plots of the Nonzero Power that was Generated by the Test and Control
Generators during 2013 and 2014 by Hour of Day..... 17.9

17.7 Total Power Produced by the UW PV Panels..... 17.11

17.8 Real Power Output of Photovoltaic Panels during the Narrowed Analysis Period of 2013
and 2014..... 17.12

17.9 Example Plot from July 26, 2013 Showing Anomalous Nighttime PV Generation..... 17.13

17.10 Average Hourly Solar Power Generation during Winter, Spring, Summer, and Fall
Seasons..... 17.14

17.11 Reported Engagement Status of the Buildings with DDCs 17.18

17.12 Total Power Consumed by the UW Buildings with DDCs during the PNWSGD..... 17.19

17.13 Histogram of Local Pacific Time Zone Hours in which Tier 3 Event Periods Occurred
during the PNWSGD 17.20

17.14 Power Consumption of Buildings with Advanced Metering Displays and EnergyHub
Devices and of a Set of Six Control Buildings that Have No Advanced Metering Displays
or EnergyHub Devices..... 17.23

17.15 Regression Analysis of the Poplar Building with its Advanced Metering Displays and
EnergyHub Devices during Pretreatment and Post-Treatment Periods 17.24

17.16 Snapshot of the UW Energy Dashboard 17.27

B.1 Regional and Subproject Transactive Nodes and Network Topology





Tables

1.1	Site Owners, Sites, and Asset Systems of the PNWSGD	1.5
1.2	Data Statistics	1.8
2.1	Range of the Modeled Changes in Load by the Various Elastic Transactive Assets at the PNWSGD Project Sites.....	2.79
2.2	Comparison of Average Metered Power at the Fox Island Site and Its Representation by the Transactive Feedback Signal for the Eight Project Months of 2014.....	2.86
2.3	Comparison of Average Metered Power at the University of Washington Site and Its Representation by the Transactive Feedback Signal for the Project Months of 2014	2.87
2.4	Comparison of Average Metered Power at the Portland General Electric Site and Its Representation by the Transactive Feedback Signal for the Project Months of 2014	2.88
2.5	Comparison of Average Metered Power at the Pullman, Washington Site and Its Representation by the Transactive Feedback Signal for the Eight Project Months of 2014.....	2.89
2.6	Comparison of Average Metered Power at the Philipsburg, Montana Site and Its Representation by the Transactive Feedback Signal for the Eight Project Months of 2014.....	2.90
2.7	Comparison of Average Metered Power at the Idaho Falls, Idaho Site and Its Representation by the Transactive Feedback Signal for the Eight Project Months of 2014.....	2.91
2.8	Seasonal Data Sets Used in Simulation	2.99
2.9	Wind-Generation Cases	2.100
2.10	Transactive-Load Penetration Cases.....	2.100
2.11	Maximum Observed Changes in Total System-Wide Load with Respect to the Base-Case Scenario	2.111
2.12	Maximum Observed Changes in Total System-Wide Load with Respect to a Base-Case Scenario that Had No Transactive Load	2.113
2.13	Linear-Regression and Correlation Coefficients for No-Wind Cases for All Seasons and Medium and High Transactive Penetration Levels.....	2.114
2.14	Linear-Regression and Correlation Coefficients between Change in Total System-Wide Costs from the No-Wind Case and Medium and High Wind-Generation Outputs, for Various Transactive Load Penetration Levels	2.119
2.15	Correlations between Medium and High Wind-Penetration Cases and Observed Values from the No-Wind Case	2.120
2.16	Linear-Regression and Correlation Coefficients Modeling Percent Change in Total Cost in 10% or 30% Transactive-Load Cases as a Function of the Scaled Total Cost in the No-Transactive-Load Case for 10% and 30% Wind-Penetration Scenarios.....	2.123
3.1	Premises Meter Counts and Data Intervals by Utility.....	3.2
3.2	Seasonal Nameplate Capacity, Energy Production, and Capacity Factor for the Demonstrated Solar Generation Systems.....	3.6
3.3	Seasonal Nameplate Capacity, Energy Production, and Capacity Factor for City of Ellensburg Wind Turbine Systems	3.8
4.1	Responsive Asset System Implementations at Transactive System Sites.....	4.2





4.2 Transactive Asset System Costs Deployed by the Utilities 4.3

4.3 Costs of the Centralized Parts of the Project’s Transactive System 4.4

4.4 Summary of Demand-Charge Results..... 4.5

4.5 Asset System Response Summaries..... 4.7

5.1 Distribution System Reliability Indices 5.2

7.1 Representative Data Offered by Avista Utilities to the PNWSGD Project 7.3

7.2 Components and Annualized Component Costs of the Avista Utilities IVVC System..... 7.7

7.3 Summary of Estimated Volt/VAr Management Impacts using Method 3 7.43

7.4 Summary of Feeder CVR Metrics 7.45

7.5 Summary of the Observed Changes in Power Factor and the Inferred Impacts from Power Factor Correction on the Pullman Feeders..... 7.53

7.6 Components and Annualized Component Costs of the Avista Utilities Reconductoring Effort..... 7.55

7.7 Components and Annualized Component Costs of the Avista Utilities System of Smart Transformers..... 7.57

7.8 Components and Annualized Component Costs of the Avista Utilities Communicating Thermostat System..... 7.62

7.9 Counts of Thermostat DR Events that were Initiated by Avista Utilities and the Transactive System, as Reported by Avista Utilities 7.64

7.10 Survey Responses to the Question, “During the STP Program were you able to detect when Avista made set point changes?” 7.69

7.11 Survey Responses to the Question, 7.70

7.12 Components and Annualized Component Costs of the Avista Utilities System of Advanced Premises Metering Displays 7.72

7.13 Count of Avoided Truck Rolls Reported by Avista Utilities for Project Months..... 7.78

7.14 Average Premises Energy Consumption of the Test and Baseline Groups over Three Consecutive Project Years 7.80

7.15 Components and Annualized Component Costs of the WSU Bio-Tech Generator System..... 7.82

7.16 Components and Annualized Component Costs of the Avista Utilities FDIR System 7.84

7.17 Recloser Operation Counts by Season for Three Representative South Pullman Feeders 7.88

7.18 System Components and Annualized Costs for the Combined WSU System..... 7.92

7.19 Times and Durations of the Twelve Events when WSU HVAC Fan Usage was Reduced 7.94

7.20 Estimated Impacts on Power and Energy during Times that the HVAC Fan Usage was Reduced, by Month and for All Months 7.101

7.21 Starting Times and Durations of the Five Events Reported to the Project Concerning WSU Controllable Chiller Loads..... 7.102

7.22 Generation Events that were Initiated by the Transactive System for the WSU Diesel Generator 7.108

7.23 Generation Events that were Initiated by the Transactive System for the First WSU Natural Gas Generator 7.112





8.1 Names Used for the Data Series that were Submitted to the PNWSGD Project by Benton PUD 8.3

8.2 Estimated Annualized Costs of the DataCatcher System 8.4

8.3 Yearly Reliability Indices over a Five-Year Period..... 8.4

8.4 Estimated Annualized Costs of Demand Shifter System..... 8.14

9.1 Existing and New Renewable Solar and Wind Generation 9.4

9.2 Annualized Costs of the 56 kW Polycrystalline Flat-Panel PV System 9.6

9.3 Average Monthly Power Generation and Value of Displaced Supply According to BPA Load Shaping Rates for the Polycrystalline PV Array 9.8

9.4 Typical Monthly Impacts on Demand Charges Based on Example Peak Hours Each Month for the Polycrystalline PV Array 9.12

9.5 Annualized Costs of the Flat Thin-Film Solar Panel System 9.14

9.6 Displaced HLH and LLH Supply Energy Consumptions and Costs, Based on BPA Load-Shaping Rates for the Thin-Film PV Array 9.15

9.7 Impact on Peak Demand Determinants and Demand Charges from Thin-Film PV System 9.18

9.8 City of Ellensburg Costs of 1.5 kW Honeywell WindTronics System..... 9.20

9.9 Energy Generated Each Month and the Value of Supply Energy that it Displaced for the Honeywell WindTronics System 9.23

9.10 City of Ellensburg Costs of 1.2 kW Windspire Wind Turbine System 9.25

9.11 Monthly Energy Production and the Monetary Value of the Energy Supply Displaced by the Windspire Generator 9.29

9.12 City of Ellensburg Costs of 2.25 kW Home Energy International Energy Ball V200 System..... 9.31

9.13 Typical Calendar Month Energy Generation and its Monetized Value for the Energy Ball System..... 9.34

9.14 City of Ellensburg Costs of the 2.4 kW Southwest Windpower Skystream 3.7 System 9.36

9.15 Typical Energy Generated Each Month and the Monetary Value of the Displaced Energy for the Southwest Windpower System..... 9.41

9.16 Typical Monthly Impact of Generation on Peak Demand for the Southwest Windpower System..... 9.41

9.17 City of Ellensburg Costs of 10 kW Bergey WindPower Excel 10 System..... 9.43

9.18 HLH and LLH Energy Generation for Each Month and the Value of the Energy Supply that it Displaced for the Bergey Windpower System..... 9.47

9.19 Estimated Monthly Impact on Peak Demand for the Bergey WindPower System..... 9.48

9.20 City of Ellensburg Costs of 10 kW Tangarie Alternative Power Gale Wind Turbine System..... 9.50

9.21 Quantities of HLH and LLH Energy Generated During the Two Months of Operation for the Tangarie System..... 9.52

9.22 Impact on Peak Demand for the Two Months of Operation of the Tangarie System..... 9.53

9.23 City of Ellensburg Costs of 4 kW Urban Green Energy Wind Turbine System..... 9.54



9.24	Energy and Monetary Value of Displaced Energy Supply by Calendar Month for the Urban Green Energy System	9.57
9.25	Impact of Generation on Peak Demand for the Urban Green Energy System.....	9.58
9.26	City of Ellensburg Costs of 10 kW Ventera Wind Turbine System	9.59
9.27	Monthly HLH and LLH Energy Production and the Monetary Value of Displaced Supply Energy for the Ventera Wind System	9.63
9.28	Impact of Generation on Peak Demand for the Ventera Wind System	9.64
9.29	City of Ellensburg Costs of 1.4 kW Wing Power Wind Turbine System.....	9.66
9.30	Generated Energy and the Value of the Supply that it Displaced for the Wing Power System.....	9.69
9.31	Projected Annual Energy Generation and Monetized Value of the Energy for each Technology	9.70
9.32	The City of Ellensburg’s Assessment of Generated Renewable Energy and the Effective Unit Cost of the Renewable Energy.....	9.73
10.1	Annualized Costs of Group-A Advanced Metering Infrastructure at the Libby, Montana, Site	10.7
10.2	Annualized Costs of Group-A Advanced Metering Infrastructure at the Marion/Kila, Montana Site	10.7
10.3	Reliability Indices for Affected Flathead Electric Cooperative Feeders from September 1, 2011 to October 16, 2013.....	10.8
10.4	Counts and Causes of Feeder Outages from September 1, 2011 to October 16, 2013	10.9
10.5	Incremental Annualized Costs of Installing and Operating 90 In-Home Displays at the Libby, Montana, Site.....	10.12
10.6	Incremental Annualized Costs of Installing and Operating 12 In-Home Displays at the Marion/Kila, Montana, Site	10.12
10.7	Starting Times and Durations of the Libby, Montana, In-Home Display Peak-Time Events.....	10.14
10.8	Starting Times and Durations of the Marion/Kila, Montana, In-Home Display Peak-Time Events.....	10.14
10.9	Estimated Energy Curtailed by In-Home Display Premises each Calendar Month and the Supply Value of that Energy as the In-home Display Premises Responded to Peak Time Events.....	10.22
10.10	Estimated Impact of the System of Libby In-Home Displays on the Demand Charges that are Incurred each Month by Flathead Electric Cooperative.....	10.23
10.11	Flathead Electric Incremental Costs of DRUs at the Libby Site.....	10.25
10.12	Flathead Electric Incremental Costs of DRUs at the Marion/Kila Site	10.25
10.13	DRU Peak-Time Event Starting Times and Durations at the Libby Site.....	10.27
10.14	DRU Peak-Time Event Starting Times and Durations at the Marion/Kila Site.....	10.28
10.15	Estimated Energy Curtailed by Premises with DRUs each Calendar Month and the Supply Value of that Energy as the DRU Premises Responded to Peak Time Events	10.36
10.16	Estimated Impact of the System of Libby DRUs on the Demand Charges that are Incurred each Month by Flathead Electric Cooperative.....	10.37



10.17	Incremental Annualized Costs of Demand-Response Appliances at the Libby, Montana, Site	10.40
10.18	Incremental Annualized Costs of Demand-Response Appliances at the Marion/Kila, Montana, Site	10.41
10.19	Peak-Time Event Times and Durations for the Libby, Montana, Demand-Response Appliances	10.42
10.20	Peak-Time Event Times and Durations for the Marion/Kila, Montana, Demand-Response Appliances	10.43
10.21	Estimated Energy Curtailed by Premises with Communicating Appliances each Calendar Month and the Supply Value of that Energy as the Premises Responded to Peak Time Events.....	10.48
10.22	Estimated Impact of the System of Libby Communicating Appliances on the Demand Charges that are Incurred each Month by Flathead Electric Cooperative	10.49
11.1	Data Notation Shorthand used by the Project in Layout Diagram Figure 11.1 and Figure 11.2	11.2
11.2	Idaho Falls Power Costs of Voltage Management System	11.6
11.3	Total Measured Power Impact when Voltage was Reduced.....	11.14
11.4	Estimated Impact on HLH and LLH Energy Usage and Energy Cost Impacts, based on the period August 2013 – July 2014	11.15
11.5	Estimated Changes in the Peak Demand Determinant and Resulting Demand Charges, based on the period August 2013–July 2014	11.16
11.6	Idaho Falls Power Costs of Power Factor Control System.....	11.20
11.7	Idaho Falls Power Costs of Distribution Automation System	11.25
11.8	Yearly Reliability Indices Reported to the Project by Idaho Falls Power	11.26
11.9	Idaho Falls Power Costs of Water Heater Control System.....	11.27
11.10	Results of Many Unfruitful Analysis Investigations that were Attempted for Water Heater Curtailments.....	11.34
11.11	Idaho Falls Power Costs of PHEV, Solar, and Battery Storage System	11.36
11.12	Idaho Falls Power Costs of Thermostat Control System	11.37
11.13	Average Change in Premises Power During Thermostat Events by Calendar Month, Based on the Period from December 2013 through August 2014	11.43
11.14	Total HLH and LLH Energy Impact and Value of Avoided Supply Energy, Based on the Period from December 2013 through August 2014.....	11.44
11.15	Estimated Demand-Charge Determinants and the Estimated Monetary Impact of Thermostat Control on Demand Charges after September 2013	11.45
11.16	Idaho Falls Power Costs of In-Home Display System.....	11.47
12.1	Lower Valley Electric Costs of In-Home Display System	12.7
12.2	Counts of Premises in Each Test Population According to Assets at the Premises.....	12.7
12.3	Lower Valley Electric Costs of DRU System.....	12.14
12.4	Annualized Costs of the DRU and AMI System and its Components.....	12.23
12.5	Calculated SAIFI for 16 Lower Valley Energy Distribution Feeders by Year.....	12.24





12.6 Calculated SAIDI for 16 Lower Valley Energy Distribution Feeders by Year 12.26

12.7 Calculated CAIDI for 16 Lower Valley Energy Distribution Feeders by Year..... 12.27

12.8 Lower Valley Electric Costs of Adaptive Voltage Regulation System 12.29

12.9 Average Percent Change in Feeder Voltage for Months in which the Voltage was Modified..... 12.32

12.10 List of Events when Lower Valley Energy Reduced the East Jackson Feeder Voltage 12.34

12.11 Lower Valley Electric Costs of Power Factor Improvement System 12.44

12.12 Feeder Power Factors as affected by SVC Status and Voltage-Management Status..... 12.52

12.13 Lower Valley Electric Costs of Battery Storage System 12.53

12.14 Summary of Monthly Energy and Demand Impacts from the Demonstrated Operation of the Battery System 12.61

12.15 Lower Valley Electric Costs of 20 kW Solar Photovoltaic System..... 12.63

12.16 Summary of Generation and the Value of Its Displaced Supply 12.67

12.17 Lower Valley Electric Costs of a 10 kW Wind Turbine System 12.69

13.1 Annualized Costs of the Milton-Freewater System of 800 DRUs..... 13.7

13.2 Representative Rows from a Table for Accumulating Customer Hours and Total Energy Impact by Event and Cumulatively..... 13.16

13.3 Estimated Supply Energy and the Value of Supply Energy Displaced each Calendar Month by Milton-Freewater’s DRU Events..... 13.25

13.4 Estimated Impact of Milton-Freewater’s DRUs on the Utility’s Demand Charges 13.26

13.5 Costs of the Milton-Freewater Voltage Management on Feeders 5–13 13.27

13.6 Costs of the Milton-Freewater Voltage-Responsive DRU Water Heaters..... 13.37

13.7 Estimated Supply Energy and the Value of Supply Energy Displaced each Calendar Month by Voltage Responsive Water Heater Events..... 13.43

13.8 Estimated Impact of Milton-Freewater’s Voltage-Responsive Water Heaters on the Utility’s Demand Charges..... 13.44

13.9 Costs of the Milton-Freewater CVR System on Feeders 1–4..... 13.45

13.10 Projected Supply Energy and the Value of Supply Energy that Would be Displaced by CVR on Feeders 1–4..... 13.53

13.11 Projected Impact of CVR on the Utility’s Demand Charges 13.54

14.1 Annualized Costs of the Helena IVVC System and its Components..... 14.4

14.2 Annualized Costs of the FDIR System and its Components over the Four-Year Term 14.14

14.3 Yearly Distribution Restoration Costs that were Reported to the PNWSGD by NorthWestern Energy 14.15

14.4 Yearly CAIDI Values Reported to the PNWSGD by NorthWestern Energy for the Four Helena Circuits in which FDIR was Used 14.15

14.5 Yearly SAIDI Values Reported to the PNWSGD by NorthWestern Energy for the Four Helena Circuits in which FDIR was Used 14.16

14.6 Annualized Costs of the Helena Residential and Commercial DR System and its Components 14.18





14.7 Outcome of the First Quarterly Customer Conservation Contest and its Top Three Customer Awards 14.19

14.8 DR Events Reported to the Project by NorthWestern Energy. All events were reported to have occurred August 28, 2014 14.19

14.9 Time-of-Use Pricing for Selected Participants Showing On-Peak (red, \$0.08/kWh), Mid-Peak, and Off-Peak Price Levels 14.21

14.10 Annualized Costs of the Philipsburg IVVC System and its Components 14.24

15.1 Definitions of Data Collection Points that Were Shown in Figure 15.2..... 15.2

15.2 Annualized Cost of the Load-Control Module System and Its Components..... 15.5

15.3 Linear Models of the Average Daily Premises Power Consumption for Cooling and Heating Regimes during Event Days and Non-Event Days..... 15.13

15.4 Annualized Cost of the CVR System and its Components 15.17

15.5 Annualized Costs of the Automated Switching System and its Components..... 15.22

15.6 SAIDI Values(a) by Month..... 15.22

15.7 Average Outage Response Times(a)..... 15.23

16.1 Key to Data Stream Names Used in Figure 16.1 16.2

16.2 Portland General Electric Commercial DR Temporal System Limitations 16.6

16.3 Annualized Costs of the Commercial DR System and its Components 16.7

16.4 Three Commercial DR Events that Occurred in 2013 16.9

16.5 Annualized Costs of the Commercial Distributed Generation System and its Components 16.11

16.6 Approximate Distribution of the Highest Hourly WECC Interconnect Prices per Year and Value of Energy Generated these Hours..... 16.13

16.7 Annualized Costs of the Battery Storage System and Its Components 16.16

16.8 Calculated Charge/Discharge Cycle Efficiencies at 25°C and 1,250 kW Charge Rate..... 16.22

16.9 Hypothetical Distribution of Differential Wholesale Energy Prices and the Calculated Arbitrage Value that May be Earned using this Differential 16.24

16.10 Annualized Costs of the Distribution Switching and Microgrid System and its Components 16.26

16.11 Financial Opportunities and Challenges Faced by Portland General Electric during the Salem Smart Power Project 16.29

17.1 Annualized Costs of the UW Steam Turbine System and its Components 17.3

17.2 Annualized Costs of the UW Diesel Generator System and its Components..... 17.7

17.3 Annualized Costs of the UW PV System and its Components..... 17.10

17.4 Energy Generated by the UW PV Generators Summed by Month and SCL Hour Type 17.15

17.5 Annualized Costs of the UW DDC System and its Components..... 17.16

17.6 Annualized Costs of the UW System of Displays and EnergyHub Devices and its Component Costs 17.21

17.7 Annualized Costs of the UW FEMS and its Components 17.26

C.1 BPA Load-Shaping Rates from October 1, 2011 through September 2013C.1

C.2 BPA Load-Shaping Rates from October 1, 2013 through September 2015C.2





Contents

C.3 BPA Demand Rates from October 1, 2011 through September 2013 C.3

C.4 BPA Demand Rates from October 1, 2013 through September 2015C.3

D.1 Method Example..... D.3

D.2 Results by Percentage D.4

