

Virtual Batteries

2017 Building Technologies Office Peer Review

Decision support tools allow building owners and utilities/grid operators to quantify the amount of virtual storage potential



Virtual storage assets provide grid flexibility

Refrigeration
Warehouses
and
Supermarkets



Commercial
HVAC with
Roof Top
Units



Commercial
HVAC with
Air Handling
Units



Residential
Water Heaters
and
Refrigerators



Residential Air
Conditioners
and
Heat Pumps



Project Summary

Timeline:

Start date: April 2016

Planned end date: March 2018

Key Milestones

1. Flexibility characterization for residential and commercial buildings; 2/28/17
2. Techno-economic assessment of virtual building and dedicated grid storage systems; 2/28/18
3. Develop dispatch and control apps and deploy VOLTTRON apps in at least one test site; 12/31/17

Budget:

Total Project \$ to Date:

- DOE: \$1,000K
- Cost Share: \$0K

Total Project \$:

- DOE: \$3,550K
- Cost Share: \$0K

Key Partners:



ORNL
UTRC
TVA
University of Florida

Project Outcome:

Enable utilities to use flexible building loads as virtual storage resources to provide grid services, integrate more renewable generation such as wind and photovoltaics (PV) into the grid, and improve building operational efficiency

Purpose and Objective: Problem Statement

- Growing need for more flexible grid assets with increasing wind and solar deployments
- Current grid-scale energy storage technologies have high capital investment
- Commercial/residential buildings can provide distributed 'virtual' storage capacity for the grid services and generate new value streams for building owners
- Virtual energy storage assets already exist but need to be:
 - Identified
 - Quantified
 - Controlled
- Complimentary to physical energy storage (thermal and electric) to provide grid services



Purpose and Objectives: Objectives

- Perform national opportunity assessment to quantify potential (GW/GWh) of virtual storage (VS) resources
- Develop flexibility screening tool to quantify regional potential of virtual storage resources
- Perform cost-benefit assessment for using virtual storage to provide grid services complimentary to physical storage
- Develop controls for virtual storage assets to provide grid services using VOLTTRON platform
- Test and validate virtual storage performance using realistic scenarios based on input from utilities and building owners


Purpose and Objectives: Target Market and Impact of Project

Target Market: Grid operators and behind-the meter asset owners/operators

Impact: Lower cost delivery of grid related services by using behind-the meter virtual storage assets enabled by

- Flexibility screening tool that provides building owners and utilities a means of quantifying potential of virtual storage resources to provide grid services
- Decision-support tools for grid operators and building owners to evaluate investments for using virtual storage resources
- Widely available control applications implemented in VOLTTRON available that enable virtual storage assets to provide grid services
- Testing and validation in realistic environments prove that virtual storage resources can complement physical storage

Progress and Accomplishments



National Opportunity Assessment – Background

Total Intra-Hour Balancing Requirements (2020 Grid with 20% RPS)

TOTALS

WECC




EIC



ERCOT



U.S.



M. Kintner-Meyer et.al. “National Assessment of Energy Storage for Grid Balancing and Arbitrage Phase II: WECC, ERCOT, EIC,”

National Opportunity Assessment – Virtual Storage Max. Tech

	Virtual Storage Assets	Power Potential (GW)*	Energy Potential (GWh)*	Current Investigation
1	Residential Air Conditioners and Heat Pumps	26.3	6.6	✓
2	Commercial HVAC with Roof Top Units	17.6	25.9	✓
3	Commercial HVAC with Air Handling Units	12.9	38.7	✓
4	Residential Water Heaters	10.6	10.6	✓
5	Refrigerators	4.3	2.2	
6	Residential Pool Pumps	4.7	4.7	
7	Commercial Water Heaters	1.0	1.0	
8	Electric Vehicles	0.8	1.6	
9	Super Markets and Grocery Stores	1.4	7.0	
10	Refrigerated Warehouses	0.3	0.6	
11	Data Centers	0.5	2.0	
12	Municipal Water Pumping	0.7	1.4	
	Total	81.1	129.2	

*peak load reduction study

- Virtual storage resources could provide a maximum capacity of 81GW
- 20% of max capacity enough to meet additional 18GW intra-hour balancing requirements in 2020 scenario

Commercial HVAC with Roof Top Units

National Opportunity Assessment for Commercial HVAC with Roof Top Units

Total floor space (million square feet), 2012 ^[1]	45,153
Median peak demand intensity (W/ft ²) ^[2]	5.4
Cooling/Ventilation percentage of the WBE ^[1]	32%
Total peak power	$45,153 \times 5.4 \times 32\% \approx 39.0 \text{ GW}$
Power reduction potential from peak demand ^[3]	15-30% *
Total power reduction capacity	$39.0 \times (15\% + 30\%) / 2 \approx 17.6 \text{ GW}$
Annual electricity energy consumption (billion kWh) ^[1]	727
Duration of power reduction (hours) ^[1]	1.5 *
Total “daily” energy consumption	$17.6 \times 1.5 \approx 25.9 \text{ GWh}$
Energy reduction capacity	$727 \times 32\% / 365 \approx 637.4 \text{ GWh}$

[1] EIA, “2012 Commercial Buildings Energy Consumption Survey,” 2012. URL: 2012 Commercial Buildings Energy Consumption Survey

[2] S. Kiliccote, M. A. Piette, and D. Hansen, “Advanced Control and Communication Technologies for Energy Efficiency and Demand Response,” in Proceedings of Second Carnegie Mellon Conference in Electric Power Systems: Monitoring, Sensing, Software and Its Valuation for the Changing Electric Power Industry, Pittsburgh PA. January 2006.

[3] Xu, Yin, Brown, and Kim, “Demand Shifting With Thermal Mass in a Large Commercial Building in a California Hot Climate Zone,” technical report, LBNL-61172, 2008.

Residential Air Conditioning Units (including Heat Pumps)

National Opportunity Assessment for Residential HVAC Units

Number of households using AC units (million) ^[4]	94
Average rated power (kW) ^[10]	5.6
AC units that are running at the same time	20%
Total peak power:	$94 \times 5.6 \times 20\% \approx 105.3 \text{ GW}$
Power reduction potential from peak demand	25%*
Total power reduction capacity:	$105.3 \times 25\% \approx 26.3 \text{ GW}$
Total annual energy consumption (quadrillion Btu) ^[5]	0.635
Duration of power reduction (minutes)	15
Total “daily” energy consumption:	$0.635 \times 293,000 / 365 \approx 509.7 \text{ GWh}$
Energy reduction capacity:	$26.3 \times 15 / 60 \approx 6.6 \text{ GWh}$

[4] U.S. Energy Information Administration, “Residential Energy Consumption Survey (RECS),” 2009. URL: <http://www.eia.gov/consumption/residential/>

[5] He Hao, Borhan Sanandaji, Kameshwar Poolla, and Tyrone L. Vincent, “Potentials and Economics of Residential Thermal Loads Providing Regulation Reserve,” Energy Policy, 79, 115–126, January 2015.

Flexibility Assessment Screening Tool –DEMO



Daily Virtual Storage of Residential AC – County Level



Siskiyou

Total # of ACs = 8000



San Diego

Total # of ACs = 280,000

Ambient
Temp. (°C)



No. of active
ACs



- Virtual storage potential varies based on outside temp
- # of ACs available to participate in grid services varies based on outside air temp
- Greater # of houses does not mean greater potential to provide grid services

Initial Benefit Assessment – County Level

- Case Study
 - Prices: 2015 CAISO average LMP and regulation prices
 - Objective: Maximize total revenue from energy arbitrage, regulation up/down, and spinning reserve
 - Constraints: Virtual storage power and energy limits, power limits for regulation and spinning reserve, hourly regulation reserve, etc.

	Energy Arbitrage \$/year	Regulation Up \$/year	Regulation Down \$/year	Spinning Reserve \$/year	Total \$/year
Siskiyou	10,983	150,501	25,651	2,559	189,696
San Diego	1,534	11,764	42,447	0	55,746

- Key Observations
 - Total revenue in Siskiyou higher → greater number of AC units available
 - Regulation up and down accounts for most of total benefits
 - Increased benefits in Siskiyou are from regulation up

Benefits from Virtual Storage and Real Storage

- CPUC state level storage procurement targets of 1.3 GW*
 - Physical storage: 500MW/1000MWh
 - Virtual storage: 800MW/560MWh (20% residential loads aggregated peak capacity)

	Energy Arbitrage \$M/year	Regulation Up \$M/year	Regulation Down \$M/year	Spinning Reserve \$M/year	Total \$M/year
Physical Storage	3.21	19.14	13.48	0.01	35.83
Virtual Storage	4.32	11.85	22.19	0.07	38.43

- Key Observations
 - Virtual storage can complement physical storage to meet procurement targets
 - Revenue for providing regulation down greater for virtual storage resources
 - Revenue for providing regulation up greater for physical storage
 - Comparable revenue streams for providing energy arbitrage

* <https://www.reedsmith.com/California-Public-Utilities-Commission-Adopts-Energy-Storage-Procurement-Targets-10-23-2013/>

Project Integration and Coordination

- PNNL (lead)
 - Develop flexibility characterization screening tool
 - Perform cost-benefit analysis
- ORNL
 - Provide experimental data from test sites used in flexibility screening tool
- University of Florida
 - Develop models used in flexibility screening tool
- TVA, BPA, and UTRC
 - Testing and deployment



Pacific Northwest
NATIONAL LABORATORY



United Technologies
Research Center



BONNEVILLE
POWER ADMINISTRATION



Next Steps and Future Plans

- Continue development of flexibility screening tool
 - Perform assessment for different regions
 - Extend asset catalog
- Extend cost-benefit analysis to include all revenue streams and cost projections
- Estimate dedicated physical storage capacity needed to complement virtual storage
- Specify and document VOLTTRON control app development and testing process
- Develop and field test VOLTTRON control apps at selected test sites

REFERENCE SLIDES

Project Budget

Project Budget: \$1,000K received in FY16. Planned funding for FY17 is \$1,050K.

Variations: None

Cost to Date: Of Year 1 funding (FY16), expenditures total \$612K. Year 1 funding was received in Spring 2016.

Additional Funding: ORNL received funding directly from DOE for this effort in FY16, which is not reflected in the table below. Funding was also provided to University of Florida (\$100K – \$60K from PNNL and \$40K from ORNL) in FY16.

Budget History

FY 2016 (past)		FY 2017 (current)		FY 2018 (planned)	
DOE	Cost-share	DOE	Cost-share	DOE	Cost-share
\$1,000K	\$0K	\$1,050K	\$0K	\$1,500K	\$0K

Project Plan and Schedule

Project Schedule													
Project Start: April 2016	Completed Work												
Projected End: March 2018	Active Task (in progress work)												
	Milestone/Deliverable (Originally Planned)												
	Milestone/Deliverable (Actual)												
	FY2016				FY2017				FY2018				
Task	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4	Q1	Q2	Q3	Q4	
Past Work													
Q4 Milestone: Identify flexible building load candidates to be represented as virtual storage resources													
Q1 Milestone: Develop flexibility characterization methodology for various classes of building loads													
Q1 Milestone: Perform techno-economic assessment of virtual and dedicated storage systems													
Q2 Milestone: Initial benefits evaluation of flexibility from building loads													
Q2 Milestone: Characterization method developed shows sufficient potential in quantifying the flexibility of building loads to justify performing economic assessment													
Q2 Milestone: Flexibility characterization for residential buildings and commercial buildings													
Q2 Milestone: VOLTTRON app development and testing process specified and documented													
Current/Future Work													
Q3 Milestone: Report documenting a method for characterizing the virtual battery													
Q3 Milestone: Report completed on the metrics, how to apply them, and results of using them to assess the potential impacts and benefits of using virtual storage													
Q3 Milestone: Field testing and validation Plan for deployment of VOLTTRON apps at selected test sites developed													
Q3 Milestone: Coordinate effort with ORNL and other BTO programs and identify target climates for HPWH adoption and identify and solidify partnerships with high priority program implementers, utilities, and other collaborators													
Q3 Milestone: Work plan based on coordinated effort with ORNL and other BTO programs that will identify specific milestones and deliverables													
Q4 Milestone: Initial testing of VOLTTRON apps for flexibility evaluation and monitoring/visualization													
Q4 Milestone: Investigate retailer, installer, and manufacturer potential involvement in a national initiative that incorporates demand response into project design, implementation, and evaluation													
Q1 Milestone: VOLTTRON apps for flexibility evaluation and monitoring/visualization developed													
Q1 Milestone: Developing dispatch and control applications in VOLTTRON for virtual storage systems to provide grid services													
Q1 Milestone: Complete deployment of VOLTTRON apps in at least one test site													
Q1 Milestone: Identify target markets and partners and designs for large scale deployment													
Q1 Milestone: HPWH Deployment Plan, including presentation of findings and recommended next steps for FY2018-2019													
Q2 Milestone: VOLTTRON apps for flexibility monitoring and visualization and accompanying user manual													
Q2 Milestone: A report will be completed describing the performance and cost comparison studies between different types of virtual storage and dedicated physical battery storage systems													
Q2 Milestone: Dispatch algorithms for coordinating virtual storage resources implemented and tested using GridLAB-D													
Q2 Milestone: Report documenting optimal dispatch algorithms													
Q2 Milestone: Document/report on testing of VOLTTRON apps													
Q2 Milestone: Documentation of findings													