# Review and Evaluation of Water Detritiation Technologies for Watts Bar Primary Cooling Water

Kriston Brooks Gary Sevigny Ed Love

1

Pacific Northwest National Laboratory

May 10, 2017 EMSL Auditorium, PNNL



**PNNL-SA-125901** 

# Background

- Tritium in the primary cooling water of the Watts Bar Nuclear Reactor
  - not captured nor treated but released to the river
  - Tritiated water concentration is well below the EPA's drinking water standard of 20 pCi/g met after mixed with the river
- Increased number of TPBARs may increase the amount of tritium in the cooling water
  - reactor contains 368 TPBARs, but 1504 will be used during the "equilibrium" phase
  - higher tritium levels may necessitate other pathways for tritiated water disposition




# **Report Purpose**

- Identify and evaluate disposal pathways for disposition of tritium-containing primary cooling water from Watts Bar
  - include the current approach of direct disposal into the Tennessee River
  - consider alternatives to reduce tritium prior to discharge
  - concentrated tritium stream will be grouted and disposed of in a commercial near-surface burial site
  - costs are rough order of magnitude estimates only



# **Conditions Considered**



0.6 gpm water flow rate

# **Previous Work**

- This work is based previous tritium mitigation alternatives analyses:
  - Hanford Site Wastewaters (1997, 2004, 2009)
  - Savannah River Site (1998)
  - CANDU Reactors (1984, 1990)
  - Fukushima Daiichi Nuclear Plant (2013, 2014)
  - Recent literature
- Use of previous cost estimates from literature:
  - adjusted to 2015 dollars
  - system sizing based on six-tenths-factor rule
  - processes for isotope enrichment are "in most instances . . indifferent to the feed concentration." (Miller 1998)
    - 10 ve en lifetime din en denne sistien
  - 10 year lifetime, linear depreciation



# Approach


- When Literature Cost Not Available
  - Operating costs based on electricity and natural gas costs
  - Facility footprint for nuclear facility estimate \$3500/ft<sup>2</sup>
  - Use available current cost data from DOE Energy Efficiency and Renewable Energy (EERE)
    - Electrolysis, Hydrogen Liquefaction, Fuel Cells
- Estimate of Technology Readiness (TRL) from DOE EM

TRL Level	Scale of Testing	Fidelity	Environment	
9	Full	Identical	Operational (Full Range)	
8	Full	Identical	Operational (Limited Range)	
7	Full	Similar	Relevant	
6	Engineering/Pilot	Similar	Relevant	
5	Lab/Bench	Similar	Relevant	Northwest
3-4	Lab	Pieces	Simulated	Northwest DNAL LABORATORY
1-2	None	Paper	Simulated	attelle Since 1965

### Tritium Disposal Alternatives— No Tritium Separation

Direct Disposal into the River (\$0.7/gallon)


- Only analysis and sampling required
- Grout Disposal of Tritiated Water (\$12/gallon)
  - Use phosphate/sulfate waste grout (high water)
  - 2018 disposal costs for Waste Control Specialists (WCS)
  - Equipment cost based on grouting study and SRS Engineering Scale Continuous Processing Facility (ESCPF)



Characteristic	Cost	Units			
Type of Grout	Phosphate/Sulfate Waste				
Ratio cement to water	7.5	lb/gallon water			
Density of Cement	11.7	lb/gallon grout			
Composition of Solids	41 wt% Portland cement 40 wt% Fly Ash 11 wt% Attapulgite clay 8 wt% Indian Red Pottery Clay				
WCS Class A LLW Base Disposal Cost	\$876	\$/cubic yard			
WCS Class A LLW Drum Surcharge	\$417	\$/cubic yard			
Water Shipping Cost	\$2.50	\$/gallon			
* WCS costs area based on Year 5 (2018)					

### **Combined Direct Disposal and Grout Disposal**

- Assume 1/3 of water is grouted and 2/3 disposed of into river
- Reduced cost: \$5.5/gallon



NATIONAL LABORATORY

### **Tritium: Hydrogen Separation Factors for Developed Tritium Removal Technologies**

	Low Tem	perature	High Temperature		
<b>Dual Temperatures Processes</b>	T (°C)	Т/Н	T (°C)	Т/Н	
Water Bithermal	60	5.289	150	2.918	
Girdler Sulfide	32	3.599	130	2.563	
Ammonia Bithermal	-30	16.1	40	8.6	
Single Temperature Processes	T (°C)	T/H			
Catalytic Exchange	60	5.289			
Water Distillation	50	1.059			
Electrolysis	50-80	15			
Cryogenic Distillation	-250	1.8			
Graphene Oxide Membrane	100	1.6			
Adsorption Processes	RT	1.4			

Operating and Capital Costs Estimated for these Technologies



### Water Distillation


#### Lowest separation factor

- High reflux  $\rightarrow$  high heat usage + large diameter columns
- > 200 theoretical plates → tall columns
- Use of heat pump and improved packing address column size and heat requirements
- Well developed technology
- $\blacktriangleright$  Working with water  $\rightarrow$  Very safe

#### Capital + Operating = \$19/gallon TRL = 7



### Water/Gas Catalytic Exchange: Vapor Phase, Liquid Phase, or Combined Electrolysis



### Facilities Use Water/Gas Catalytic Exchange


Facility	Technologies	Input Capacity, gpm	Input <sup>3</sup> H, µCi/g
Darlington, TRF	VPCE	1.6	30,000
Grenoble	VPCE	0.1	3000
AECL Test	LPCE	0.03	23,000
Chalk River, TEP	LPCE	0.09	35,000
Wolsung	LPCE	0.44	10,000-60,000
Mound	CECE	0.09	Unknown
Mol	CECE	0.007	2×10 <sup>-3</sup>
KFK	CECE	0.004	100
FUGEN	CECE	0.004	4000

Watts Bar Application: Flow Required = 0.6 gpm Input <sup>3</sup>H, μCi/g = 14



### Thermal Cycle Adsorption Process (TCAP) + Electrolysis

- Semi-continuous temperature swing chromatographic process
- Tritium concentrates at far end of Pd/k column & protium concentrates at far end of MS column
- Used for tritium purification




# **TCAP-E Cost Estimate**

Estimate includes cost of electrolysis, electricity and heat for cooling and heating, Pd metal cost, facility cost, and tritium disposal

	Pd/k Column	MS Column	Units	
			LH <sub>2</sub> /kg bed /	
Throughput Rate	12.8	40.4	cycle	
Mass fraction Pd	27%	0%		
<b>Temperature Differential Pd/k</b>				
Bed	200	90	°C	
Cycle time	10	min/cycle		
Absorbent Fractional Heat				
Load	50			
COP for Cryocooling	0.			
Footprint of Mini-TCAP (4 sl/cycle)	18		ft <sup>2</sup>	
		5		

Capital + Operating = \$17/gallon TRL = 6 Pacific Northwest NATIONAL LABORATORY

14



Treated Water

### **Other Processes Evaluated**

Multiple Electrolysis Cycle Process

Feed electrolyzed 9 times for DF = 10,000, CF = 100

Use fuel cells to recover some electricity

• Cell concentration =  $\frac{1}{\sqrt{\alpha}} * H2$  Product Concentration

#### \$22/gallon + TRL 5

- Cryogenic Distillation
  - Issues with safety, purification, liquefaction
  - \$9/gallon + TRL 6
- Graphene Oxide Membrane
  - Direct tritiated water clean-up
  - Low energy, but extremely high capital cost
  - \$227/gallon + TRL 3



# **Separation Techniques Not Costed**

Low TRL / Research Level Techniques

- Selective Laser Excitation (fluoro- and chloro-alkanes)
- Freeze concentration ( $\Delta T_{melt} = 4.49^{\circ}C$ )
- Pressure swing adsorption (synthetic zeolites)
- Palladium membrane reactor (alternative electrolysis)
- Chromatographic adsorption (isotopically swamping of tritium loaded molecular sieve bed)
- Thermal diffusion (T gradient)
- Formic acid electrolysis (8X faster kinetics than water)
- Functionalized Zn and Cu MOF adsorption (increased cryogenic temperature)



# **Summary of Results**

		Estimated Cost					
Proposed Technology	Technology Readiness Level	(\$/gallon)	< \$1	\$ 1-10	\$ 1-20	\$20-100	>\$100
Direct River Disposal	8	\$0.7					
Grout High Tritium Water	7	\$5.5					
Girdler Sulfide Process	7	\$11					
Grout Entire Volume	7	\$12					
Water Distillation	7	\$19					
Ammonia-Hydrogen Bithermal Process	7	> \$165					
Combined Electrolysis Catalytic Exchange	6	\$6.6					
Bithermal Hydrogen-Water Process	6	\$7.3					
Cryogenic Distillation Process	6	\$8.9					
Thermal Cycle Adsorption Process	6	\$17					
Multiple Electrolysis Cycle Process	5	\$22					
Graphene Oxide Membrane Process	3	> \$227					



# **Conclusions and Recommendations**

- As expected, direct disposal of tritiated water into the river is least expensive
- Grouting 1/3 tritiated water with higher concentration significant reduces the overall cost of disposal
- Separating the tritium with CECE or bithermal H<sub>2</sub>-H<sub>2</sub>O may be less expensive than grouting entire volume
- Estimates are only rough order of magnitude. Additional design and costing analysis is needed.

