



**SOLAR ENERGY**  
**TECHNOLOGIES OFFICE**  
U.S. Department Of Energy

## **ENERGISE: Eco-Idea**

*Enhanced Control, Optimization, and Integration of Distributed Energy Applications*

National Renewable Energy Laboratory

Challenges for Distribution Planning, Operational and Real-time Planning Analytics Workshop

May 16-17, 2019

---

Principal Investigators: Murali Baggu and Santosh Veda, NREL Email: [Santosh.Veda@nrel.gov](mailto:Santosh.Veda@nrel.gov)


Partners: Varentec, Telvent/Schneider Electric, EPRI, Xcel Energy

# Objective

- The project targets to develop and validate a novel ***Data-Enhanced Hierarchical Control (DEHC)*** architecture for distribution grids with high PV penetration.
- The DEHC architecture represents a hybrid approach of ADMS-based centralized controls, grid-edge controls and distributed controls for PV inverters.

## DEHC features:

- ADMS-centered operations,
- Synergistic ADMS-grid edge operations,
- PV fast-regulation capabilities,
- Comprehensive situational awareness, cybersecured and interoperable.




# Key Activities





---

- Period 1: Development and validation of co-simulation framework of DEHC architecture.
- Period 2: Hardware-in the-loop validation of DEHC architecture in lab and real-time simulation environment
- Period 3: Field validation on selected distribution feeders with DEHC architecture components and control

# Co-simulation Framework for Developing and Evaluating the DEHC Architecture



# Feeder voltages with PV Regulation (RT-OPF)




# Scenarios for Simulation

- Following simulation scenarios are planned to be carried out


Category	Description	Planned Scenarios	RTAC+ADMS required?
<b>Category 1: Evaluate the performance of ADMS and ENGO</b>	Baseline, S1: No ENGOs, No RTOFP	4 (high PV scenario * 2 load profiles * 2 PV profiles)	No
	S2: ENGOs with fixed voltage setpoint in OpenDSS	4 (same as S1)	No
	S3: No ENGOs, No RTOFP, ADMS controls LTC only to do CVR	4 (same as S1)	Yes
	S4: Enable ENGOs	4 (same as S1)	Yes
<b>Category 2: Evaluate the performance of RTOFP</b>	S5: Enable RTOFP	12 (3 PV inverter control intervals * 4 scenarios as above)	No
<b>Category 3: Evaluate the performance of ADMS, ENGO, and RTOFP</b>	S6: Combine S4 + S5	4 (same as S1)	Yes

**Note:** 2 load profiles - Peak day, Min. load day  
 2 PV profiles - Intermittent day, Moderate day  
 3 PV inverter control intervals - 1 sec, 5 sec, 10 sec

# Hardware in the Loop Setup




# HIL Test Setup



Lab infrastructure for ENERGISE ECO-IDEA Project (1)



# HIL Test Setup




SMA PV  
inverter

TI microcomputer  
(Local controller)




RTOPTF

Schneider  
ADMS



Lab infrastructure for ENERGISE ECO-IDEA Project (2)

# Interoperability Testing




DEHC Architecture Interoperability Plan Scope

Interoperability testing in DEHC architecture:

- Local RT-OPF controller to PV Inverters
- SE ADMS to Centralized RT-OPF Controller


# Cybersecurity Evaluation



# Field Deployment – Xcel Energy

## Englewood Bank 2

- All devices installed in preparation for IVVO except for the bellwether meters and small subset of ENGOS.
- Testing should be completed before the end of May and IVVO should begin running in closed loop at that time.
- Bellwether meters should be installed in November of 2019 but will have a limited scope and only be installed on residential and some commercial customers.
- Upgraded Load Tap Changer(LTC) control installed at substation transformer. SEL 2411 allows the ADMS to issue a set point which the LTC will regulate the secondary voltage to.
- 18 primary capacitor banks installed.
- 122 ENGOS installed – 22 additional ENGOS to be installed.
- WiMAX network installed and functional, WiSUN mesh network is planned for the coming months.



# Field Deployment – Xcel Energy


## East Bank 1

- Device installations should be completed in November 2019 and ADMS deployment there will follow in late Q2/early Q3 of Fiscal Year 2020 (March or April 2020).
- The bellwether deployment at EAST will likely not be in time for the Eco-Idea project as their deployment was pushed out to 2021.
- Upgraded LTC control to be installed in November 2019.
- 10 primary capacitor banks installed.
- 56 ENGOs planned for installation in coming months.
- WiMAX network installed and functional, WiSUN mesh network at East#1 is currently a little lower on the schedule, it will be ready for the ADMS enablement of that substation area in March/April 2020.

## GEMS

Xcel Energy's instance of GEMS will go live in September 2019. The deployed ENGOs will have set points issued remotely at that time.

In the next quarter, the team will also start developing the field test plan that will be executed in BP3.




# Key Outcomes and Impacts

---


- Validated novel hybrid control architecture
- Reliable and secure grid operation for high PV grids
- Interoperable interfaces for integration of system-level controls on the Utility Enterprise Bus
- Laboratory and field validation of hierarchical controls

# Questions?




# Model Updates – Load Modeling


- Historical SCADA data was received from Xcel at 1-hour resolution
- Minimum load of 11.48 MW was observed at 15 hours on May 13, 2018
- Peak load of 36.6 MW was observed at 16 hours on July 10, 2018
- Voltage-dependent load model




Yearly load profile



Profile for Peak Load Day



Profile for Min Load Day





ENGL Feeders




# Model Updates – High PV Scenario

- New high-PV scenario is created with updated criteria


PV locations



Yearly PV profile




Selected PV profiles





High-PV scenario criteria

# Scenario Results – S1, Baseline



- S1, Baseline: No ENGOs, No RTO PF
- Peak day, low-PV
- Impact of PV intermittencies are observed in max. voltage





Clear



Intermittent




Moderate




# Scenario Results – S1, Baseline

- S1, Baseline: No ENGOs, No RTO PF
- Peak day, low-PV scenario, Intermittent load profile




Voltage profile at min. voltage time step




Voltage profile at max. voltage time step

# S2 – Individual ENGO Powers



Peak load day, Intermittent PV profile

# S2 – Individual ENGO Voltages




Peak load day, Intermittent PV profile

# S2 – Individual ENGO Powers

- Similar observations are made in this scenario as well
- That is, ENGOs provide voltage boost by injecting reactive power into the system

**Extreme voltages & ENGO powers**



**Min. load day, Intermittent PV profile**

