

# Sunshine State Solar Grid Initiative (SUNGRIN)

## SYSTEMS INTEGRATION



## Solar PV Variability

- Collecting data from PV plant sites across Florida
- Resolution from 250 millisecond to 15 minute\*
- Irradiance, PV power output (P&Q), voltages and currents\*
- Installations ranging in size from 2kW to 15MW
- Also utilizing satellite data (on 10km x 10km resolution)
- Analysis of ramp rates, variability – spatial and temporal
- PV AC output data is input to models for hi-pen analysis

## High-Penetration PV Modeling and Analysis

- Examining a wide range of PV-grid integration scenarios
- Six utility partners, with PV up to 100% penetration
- Have modeled circuits with PV at:
  - Jacksonville Electric Authority (JEA), 15 MW, 100% penetration
  - Gainesville Regional Utilities (GRU), ~2MW, 30% penetration
  - NASA Kennedy Space Center (KSC), 900kW
- To model circuits in Lakeland and Orlando in subsequent phases

- JEA feeder – 100% penetration
- Penetration level of PV is *not*, by itself, an adequate indicator of the overall risk or impact of PV on a utility circuit.




Fig. 1. Voltage profile vs ckt. loading




Fig. 2. Voltage profile vs. X/R ratio

## Voltage Profile and Regulation

- Voltage drops along the feeder is well in limits for various loading and 12.6 MW PV penetration (Figure 1).
- Profile depends on circuit design (Figure 2) and other factors
- Voltage regulation issues more challenging with distributed PV, due to interaction with other PV and traditional regulation devices such as on-load tap changers (OLTC)
- Risk of tap changer run away / saturation




Fig. 3 Excessive operation of OLTC





Fig. 4 Response to a fault


## Protective Relaying Impacts

- Real time digital electromagnetic transient program (EMTP) simulations were used to investigate potential impact on protection devices and to demonstrate hardware-in-the-loop methods with relays, using a detailed model of the JEA substation.
- PV fault current magnitudes are very low compared to synchronous DG fault contribution.
- If the relays are coordinated properly, reverse power flow should not have an effect on relay operation.
- Figure 4 shows fault current contribution of PV for line to ground fault on Phase A.



## Lakeland Center, Lakeland, FL (for example)

- 250 KW
- 1232 solar collectors
- 247 roof penetrations
- 40,000 sq. ft. rooftop
- Fixed mounted / south facing
- Produces ~ 475,000 KWH annually




## Lakeland Center, July 2010 Ramp Rates

Maximum Ramp Rates:		1-minute	
Overall	Max RR:	229.487	[kW/min]
2-Jul	Max RR:	108.939	[kW/min]
3-Jul	Max RR:	146.041	[kW/min]


  

99 Percentile Ramp Rates:		1-minute	
Overall	RR99	129.05262	[kW/min]
2-Jul	RR99	22.48161	[kW/min]
3-Jul	RR99	36.12926	[kW/min]




## High-penetration PV Statewide Analysis with Satellite Data

- Based on satellite-derived irradiance data
- 10km x 10km grid
- Average hourly change
- Aggregate effects
- Useful tool for examining scheduling and dispatch of power, and,
- To quantify daily variability and ramp rates for different PV system layouts.



## Issues examined

- Voltage rise due to reverse power flow
- Voltage fluctuations associated with solar irradiance variation
- Interaction of voltage regulation devices
- Protection coordination and fault response
- Low voltage result from false tripping of mass distributed PV systems.
- Potential islanding issues due to the interaction between multiple PV systems
- Appropriate metrics and modeling and analysis tools for identifying hi-pen issues
- De-risking solutions with HIL:



Plant Project Name	Utility	Map ID Number	System Power Rating	Approx. Area (sq. mi)	No. of Panels	Circuit Feeds/Load	Connection Type
Keys Eco-Discovery Center	FMPA	1	30 kW	0.11	8000 kW		Distribution
DeSoto	FPL/Nextera	2	25 MW	235	90,500		Transmission
Kennedy Space Center PV Site (PKS)	FPL/Nextera	3	900 kW AC	5.4	3,420	8 MVA	Distribution
Space Coast	FPL/Nextera	4	10 MW AC	60	37,000		Transmission
6th Street Solar Energy Park (Ckt. 435)	GRU	5	2 MW	7	8,600	11 MW	Distribution
Butler Plaza	GRU	5	2.6 MW 2011 3.8 MW 2016				Distribution
Jacksonville Solar (JS)	JEA	6	15 MW DC 12.6 MW DC	91	200,000	18 MVA	Distribution
The Lakeland Center	Lakeland Electric	7	250 kW AC	0.92	1,232	10,553 kVA	Distribution
Lakeland Linder Airport Ph. 1, (Circuit T374)	Lakeland Electric	7	2.3 MW	41*	9,500	>27 MVA	Distribution
Lakeland Linder Airport Ph. 2 (Circuit D334)	Lakeland Electric	7	3.2 MW	41*	>8000	>25 MVA	Distribution
CNL/City of Orlando Parking Garage	OCU	8	500 kW	1.7		12.96 MW, 600 A	Distribution
Orange County Convention Center	OCU	8	1 MW	4.6	5,808	600 A - 12.96 MW	Distribution
Pershing Facilities	OCU	8	149 kW	0.22		600 A - 12.96 MW	Distribution
Stanton Energy Center Solar Project	OCU	9	5.91 MW	30	25,172	600 A - 12.96 MW	Distribution